

IMMEDIATE ACTION LETTER

CENTRAL FILES

July 6, 1979

Docket No. 50-331

Iowa Electric Light and
Power Company
ATTN: Mr. Duane Arnold
President
IE Towers
P. O. Box 351
Cedar Rapids, IA 52406

Gentlemen:

This refers to the meeting conducted by Messrs. E. J. Jordan, T. A. Ippolito, and W. P. Gammill and other members of the NRC staff with Mr. L. D. Root and other members of your staff in Bethesda, Maryland on July 6, 1979, regarding the base plate and anchor bolt test results and analyses obtained for Duane Arnold Energy Center pursuant to IE Bulletin No. 79-02, Revision 1.

Based on the results of this meeting, it is our understanding that you will take the following actions:

1. An evaluation of the operability of those safety related systems required to be operable by the Technical Specifications will be performed.
2. The adequacy of anchor bolt installations in concrete block walls will be included in the evaluation described in 1 above.
3. A written report of your evaluations described in 1 and 2 above will be provided to the regional office by COB July 10, 1979.

Please inform us immediately if your understanding of these items is different from that stated above.

Sincerely,

James G. Keppler
Director

cc: Central Files
Reproduction Unit NRC 20b
PDR
Local PDR
NSIC
TIC

IMMEDIATE ACTION LETTER

AO 2

60

OFFICE ▶	RIII <i>Spessard</i>	RIII <i>For</i>	RIII <i>Q30</i>	RIII <i>Q34</i>		
SURNAME ▶	Spessard/ls	<i>For</i>	Norelius	Keppler		
DATE ▶	7/6/79		7/6	7/6		

7908130205 9