

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 7910030471 DOC. DATE: 79/09/27 NOTARIZED: NO DOCKET #
 FACIL: 50-331 Duane Arnold Energy Center, Iowa Electric Light & Pow 05000331
 AUTH. NAME AUTHOR AFFILIATION
 VANSICKEL, J. Iowa Electric Light & Power Co.
 RECIP. NAME RECIPIENT AFFILIATION
 Region 3, Chicago, Office of the Director

SUBJECT: LER 79-020/03L-0: on 790202, critical power ratio was found to be 1.289, below Tech Specs limit of greater than or equal to 1.290. Caused by xenon transient causing thermal power to increase. Recirculation flow reduced immediately.

DISTRIBUTION CODE: A002S COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 1+1
 TITLE: Incident Reports

NOTES:

ACTION:	RECIPIENT ID CODE/NAME	COPIES		RECIPIENT ID CODE/NAME	COPIES	
		LTTR	ENCL		LTTR	ENCL
	05 BC <u>ORB #3</u>	4	4			
INTERNAL:	<u>01 REG FILE</u>	1	1	02 NRC PDR	1	1
	09 I&E	2	2	11 MPA	3	3
	14 TA/EDO	1	1	15 NOVAK/KNIEL	1	1
	16 EEB	1	1	17 AD FOR ENGR	1	1
	18 PLANT SYS BR	1	1	19 I&C SYS BR	1	1
	20 AD PLANT SYS	1	1	22 REAC SAFT BR	1	1
	23 ENGR BR	1	1	24 KREGER	1	1
	25 PWR SYS BR	1	1	26 AD/SITE ANAL	1	1
	27 OPERA LIC BR	1	1	28 ACIDENT ANALYS	1	1
	29 AUX SYS BR	1	1	E JORDAN/IE	1	1
	HANAUER, S.	1	1	STS GROUP LEADR	1	1
	TMI-H STREET	1	1			
EXTERNAL:	03 LPDR	1	1	04 NSIC	1	1
	29 ACRS	16	16			

OCT 5 1979

A011
4

60