

B 04 120 198

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)
DISTRIBUTION FOR INCOMING MATERIAL 50-331

REC: KEPPLER J G
NRC

ORG: HAMMOND E L
IA ELEC LIGHT & PWR

DOC DATE: 04/12/78
DATE RCVD: 04/18/78

DOCTYPE: LETTER NOTARIZED: NO
SUBJECT:

COPIES RECEIVED
LTR 1 ENCL 1

LICENSEE EVENT REPT #78-019 ON 3/15/78 CONCERNING REACTOR VESSEL LEVEL SWITCH
LIS 4534 FOUND TO HAVE NONCONSERVATIVE SETPOINTS.

PLANT NAME: DUANE ARNOLD

REVIEWER INITIAL: XRS
DISTRIBUTOR INITIAL: *me*

***** DISTRIBUTION OF THIS MATERIAL IS AS FOLLOWS *****

INCIDENT REPORTS
(DISTRIBUTION CODE A002)

FDR ACTION: BB CHIEF LEAF**W/4 ENCL

INTERNAL: REG FILE**W/ENCL
I & E**W/2 ENCL
SCHROEDER/IPPOLITO**W/ENCL
NOVAK/CHECK**W/ENCL
KNIGHT**W/ENCL
HANAUER**W/ENCL
EISENHUT**W/ENCL
SHAO**W/ENCL
KREGER/J. COLLINS**W/ENCL
K SEYFRIT/IE**W/ENCL

NRC PDR**W/ENCL
MIPC**W/3 ENCL
HOUSTON**W/ENCL
EEB**W/ENCL
BUTLER**W/ENCL
TEDESCO**W/ENCL
BAER**W/ENCL
VOLLMER/BUNCH**W/ENCL
ROSA**W/ENCL

EXTERNAL: LPDR'S
CEDAR RAPIDS, IA**W/ENCL
TIC**W/ENCL
NSIC**W/ENCL
ACRS CAT B**W/16 ENCL

COPIES NOT SUBMITTED PER
REGULATORY GUIDE 10.1

DISTRIBUTION: LTR 45 ENCL 45
SIZE: 1P+1P

CONTROL NBR: 781100295

*As 4
GO*

***** THE END *****

D. Lanham
FILE

IOWA ELECTRIC LIGHT AND POWER COMPANY

DUANE ARNOLD ENERGY CENTER
P. O. Box 351
Cedar Rapids, Iowa 52406
April 12, 1978
DAEC - 78 - 213

Mr. James G. Keppler, Director
Office of Inspection and Enforcement
U. S. Nuclear Regulatory Commission - Region III
799 Roosevelt Road
Glen Ellyn, Illinois 60137

Subject: Licensee Event Report No. 78-019
(30 day)

File: A-118a

Dear Mr. Keppler:

In accordance with Appendix A to Operating License DPR-49, Technical Specifications and Bases for Duane Arnold Energy Center and Regulatory Guide 10.1, please find attached a copy of the subject Licensee Event Report. (Total of 3 copies transmitted)

Very truly yours,

Ellery L. Hammond

Ellery L. Hammond
Chief Engineer
Duane Arnold Energy Center

Docket 50-331

attachment
ELH/JVS/nf

cc: Director, Office of Inspection and Enforcement (30)
U. S. Nuclear Regulatory Commission
Washington, D.C. 20555

Director, Management Information and Program Control (3)
U. S. Nuclear Regulatory Commission
Washington, D.C. 20555

APR 14 1978

LICENSEE EVENT REPORT

CONTROL BLOCK: _____ (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0 1 | I A D A C | 1 | 2 | 0 0 - 0 0 0 0 0 0 - 0 0 | 3 | 4 | 1 1 1 1 1 1 | 4 | 5 |

CON'T REPORT SOURCE | 6 | 0 5 | 0 0 | 0 3 3 1 | 7 | 0 3 1 5 7 8 | 8 | 0 4 1 2 7 8 | 9 |

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)
0 2 | During surveillance testing, reactor vessel level switch LIS 4534 was fou
0 3 | nd to have nonconservative setpoints. Provides initiation signal for ADS
0 4 | Core spray, LPCI, and standby diesel generators. Redundant level switches
0 5 | operable. Repetitive occurrence. See RO Report 78-016. Requirements list
0 6 | ed in TS Table 3.2-B.
0 7 |
0 8 |

0 9 | SYSTEM CODE | CAUSE CODE | CAUSE SUBCODE | COMPONENT CODE | COMP. SUBCODE | VALVE SUBCODE |
T R	11	X	12	X	13	I N S T R U	14	E	15	Z	16								
7 8	9 10	11 12	13 14	15 16	17 18	19 20													
17	LER/RO REPORT NUMBER	EVENT YEAR	SEQUENTIAL REPORT NO.	OCCURRENCE CODE	REPORT TYPE	REVISION NO.													
X	18	X	19	7 8	21 22	-	23	0 1 9	24 26	/	27	0 3	28 29	L	30	-	31	0	32
ACTION TAKEN	FUTURE ACTION	EFFECT ON PLANT	SHUTDOWN METHOD	HOURS	ATTACHMENT SUBMITTED	NPRD-4 FORM SUB.	PRIME COMP. SUPPLIER	COMPONENT MANUFACTURER											
X	33	X	34	Z	35	Z	36	0 0 0 0	37 40	N	41	N	42	N	43	Y 0 1 0	44 47		

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)
1 0 | Unknown. Under investigation. LIS to be disassembled and inspected during
1 1 | 1978 refueling outage. Switch placed in conservative tripped condition
1 2 | pending repair. LIS is Yarway Model 4418c. See RO Report 78-016 for
1 3 | details of corrective action.
1 4 |

1 5 | FACILITY STATUS | % POWER | OTHER STATUS | METHOD OF DISCOVERY | DISCOVERY DESCRIPTION |
E	28	0 9 2	29	NA	30	B	31	Surveillance Testing	32
7 8	9 10	11 12	13 14	15 16	17 18	19 20			
1 6	ACTIVITY CONTENT	AMOUNT OF ACTIVITY	LOCATION OF RELEASE						
Z	33	Z	34	NA	35	NA	36		
7 8	9 10	11 12	13 14	15 16	17 18				
1 7	PERSONNEL EXPOSURES	DESCRIPTION							
0 0 0	37	Z	38	NA	39				
7 8	9 10	11 12	13 14						
1 8	PERSONNEL INJURIES	DESCRIPTION							
0 0 0	40	NA	41						
7 8	9 10	11 12							
1 9	LOSS OF OR DAMAGE TO FACILITY	DESCRIPTION							
Z	42	NA	43						
7 8	9 10								
2 0	PUBLICITY	DESCRIPTION							
N	44	NA	45						
7 8	9 10								