

Central file

Iowa Electric Light and Power Company

September 21, 1979  
LDR-79-208

LARRY D. ROOT  
ASSISTANT VICE PRESIDENT  
NUCLEAR GENERATION

Mr. James G. Keppler, Director  
Nuclear Regulatory Commission  
Office of Inspection & Enforcement  
Region III  
799 Roosevelt Road  
Glen Ellyn, ILL 60137

Dear Mr. Keppler:

This letter is intended to complete our response to Item 2 of IE Bulletin No. 79-14. The results of the analytical evaluation made concerning the nonconformances identified in our August 31, 1979 submittal confirm that there are no cases in which the stress levels exceed code allowables in either the "as-found" or the "as-modified" conditions. Therefore, the results of our analytical evaluation not only show that system operability was not jeopardized, but that the nonconformances neither existed at the time of our initial evaluation nor do they exist presently as a result of the modifications identified in our August 31 letter.

Very truly yours,

*Larry D. Root*

Larry D. Root  
Assistant Vice President  
Nuclear Generation

LDR/RFS/mz

cc: R. Salmon  
D. Arnold  
S. Tuthill  
L. Liu  
E. Hammond  
K. Meyer  
T. Kevern (NRC)  
D. Wilson (DAEC)  
Director, Office of Inspection & Enforcement  
U. S. Nuclear Regulatory Commission  
Washington, D.C. 20555

Director, Division of Operating Reactors  
Office of Nuclear Reactor Regulation  
Washington, D.C. 20555

AOI  
2

SEP 24 1979

60