

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR:8003180625 DOC,DATE: 80/03/10 NOTARIZED: NO DOCKET #
 FACIL:50-331 Duane Arnold Energy Center, Iowa Electric Light & Pow 05000331
 AUTH.NAME AUTHOR AFFILIATION
 MINECK,D,L. Iowa Electric Light & Power Co.
 RECIP.NAME RECIPIENT AFFILIATION

SUBJECT: RO: on 800310, during surveillance testing of main steam relief valves, three valves had setpoints outside Tech Spec limits. Caused not stated. Corrective action & retesting in progress.

DISTRIBUTION CODE: A002S COPIES RECEIVED: LTR 1 ENCL 0 SIZE: 1
 TITLE: Incident Reports

NOTES: -----

	RECIPIENT ID CODE/NAME	COPIES		RECIPIENT ID CODE/NAME	COPIES	
		LTR	ENCL		LTR	ENCL
ACTION:	05 BC ORB #3	4	4			
INTERNAL:	01 REG FILE	1	1	02 NRC PDR	1	1
	09 I&E	2	2	11 MPA	3	3
	14 TA/EDO	1	1	15 NOVAK/KNIEL	1	1
	16 EEB	1	1	17 AD FOR ENGR	1	1
	18 PLANT SYS BR	1	1	19 I&C SYS BR	1	1
	20 AD PLANT SYS	1	1	22 REAC SAFT BR	1	1
	23 ENGR BR	1	1	24 KREGER	1	1
	25 PWR SYS BR	1	1	26 AD/SITE ANAL	1	1
	27 OPERA LIC BR	1	1	28 ACIDENT ANLYS	1	1
	29 AUX SYS BR	1	1	AD/ORP-DOR	1	1
	AEOD	1	1	DOUG MAY-TERA	1	1
	HANAUER, S.	1	1	IRELAND, R.	3	3
	JORDAN, E./IE	1	1			
EXTERNAL:	03 LPDR	1	1	04 NSIC	1	1
	29 ACRS	16	16			

MAR 20 1980

650

TOTAL NUMBER OF COPIES REQUIRED: LTR 52 ENCL 0

DSB

Iowa Electric Light and Power Company

March 10, 1980
DAEC - 80 - 120

Mr. James G. Keppler, Director
Office of Inspection and Enforcement - Region III
U. S. Nuclear Regulatory Commission
799 Roosevelt Road
Glen Ellyn, IL 60137

Subject: Prompt Notification of a
Reportable Occurrence

File: A-118a

Dear Mr. Keppler:

This letter, telecopied to your office, is intended to satisfy the requirement for prompt notification of a Reportable Occurrence in accordance with Specification 6.11.2.a of the Duane Arnold Energy Center Technical Specifications.

Technical Specification paragraph(s) violated: 2.2.1.B

Description Occurrence: During surveillance testing of main steam relief valves, three valves were found to have out of specification as found setpoints. One valve was 2 PSI low, one valve was 20 PSI high and one valve was 12 PSI high. Corrective action and retesting are in progress.

Very truly yours,

D. L. Mineck/Buy

Daniel L. Mineck
Chief Engineer
Duane Arnold Energy Center

A002
S
1/0

DLM/JVS/n

cc: Director, Management Information and Program Control (2)
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

DUPE

MAR 13 1980