

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8003200391 DOC. DATE: 80/03/14 NOTARIZED: NO DOCKET #  
 FACIL: 50-331 Duane Arnold Energy Center, Iowa Electric Light & Pow 05000331  
 AUTH. NAME: AUTHOR AFFILIATION  
 TOOKER, D. W. Iowa Electric Light & Power Co.  
 RECIP. NAME: RECIPIENT AFFILIATION  
 Region 3, Chicago, Office of the Director

SUBJECT: LER 80-008/03L-0: on 800216, during surveillance testing, core spray sparger to reactor vessel delta pressure PDIS-2139 trip setpoint found out of tolerance, Redundant channel switch found to be in tolerance. Caused by instrument drift.

DISTRIBUTION CODE: A002S COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 1+1  
 TITLE: Incident Reports

NOTES: -----

ACTION:	RECIPIENT	COPIES		RECIPIENT	COPIES	
	ID CODE/NAME	LTR	ENCL		ID CODE/NAME	LTR
	05 BC <b>ORB#3</b>	4	4			
INTERNAL:	<b>REG FILE</b>	1	1	02 NRC PDR	1	1
	09 I&E	2	2	11 MPA	3	3
	14 TA/EDO	1	1	15 NOVAK/KNIEL	1	1
	16 EEB	1	1	17 AD FOR ENGR	1	1
	18 PLANT SYS BR	1	1	19 I&C SYS BR	1	1
	20 AD PLANT SYS	1	1	22 REAC SAFT BR	1	1
	23 ENGR BR	1	1	24 KREGER	1	1
	25 PWR SYS BR	1	1	26 AD/SITE ANAL	1	1
	27 OPERA LIC BR	1	1	28 ACIDENT ANALYS	1	1
	29 AUX SYS BR	1	1	AD/ORP-DOR	1	1
	AEOD	1	1	DOUG MAY-TERA	1	1
	HANAUER, S.	1	1	IRELAND, R.	3	3
	JORDAN, E./IE	1	1			
EXTERNAL:	03 LPDR	1	1	04 NSIC	1	1
	29 ACRS	16	16			

MAR 24 1980

50

