

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR:8005130544 DOC.DATE: 80/05/06 NOTARIZED: NO DOCKET #
 FACIL:50-331 Duane Arnold Energy Center, Iowa Electric Light & Pow 05000331
 AUTH.NAME AUTHOR AFFILIATION
 TOOKER,D.W. Iowa Electric Light & Power Co.
 RECIPI.NAME RECIPIENT AFFILIATION
 Region 3, Chicago, Office of the Director

SUBJECT: LER 80-016/03L-0:on 800417,weekly battery surveillance
 documentation not completed for five wk during 1980
 refueling outage.Caused by personnel error.Battery tests
 completed & documented.Personnel advised.

DISTRIBUTION CODE: A002S COPIES RECEIVED:LTR 1 ENCL 1 SIZE: 1+1
 TITLE: Incident Reports

NOTES: _____

ACTION:	RECIPIENT ID CODE/NAME	COPIES		RECIPIENT ID CODE/NAME	COPIES	
		L	T		L	T
	05 BC ORBIT 3	4	4			
INTERNAL:	01 REG FILE	1	1	02 NRC PDR	1	1
	09 I&E	2	2	11 MPA	3	3
	14 TA/EDO	1	1	15 NOVAK/KNIEL	1	1
	16 EEB	1	1	17 AD FOR ENGR	1	1
	18 PLANT SYS BR	1	1	19 I&C SYS BR	1	1
	20 AD PLANT SYS	1	1	22 REAC SAFT BR	1	1
	23 ENGR BR	1	1	24 KREGER	1	1
	25 PWR SYS BR	1	1	26 AD/SITE ANAL	1	1
	27 OPERA LIC BR	1	1	28 ACIDENT ANLYS	1	1
	29 AUX SYS BR	1	1	AD/ORP=DQR	1	1
	AEOD	10	10	BERLINGER,C,	3	3
	DOUG MAY-TERA	1	1	HANAUER,S,	1	1
	JORDAN,E./IE	1	1			
EXTERNAL:	03 LPDR	1	1	04 NSIC	1	1
	29 ACRS	16	16			

MAY 15 1980

AD/E
4
60