

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR:8006030473 DOC.DATE: 80/05/27 NOTARIZED: NO DOCKET #
 FACIL:50-331 Duane Arnold Energy Center, Iowa Electric Light & Pow 05000331
 AUTH.NAME AUTHOR AFFILIATION
 TOOKER,D.W. Iowa Electric Light & Power Co.
 RECIP.NAME RECIPIENT AFFILIATION
 Region 3, Chicago, Office of the Director

SUBJECT: LER 80-017/03L-0:on 800430,A reactor circulation pump motor generator set tripped.Caused by electrical short in motor. Cause of short unknown,Motor removed & rewound.

DISTRIBUTION CODE: A002S COPIES RECEIVED:LTR 1 ENCL 1 SIZE: 151
 TITLE: Incident Reports

NOTES: -----

ACTION:	RECIPIENT ID CODE/NAME	COPIES		RECIPIENT ID CODE/NAME	COPIES	
		LTR	ENCL		LTR	ENCL
	05 BC ORB #3	4	4			
INTERNAL:	01 REG FILE	1	1	02 NRC PDR	1	1
	09 I&E	2	2	11 MPA	3	3
	15 NOVAK/KNIEL	1	1	16 EEB	1	1
	17 AD FOR ENGR	1	1	18 PLANT SYS BR	1	1
	19 I&C SYS BR	1	1	20 AD PLANT SYS	1	1
	22 REAC SAFT BR	1	1	23 ENGR BR	1	1
	24 KREGER	1	1	25 PWR SYS BR	1	1
	26 AD/SITE ANAL	1	1	27 OPERA LIC BR	1	1
	28 ACIDENT ANALYS	1	1	29 AUX SYS BR	1	1
	AD/ORP-DOR	1	1	AEOD	10	10
	BERLINGER,C.	3	3	DOUG MAY-TERA	1	1
	HANAUER,S.	1	1	JORDAN,E./IE	1	1
EXTERNAL:	03 LPDR	1	1	04 NSIC	1	1
	29 ACRS	16	16			

MAY 4 1980

ACT
4
60

TOTAL NUMBER OF COPIES REQUIRED: LTR 60 ENCL 60