

This drawing and the design it covers are the property of BECHTEL. They are merely loaned and on the borrower's express agreement that they will not be reproduced, copied, loaned, antiheld, or used except in the limited way and private use permitted by the lender to the borrower.

REV.	MCC CUBICLE NO	CONTROL SCHEME DWG. NO	SCHEME NO (UNIT NO)	BREAKER			STARTER			LOAD DESCRIPTION	F.P. SCHEMATIC WIRING	FIELD MODIFICATION SEE SH.	EQUIP. NO	LOAD H.P.	FLA/LRA	WIRE SIZE (AWG)	CONTR. LOCAT.	REL. FOR CONSTR.
				FRAME SIZE AMPS	CONTINUOUS RATING OR THERMAL AMPS	TRIP SETTING POSITION AMPS POS	SIZE	TYPE	AUX. CONTACTS									
	2A	E-120, 5H.6	2B4480	150*	10	35 LOW	1	FVR	25/25 25/25	H33	REACTOR REC. LOOP II PUMP SUCTION VALVE (B31-FO23B)	E-9-85	MO-4602	1.6	52/24.1	3/C #12	1C04	6/7/71
	2B	E-120, 5H.6	91		30	115 9	1			FH44***	REACTOR REC. LOOP II PUMP DISCH. VALVE (B31-FO31B)		MO-4628	7.3	11.4/44.3	3/C #8	1C04	6/7/71
	3B	E-120, 5H.6	92		10	35 LOW	1			H14	REACTOR REC. LOOP II PUMP BYPASS VALVE (B31-FO32B)		MO-4630	0.33	9/	3/C #12	1C04	6/7/71
	3C	E-121, 5H.52A	93		100	254 6	3			FH76***	RHR LOOP II INJECT. VALVE TO LPCI (E11-FO15B)	E-9-150	MO-1905	79.2	25.4/195	TRIPL. #2	1C03	6/7/71
	2C	E-121, 5H.53A	94	400**	400	374 1	4			FH76***	RHR LOOP II INJECT. VALVE TO LPCI (E11-FO17B)		MO-1904	26.4	37.4/332	TRIPL. #6	1C03	11/3/72
		E-104, 5H.21	2B4401								TIE BREAKER TO MCC 1B44A AND 1B34A (EL OPERATED)		52-4401				1C08	6/7/71

* MAGNETIC ONLY CB
 ** THERMAL MAGNETIC CB
 *** SEE 7884-E105-3, NOTE 19

REF DWG.:
 1. ALLIS-CHALMERS DWG. 25-405-824-502
 [F.P. 7884-E9-163]

480V MOTOR CONTROL CENTER 1B44A (ESSENTIAL)
 LOCATION: REACTOR BUILDING EL. 757'-6" WEST

DCP PACKAGE INDEX
 ITEM NO. 6.2.9

REV.	DESCRIPTION	ENG	DRN	CHK.	SUPR	MATL.	APPR	DATE	REV.	DESCRIPTION	ENG	DRN	CHK.	SUPR	MATL.	APPR	DATE
11	REV. PER DCP-1277							12-9-85	8	REV TRIP SETTINGS & LRA FOR MO-1904, PER DR-IE-6-6							2-13-74
10	REV. BKR SIZE & ASSOC DETAILS FOR MO-1904 (DR IE-6-6)							4-19-74	13	REV PER DCP #1206							10-10-84
9	REV. BKR SIZE & ASSOC DETAILS FOR MO-1904 (DR-IE-6-6)							9-22-74	12	REV PER DCP #1203							2-18-88

480V MOTOR CONTROL CENTER SCHEDULES

JOB No. 7884
 DRAWING No. BECH-E105 (19A)
 SHEET REV. 13

DCP Closure Note
 BREAKER 52-4401 is being replaced by DCP 1430. INDICATED AREA SHALL BE REVISED AT DCP CLOSURE TO REFLECT NEW DATA ISSUED FOR THIS BKR AND NEW BKR RATINGS AND SETPOINTS
 DCP 1430, REV 0

FOR DCP 1430 USE ONLY

REV	PREPARED BY	VERIFIED BY
0		
1		

ie:

SI APERTURE CARD

8810120243