



ZS-2-1 1.TB3-32 2.TB3-33
 ZS-2-2 1.TB3-34 2.TB3-35
 TAMPER SWITCHES
 MOUNTED ABOVE INNER DOOR-SHOWN REAR VIEW
 CONTACTS SHOWN WITH OUTER DOOR OPEN

DRAFTING NOTE:
 CLOUDED WIRES & CABLES OR X X X
 CODED WIRES & CABLES ARE DELETED
 WIRES & CABLES. REMOVE THESE
 WIRES & CABLES FROM THE DRAWING
 AT DCP CLOSURE.

- WIRING NOTES:
 1. UNSHIELDED WIRE - ANACONDA ERICSSON FLAMEGUARD, TYPE NSINS, NO. 14 AWG UNLESS NOTED OTHERWISE.
 2. SHIELDED WIRE - ANACONDA ERICSSON FLAMEGUARD, NO. 16 AWG, 2/C, SHIELDED PAIR, ERCP-5600-16-25.
 3. USE AMP UNSHIELDED RING TONGUE TERMINALS, SIZE AS REQ'D.
 4. AC WIRING (MARKED Ⓢ) AND DC WIRING (NOT MARKED) SHALL BE BUNDLED SEPARATELY AND KEPT AT LEAST 4" APART IF POSSIBLE.

CUSTOMER IOWA ELECTRIC		DUANE ARNOLD ENERGY CENTER	
ORDER NO. 009560	DATE	DATE	DATE
ISSUED INTO IND. PER. DCP-1355	DATE	DATE	DATE
DESTINATION PALO, IOWA	DATE	DATE	DATE

DCP PACKAGE INDEX
 ITEM NO. 6.3.13

CONSTRUCTION DELETE
 FRANK ELECTRIC CORPORATION
 YORK, PA.

CONNECTION DIAGRAM
 REMOTE SHUTDOWN PANEL B
 PANEL IC390

FOR DCP 1430 USE ONLY
 REV. PREPARED BY: [Signature]
 VERIFIED BY: [Signature]

8810120306

ie: iowa electric light & power co.
 DAEC CONNECTION DIAGRAM
 REMOTE SHUTDOWN PANEL B
 PANEL IC390
 E134-020

SI APERTURE CARD
 Control # [blank]
 REGULATORY DOCKET FILE

FOR INFORMATION ONLY

