



ZS-2-1 1.TB3-32 2.TB3-33
ZS-2-2 1.TB3-34 2.TB3-35
TAMPER SWITCHES
MOUNTED ABOVE INNER DOOR-SHOWN REAR VIEW
CONTACTS SHOWN WITH OUTER DOOR OPEN

WIRING NOTES:
1. UNSHIELDED WIRE - ANACONDA ERICSSON FLAMEGUARD, TYPE NSINS, NO. 14 AWG UNLESS NOTED OTHERWISE.
2. SHIELDED WIRE - ANACONDA ERICSSON FLAMEGUARD, NO. 16 AWG, 2/C, SHIELDED PAIR, ERCP-5600-16-25.
3. USE AMP UNSHIELDED RING TONGUE TERMINALS, SIZE AS REQ'D.
4. AC WIRING (MARKED Ⓢ) AND DC WIRING (NOT MARKED) SHALL BE BUNDLED SEPARATELY AND KEPT AT LEAST 4" APART IF POSSIBLE.

GRAFTING NOTE:
CLOUDED WIRES & CABLES OR CLOTTED WIRES & CABLES ARE NEW ADDED WIRES & CABLES. DO NOT DRAFT THE "O" ON THE WIRES & CABLES AT DCP CLOSURE.

DCP PACKAGE INDEX
ITEM NO. 6.3.14

CONSTRUCTION ADD
FRANK ELECTRIC CORPORATION
TOWNE, PA.

CONNECTION DIAGRAM
REMOTE SHUTDOWN PANEL B
PANEL IC390

| | | | | | | | | |
|---|--|---------|-----|----|----------|------------------|------------|--------------|
| C | CHANGE WIRING FROM CS-2-2 TO CS-2-1 | 8-18-84 | ENG | AK | 10/10/84 | ORDER NO. 009560 | DATE | REV |
| B | ADD WIRING FROM TB1-21 THROUGH TO CS-2-2 | 5-18-84 | ENG | AK | 10/10/84 | PROJECT | DATE | REV |
| A | CHANGE 28 SW TERMINAL WTS. | 3-18-84 | ENG | AK | 10/10/84 | ITEM NO. | SCALE NONE | DATE 2-24-84 |

FOR DCP 1430 USE ONLY
REV. PREPARED BY VERIFIED BY
D [Signature] M [Signature] C [Signature] 10/10/84

8810120310

ie Iowa Electric Light & Power Co.
DALE
CONNECTION DIAGRAM -
REMOTE SHUTDOWN PANEL B
PANEL IC390

FOR INFORMATION ONLY

SI APERTURE CARD

Product # 1010101010
Control # 1010101010
Data # 1010101010
REGULATORY DOCKET FILE #