

DUANE ARNOLD ENERGY CENTER

UNIT #1 PALO, IOWA

Commercial Service Date: February 1, 1975

INSERVICE INSPECTION REPORT

December 28, 1988 through September 10, 1990

Dated: November 19, 1990

OWNER:

IOWA ELECTRIC LIGHT and POWER COMPANY
P.O. Box 351
Cedar Rapids, Iowa 52406

Prepared by:

[Signature]

ISI/EC Specialist

Date: 11-19-90

Reviewed by:

[Signature]
Codes & Materials, GL

Date: 11-20-90

Concurred by:

[Signature]
Supervising Engineer

Date: 11-21-90

Approved by:

[Signature]
Manager, Design Engineering

Date: 11/21/90

Table of Contents

PART	DESCRIPTION	PAGE NO.
A	Form NIS-1	A, pages 1-2
B	Certificate of Inservice Inspection	B, pages 1-6
C	Abstract	C, page 1
D	Table of Component and Weld Examination Identification Records	D, pages 1-12
E	Table of Additional and Successive Examinations Identification Records	E, pages 1-6
F	Abstract of ASME Section XI Repairs and Replacements	F, pages 1-3
G	Form NIS-2's	G, pages 1-197
H	Abstract of Conditions Noted and Corrective Measures Taken	H, page 1
I	ISI Figures and ISO's	I, pages 1-45
J	Status of Work for Second Interval	J, pages 1-6

FORM NIS-1 OWNERS' DATA REPORT FOR INSERVICE INSPECTIONS**As required by the Provisions of the ASME Code Rules**1. Owner Iowa Electric Light & Power, P.O. Box 351, Cedar Rapids, IA 52406 (Note 2)
(Name and Address of Owner)2. Plant Duane Arnold Energy Center, 3277 DAEC Road, Palo, IA 52324
(Name and Address of Plant)3. Plant Unit 1 4. Owner Certificate of Authorization (if required) N/A5. Commercial Service Date 02-01-75 6. National Board Number for Unit N/A

7. Components Inspected This report includes a Table of Contents (p1), Part A (pp 1-2), Part B (pp 1-6), Part C (p 1), Part D (pp 1-12), Part E (pp 1-6),

Component or Appurtenance	Manufacturer or Installer	Manufacturer or Installer Serial No.	State or Province No.	National Board No.
Reactor Press. Vessel (RPV)**	Chicago Bridge and Iron	3-4833	N/A	3663
Refer to Part B, Pages 1 through 6, of components examined.		this report	for continuation of	

Note: Supplemental sheets in form of lists, sketches, or drawings may be used provided (1) size is 8½ in. x 11 in., (2) information in items 1 through 6 on this data report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

* Part F (pp 1-3), Part G (pp 197), Part H (p 1), Part I (p 45) Part J (pp 1-6).

** and items listed under RPV interior or Reactor Pressure Vessel in Part B, pages 1-6 of this report.

This form (E00029) may be obtained from the Order Dept., ASME, 345 E. 47th St., New York, N.Y. 10017

FORM NIS-1 (back)

8. Examination Dates 12-28-88 to 09-10-90 9. Inspection Interval from 11-01-85 to 11-01-95

10. Abstract of Examinations. Include a list of examinations and a statement concerning status of work required for current interval.

SEE PART D AND PART J.

11. Abstract of Conditions Noted

SEE PART H

12. Abstract of Corrective Measures Recommended and Taken

SEE PART H

We certify that the statements made in this report are correct and the examinations and corrective measures taken conform to the rules of the ASME Code, Section XI. SEE NOTE 1 BELOW

Date 11-26 19 90 Signed Iowa Electric Light and Power Company By [Signature]
Owner Manager, Nuclear Division

Certificate of Authorization No. (if applicable) N/A Expiration Date N/A

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and/or the State or Province of Iowa and employed by Hartford Boiler Co. of Hartford, CT have inspected the components described in this Owners' Data Report during the period 12-28-88 to 9-10-90, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owners' Data Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owners' Data Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date Nov 26 19 90

[Signature] Commissions NB 8829(I) (N) 941-IA
Inspector's Signature National Board, State, Province and No.

Note 1: As per letter NG-89-3390, the ASME Section XI "Vessels", RHR Heat Exchangers, 1E-201A and 1E-201B and the Reactor Vessel are excluded from the summary report to the State.

Note 2: Other Owners are Central Iowa Power Cooperative and Corn Belt Power Cooperative.

INSERVICE INSPECTION REPORT

Part B, Page 1 of 6

September 28, 1988 through September 10, 1990

- 1) Owners: Iowa Electric Light and Power Company
P.O. Box 351
Cedar Rapids, Iowa 52406

Central Iowa Power Cooperative
Marion, Iowa

Corn Belt Power Cooperative
Humboldt, Iowa

- 2) Plant Duane Arnold Energy Center, Palo, Iowa 52324
- 3) Plant Unit #1
- 4) Owners Certificate of Authorization (if required) N/A
- 5) Commercial Service Date 2-1-75
- 6) National Board Number of Unit N/A

GROSS GENERATING CAPACITY: 565 MWE

CERTIFICATE OF INSERVICE INSPECTION

COMPONENTS EXAMINED:

Reactor Pressure Vessel

Manufacturer: Chicago Bridge and Iron
Post Office Box 13308
Memphis, TN 38113

National Board Number 3663, Mfr. Serial Number 3-4833

Refer to Part A, Page 1, From NIS-1, Owners Data Report for Inservice Inspections.

Piping:

Manufacturers, sizes, part numbers and locations are noted and traceable through the piping isometric and piping instrumentation drawings (P&ID). Installation contractor, fabricator, systems P&ID's and isometric drawings are listed below.

Constructor - Bechtel Power Co.
P.O. Box 3865
San Francisco, CA 94119

Fabricator - Southwest Fabricating and Welding Co.
P.O. Box 9449
Houston, TX 77011

INSERVICE INSPECTION REPORT
December 28, 1988 through September 10, 1990

Part B, Page 2 6

- 1) Owners: Iowa Electric Light and Power Company
P.O. Box 351
Cedar Rapids, Iowa 52406

Central Iowa Power Cooperative
Marion, Iowa

Corn Belt Power Cooperative
Humboldt, Iowa
- 2) Plant Duane Arnold Energy Center, Palo, Iowa 52324
- 3) Plant Unit #1
- 4) Owners Certificate of Authorization (if required) N/A
- 5) Commercial Service Date 2-1-75
- 6) National Board Number of Unit N/A

GROSS GENERATING CAPACITY: 565 MWE

CERTIFICATE OF INSERVICE INSPECTION

COMPONENTS EXAMINED:

Class 1 Components

Reactor Pressure Vessel	Figure 1.1-2, 1.1-3, 1.1-5 and 1.1-6
Control Rod Drive	Figure 1.1-8A and 1.1-8B
Main Steam Loops A, B, C and D	P&ID M-103, GE Drawing 731E615 ISO Nos. 1.2-1, 1.2-2, 1.2-3, 1.2-4
Feedwater A and B	P&ID M-106, M-107, Bechtel ISO DLA-2-4, ISO No. 1.2-5
Feedwater C and D	P&ID M-106, M-107, Bechtel ISO DLA-2-4, ISO No. 1.2-6
Core Spray A	P&ID M-121, Bechtel Drawings DLA-7-1 and DLA-7-2, ISO No. 1.2-7
High Pressure Coolant Injection - Steam	P&ID M-122, Bechtel Drawing DBA-3-1, ISO No. 1.2-9
High Pressure Coolant Injection - Water	P&ID M-123, Bechtel Drawing DLA-1-1, ISO No. 1.2-10

INSERVICE INSPECTION REPORT

September 28, 1988 through September 10, 1990

Part B, Page 3 of 6

- 1) Owners: Iowa Electric Light and Power Company
P.O. Box 351
Cedar Rapids, Iowa 52406

Central Iowa Power Cooperative
Marion, Iowa

Corn Belt Power Cooperative
Humboldt, Iowa

- 2) Plant Duane Arnold Energy Center, Palo, Iowa 52324
- 3) Plant Unit #1
- 4) Owners Certificate of Authorization (if required) N/A
- 5) Commercial Service Date 2-1-75
- 6) National Board Number of Unit N/A

GROSS GENERATING CAPACITY: 565 MWE

CERTIFICATE OF INSERVICE INSPECTION

COMPONENTS EXAMINED:

Motor Water Cleanup - Discharge

P&ID M-127, Bechtel Drawing
DCA-6-1, ISO No. 1.2-11B

Control Rod Drive Return

P&ID M-113, Bechtel Drawing
DBA-6-1, ISO Nos. 1.2-12A and
1.2-12B

Residual Heat Removal - Head Spray

P&ID M-119, Bechtel Drawing
DBA-5-1, ISO No. 1.2-13

Residual Heat Removal - 18B

P&ID M-119, Bechtel Drawing
DLA-4-1, ISO No. 1.2-14

Residual Heat Removal - 20A

P&ID M-120, M-107, Bechtel
Drawing DLA-5-1, ISO No. 1.2-15

Residual Heat Removal - 20B

P&ID M-119, Bechtel Drawing
DLA-6-1, ISO No. 1.2-16

Recirculation Pump A and Bypass

P&ID M-116, GE Drawing 731E781,
APED B31-9(1)-6, ISO No. 1.2-
19A

Recirculation Drain Line 'A'

P&ID M-116, GE Drawing 731E781,
APED B31-9(1)-6, ISO No. 1.2-
19A

INSERVICE INSPECTION REPORT
December 28, 1988 through September 10, 1990

Part B, Page 4 6

- 1) Owners: Iowa Electric Light and Power Company
P.O. Box 351
Cedar Rapids, Iowa 52406

Central Iowa Power Cooperative
Marion, Iowa

Corn Belt Power Cooperative
Humboldt, Iowa

- 2) Plant Duane Arnold Energy Center, Palo, Iowa 52324
3) Plant Unit #1
4) Owners Certificate of Authorization (if required) N/A
5) Commercial Service Date 2-1-75
6) National Board Number of Unit N/A

GROSS GENERATING CAPACITY: 565 MWE

CERTIFICATE OF INSERVICE INSPECTION

COMPONENTS EXAMINED:

Recirculation Manifold A and Risers E,
F, G and H

P&ID M-116, GE Drawing 731, APED B31-9(1)-6, ISO No. 1.2-0

Recirculation Pump B and Bypass

P&ID M-116, GE Drawing 731E781, APED B31-9-(1)-6, ISO No. 1.2-21

Jet Pump Instrumentation 'A'

P&ID M-115, APED B11-2655-105-4, ISO No. 1.2-25

Recirculation Pump 'A' & 'B' Details

P&ID M-116, GE Drawing 731E781, APED B31-9(1)-6, Figure No. 1.3-1

Recirculation Pump 'A' Supports

P&ID M-116, GE Drawing 731E781, APED B31-9-(1)-6, Figure No. 1.3-2

Recirculation Pump 'B' Supports

P&ID M-116, GE Drawing 731E781, APED B31-9-(1)-6, Figure No. 1.3-3

SERVICE INSPECTION REPORT

September 28, 1988 through September 10, 1990

Part B, Page 5 of 6

- 1) Owners: Iowa Electric Light and Power Company
P.O. Box 351
Cedar Rapids, Iowa 52406

Central Iowa Power Cooperative
Marion, Iowa

Corn Belt Power Cooperative
Humboldt, Iowa

- 2) Plant Duane Arnold Energy Center, Palo, Iowa 52324
- 3) Plant Unit #1
- 4) Owners Certificate of Authorization (if required) N/A
- 5) Commercial Service Date 2-1-75
- 6) National Board Number of Unit N/A

GROSS GENERATING CAPACITY: 565 MWE

CERTIFICATE OF INSERVICE INSPECTION

COMPONENTS EXAMINED:

s 2 Components

RHR Pump Suction (S.E.)	P&ID M-120, Bechtel Drawing M-712, ISO No. 2.2-32
RHR Pump Suction (N.W.)	P&ID M-119, Bechtel Drawing M-713, ISO No. 2.2-33
RHR Pump Shutdown	P&ID M-119, M-120 and M-122, Bechtel Drawing M-723, ISO No. 2.2-34
RHR Heat Exchanger Discharge (S.E.)	P&ID M-120, Bechtel Drawing M-720, ISO No. 2.2-37A, ISO No. 2.2-37B
RHR Fuel Pool Cooling and Cleanup	P&ID M-119 and M-134, Bechtel Drawing HBB-24-2, 3, 4 and 5, ISO No. 2.2-43
HPCI Turbine Steam Inlet	P&ID M-122, Bechtel Drawing M-702, ISO No. 2.2-46
HPCI Turbine Steam Exhaust	P&ID M-122, Bechtel Drawing M-703, ISO No. 2.2-47
Spray Suction (S.E.)	P&ID M-121, Bechtel Drawing M-708, ISO No. 2.2-48

INSERVICE INSPECTION REPORT
December 28, 1988 through September 10, 1990

Part B, Page 6 6

- 1) Owners: Iowa Electric Light and Power Company
P.O. Box 351
Cedar Rapids, Iowa 52406

Central Iowa Power Cooperative
Marion, Iowa

Corn Belt Power Cooperative
Humboldt, Iowa

- 2) Plant Duane Arnold Energy Center, Palo, Iowa 52324
3) Plant Unit #1
4) Owners Certificate of Authorization (if required) N/A
5) Commercial Service Date 2-1-75
6) National Board Number of Unit N/A

GROSS GENERATING CAPACITY: 565 MWE

CERTIFICATE OF INSERVICE INSPECTION

COMPONENTS EXAMINED:

Core Spray Discharge (S.E.)	P&ID M-119, Bechtel Drawing 710, ISO No. 2.2-50
Main Steam Loop A	P&ID M-103, Bechtel Drawing M-716, ISO No. 2.2-53
Main Steam Loop B	P&ID M-103, Bechtel Drawing M-716, ISO No. 2.2-54
Main Steam Bypass	P&ID M-103, Bechtel Drawing EDB-6-1 and EDB-6-2, ISO No. 2.2-57
Main Steam Bypass	P&ID M-103, Bechtel Drawing EDB-6-3, ISO No. 2.2-58
Scram Discharge Header - South	P&ID M-118, ISO No. 2.2-60

SERVICE INSPECTION REPORT

Part C, Page 1 of 1

September 28, 1988 through September 10, 1990

- 1) Owners: Iowa Electric Light and Power Company
P.O. Box 351
Cedar Rapids, Iowa 52406

Central Iowa Power Cooperative Corn Belt Power Cooperative
Marion, Iowa Humboldt, Iowa
- 2) Plant Duane Arnold Energy Center, Palo, Iowa 52324
- 3) Plant Unit #1
- 4) Owners Certificate of Authorization (if required) N/A
- 5) Commercial Service Date 2-1-75
- 6) National Board Number of Unit N/A

Abstract:

The Inservice Inspection addressed in this report was performed in accordance with the American Society of Mechanical Engineers Boiler and Pressure Vessel Code, Section XI 1980 Edition through Winter 1981 Addenda, and the Duane Arnold Energy Center updated Final Safety Analysis Report. The inspections were performed utilizing Non-Destructive Examination techniques (i.e., Ut, Pt, Mt, etc.). The examinations were conducted during the period of December 28, 1988 through September 10, 1990. The specific details and associated records of the examinations are on file at Iowa Electric Light and Power Company.

INSERVICE INSPECTION REPORT
December 28, 1988 through September 10, 1990

Part D pages 1 of 12

1) Owners: Iowa Electric Light and Power Company
P.O. Box 351
Cedar Rapids, Iowa 52406

Central Iowa Power Cooperative
Marion, Iowa

Corn Belt Power Cooperative
Humboldt, Iowa

2) Plant Duane Arnold Energy Center, Palo, Iowa 52324

3) Plant Unit #1

4) Owners Certificate of Authorization (if required) N/A

5) Commercial Service Date 2-1-75

6) National Board Number of Unit N/A

GROSS GENERATING CAPACITY: 565 MWE

Component and Weld Examinations Identification Records

COMPONENT	DESCRIPTION	ISI REPORT	ISI ISO NUM.	CATEGORY	RESULTS	COMMENTS
CLASS 1 RPV INTERIOR	RPV Interior	89-439, VT-3	N/A	B-N-1	ACCEPTED	AREAS ABOVE AND BELOW THE REACTOR CORE REFERENCE 1990
	RPV INTERIOR	89-439	N/A	B-N-2	ACCEPT	RFO GE INVESSEL INSPECTION BOOK AREAS ABOVE AND BELOW THE REACTOR CORE REF. 1990 RFO (C) INVESSEL INSPECTION BOOK
REACTOR VESSEL	HCC-B002	89-23, UT-0 89-24, UT-45 89-25, UT-60	1.1-02	B-A	NRI	
	HMC-B002	89-26, UT-0 89-27, UT-45 89-28, UT-60		B-A	NRI	
	VCB-C005	89-29, UT-0 89-30, UT-45 89-31, UT-60	1.1-03	B-A	NRI	FROM STUDS 20-4
	HCC-C001	89-32, MT 89-33, UT-0 89-34, UT-45 89-35, UT-60		B-A	NRI	FROM STUDS 20-4
	HCA-H002	89-36, MT		B-H	NRI	SKIRT WELD FROM 13'-4" TO 26'-8"
	CLOSURE HEAD NUTS	89-37, MT	1.1-05	B-G-1	NRI	NUTS 1 - 40
	CLOSURE HEAD STUDS	89-38, UT-0			NRI	STUDS 1
	CLOSURE HEAD LIGAMENTS	89-39, UT-0			NRI	LIGAMENTS 1 - 4
	CLOSURE HEAD WASHERS	89-40, VT-1			NRI	WASHERS 1 - 40

INSERVICE INSPECTION REPORT
December 28, 1988 through September 10, 1990

Part D page 2 of 12

1) Owners: Iowa Electric Light and Power Company
P.O. Box 351
Cedar Rapids, Iowa 52406

Central Iowa Power Cooperative
Marion, Iowa

Corn Belt Power Cooperative
Humboldt, Iowa

2) Plant Duane Arnold Energy Center, Palo, Iowa 52324

3) Plant Unit #1

4) Owners Certificate of Authorization (if required) N/A

5) Commercial Service Date 2-1-75

6) National Board Number of Unit N/A

GROSS GENERATING CAPACITY: 565 MWE

Component and Weld Examinations Identification Records

COMPONENT	DESCRIPTION	ISI REPORT	ISI ISO NUM.	CATEGORY	RESULTS	COMMENTS
RPV (cont)	VESSEL STABILIZER WELD-90 DEG VID-D001	89-41,MT		B-H	NRI	
		89-52,UT-70	1.1-06	B-D	NRI	
		89-53,UT-0				
	JPA-D001	89-54,UT-45				
		89-55,UT-60				
		89-56,UT-70			NRI	
	RRF-D001	89-57,UT-0				
		89-58,UT-45				
		89-59,UT-60			NRI	
	RCA-D001	89-60,UT-70				
		89-61,UT-0				
		89-62,UT-45				
	CRA-D001	89-63,UT-60			NRI	
		89-64,UT-70				
		89-65,UT-0				
	HSE-D001	89-66,UT-45				
		89-67,UT-60			NRI	
		89-69,UT-0				
CONTROL ROD DRIVE BOLTING, STUDS AND NUTS	CRD FLANGE 1R215(06-23)	89-70,UT-45				
		89-71,UT-70			NRI	
	CRD FLANGE 1R215(10-19)	89-72,UT-70			NRI	
		89-73,UT-0				
	CRD FLANGE 1R215(10-35)	89-74,UT-45				
		89-75,UT-60				
	CRD FLANGE 1R215(34-31)					
	CRD FLANGE 1R215(10-19)	90-29,VT-1	1.1-08A,B	B-G-2	ACCEPTED	
		90-31,VT-1			ACCEPTED	
	CRD FLANGE 1R215(10-35)	90-32,VT-1			ACCEPTED	
		90-33,VT-1			ACCEPTED	
	CRD FLANGE 1R215(34-15)	90-34,VT-1			ACCEPTED	
		90-35,VT-1			ACCEPTED	
	CRD FLANGE 1R215(42-19)					

INSERVICE INSPECTION REPORT
December 28, 1988 through September 10, 1990

Part D page 3 of 1

1) Owners: Iowa Electric Light and Power Company
P.O. Box 351
Cedar Rapids, Iowa 52406

Central Iowa Power Cooperative
Marion, Iowa

Corn Belt Power Cooperative
Humboldt, Iowa

2) Plant Duane Arnold Energy Center, Palo, Iowa 52324

3) Plant Unit #1

4) Owners Certificate of Authorization (if required) N/A

5) Commercial Service Date 2-1-75

6) National Board Number of Unit N/A

GROSS GENERATING CAPACITY: 565 MWE

Component and Weld Examinations Identification Records

COMPONENT	DESCRIPTION	ISI REPORT	ISI ISO NUM.	CATEGORY	RESULTS	COMMENTS
CRD BOLTING (cont)	CRD FLANGE	90-36, VT-1			ACCEPTED	
	1R215(02-19)					
	CRD FLANGE	90-37, VT-1			ACCEPTED	
	1R215(06-11)					
	CRD FLANGE	90-38, VT-1			ACCEPTED	
	1R215(10-39)					
	CRD FLANGE	90-39, VT-1			ACCEPTED	
	1R215(14-15)					
	CRD FLANGE	90-41, VT-1			ACCEPTED	
	1R215(30-23)					
	CRD FLANGE	90-42, VT-1			ACCEPTED	
	1R215(38-11)					
	CRD FLANGE	90-43, VT-1			ACCEPTED	
	1R215(42-43)					
	CRD FLANGE	90-44, VT-1			ACCEPTED	
	1R215(02-23)					
	CRD FLANGE	90-45, VT-1			ACCEPTED	
	1R215(10-11)					
	CRD FLANGE	90-46, VT-1			ACCEPTED	
	1R215(10-27)					
	CRD FLANGE	90-47, VT-1			ACCEPTED	
	1R215(22-23)					
	CRD FLANGE	90-48, VT-1			ACCEPTED	
	1R215(26-19)					
MAIN STEAM 'A'	MSA-K035	89-76, VT-3/4	1.2-01	F-C	ACCEPTED	
	CV-4412	90-246, VT-1		B-G-2	ACCEPTED	
		90-247, VT-3		B-M-2	ACCEPTED	
	CV-4413	90-248, VT-1		B-G-2	ACCEPTED	
		90-249, VT-3		B-M-2	ACCEPTED	
	PSV-4400	90-187, VT-1		B-G-2	ACCEPTED	
		90-188, VT-3		B-M-2	ACCEPTED	
	PSV-4401	90-189, VT-1		B-G-2	ACCEPTED	
		90-191, VT-3		B-M-2	ACCEPTED	
MAIN STEAM 'B'	MSB-K040	89-446, VT3/4	1.2-02	F-C	ACCEPTED	
	CV-4415	89-452, VT-1		B-G-2	ACCEPTED	
		89-451, VT-3		B-M-2	ACCEPTED	
	CV-4416	90-252, VT-1		B-G-2	ACCEPTED	
		90-253, VT-3		B-M-2	ACCEPTED	

INSERVICE INSPECTION REPORT
December 28, 1988 through September 10, 1990

Part D page 4 of 12

1) Owners: Iowa Electric Light and Power Company
P.O. Box 351
Cedar Rapids, Iowa 52406

Central Iowa Power Cooperative
Marion, Iowa

Corn Belt Power Cooperative
Humboldt, Iowa

2) Plant Duane Arnold Energy Center, Palo, Iowa 52324

3) Plant Unit #1

4) Owners Certificate of Authorization (if required) N/A

5) Commercial Service Date 2-1-75

6) National Board Number of Unit N/A

GROSS GENERATING CAPACITY: 565 MWE

Component and Weld Examinations Identification Records

COMPONENT	DESCRIPTION	ISI REPORT	ISI ISO NUM.	CATEGORY	RESULTS	COMMENTS
SB (cont)	PSV-4402	90-195, VT-1		B-G-2	ACCEPTED	
		90-272, VT-3		B-G-2	ACCEPTED	
	PSV-4403	90-008, VT-1		B-G-2	ACCEPTED	
		90-009, VT-3		B-M-2	ACCEPTED	
MAIN STEAM 'C'	MSC-J009	89-78, MT	1.2-03	B-J	ACCEPTED	
		89-79, UT-45		B-J	ID ROOT	GEOMETRY
	MSC-J009-OA	89-80, MT		B-J	NRI	
		89-81, UT-45		B-J	NRI	
	MSC-J009-IA	89-82, MT		B-J	NRI	
		89-83, UT-45		B-J	NRI	
	MSC-J010	89-84, MT		B-J	NRI	
		89-85, UT-45		B-J	NRI	
	MSC-K011A	89-86, MT		B-K-1	NRI	
		89-87, VT-3/4		F-C	ACCEPTED	
	MSC-K011B	89-89, VT-3/4		F-C	ACCEPTED	
	MSC-J015-OA	89-90, MT		B-J	NRI	
		89-91, UT-45		B-J	NRI	
	MSC-J015-IA	89-92, MT		B-J	NRI	
		89-93, UT-45		B-J	NRI	
	MSC-J027	89-94, MT		B-J	NRI	
		89-95, UT-45		B-J	NRI	
	CV-4419	89-454, VT-1		B-G-2	ACCEPTED	
		89-453, VT-3		E-M-2	ACCEPTED	
	CV-4418	90-254, VT-1		B-G-2	ACCEPTED	
		90-255, VT-3		H-M-2	ACCEPTED	
	PSV-4404	90-010, VT-1		B-G-2	ACCEPTED	
		90-011, VT-3		B-M-2	ACCEPTED	
	PSV-4405	90-197, VT-3		B-M-2	ACCEPTED	
		90-186, VT-3		B-M-2	ACCEPTED	
		90-26, VT-1		B-G-2	ACCEPTED	
MAIN STEAM 'D'	MSD-K018	89-96, MT	1.2-04	B-K-1	NRI	
		89-97, VT-3/4		F-C	ACCEPTED	
	MSD-J031-OA	89-98, MT		B-J	NRI	
		89-99, UT-45		B-J	NRI	
	MSD-J031-IA	89-100, MT		B-J	NRI	
		89-101, UT-45		B-J	NRI	
	MSD-J032	89-102, MT		B-J	NRI	
		89-103, UT-45		B-J	NRI	

INSERVICE INSPECTION REPORT
December 28, 1988 through September 10, 1990

Part D page 5 of 12

- 1) Owners: Iowa Electric Light and Power Company
P.O. Box 351
Cedar Rapids, Iowa 52406

Central Iowa Power Cooperative
Marion, Iowa

Corn Belt Power Cooperative
Humboldt, Iowa

- 2) Plant Duane Arnold Energy Center, Palo, Iowa 52324
3) Plant Unit #1
4) Owners Certificate of Authorization (if required) N/A
5) Commercial Service Date 2-1-75
6) National Board Number of Unit N/A

GROSS GENERATING CAPACITY: 565 MWE

Component and Weld Examinations Identification Records

COMPONENT	DESCRIPTION	ISI REPORT	ISI ISO NUM.	CATEGORY	RESULTS	COMMENTS
MSD (cont)	MSD-J032-OA	89-104, MT		B-J	NRI	
		89-105, UT-45		B-J	NRI	
	MSD-J032-IA	89-106, MT		B-J	NRI	
		89-107, UT-45		B-J	NRI	
	MSD-J016	89-108, MT		B-J	NRI	
		89-109, UT-45		B-J	NRI	
	CV-4420	90-258, VT-1		E-G-2	ACCEPTED	
		90-259, VT-3		B-M-2	ACCEPTED	REPAIRED AREAS ACCEPTED UNDER 90-327
	CV-4421	90-260, VT-1		B-G-2	ACCEPTED	
		90-261, VT-3		B-M-2	ACCEPTED	
	PSV-4406	90-199, VT-3		B-M-2	ACCEPTED	
		90-198, VT-1		B-G-2	ACCEPTED	
		89-15, VT-1		B-G-2	ACCEPTED	
	PSV-4407	89-19, VT-3		B-M-2	ACCEPTED	
		90-201, VT-3		B-M-2	ACCEPTED	
		90-200, VT-1		B-G-2	ACCEPTED	
		89-18, VT-1		B-G-2	ACCEPTED	
FEEDWATER A & B	V-14-3	90-164, VT-3	1.2-05	B-M-2	ACCEPTED	
FEEDWATER C & D	FWC-J027	89-110, MT	1.2-06	B-J	NRI	
		89-111, UT-45		B-J	NRI	
	FWC-K026A	89-112, VT3/4		F-C	ACCEPTED	
	FWC-K020	89-113, VT3/4		F-C	ACCEPTED	
	FWC-K018	89-114, VT3/4		F-C	ACCEPTED	
	FWC-J012	89-115, MT		B-J	NRI	
		89-116, UT-45		B-J	ROOT GEO.	
	FWD-J016	89-117, MT		B-J	NRI	
		89-118, UT-45		B-J	ROOT GEO.	
	FWD-K014	89-119, VT3/4		F-C	ACCEPTED	
	FWC-J037	89-120, MT		B-J	NRI	
		89-121, UT-45		B-J	NRI	
	V-14-1	90-22, VT-3		B-M-2	ACCEPTED	
CORE SPRAY A	CSA-J023	89-129, MT	1.2-07	B-J	NRI	
		89-130, UT-45		B-J	NRI	

INSERVICE INSPECTION REPORT
December 28, 1988 through September 10, 1990

Part D page 6 of 12

- 1) Owners: Iowa Electric Light and Power Company
P.O. Box 351
Cedar Rapids, Iowa 52406

Central Iowa Power Cooperative
Marion, Iowa

Corn Belt Power Cooperative
Humboldt, Iowa

- 2) Plant Duane Arnold Energy Center, Palo, Iowa 52324
3) Plant Unit #1
4) Owners Certificate of Authorization (if required) N/A
5) Commercial Service Date 2-1-75
6) National Board Number of Unit N/A

GROSS GENERATING CAPACITY: 565 MWE

Component and Weld Examinations Identification Records

COMPONENT	DESCRIPTION	ISI REPORT	ISI ISO NUM.	CATEGORY	RESULTS	COMMENTS
CSA (cont)	CSA-J022	89-131,MT		B-J	NRI	
		89-132,UT-45		B-J	NRI	
	CSA-K017	89-133,VT3/4		F-C	ACCEPTED	
HPCI-STEAM	MO-2238	89-08,VT-3	1.2-09	B-M-2	ACCEPTED	
	MO-2239	90-06,VT-3		B-M-2	ACCEPTED	
HPCI-WATER	MO-2312	89-20,VT-3	1.2-10	B-M-2	ACCEPTED	
	V23-0049	89-459,VT-3		B-M-2	ACCEPTED	
RWCU-DISCHARGE	CUB-K024	89-144,VT3/4	1.2-11B	F-C	ACCEPTED	
	CUB-K018	89-145,VT3/4		F-C	ACCEPTED	
	CUB-J017	89-146,PT		B-J	ACCEPTED	
		89-135,UT-45		B-J	NRI	
CRD-RETURN	CRA-K017AA	89-152,VT3/4	1.2-12A	F-C	ACCEPTED	
	CRA-K017AB	89-153,VT3/4		F-C	ACCEPTED	
	CRA-F004	89-154,PT		B-F	NRI	
		89-147,UT-45		B-F	NRI	
		89-148,UT-45		B-F	NRI	
	CRA-F002	89-155,PT		B-F	NRI	
		89-150,UT-45		B-F	NRI	
		89-151,UT-45		B-F	NRI	
	CRA-K041D	89-156,VT3/4		F-C	ACCEPTED	
	CRA-K041A	89-157,VT3/4		F-C	ACCEPTED	
	CRA-J041	89-158,MT		B-J	NRI	
	CRA-J040	89-159,MT		B-J	NRI	
	CRA-J034	89-160,MT		B-J	NRI	
RHR-HEADSPRAY	RHA-J002	89-161,MT	1.2-13	B-J	NRI	
		89-162,UT-45		B-J	NRI	
RHR-SDC	RHB-J001-LS	89-166,PT	1.2-14	B-J	NRI	
		89-167,UT-45		B-J	NRI	
	RHB-F003	89-168,PT		B-F	NRI	
		89-169,UT-45		B-F	NRI	
		89-170,UT-45		B-F	NRI	
	RHB-K004	89-171,VT3/4		F-C	ACCEPTED	
	RHB-K009	89-172,VT3/4		F-C	ACCEPTED	

INSERVICE INSPECTION REPORT
December 28, 1988 through September 10, 1990

Part D page 7 of 12

- 1) Owners: Iowa Electric Light and Power Company
P.O. Box 351
Cedar Rapids, Iowa 52406

Central Iowa Power Cooperative
Marion, Iowa

Corn Belt Power Cooperative
Humboldt, Iowa

- 2) Plant Duane Arnold Energy Center, Palo, Iowa 52324
3) Plant Unit #1
4) Owners Certificate of Authorization (if required) N/A
5) Commercial Service Date 2-1-75
6) National Board Number of Unit N/A

GROSS GENERATING CAPACITY: 565 MWE

Component and Weld Examinations Identification Records

COMPONENT	DESCRIPTION	ISI REPORT	ISI ISO NUM.	CATEGORY	RESULTS	COMMENTS
RHR-SDC (cont)	RHR-J016	89-173, MT		B-J	NRI	
		89-174, UT-45		B-J	NRI	
	RHB-J002	89-175, PT		B-J	NRI	
		89-165, UT-45		B-J	NRI	
RHR-20A	RHC-J024	89-176, MT	1.2-15	B-J	NRI	BORE AND O.D. GEOMETRY
		89-177, UT-45		B-J	COUNTER	
	RHC-J023	89-178, MT		B-J	NRI	
		89-179, UT-45		B-J	NRI	
	RHC-K016A	89-180, VT3/4		F-C	ACCEPTED	
	RHC-K016	89-181, VT3/4		F-C	ACCEPTED	
RHR-20B	MO-1905	89-449, VT-3	1.2-16	B-M-2	ACCEPTED	
RECIRC PUMP VALVE BYPASS 'A'	RBA-FLG-BOLTING	89-200, VT-1	1.2-19A	B-G-2	ACCEPTED	
	RBA-J002	89-201, PT		B-J	NRI	
		89-183, UT-45		B-J	NRI	
	RHA-K005A	89-202, VT3/4		F-C	ACCEPTED	
	RBA-K005B	89-203, VT3/4		F-C	ACCEPTED	
RECIRC. SUCTION 'A'	RCA-F002	89-204, PT	1.2-19A	B-F	NRI	
		89-192, UT-RL		B-F	ID-GEO.	
	RCA-J003-LS	89-205, PT		B-J	NRI	
		89-206, UT-45		B-J	NRI	
	RCA-J004	89-207, PT		B-J	NRI	
		89-208, UT-45		B-J	NRI	
	RCA-J004-OA	89-209, PT		B-J	NRI	
		89-210, UT-45		B-J	NRI	
	RCA-J004-IA	89-211, PT		B-J	NRI	
		89-212, UT-45		B-J	NRI	
	RCA-K017	89-213, PT		B-K-1	NRI	
		89-214, VT3/4		F-C	ACCEPTED	
	1P201A-CASE INT	89-215, VT-3		B-L-2	ACCEPTED	
	RCA-K026	89-216, PT		B-K-1	NRI	
		89-217, VT3/4		F-C	ACCEPTED	
	RCA-K035	89-218, VT3/4		F-C	ACCEPTED	
	RCA-J018	89-219, PT		B-J	NRI	
		89-197, UT-45		B-J	NRI	
	RCA-J019	89-220, PT		B-J	NRI	

INSERVICE INSPECTION REPORT
December 28, 1988 through September 10, 1990

Part D page 8 of 12

- 1) Owners: Iowa Electric Light and Power Company
P.O. Box 351
Cedar Rapids, Iowa 52406

Central Iowa Power Cooperative Corn Belt Power Cooperative
Marion, Iowa Humboldt, Iowa

- 2) Plant Duane Arnold Energy Center, Palo, Iowa 52324

- 3) Plant Unit #1

- 4) Owners Certificate of Authorization (if required) N/A

- 5) Commercial Service Date 2-1-75

- 6) National Board Number of Unit N/A

GROSS GENERATING CAPACITY: 565 MWE

Component and Weld Examinations Identification Records

COMPONENT	DESCRIPTION	ISI REPORT	ISI ISO NUM.	CATEGORY	RESULTS	COMMENTS
RECIRC DRAIN 'A'	RDA-J006 RDA-J007	89-221,PT 89-222,PT	1.2-19B	B-J B-J	NRI NRI	
RHCIRC MANIFOLD 'A' SIDE	RMA-J007	89-241,PT 89-223,UT-45	1.2-20	B-J B-J	NRI NRI	
RECIRC MANIFOLD 'A' (cont)	RMA-K003 RRF-F002	89-242,VT3/4 89-243,PT		F-C B-F	ACCEPTED NRI	
		89-244,UT-RL		B-F	ROOT GEOM.	
	RRF-F002A	89-246,PT 89-247,UT-45		B-F B-F	NRI NRI	
RECIRC PUMP SUCTION 'B'	1P201B-CASE INT	89-251,VT-3	1.2-21A	B-L-2	ACCEPTED	
JET PUMP INST 'A'	JPA-F002	89-272,PT 89-269,UT-45	1.2-25	B-F B-F	NRI NRI	
	JPA-J003	89-270,UT-45 89-273,PT 89-271,UT-45		B-F B-F B-F	NRI NRI NRI	
RECIRC PUMP 'A'	HPA-CS-STUDS HPA-FLG-SURFACE RPA-CS-NUTS RPA-SF-SCREWS	89-278,UT-0 89-279,VT-1 89-282,VT-1 89-283,VT-1	1.3-01	B-G-1 B-G-1 B-G-1 B-G-2	NRI ACCEPTED ACCEPTED ACCEPTED	STUDS 1-16 NUTS 1-16 SCREWS 1-16
RECIRC PUMP 'B'	RPB-CS-STUDS RPB-FLG-SURFACE RPB-CS-NUTS RPA-SF-SCREWS	89-277,UT-0 89-280,VT-1 89-281,VT-1 89-284,VT-1		B-G-1 B-G-1 B-G-1 B-G-2	NRI ACCEPTED ACCEPTED ACCEPTED	STUDS 1-16 NUTS 1-16 SCREWS 1-16
RECIRC PUMP 'A'	RPA-K001 RPA-K004A	89-285,PT 89-286,VT3/4 89-287,VT3/4	1.3-02	B-K-1 F-C F-C	NRI ACCEPTED ACCEPTED	
RECIRC PUMP 'B'	RPB-K004A RPB-K005	89-289,VT3/4 89-450,PT 89-290,VT3/4	1.3-03	F-C B-K-1 F-C	ACCEPTED NRI ACCEPTED	

INSERVICE INSPECTION REPORT
December 28, 1988 through September 10, 1990

Part D page 9 of 1

1) Owners: Iowa Electric Light and Power Company
P.O. Box 351
Cedar Rapids, Iowa 52406

Central Iowa Power Cooperative
Marion, Iowa

Corn Belt Power Cooperative
Humboldt, Iowa

2) Plant Duane Arnold Energy Center, Palo, Iowa 52324

3) Plant Unit #1

4) Owners Certificate of Authorization (if required) N/A

5) Commercial Service Date 2-1-75

6) National Board Number of Unit N/A

GROSS GENERATING CAPACITY: 565 MWE

Component and Weld Examinations Identification Records

COMPONENT	DESCRIPTION	ISI REPORT	ISI ISO NUM.	CATEGORY	RESULTS	COMMENTS
CLASS 1 PRESSURE TESTS	RPV PIPING, PUMPS, VALVES & CRD DRIVES	89-13,VT-2	VARIOUS	B-P	SAT	PROCEDURE STP 46G022
CLASS 2 RHR PUMP SUCTION 'SE'	RHA-CE073A RHA-CF072 RHA-CF069 RHA-CF006	89-291,VT3/4 89-292,MT 89-293,MT 89-295,MT	2.2-32	F-C C-F C-F C-F	ACCEPTED ACCEPTED ACCEPTED ACCEPTED	
RHR PUMP SUCTION 'NW'	RHB-CE076 RHB-CE068 RHB-CE065 RHB-CE037	89-298,VT3/4 89-299,MT 89-300,VT3/4 89-301,VT3/4 89-303,VT3/4	2.2-33	F-C C-C F-C F-A F-C	ACCEPTED NRI ACCEPTED ACCEPTED ACCEPTED	
RHR PUMP SHUTDOWN	RHC-CE060 REC-CF056 REC-CE076 REC-CF080 REC-CE029 REC-CE024 RHC-CF012	89-304,MT 89-305,VT3/4 89-306,MT 89-307,VT3/4 89-308,MT 89-310,VT3/4 89-311,VT3/4 89-313,MT	2.2-34	C-C F-C C-F F-C C-F F-A F-C C-F	NRI ACCEPTED NRI ACCEPTED NRI ACCEPTED ACCEPTED NRI	
RHR HT EXCH DISCHARGE 'SE'	REF-CF004 RHF-CE040 RHF-CE045 REF-CF047 REF-CE051 REF-CE069 REF-CE131 REF-CF115 REF-CE123	89-314,MT 89-315,VT3/4 89-316,VT3/4 89-317,MT 89-318,VT3/4 89-320,VT3/4 89-321,VT3/4 89-323,MT 89-324,MT 89-325,VT3/4	2.2-37E 2.2-37A	C-F F-C F-C C-F F-A F-C F-C C-F C-C F-C	NRI ACCEPTED ACCEPTED NRI ACCEPTED ACCEPTED ACCEPTED NRI ACCEPTED ACCEPTED	
RHR FUEL POOL COOLING	RHM-CE044 RHM-CE032 RHM-CE025 RHM-CF020 RHM-CF019 RHM-CE015	89-329,VT3/4 89-330,VT3/4 89-331,VT3/4 89-333,MT 89-334,MT 89-335,VT3/4	2.2-43	F-C F-C F-C C-F C-F F-C	ACCEPTED ACCEPTED ACCEPTED NRI NRI ACCEPTED	

INSERVICE INSPECTION REPORT
December 28, 1988 through September 10, 1990

Part D page 10 of 12

1) Owners: Iowa Electric Light and Power Company
P.O. Box 351
Cedar Rapids, Iowa 52406

Central Iowa Power Cooperative
Marion, Iowa

Corn Belt Power Cooperative
Humboldt, Iowa

2) Plant Duane Arnold Energy Center, Palo, Iowa 52324

3) Plant Unit #1

4) Owners Certificate of Authorization (if required) N/A

5) Commercial Service Date 2-1-75

6) National Board Number of Unit N/A

GROSS GENERATING CAPACITY: 565 MWE

Component and Weld Examinations Identification Records

COMPONENT	DESCRIPTION	ISI REPORT	ISI ISO NUM.	CATEGORY	RESULTS	COMMENTS
RHR (cont)	RHM-CE011	90-328,MT		C-C	NRI	
	RHM-CE041	90-304,VT3/4		F-A	ACCEPTED	
HPCI-TURBINE STEAM INLET	HPC-CE090	89-338,VT3/4	2.2-46	F-C	ACCEPTED	
	HPC-CE089	89-339,VT3/4		F-B	ACCEPTED	
	HPC-CE082	89-340,VT3/4		F-C	ACCEPTED	
	HPC-CE078	89-341,VT3/4		F-B	ACCEPTED	
	HPC-CE075	89-342,VT3/4		F-C	ACCEPTED	
	HPC-CE072	89-343,VT3/4		F-C	ACCEPTED	
	HPC-CE070	89-344,VT3/4		F-C	ACCEPTED	
	HPC-CE067	89-345,VT3/4		F-C	ACCEPTED	
	HPC-CE064	89-346,VT3/4		F-C	ACCEPTED	
	HPC-CE062	89-347,MT		C-C	NRI	
		89-348,VT3/4		F-A	ACCEPTED	
	HPC-CE047	89-349,VT3/4		F-C	ACCEPTED	
	HPC-CF046	89-350,MT		C-F	NRI	
		89-351,UT-45		C-F	NRI	
	HPC-CF044	89-352,MT		C-F	NRI	
		89-353,UT-45		C-F	NRI	
	HPC-CE042	89-354,VT3/4		F-C	ACCEPTED	
HPCI TURBINE STEAM EXHAUST	HPD-CE014	89-355,VT3/4	2.2-47	F-B	ACCEPTED	
	HPD-CE016	89-356,MT		C-C	NRI	
		89-357,VT3/4		F-C	ACCEPTED	
	HPD-CE022	89-358,VT3/4		F-C	ACCEPTED	
	HPD-CE023	89-359,VT3/4		F-C	ACCEPTED	
	HPD-CE030	89-360,MT		C-C	NRI	
		89-361,VT3/4		F-B	ACCEPTED	
	HPD-CE034	89-362,VT3/4		F-A	ACCEPTED	
	HPD-CF043	89-363,MT		C-F	NRI	
	HPD-CE047A	89-364,VT3/4		F-C	ACCEPTED	
CORE SPRAY SUCTION 'SE'	CSA-CE041	89-365,VT3/4	2.2-48	F-A	ACCEPTED	
	CSA-CF040	89-366,MT		C-F	NRI	
	CSA-CE038A	89-367,VT3/4		F-C	ACCEPTED	
	CSA-CE030	89-368,VT3/4		F-A	ACCEPTED	
CORE SPRAY DISCHARGE 'SE'	CSC-CE005	89-369,VT3/4	2.2-50	F-C	ACCEPTED	

INSERVICE INSPECTION REPORT
December 28, 1988 through September 10, 1990

Part D page 11 of 1

- 1) Owners: Iowa Electric Light and Power Company
P.O. Box 351
Cedar Rapids, Iowa 52406

Central Iowa Power Cooperative
Marion, Iowa

Corn Belt Power Cooperative
Humboldt, Iowa

- 2) Plant Duane Arnold Energy Center, Palo, Iowa 52324
- 3) Plant Unit #1
- 4) Owners Certificate of Authorization (if required) N/A
- 5) Commercial Service Date 2-1-75
- 6) National Board Number of Unit N/A

GROSS GENERATING CAPACITY: 565 MWE

Component and Weld Examinations Identification Records

COMPONENT	DESCRIPTION	ISI REPORT	ISI ISO NUM.	CATEGORY	RESULTS	COMMENTS	
MAIN STEAM 'A'	MSA-CE023	89-370, VT3/4	2.2-53	F-A	ACCEPTED		
	MSA-CE029A	89-371, VT3/4		F-C	ACCEPTED		
	MSA-CE029B	89-372, VT3/4		F-C	ACCEPTED		
MAIN STEAM 'B'	MSB-CF002	89-373, MT	2.2-54	C-F	NRI		
	MSB-CE013	89-374, VT3/4		F-C	ACCEPTED		
	MSB-CE021	89-375, VT3/4		F-C	ACCEPTED		
	MSB-CE024	89-376, VT3/4		F-C	ACCEPTED		
	MSB-CE030	89-377, VT3/4		F-C	ACCEPTED		
MAIN STEAM BYPASS	MSE-CE028	89-378, VT3/4	2.2-57	F-C	ACCEPTED		
	MSE-CE032	89-379, VT3/4		F-B	ACCEPTED		
	MSE-CE004	89-380, VT3/4		F-C	ACCEPTED		
	MSE-CF009	89-381, MT	2.2-58	C-F	ACCEPTED		
		89-382, UT-45		C-F	NRI		
	MSE-CF013	89-383, MT		C-F	NRI		
		89-384, UT-45	2.2-58	C-F	NRI		
	MSF-CE006	89-385, VT3/4		F-C	ACCEPTED		
	MSF-CE007	89-386, VT3/4		F-C	ACCEPTED		
	MSF-CE008	89-387, MT	2.2-58	C-F	NRI		
		89-388, UT-45		C-F	NRI		
	MSF-CE009	90-163, MT		C-C	ACCEPTED		
		MSF-CF011	89-389, MT	2.2-60	C-F	NRI	
			89-390, UT-45		C-F	NRI	
SCRAM DISCHARGE HDR "SOUTH"	SDS-CF002	89-391, MT	2.2-60	C-F	NRI		
		89-392, UT-45		C-F	NRI		
	SDS-CE001B	89-393, VT3/4		F-A	ACCEPTED		
CLASS 2							
PRESSURE TESTS							
CRD MINIPURGE	CRD MINIPURGE	90-53, VT-2	VARIOUS	C-H	SAT	PROCEDURE	
10 YEAR HYDRO TEST						STP 46G018	
CRD HYD CONTROL UNIT LEAKAGE TEST	CRA-HCU-ALL 89	89-436, VT-2	VARIOUS	C-H	SAT	PROCEDURE	
						STP BS-47	

INSERVICE INSPECTION REPORT
December 28, 1988 through September 10, 1990

Part D page 12 of 12

1) Owners: Iowa Electric Light and Power Company
P.O. Box 351
Cedar Rapids, Iowa 52406

Central Iowa Power Cooperative
Marion, Iowa

Corn Belt Power Cooperative
Humboldt, Iowa

2) Plant Duane Arnold Energy Center, Palo, Iowa 52324

3) Plant Unit #1

4) Owners Certificate of Authorization (if required) N/A

5) Commercial Service Date 2-1-75

6) National Board Number of Unit N/A

GROSS GENERATING CAPACITY: 565 MWE

Component and Weld Examinations Identification Records

COMPONENT	DESCRIPTION	ISI REPORT	ISI ISO NUM.	CATEGORY	RESULTS	COMMENTS
HPCI 10 YEAR HYDRO TEST	HPCI STEAM SIDE	90-54, VT-2	VARIOUS	C-H	SAT	PROCEDURE STP 46G010
HPCI FUNCTION TEST	HPCI STEAM AND PUMP SIDE	89-437, VT-2	VARIOUS	C-H	SAT	PROCEDURE STP 45D001
PRESSURE TEST OF INSTRUMENT LINES	RPV	89-13, VT-2	VARIOUS	C-H	SAT	PROCEDURE STP 46G022
	MAIN STEAM	89-13, VT-2	VARIOUS	C-H	SAT	PROCEDURE STP 46G022
	RECIRC	89-13, VT-2	VARIOUS	C-H	SAT	PROCEDURE STP 46G022
	RCIC	89-13, VT-2	VARIOUS	C-H	SAT	PROCEDURE STP 46G022
	HPCI	89-13, VT-2	VARIOUS	C-H	SAT	PROCEDURE STP 46G022
	CORE SPRAY	89-13, VT-2	VARIOUS	C-H	SAT	PROCEDURE

Abbreviations

RPV - Reactor Pressure Vessel
NRI - Non-Recordable Indication "Acceptable"
RFO - Refueling Outage
ID - Inner Diameter
GEO.- Geometry
OD - Outer Diameter
SAT - Satisfactory

INSERVICE INSPECTION REPORT

December 28, 1988 through September 10, 1990

Part E, Page 1

ABSTRACT OF ASME SECTION XI ADDITIONAL AND SUCCESSIVE EXAMINATIONS

The following is a list of the additional examinations due to ASME Section XI corrective measures. Also included are successive examinations required due to corrective measures during previous outages.

- 1) Owners: Iowa Electric Light and Power Company
P.O. Box 351
Cedar Rapids, Iowa 52406

Central Iowa Power Cooperative Corn Belt Power Cooperative
Marion, Iowa Humboldt, Iowa
- 2) Plant Duane Arnold Energy Center, Palo, Iowa 52324
- 3) Plant Unit #1
- 4) Owners Certificate of Authorization (if required) N/A
- 5) Commercial Service Date 2-1-75
- 6) National Board Number of Unit N/A

Additional Examinations

<u>Corrective Measured Component</u>	<u>Class</u>	<u>Additional Inspected Component</u>	<u>Report #</u>	<u>ISI ISO.</u>
Hanger EBB-14-H-5 (89-345)	2	EBB-14-H-8	90-012	2.2-46
Hanger EBB-14-H-11 (89-354)	2	EBB-14-H-9	90-013	2.2-46
		EBB-14-H-12	90-014	2.2-46
		EBB-14-H-13	90-015	2.2-46
		HLE-6-H-7A	90-017	2.2-47
Hanger EBB-14-H-8 (90-12)	2	All similar	N/A	2.2-46
Hanger EBB-14-H-12 (90-14)	2	hangers examined		
Hanger GBB-5-H-20 (89-325)	2	GBB-5-H19	90-207	2.2-37A
		GBB-3-H-20C	90-208	2.2-40
		DBB-2-H-20B	90-209	2.2-40
		GLE-5-H-24	90-210	2.2-50
		GBB-5-H-18	90-211	2.2-37A

SERVICE INSPECTION REPORT

Part E, Page 2 of 6

September 28, 1988 through September 10, 1990

ABSTRACT OF ASME SECTION XI ADDITIONAL AND SUCCESSIVE EXAMINATIONS

The following is a list of the additional examinations due to ASME Section XI corrective measures. Also included are successive examinations required due to corrective measures during previous outages.

- 1) Owners: Iowa Electric Light and Power Company
P.O. Box 351
Cedar Rapids, Iowa 52406

Central Iowa Power Cooperative
Marion, Iowa

Corn Belt Power Cooperative
Humboldt, Iowa

- 2) Plant Duane Arnold Energy Center, Palo, Iowa 52324
- 3) Plant Unit #1
- 4) Owners Certificate of Authorization (if required) N/A
- 5) Commercial Service Date 2-1-75
- 6) National Board Number of Unit N/A

<u>Corrective Measured Component</u>	<u>Class</u>	<u>Additional Inspected Component</u>	<u>Report #</u>	<u>ISI ISO.</u>
Hanger HBB-25-H-166 (89-336)	2	HBB-25-H-163	90-212	2.2-43
		HBB-25-H-164	90-213	2.2-43
		HBB-25-H-165	90-214	2.2-43
		HBB-25-H-168	90-215	2.2-43
		HBB-25-H-172	90-216	2.2-43
Lug Weld RHF-CE123 (89-324)	2	RHF-CE107	90-262	2.2-37A
		RHC-CE054	90-263	2.2-34
		RHE-CE069	90-264	2.2-36
		HPC-CE030	90-265	2.2-46
		HPC-CE077	90-266	2.2-46
		CSB-CE013	90-267	2.2-49
		RHJ-CE008	90-268	2.2-40
Weld Surface MSC-J009 (89-078)	1	RHI-CE073	90-269	2.2-39
		MSB-J010	90-273	1.2-2
		MSB-J011	90-274	1.2-2
		MSC-J015	90-275	1.2-3
Hanger EBD-2-SR-111 (89-370)	2	MSC-J016	90-276	1.2-3
		EBD-2-SR-109	90-277	2.2-53
		EBD-2-H-10	90-278	2.2-53
		EBD-2-SA-135	90-279	2.2-53

ABSTRACT OF ASME SECTION XI ADDITIONAL AND SUCCESSIVE EXAMINATIONS

The following is a list of the additional examinations due to ASME Section XI corrective measures. Also included are successive examinations required due to corrective measures during previous outages.

- 1) Owners: Iowa Electric Light and Power Company
P.O. Box 351
Cedar Rapids, Iowa 52406

Central Iowa Power Cooperative Corn Belt Power Cooperative
Marion, Iowa Humboldt, Iowa
- 2) Plant Duane Arnold Energy Center, Palo, Iowa 52324
- 3) Plant Unit #1
- 4) Owners Certificate of Authorization (if required) N/A
- 5) Commercial Service Date 2-1-75
- 6) National Board Number of Unit N/A

<u>Corrective Measured Component</u>	<u>Class</u>	<u>Additional Inspected Component</u>	<u>Report #</u>	<u>ISI ISO.</u>
Snubber EBD-2-SS-115 (89-371)	2	EBD-2-H-9	90-286	2.2-53
		EBD-2-H-19	90-287	2.2-53
		EBD-2-SS-117	90-288	2.2-54
		EBD-2-SS-118	90-289	2.2-54
Snubber EBD-2-SS-116 (89-372)	2	All snubbers of this type examined in this area	N/A	2.2-53
Weld MSE-CF009 (89-381)	2	MSE-CF010	90-280	2.2-57
		MSE-CF006	90-281	2.2-57
		MSE-CF014	90-282	2.2-57
		MSE-CF020	90-283	2.2-57
Hanger GBB-5-H-19 (90-707)	2	GBB-5-SA-230	90-303	2.2-37
Weld MSE-CF010 (90-280)	2	MSE-CF022	90-306	2.2-57
Weld MSE-CF006 (90-281)	2	MSE-CF023	90-307	2.2-57
		MSE-CF024	90-308	2.2-57
		MSE-CF026	90-309	2.2-57
		MSE-CF027	90-310	2.2-57

SERVICE INSPECTION REPORT

Part E, Page 4 of 6

September 28, 1988 through September 10, 1990

ABSTRACT OF ASME SECTION XI ADDITIONAL AND SUCCESSIVE EXAMINATIONS

The following is a list of the additional examinations due to ASME Section XI corrective measures. Also included are successive examinations required due to corrective measures during previous outages.

- 1) Owners: Iowa Electric Light and Power Company
P.O. Box 351
Cedar Rapids, Iowa 52406

Central Iowa Power Cooperative Corn Belt Power Cooperative
Marion, Iowa Humboldt, Iowa
- 2) Plant Duane Arnold Energy Center, Palo, Iowa 52324
- 3) Plant Unit #1
- 4) Owners Certificate of Authorization (if required) N/A
- 5) Commercial Service Date 2-1-75
- 6) National Board Number of Unit N/A

<u>Defective Measured Component</u>	<u>Class</u>	<u>Additional Inspected Component</u>	<u>Report #</u>	<u>ISI ISO.</u>
		MSE-CF029	90-311	2.2-57
		MSE-CF030	90-312	2.2-57
		MSE-CF034	90-313	2.2-57
		MSE-CF035	90-314	2.2-57
		MSE-CF038	90-315	2.2-57
		MSE-CF039	90-316	2.2-57
		MSF-CF002	90-317	2.2-57
		MSF-CF012	90-318	2.2-57
		MSF-CF013	90-319	2.2-57
		MSF-CF022	90-320	2.2-57
		MSF-CF023	90-321	2.2-57
		MSE-CF024	90-322	2.2-57
CRD Drive Bolting 10-19 (90-32)	1	Remaining bolts in tension	89-13	1.1-8A
10-35 (90-33)		During leakage test		
02-19 (90-36)				
06-11 (90-37)				
14-15 (90-39)				

ABSTRACT OF ASME SECTION XI ADDITIONAL AND SUCCESSIVE EXAMINATIONS

The following is a list of the additional examinations due to ASME Section XI corrective measures. Also included are successive examinations required due to corrective measures during previous outages.

- 1) Owners: Iowa Electric Light and Power Company
P.O. Box 351
Cedar Rapids, Iowa 52406

Central Iowa Power Cooperative Corn Belt Power Cooperative
Marion, Iowa Humboldt, Iowa
- 2) Plant Duane Arnold Energy Center, Palo, Iowa 52324
- 3) Plant Unit #1
- 4) Owners Certificate of Authorization (if required) N/A
- 5) Commercial Service Date 2-1-75
- 6) National Board Number of Unit N/A

<u>Corrective Measured Component</u>	<u>Class</u>	<u>Additional Inspected Component</u>	<u>Report #</u>	<u>ISI ISO.</u>
30-23 (90-41)				
42-23 (90-43)				
02-23 (90-44)				
10-11 (90-45)				
10-27 (90-46)				

September 28, 1988 through September 10, 1990

ABSTRACT OF ASME SECTION XI ADDITIONAL AND SUCCESSIVE EXAMINATIONS

The following is a list of the additional examinations due to ASME Section XI corrective measures. Also included are successive examinations required due to corrective measures during previous outages.

- 1) Owners: Iowa Electric Light and Power Company
P.O. Box 351
Cedar Rapids, Iowa 52406

Central Iowa Power Cooperative Corn Belt Power Cooperative
Marion, Iowa Humboldt, Iowa
- 2) Plant Duane Arnold Energy Center, Palo, Iowa 52324
- 3) Plant Unit #1
- 4) Owners Certificate of Authorization (if required) N/A
- 5) Commercial Service Date 2-1-75
- 6) National Board Number of Unit N/A

Successive Exams

Corrective Measured Component	Class	Additional Inspected Component	Report #	ISI ISO.	Results
RPA-K002	1	87-559	89-288	1.3-2	Accepted
RHA-CE056	2	87-713	89-294	2.2-32	Accepted
RHA-CE050	2	87-714	89-296	2.2-32	Accepted
RHA-CE042	2	87-598	89-297	2.2-32	Accepted
RHB-CE057	2	87-658	89-302	2.2-33	Accepted
RHC-CE038A/B	2	87-342	89-309	2.2-34	Accepted
RHC-CE022A/B	2	87-668	89-312	2.2-34	Accepted
RHF-CE056	2	89-042	89-319	2.2-37A	Accepted
RHF-CE092A	2	87-560	89-322	2.2-37A	Accepted
RHM-CE021	2	87-601	89-332	2.2-43	Accepted
RHM-CE010	2	87-562	89-337	2.2-43	Accepted

ABSTRACT OF ASME SECTION XI REPAIRS AND REPLACEMENTS

The following is a list of Repairs and Replacements completed with a brief description of work performed.

- 1) Owners: Iowa Electric Light and Power Company
P.O. Box 351
Cedar Rapids, Iowa 52406
- Central Iowa Power Cooperative
Marion, Iowa
- Corn Belt Power Cooperative
Humboldt, Iowa

- 2) Plant Duane Arnold Energy Center, Palo, Iowa 52324
- 3) Plant Unit #1
- 4) Owners Certificate of Authorization (if required) N/A
- 5) Commercial Service Date 2-1-75
- 6) National Board Number of Unit N/A

<u>NIS-2 No.</u>	<u>Class</u>	<u>Components</u>	<u>Description</u>
10-89-01	1	PSV4402, pilot valve S/N 141	Replaced pilot valve
10-89-02	1	CV4416	Replaced stem/stem disassembly
10-89-03	2	LS2206 (level switch)	Repaired plug
10-89-04	1	CV4416	Replaced stem/stem disassembly, disk, bonnet nut
10-89-05	1	PSV4402, pilot valve S/N 200	Replaced pilot valve, stud, nuts
10-90-01	2	Hydraulic snubber, GBB-003-SS-225	Replaced snubber
10-90-02	2	Hydraulic snubber, GLE-008-SS-240	Replaced snubber
10-90-03	2	Hydraulic snubber, HBB-002-SS-300	Replaced snubber
10-90-04	1	MSRV pilot valve S/N 141 to be placed on PSV4405. See NIS2 10-90-43	Replaced pilot disc and pre load spacer
10-90-05	1	MSRV pilot valve S/N 218 to be placed on PSV4402. See NIS2 10-90-44	Repaired valve body and pilot disc
10-90-06	1	MSRV pilot valve S/N 203 to be placed on PSV4406	Welded bellows and pilot valve body
10-90-07	1	Hydraulic snubber, DCA-14-SS-73	Replaced studs/nuts
10-90-08	2	Valve, V-19-27	Replaced valve

SERVICE INSPECTION REPORT

Part F, Page 2 of 5

September 28, 1988 through September 10, 1990ABSTRACT OF ASME SECTION XI REPAIRS AND REPLACEMENTS

The following is a list of Repairs and Replacements completed with a brief description of work performed.

- 1) Owners: Iowa Electric Light and Power Company
P.O. Box 351
Cedar Rapids, Iowa 52406

Central Iowa Power Cooperative
Marion, Iowa

Corn Belt Power Cooperative
Humboldt, Iowa

- 2) Plant Duane Arnold Energy Center, Palo, Iowa 52324
- 3) Plant Unit #1
- 4) Owners Certificate of Authorization (if required) N/A
- 5) Commercial Service Date 2-1-75
- 6) National Board Number of Unit N/A

<u>NIS-2 No.</u>	<u>Class</u>	<u>Components</u>	<u>Description</u>
10-90-09	2	Hanger lug, RHF-CE-123	Repaired hanger lug (surface)
10-90-10	1	Weld, MSC-J009	Repaired weld (surface)
10-90-11	1	Mechanical snubber, EBA-X7D-SS-001	Replaced snubber for functional test
10-90-12	1	Mechanical snubber, DLA-003-SS-003	Replaced snubber for functional test
10-90-13	2	Weld, MSE-CF009	Repaired weld (surface)
10-90-14	2	Weld, MSE-CF006	Repaired weld (surface)
10-90-15	2	Weld, MSE-CF010	Repaired weld (surface)
10-90-16	2	Valve, MO-1934	Repaired valve body, welding disc
10-90-17	1	Snubber pin for DCA-004-SSB-001	Replaced snubber pin for proper fit
10-90-18	1	Mechanical snubber, DCA-004-SSB-004	Replaced snubber for functional test
10-90-19	2	Line 10"-EBB-16 (RHR side)	Modified line
10-90-20	2	Line 10"-EBB-16 (HPCI side)	Modified line
10-90-21	1	Snubber pin for DCA-004-SSA-001	Replaced snubber pin for proper fit
10-90-22	1	Valve, MO1905	Repaired valve internals
10-90-23	1	Mechanical snubber, DBA-004-SS-036	Replaced snubber for functional test
10-90-24	2	Valve, MO1989	Repaired guide rib and replaced 3 studs

ABSTRACT OF ASME SECTION XI REPAIRS AND REPLACEMENTS

The following is a list of Repairs and Replacements completed with a brief description of work performed.

- 1) Owners: Iowa Electric Light and Power Company
P.O. Box 351
Cedar Rapids, Iowa 52406

Central Iowa Power Cooperative Corn Belt Power Cooperative
Marion, Iowa Humboldt, Iowa
- 2) Plant Duane Arnold Energy Center, Palo, Iowa 52324
- 3) Plant Unit #1
- 4) Owners Certificate of Authorization (if required) N/A
- 5) Commercial Service Date 2-1-75
- 6) National Board Number of Unit N/A

<u>NIS-2 No.</u>	<u>Class</u>	<u>Components</u>	<u>Description</u>
10-90-25	2	HPCI Line 1" EBB-14	Modified line, sockolet with 1-1/2" diameter pieces
10-90-26	1	Mechanical snubber, DBA-004-SS-001	Replaced snubber for functional testing
10-90-27	1	Mechanical snubber, DBA-009-SS-002B	Replaced snubber for functional testing
10-90-28	2	Hanger, HBB-25-H163	Replaced base plate
10-90-29	2	Valve, V03-0005	Replaced valve bonnet and valve disk
10-90-30	2	Valve, V03-0004	Replaced valve bonnet and valve disk
10-90-31	2	Valve, V19-46	Replaced valve
10-90-32	1	RWCU line 4"-DCA-6 and 4"-DCA-14	Modified line and two supports
10-90-34	1	Valve, MO-2312	Replaced bonnet
10-90-35	1	CRD drives, see CRD Table OP cycle 10/11	Replaced CRD drives, some bolting
10-90-36	1	Socket weld, 4F3 on Recirc Riser 'F'	Weld repair of socket weld
10-90-37	1	N7 vent flange	Machined flange for better fit
10-90-38	1	Head Vent line flange, (lower, 2" DBA-9)	Replaced studs and nuts
10-90-39	1	Valve, V14-06	Replaced valve
10-90-40	1	Valve, V14-05	Replaced valve

SERVICE INSPECTION REPORT

Part F, Page 4 of 5

September 28, 1988 through September 10, 1990

ABSTRACT OF ASME SECTION XI REPAIRS AND REPLACEMENTS

The following is a list of Repairs and Replacements completed with a brief description of work performed.

- 1) Owners: Iowa Electric Light and Power Company
P.O. Box 351
Cedar Rapids, Iowa 52406

Central Iowa Power Cooperative Corn Belt Power Cooperative
Marion, Iowa Humboldt, Iowa
- 2) Plant Duane Arnold Energy Center, Palo, Iowa 52324
- 3) Plant Unit #1
- 4) Owners Certificate of Authorization (if required) N/A
- 5) Commercial Service Date 2-1-75
- 6) National Board Number of Unit N/A

<u>2 No.</u>	<u>Class</u>	<u>Components</u>	<u>Description</u>
10-90-41	2	Line to relief valve PSV2223	Replaced threaded pipe with flanges
10-90-42	1	Relief valve, PSV4407	Replaced pilot valve, main body
10-90-43	1	Relief valve, PSV4405	Replaced pilot valve
10-90-44	1	Relief valve, PSV4402	Replaced pilot valve
10-90-45	1	Valve, MO-2239	Repaired valve internals
10-90-46	1	Valve, MO-4630	Replaced disc, studs, nuts
10-90-47	1	Valve, MO-4629	Repaired valve internals
10-90-48	1	CRD housing, 1R215 (22-19)	Replaced bolts
10-90-49	1	Relief valve, PSV4406	Replaced bolts and nuts
10-90-54	1	Recirc Pump A	Modified internals
10-90-55	1	Recirc Pump B	Modified internals
10-90-56	1	Relief valve, PSV4401	Replaced pilot
10-90-57	1	Relief valve, PSV4403	Replaced studs and nut
10-90-58	1	Valve, CV4412	Modified valve internals
10-90-59	1	Valve, CV4413	Modified valve internals
10-90-60	1	Valve, CV4415	Modified valve internals
10-90-61	1	Valve, CV4416	Modified valve internals

ABSTRACT OF ASME SECTION XI REPAIRS AND REPLACEMENTS

The following is a list of Repairs and Replacements completed with a brief description of work performed.

- 1) Owners: Iowa Electric Light and Power Company
P.O. Box 351
Cedar Rapids, Iowa 52406

Central Iowa Power Cooperative Corn Belt Power Cooperative
Marion, Iowa Humboldt, Iowa
- 2) Plant Duane Arnold Energy Center, Palo, Iowa 52324
- 3) Plant Unit #1
- 4) Owners Certificate of Authorization (if required) N/A
- 5) Commercial Service Date 2-1-75
- 6) National Board Number of Unit N/A

<u>NIS-2 No.</u>	<u>Class</u>	<u>Components</u>	<u>Description</u>
10-90-62	1	Valve, CV4418	Modified valve internals
10-90-63	1	Valve, CV4419	Modified valve internals
10-90-64	1	Valve, CV4420	Modified valve internals
10-90-65	1	Valve, CV4421	Modified valve internals

INSERVICE INSPECTION REPORT
December 28, 1988 through September 10, 1990

Part G, Pages 197

- 1) Owners: Iowa Electric Light and Power Company
P.O. Box 351
Cedar Rapids, Iowa 52406

Central Iowa Power Cooperative
Marion, Iowa

Corn Belt Power Cooperative
Humboldt, Iowa

- 2) Plant Duane Arnold Energy Center, Palo, Iowa 52324
- 3) Plant Unit #1
- 4) Owners Certificate of Authorization (if required) N/A
- 5) Commercial Service Date 2-1-75
- 6) National Board Number of Unit N/A

GROSS GENERATING CAPACITY: 565 MWE

FORM NIS2'S

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Iowa Electric Light and Power Date February 7, 1989
Name
P.O. Box 351, Cedar Rapids, IA 52406 Sheet 1 of 1
Address
2. Plant Duane Arnold Energy Center Unit 1
Name
3277 DAEC Rd., Palo, IA 52324 CMAR 93369
Address Repair Organization P.O. No., Job No., etc.
3. Work Performed by Iowa Electric Type Code Symbol Stamp None
Name Authorization No. None
3277 DAEC Rd., Palo, IA 52324 Expiration Date None
Address
4. Identification of System Main Steam 'B' (Class 1)
ASME Section
5. (a) Applicable Construction Code III 19 68 Edition, W68 Addenda, N/A Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 80 W81

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Tested	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
Target Rock Pilot Valve	Target Rock	S/N 141	N/A	PSV 4402	1988	Replaced	Yes

7. Description of Work Replaced pilot valve S/N 189 with pilot valve S/N 141

8. Tests Conducted: Hydrostatic ☐ Pneumatic ☐ Nominal Operating Pressure ☒
 Other ☐ Pressure 1025 psi Test Temp. 550 °F

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8½ in. x 11 in., (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

FORM NIS-2 (Back)

9. Remarks Replaced pilot valve S/N 189 with pilot valve 141. (P.O. S46339)
Applicable Manufacturer's Data Reports to be attached
VT-3 inservice inspection of valve internals (partial only) performed
and acceptable. Reference inspection report no. 89-03. VT-2 of the
pressure retaining components were performed under inspection report no.89-01.

CERTIFICATE OF COMPLIANCE

We certify that the statements made in the report are correct and this replacement conforms to the rules of the
ASME Code, Section XI. repair or replacement

Type Code Symbol Stamp None

Certificate of Authorization No. None Expiration Date None

Signed [Signature], ASME Administrator Date February 10, 19 89
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State
or Province of Iowa and employed by Lumbermens Mutual Casualty Company of
Long Grove, Illinois have inspected the components described
in this Owner's Report during the period 1-18-89 to 10-4-89, and state that
to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this
Owner's Report in accordance with the requirements of the ASME Code, Section XI, except IWA-7210.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the
examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer
shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this
inspection.

[Signature] Commissions Nat'l Bd. 5813 (I)(N) IA-1041
Inspector's Signature National Board, State, Province, and Endorsements

Date Oct. 4 19 89

(12/82) * Consideration is given to Iowa Electric Relief Request No. NDE-009, re:
IE Letter Minnack to Murray, 9-18-89, NG-89-1680. WRP/gyk 10-4-89

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Iowa Electric Light and Power Date April 3, 1989
Name
P.O. Box 351, Cedar Rapids, IA 52406 Sheet 1 of 1
Address
2. Plant Duane Arnold Energy Center Unit 1
Name
3277 DAEC Rd. Palo, Iowa 52324 CMAR 93695 CSR 'A'
Address Repair Organization P.O. No., Job No., etc.
3. Work Performed by Iowa Electric Type Code Symbol Stamp None
Name Authorization No. None
3277 DAEC Rd., Palo, IA 52324 Expiration Date None
Address
4. Identification of System Main Steam 'A' (Class 1)
ASME Section
5. (a) Applicable Construction Code III 19 71 Edition, - Addenda, - Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 80 W81
 * except as noted in GE Spec 21A9230 Rev. 2
6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
Valve Bonnet	Rockwell	N/A	None	CV 4416	1989	Repaired	No
Stem/stem disc assembly	Rockwell	*	None	CV 4416	1989	Replaced**	No

7. Description of Work Replaced stem/stem disc assembly for control valve CV4416. Machined valve bonnet for proper fit.
8. Tests Conducted: Hydrostatic ☐ Pneumatic ☐ Nominal Operating Pressure ☒
 Other ☐ Pressure 1025 psi Test Temp. 525 °F

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8½ in. x 11 in., (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

FORM NIS-2 (Back)

9. Remarks Replaced stem/stem disc assembly with certified stem/stem disc assembly
Applicable Manufacturer's Data Reports to be attached
(P.O. 15757). Valve bonnet remachined, then PT tested, and was found acceptable
VT-3 inservice inspection of valve internals performed and acceptable
reference inspection report no. 89-005. VT-2 of the pressure retaining components
were performed under inspection report no. 89-007.

CERTIFICATE OF COMPLIANCE

We certify that the statements made in the report are correct and this Replacement conforms to the rules of the ASME Code, Section XI. repair or replacement

Type Code Symbol Stamp None

Certificate of Authorization No. None Expiration Date None

Signed *[Signature]*, ASME Administrator Date April 3, 19 89
Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Iowa and employed by Lumbermens Mutual Casualty Company of Long Grove, Illinois have inspected the components described in this Owner's Report during the period 3-10-89 to 4-17-89, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI, except IWA 7210.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

[Signature] Commissions Nat'l Bd. 5813(T) (N) IA-1041
Inspector's Signature National Board, State, Province, and Endorsements

Date April 17, 19 89

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Iowa Electric Light and Power Date October 25, 1989
Name
P.O. Box 351, Cedar Rapids, IA 52406
Address
2. Plant Duane Arnold Energy Center Sheet 1 of 1
Name
3277 DAEC Rd. Palo, IA 52324
Address
3. Work Performed by Iowa Electric Unit 1
Name
3277 DAEC Rd. Palo, IA 52324
Address
4. Identification of System HPCI Supply Line D.P. Level Switch (LS2206)
5. (a) Applicable Construction Code ANSI B31.7 19 69 Edition, 71 Addenda, N/A Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 80 W81
6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
LS2206	Robert Shaw Controls Co.	N/A	N/A	Model No. 82938-GI	1970	Repaired	No

7. Description of Work Seal weld of 3/4" NPT Plug

8. Tests Conducted: Hydrostatic ☐ Pneumatic ☐ Nominal Operating Pressure ☐
 Other ☐ Pressure N/A psi Test Temp. N/A °F

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8½ in. x 11 in., (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

FORM NIS-2 (Back)

9. Remarks 3"
A 4 NPT plug had a steam leak that was seal welded under CMAR 97337.

Applicable Manufacturer's Data Reports to be attached

The seal weld was liquid penetrant inspected and found acceptable.

CERTIFICATE OF COMPLIANCE

We certify that the statements made in the report are correct and this repair conforms to the rules of the ASME Code, Section XI. repair or replacement

Type Code Symbol Stamp N/A

Certificate of Authorization No. N/A Expiration Date N/A

Signed [Signature], ASME Administrator Date 10-30, 19 89
 Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Iowa and employed by Lumbermens Mutual Casualty Company of Long Grove, Illinois have inspected the components described in this Owner's Report during the period 10-23-89 to 12-4-89, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

[Signature] Commissions Nat'l Bd. 5813 (I)(N) IA-1041
 Inspector's Signature National Board, State, Province, and Endorsements

Date Dec. 4, 19 89

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Iowa Electric Light and Power Date November 2, 1989
Name
P.O. Box 351, Cedar Rapids, IA 52406 Sheet 1 of 21
Address
2. Plant Duane Arnold Energy Center Unit One
Name
3277 DAEC Rd, Palo, IA 52324 Note 2 Note 3
Address PMAR 1038426, CMAR 92975
Repair Organization P.O. No., Job No., etc.
3. Work Performed by Iowa Electric Type Code Symbol Stamp None
Name
3277 DAEC R Palo, IA 52324 Authorization No. None
Address Expiration Date None
4. Identification of System Main Steam 'B' Class 1 Note 1
5. (a) Applicable Construction Code B31.1 19 67 Edition, ----- Addenda, ----- Code Case
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 80 w81
Note 1 - except as noted in GE Spec 21A9230, Rev. 2
6. Identification of Components Repaired or Replaced and Replacement Components

	Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
Note 2	Stem/Stem Disk Assembly	Rockwell	*	None	CV4416	1985	Replaced	No
Note 2	Disk	Rockwell	**	None	CV4416	1985	Replaced	No
Note 2	Bonnet Nut	Rockwell	IN85326	None	CV4416	1988	Replaced	No
Note 3	Disk	Rockwell	**	None	Spare	1989	Repaired	No
Note 2	Main Valve Body	Rockwell	N/A	None	Guide Rib	1989	Repaired	No

7. Description of Work Replaced disc and stem/stem disk assembly for control valve CV4416 Not
8. Tests Conducted: Hydrostatic ☐ Pneumatic ☐ Nominal Operating Pressure ☒
Other ☐ Pressure 1025 psi Test Temp. 185 °F

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8½ in. x 11 in., (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

(12/82)

This Form (E00030) may be obtained from the Order Dept., ASME, 345 E. 47th St., New York, N.Y. 10017

- * 6062065-29 Note 4 disk had removed all stellite on seating area by grinding, rewelded and machined to proper dimensions. Stem was redressed and acceptable for reuse by Quality Control. Guide Rib was smoothed for proper fit of valve internals.
- ** 6062065-61

FORM NIS-2 (Back)

9. Remarks Replacing stem/stem disc assembly and disk with certified stem/stem disc assembly and disk (P.O. E9-15757-N-DA) (see Note 5). VT-3 inservice inspection of valve internals performed and accepted (Report No. 89-451). All welded components after grinding, rewelded and machined to proper fit were PT and acceptable VT-2 of the pressure retains components were performed and acceptable under inspection report no. 89-017 Bonnet Nut was replaced with certified nut (P.O. 101859). Replaced nut was inspected and acceptable (see Report No. 89-452).

CERTIFICATE OF COMPLIANCE	
We certify that the statements made in the report are correct and this <u>Repair & Replacement</u> conforms to the rules of the ASME Code, Section XI.	
Type Code Symbol Stamp	<u>None</u>
Certificate of Authorization No.	<u>None</u> Expiration Date <u>None</u>
Signed <u>R. P. Miller</u> Owner or Owner's Designee, Title <u>ASME Admin.</u>	Date <u>December 8</u> , 19 <u>89</u>

CERTIFICATE OF INSERVICE INSPECTION	
I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of <u>IOWA</u> and employed by <u>Lumbermens Mutual Casualty Company</u> of <u>Long Grove, Illinois</u> have inspected the components described in this Owner's Report during the period <u>9-10-89</u> to <u>1-12-90</u> , and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI, except Note 6.	
By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.	
<u>W. R. Ruggles</u> Inspector's Signature	Commissions <u>Nat'l Bd. 5813 (I) (N) IA-1041</u> National Board, State, Province, and Endorsements
Date <u>January 12</u> , 19 <u>90</u>	

(12/82)

Note 5 - disk assembly was formly in CV4421 and stem/stem disc assembly was formly in CV4419, then both as spares.

Note 6 - except as described by NCR 89-20 and NCR 89-21. 1-12-90

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Iowa Electric Light and Power Date December 20, 1989
Name
P.O. Box 351, Cedar Rapids IA 52406 Sheet 1 of 1
Address
2. Plant Duane Arnold Energy Center Unit One
Name
3277 DAEC Road, Palo, IA 52324 CMAR 94253
Address Repair Organization P.O. No., Job No., etc.
3. Work Performed by Iowa Electric Type Code Symbol Stamp None
Name
3277 DAEC Road, Palo, IA 52324 Authorization No. None
Address Expiration Date None
4. Identification of System Main Steam 'B' (class 1)
5. (a) Applicable Construction Code Section III 19 68 Edition, Winter 1968 Addenda, N/A Code Case
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 80 w81

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
Pilot Valve Assembly	Target-Rock	200	N/A	PSV 4402	1976	Replacement	Yes
6 - Base pilot Op bolting	Cardinal	Ht no. 211916	N/A	PSV 4402	1989	Replacement	No
3 - Base pilot Op nuts	Target-Rock	Ht no. 51480	N/A	PSV 4402	1977	Replacement	No
3 - Base pilot Op nuts	Target-Rock	Ht no. 578L7375	N/A	PSV 4402	1984	Replacement	No

7. Description of Work Replaced pilot valve assembly, base pilot operator bolting and nuts.

8. Tests Conducted: Hydrostatic ☐ Pneumatic ☐ Nominal Operating Pressure ☒
Other ☐ Pressure 1025 psi Test Temp. 525 °F

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8½ in. x 11 in., (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

FORM NIS-2 (Back)

9. Remarks Replaced 6 base pilot operator bolts with certified bolts (P.O. S49381)
Replaced 6 base pilot operator nuts with certified nuts (P.O. 25364*21635) (3 ea.)
Replaced pilot valve assembly (P.O. 18747) VT-1 of bolting was performed under
inspection report #89.464, VT-3 of valve body performed under inspection report
89-465. Valve #200 was operability test was satisfactory (P.O. 546339).
VT-2 of the valve was performed under inspection report #89-466

CERTIFICATE OF COMPLIANCE

We certify that the statements made in the report are correct and this Replacement conforms to the rules of the ASME Code, Section XI. repair or replacement

Type Code Symbol Stamp None

Certificate of Authorization No. None

Expiration Date None

Signed [Signature] ASME Administrator Date December 20, 19 89
Owner or Owner's Designee Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Iowa and employed by Lumbermans Mutual Casualty Company of Long Grove, Illinois have inspected the components described in this Owner's Report during the period 11-28-89 to 1-11-90, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

[Signature]
 Inspector's Signature

Commissions Nat'l Bd. 5813 (I) (N) IA-1041
 National Board, State, Province, and Endorsements

Date January 11, 19 90

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Iowa Electric Light and Power Date February 7, 1990
Name
P.O. Box 351, Cedar Rapids, IA 52406
Address
2. Plant Duane Arnold Energy Center Sheet 1 of 1
Name
3277 DAEC Rd., Palo, IA 52324
Address
3. Work Performed by Iowa Electric Unit 1
Name
3277 DAEC Rd., Palo, IA 52324
Address
4. Identification of System RHR PUMP DISCHARGE (N.W.) (CLASS 2)
5. (a) Applicable Construction Code ANSI 831.7 19 69 Edition, 71 Addenda, N/A Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 1980W81
6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
Hydraulic Snubber	Bergen Patterson	D. Arnold #38	None	GBB-003 -SS-225	1988	Replacement	No

7. Description of Work Hydraulic Snubber Replacement - Type (HSSA-10)
8. Tests Conducted: Hydrostatic ☐ Pneumatic ☐ Nominal Operating Pressure ☐
 Other ☐ Pressure None psi Test Temp. None °F

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8½ in. x 11 in., (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

FORM NIS-2 (Back)

9. Remarks Replacement of Hydraulic Snubber with certified Hydraulic Snubber

(P.O. 45911) VT-3/VT-4 pre-service inspection performed. Reference
inspection report no. 90-001.

CERTIFICATE OF COMPLIANCE

We certify that the statements made in the report are correct and this replacement conforms to the rules of the ASME Code, Section XI. repair or replacement

Type Code Symbol Stamp None

Certificate of Authorization No. None Expiration Date None

Signed [Signature], ASME Administrator Date February 12, 19 90
 Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Iowa and employed by Lumbermans Mutual Casualty Company of Long Grove, Illinois

[Signature] have inspected the components described in this Owner's Report during the period 1-31-90 to 2-26-90, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

[Signature] Commissions Nat'l Bd. 5813(I) (N) IA-1041
 Inspector's Signature National Board, State, Province, and Endorsements

Date February 26, 19 90

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Iowa Electric Light and Power Date February 7, 1990
Name
P.O. Box 351, Cedar Rapids, IA 52406
Address
2. Plant Duane Arnold Energy Center Sheet 1 of 1
Name
3277 DAEC Rd., Palo, IA 52324
Address
3. Work Performed by Iowa Electric Unit 1
Name
3277 DAEC Rd., Palo, IA 52324
Address
4. Identification of System RHR Heat Exchanger Discharge (NW) (Class 2)
5. (a) Applicable Construction Code ANSI B31.7 19 69 Edition, 71 Addenda, N/A Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 80W81
6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
Hydraulic Snubber	Bergen Patterson	D. Arnold #55	None	GLE-008 -SS-240	1988	Replacement	No

7. Description of Work Hydraulic Snubber Replacement - Type (HSSA-3)
8. Tests Conducted: Hydrostatic ☐ Pneumatic ☐ Nominal Operating Pressure ☐
 Other ☐ Pressure None psi Test Temp. None °F

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8½ in. x 11 in., (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

FORM NIS-2 (Back)

9. Remarks Replacement of Hydraulic Snubber with certified Hydraulic Snubber

Applicable Manufacturer's Data Reports to be attached
(P.O. 45911) VT-3/VT-4 pre-service inspection performed. Reference

inspection report no. 90-002.

CERTIFICATE OF COMPLIANCE

We certify that the statements made in the report are correct and this Replacement conforms to the rules of the ASME Code, Section XI. repair or replacement

Type Code Symbol Stamp None

Certificate of Authorization No. None Expiration Date None

Signed [Signature], ASME Administrator Date February 12, 1990
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Iowa and employed by Lumbermans Mutual Casualty Company of Long Grove, Illinois have inspected the components described in this Owner's Report during the period 1-31-90 to 2-26-90, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

[Signature] Commissions Nat'l Bd. 5813(I) (N) IA-1041
Inspector's Signature National Board, State, Province, and Endorsements

Date February 26, 1990

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Iowa Electric Light and Power Date July 10, 1990
Name
P.O.Box 351, Cedar Rapids, IA 52406 Sheet 1 of 2
Address

2. Plant Duane Arnold Energy Center Unit 1
Name
3277 DAEC Rd. Palo, IA 52324 PMAR #1045101
Address Repair Organization P.O.No., Job No.

3. Work Performed by Iowa Electric Type Code Symbol Stamp None
Name
Authorization No. None
3277 DAEC Road Palo, IA 52324 Expiration Date None
Address

4. Identification of System Suction of Core Spray (A) Pump (Class 2)

5. (a) Applicable Const. Code ASME SECT. III 19 77 Edition, W77 Addenda, N-249, N-71, N-225 Code Case
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements 1980 W81

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacture	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired Replaced, or Replacement	ASME Code Stamped (Yes or No)
Hydraulic Snubber	Berg-Patter	2500-10 866	N/A	HBB-002-SS-300	1983	Replaced	No
Hydraulic Snubber	Berg-Patter	2500-10 865	N/A	HBB-002-SS-300	1983	Replacement	No

7. Description of Work Hydraulic Snubber Replacement - Type HSSA-10

8. Tests Conducted: Hydrostatic ☐ Pneumatic ☐ Nominal Operation Pressure ☐
 Other ☐ Pressure N.A. psi Test Temp. N.A. °F
 Tested per STP 46H002
 before installation.

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8½ in. x 11 in., (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.



Sheet 2 of 2

FORM NIS-2 (Back)

9. Remarks Replacement of hydraulic snubber with certified hydraulic snubber (P.O. #062285), VT-3/4 preservice
Applicable Manufacturer's Data Reports to attached
inspection performed, Reference Inspection Report No. 90-192

CERTIFICATE OF COMPLIANCE

We certify that the statements made in the report are correct and this replacement conforms
 to the rules of the ASME Code, Section XI. repair of replacement

Type Code Symbol Stamp None

Certificate of Authorization No. None Expiration Date N.A.

Signed Srinivasan Shaniga 8-6-90 Codes & Materials, TGL Date 8-6-90, 19 90
 Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel
 Inspectors and the State or Province of Iowa and employed by Hartford Steam Boiler
ITC Co of Hartford, Connecticut have inspected the components described in
 this Owner's Report during the period 5-31-90 to 9-3-90
 , and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective
 measures described in the Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied,
 concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the
 Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of
 any kind arising from or connected with this inspection.

Scott P. Fisher Commissions NB8829 (I)(N) 941-1A
 Inspectors Signature National Board, State, Province, and Endorsements

Date 9-3 19 90

FORM NIS-2 (Back)

sheet 2 of 2

9. Remarks Pilot Valve (S/N 141) was removed and sent to Wyle Labs for testing. The pilot disc and pre-load spacer
Applicable Manufacturer's Data Reports to be attached
required replacement due to steam cutting. Pilot valve disc (S/N 407) and pre-load spacer (S/N 376) (P.O. 05954)
was installed. A preservice VT-3 exam (89-467) was performed and accepted. The valve was then tested and accepted.

CERTIFICATE OF COMPLIANCE

We certify that the statements made in the report are correct and this replacement conforms
 to the rules of the ASME Code, Section XI. repair or replacement

Type Code Symbol Stamp NoneCertificate of Authorization No. NoneExpiration Date NoneSigned Sumudu Shaula
 Owner or Owner's Designee, TitleCodes & Materials, TGL Date 7-27-, 19 90

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel
 Inspectors and the State or Province of IOWA and employed by Hartford Steam Boiler I&I Co.
of Hartford, Connecticut have inspected the components described in
 this Owner's Report during the period 3-30-90 to 8-11-90
 , and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective
 measures described in the Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied,
 concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the
 Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of
 any kind arising from or connected with this inspection.

Scott Paulsen
 Inspector's Signature

Commission NB 8829(I)(N) 941-1A
 National Board, State, Province, and Endorsements

Date August 11 19 90

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Iowa Electric Light and Power Date July 31, 1990
Name
P.O.Box 351, Cedar Rapids, IA 52406 Sheet 1 of 2
Address
2. Plant Duane Arnold Energy Center Unit 1
Name
3277 DAEC Rd. Palo, IA 52324 P.O. 802568 (CMAR 92907)
Address Repair Organization P.O.No., Job No.
3. Work Performed by Target Rock Type Code Symbol Stamp None
Name
Authorization No. None
1966E Broadhollow Rd. Farmingdale, N.Y. 11735-0919 Expiration Date None
Address
4. Identification of System Main Steam (Class 1)
- 5.* (a) Applicable Const. Code ASME SECT. III 19 68 Edition, W68 Addenda, / N A Code Case
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements 1980 W81
* GE SPEC. 21A9206 Rev. 6 & 7
6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacture	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired Replaced, or Replacement	ASME Code Stamped (Yes or No)
MSRV Pilot Valve	Target Rock	S/N 218	N/A	SPARE	1975	Repaired	Yes

7. Description of Work New second stage seat welded into valve body, Pilot disc, S.S.discs skim-cut & polished
8. Tests Conducted: Hydrostatic ☐ Pneumatic ☐ Nominal Operating Pressure ☐
Other * ☒ Pressure 1130 +/- 1% psi Test Temp. 500 °F

*Set pressure test performed at WYLE Labs

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8½ in. x 11 in., (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

8-11-98

FORM NIS-2 (Back)

sheet 2 of 2

9. Remarks Pilot valve (S/N 218) was removed and sent to Wyle Labs for testing. Welded new second stage seat to valve
Applicable Manufacturer's Data Reports to be attached
body & pilot disc and second stage disc were lapped for proper fit. Pt was performed on Pilot disc, S.S. discs &
S.S. seat by DAEC QA, Vt-3 of valve internals performed under ISI report # 89-463

CERTIFICATE OF COMPLIANCE

We certify that the statements made in the report are correct and this repair conforms
to the rules of the ASME Code, Section XI. repair or replacement

Type Code Symbol Stamp N/ACertificate of Authorization No. N/A Expiration Date N/A

Signed Sumner Shaughan Codes & Materials, TGL Date 8-7-, 19 90
Owner or Owner's Designee, Title 8

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Iowa and employed by Hartford Steam Boiler I&I Co of Hartford, Connecticut have inspected the components described in this Owner's Report during the period 5-2-90 to 8-11-90, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in the Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Scott Rustin Commissions NB 8829(I)(N) 941-1A
Inspectors Signature National Board, State, Province, and Endorsements

Date August 11 19 90

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Iowa Electric Light and Power Date July 31, 1990
 Name
P.O.Box 351, Cedar Rapids, IA 52406 Sheet 1 of 2
 Address
2. Plant Duane Arnold Energy Center Unit 1
 Name
3277 DAEC Rd. Palo, IA 52324 P.O. 802568 (CMAR 92908)
 Address Repair Organization P.O.No., Job No.
3. Work Performed by Target Rock Type Code Symbol Stamp None
 Name
 Authorization No. None
1966E Broadhollow Rd. Farmingdale, N.Y. 11735-0919 Expiration Date None
 Address
4. Identification of System Main Steam (Class 1)
- 5.* (a)Applicable Const. Code ASME SECT. III 19 68 Edition, W68 Addenda, N/A Code Case
 (b)Applicable Edition of Section XI Utilized for Repairs or Replacements 1980 W81
 * GE SPEC. 21A9206 Rev. 6 & 7
6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacture	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired Replaced, or Replacement	ASME Code Stamped (Yes or No)
MSRV Pilot Valve	Target Rock	S/N 203	N/A	SPARE	1975	Repaired	Yes

7. Description of Work Bellows and new pilot seat welded into valve body
8. Tests Conducted: Hydrostatic ☐ Pneumatic ☐ Nominal Operating Pressure ☐
 Other * ☒ Pressure 1140 +/- 1% psi Test Temp. 550 °F

*Set pressure test performed at WYLE Labs

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8½ in. x 11 in., (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

AP
 8-16-98
 ANII
 Review

FORM NIS-2 (Back)

sheet 2 of 2

9. Remarks Pilot valve (S/N 203) was removed and sent to Wyle Labs for testing. The bellows was removed to allow
Applicable Manufacturer's Data Reports to be attached
- access for pilot seat. Pt was performed on bellows, pilot seat, pilot & 2nd Stage by DAEC QA. Vt-3 inspection of
pilot valve assembly was performed under ISI# 89-462

CERTIFICATE OF COMPLIANCE

We certify that the statements made in the report are correct and this repair conforms
to the rules of the ASME Code, Section XI. repair or replacement

Type Code Symbol Stamp N/ACertificate of Authorization No. N/A Expiration Date N/A

Signed Sunder Shaugan Codes & Materials, TGL Date 8-7-, 19 90
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel
Inspectors and the State or Province of Iowa and employed by Hartford Steam Boiler I&I Co
of Hartford, Connecticut have inspected the components described in
this Owner's Report during the period 5-2-90 to 5-11-90
, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective
measures described in the Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied,
concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the
Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of
any kind arising from or connected with this inspection.

Scott Pruster Commissions NB 8829(I)(N) 941-1A
Inspectors Signature National Board, State, Province, and Endorsements

Date August 11, 19 90

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Iowa Electric Light and Power Date August 11, 1990
Name
P.O.Box 351, Cedar Rapids, IA 52406 Sheet 1 of 2
Address

2. Plant Duane Arnold Energy Center Unit 1
Name
3277 DAEC Rd. Palo, IA 52324 CHAR #A 02652
Address Repair Organization P.O.No., Job No.

3. Work Performed by Iowa Electric Type Code Symbol Stamp None
Name
Authorization No. None
3277 DAEC Road Palo, IA 52324 Expiration Date None
Address

4. Identification of System Reactor Water Cleanup System (Class1)

5. (a)Applicable Const. Code ANSI B31.7 19 69 Edition, 71 Addenda, N/A Code Case
(b)Applicable Edition of Section XI Utilized for Repairs or Replacements 1980 W81
(c)Construction code of Replacement Code Section III 19 83 Edition, S85 Addenda

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacture	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired Replaced, or Replacement	ASME Code Stamped (Yes or No)
4 studs for Hydraulic Snubber	Cardinal	006	N/A	DCA-14-SS-73	1986	Replacement	No
8 nuts for Hydraulic Snubber	Cardinal	093	N/A	DCA-14-SS-73	1986	Replacement	No

7. Description of Work Removed hanger clamp for UT access. Replacing studs/nuts with higher grade material

8. Tests Conducted: Hydrestatic ☐ Pneumatic ☐ Nominal Operation Pressure ☐
Other ☐ Pressure N/A psi Test Temp. N/A °F

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8½ in. x 11 in., (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.



FORM NIS-2 (Back)

sheet 2 of 2

9. Remarks Replacement of snubbers (Ber-Pat HSSA-3) clamp nuts and studs with higher grade. (PO s26710, s26813)
Applicable Manufacturer's Data Reports to be attached
VT-3/4 of snubber preservice inspection performed. Reference inspection report no. 90-290.

CERTIFICATE OF COMPLIANCE

We certify that the statements made in the report are correct and this replacement conforms to the rules of the ASME Code, Section XI. repair or replacement

Type Code Symbol Stamp NoneCertificate of Authorization No. None Expiration Date _____

Signed Sumner Shaugan Codes & Materials, TGL Date 8-18-, 19 90
 Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Iowa and employed by Hartford Steam Boiler I&I Co of Hartford, Connecticut have inspected the components described in this Owner's Report during the period 8-6-90 to 7-3-90, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in the Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Scott Parker Commissions NB 8829(I)(N) 941-1A
 Inspectors Signature National Board, State, Province, and Endorsements

Date 9-3 19 90

FORM NIS-2 (Back)

sheet 2 of 2

9. Remarks Replacement stop valve v-19-27 and added associated piping for proper fit. Replacement performed with
Applicable Manufacturer's Data Reports to be attached
certified material (valve- P.O.s55488)(pipe- P.O.s57406). Welds were liquid penetrant inspected and was found
acceptable. Hydrostatic test performed under ISI # 90-007.

CERTIFICATE OF COMPLIANCE

We certify that the statements made in the report are correct and this replacement conforms
to the rules of the ASME Code, Section XI. repair or replacement

Type Code Symbol Stamp NoneCertificate of Authorization No. None Expiration Date _____

Signed Sunder Shaujan Codes & Materials, TGL Date 8-18-, 19 90
Owner or Owner's Designee Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel
Inspectors and the State or Province of Iowa and employed by Hartford Steam Boiler I&I Co
of Hartford, Connecticut have inspected the components described in
this Owner's Report during the period 8-18-90 to 9-3-90
, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective
measures described in the Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied,
concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the
Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of
any kind arising from or connected with this inspection.

Scott Kusler Commissions NB 8829(I)(N) 941-IA
Inspectors Signature National Board, State, Province, and Endorsements

Date 9-3 19 90

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Iowa Electric Light and Power Date August 13, 1990
 Name
P.O.Box 351, Cedar Rapids, IA 52406 Sheet 1 of 2
 Address
2. Plant Duane Arnold Eneg Center Unit 1
 Name
3277 DAEC Rd. Palo, IA 52324 CMAR #A 00577
 Address Repair Organization P.O.No., Job No.
3. Work Performed by Iowa Electric Type Code Symbol Stamp None
 Name
 Authorization No. None
3277 DAEC Road Palo, IA 52324 Expiration Date None
 Address
4. Identification of System RHR (class 2)
5. (a)Applicable Const. Code ANSI B31.7 19 69 Edition, 71 Addenda, N/A Code Case
 (b)Applicable Edition of Section XI Utilized for Repairs or Replacements 1980 W81 class 2

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacture	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired Replaced, or Replacement	ASME Code Stamped (Yes or No)
Welded hanger lug RHF-CE-123	Bechtel	n/a	N/A	G88-5-H-20	1978	Repair	No

7. Description of Work Removal of 1" linear indication on hanger lug
8. Tests Conducted: Hydrostatic ☐ Pneumatic ☐ Nominal Operation Pressure ☐
 Other ☐ Pressure N/A psi Test Temp. N/A °F

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8½ in. x 11 in., (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.



FORM NIS-2 (Back)

sheet 2 of 2

9. Remarks 1" linear indication discovered during ISI(MT) of hanger lug CE-123. Repaired indication by grinding it out
Applicable Manufacturer's Data Reports to be attached
- Performed Mt exam under same inspection number 89-324 and was acceptable.

CERTIFICATE OF COMPLIANCE

We certify that the statements made in the report are correct and this repair conforms to the rules of the ASME Code, Section XI. repair or replacement

Type Code Symbol Stamp None

Certificate of Authorization No. Nons Expiration Date _____

Signed Sumida Shargai Codes & Materials, TGL Date 8-18-, 19 90
 Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Iowa and employed by Hartford Steam Boiler I&I Co of Hartford, Connecticut have inspected the components described in this Owner's Report during the period 8-1-90 to 9-3-90, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in the Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Scott Ressler Commissions NB 8829(I)(N) 941-1A
 Inspectors Signature National Board, State, Province, and Endorsements

Date 9-3 19 90

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Iowa Electric Light and Power Date August 24, 1990
Name
P.O.Box 351, Cedar Rapids, IA 52406 Sheet 1 of 2
Address

2. Plant Duane Arnold Energy Center Unit 1
Name
3277 DAEC Rd. Palo, IA 52324 CHAR #A 00578
Address Repair Organization P.O.No., Job No.

3. Work Performed by Iowa Electric Type Code Symbol Stamp None
Name
Authorization No. None
3277 DAEC Road Palo, IA 52324 Expiration Date None
Address

4. Identification of System Main Steam "C" line (class 1)

5. (a) Applicable Const. Code ANSI B31.1 19 67 Edition, Addenda, N/A Code
Case
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements 1980 W81 class 2

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacture	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired Replaced, or Replacement	ASME Code Stamped (Yes or No)
Weld MSC-J009	General Electric	PS-1-C2	N/A	Main steam 'c'	1973	Repoir	No

7. Description of Work Removal of 1/2" in length, 1/16" width linear indication at the toe of the weld

8. Tests Conducted: Hydrostatic ☐ Pneumatic ☐ Nominal Operation Pressure ☐
Other ☐ Pressure N/A psi Test Temp. N/A °F

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8 1/2 in. x 11 in., (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.



FORM NIS-2 (Back)

sheet 2 of 2

9. Remarks 1/2" long linear indication discovered during ISI(MT) of Main Steam 'C' line weld MSC-J009. Repaired weld
Applicable Manufacturer's Data Reports to be attached
by grinding out indications. Performed MT using the same ISI No. 89-078 and was found acceptable. Minimum wall
thickness was verified by UT, minimum wall required .902"; as left 1.003".

CERTIFICATE OF COMPLIANCE

We certify that the statements made in the report are correct and this repair conforms
 to the rules of the ASME Code, Section XI. repair or replacement

Type Code Symbol Stamp NoneCertificate of Authorization No. Nons

Expiration Date _____

Signed Sunderhaugan Codes & Materials, TGL Date 8-25-, 19 90
 Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel
 Inspectors and the State or Province of Iowa and employed by Hartford Steam Boiler I&I Co
 of Hartford, Connecticut have inspected the components described in
 this Owner's Report during the period 7-26-92 to 7-3-92
 , and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective
 measures described in the Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied,
 concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the
 Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of
 any kind arising from or connected with this inspection.

Scott Kuster
 Inspectors Signature

Commissions NB 8829(I)(N) 941-1A

National Board, State, Province, and Endorsements

Date 9-3 19 92

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Iowa Electric Light and Power Date August 25, 1990
Name
P.O.Box 351, Cedar Rapids, IA 52406 Sheet 1 of 2
Address

2. Plant Duane Arnold Energy Center Unit 1
Name
3277 DAEC Rd. Palo, IA 52324 PMAR #1045061, P.O. 51555
Address Repair Organization P.O.No., Job No.

3. Work Performed by Iowa Electric Type Code Symbol Stamp None
Name
Authorization No. None
3277 DAEC Road Palo, IA 52324 Expiration Date None
Address

4. Identification of System MAIN STEAM 'D' (CLASS 1)

5. (a) Applicable Const. Code ANSI 831.1 19 67 Edition, NONE Addenda, NONE Code Case
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements 1980 W81
(c) Construction code of Replacement ITEM Section III 19 74 Edition, W76 Addenda 1644-5 Code Case*
*Item replaced built to this construction code

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacture	Manufacturer's Serial No.	National Board No.	Other Identification	Year Built	Repaired Replaced, or Replacement	ASME Code Stamp (Yes or No)
Mechanical Snubber	Pacific-Scientific	SN9549	N/A	EBA-X7D-SS-001	1982	Replaced	No
Mechanical Snubber	Pacific-Scientific	SN9553	N/A	EBA-X7D-SS-001	1982	Replacement	No

7. Description of Work Replace snubber for functional test. Formerly ID no. SSD-1-MS

8. Tests Conducted: Hydrostatic ☐ Pneumatic ☐ Nominal Operation Pressure ☐
Other ☐ Pressure N/A psi Test Temp. N/A °F

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8 1/2 in. x 11 in., (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.



AP
8-30-92

FORM NIS-2 (Back)

sheet 2 of 2

9. Remarks Replacement of snubber (PSA-35) with new one for functional testing purposes. New snubber never beenApplicable Manufacturer's Data Reports to be attachedinstalled before. Vt-3/4 preservice examination performed reference inspection 90-177.

CERTIFICATE OF COMPLIANCE

We certify that the statements made in the report are correct and this replacement conforms to the rules of the ASME Code, Section XI. repair or replacement

Type Code Symbol Stamp NoneCertificate of Authorization No. None Expiration Date

Signed Surinder Shergill Codes & Materials, TGL Date 8 - 25 -, 19 90
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Iowa and employed by Hartford Steam Boiler I&I Co of Hartford, Connecticut have inspected the components described in this Owner's Report during the period 5-31-90 to 8-30-90, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in the Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Scott P. Fisher Commissions NB 8829(I)(N) 941-1A
Inspectors Signature National Board, State, Province, and Endorsements

Date 8-30 19 90

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Iowa Electric Light and Power Date August 25, 1990
Name
- P.O.Box 351, Cedar Rapids, IA 52406 Sheet 1 of 2
Address
2. Plant Duane Arnold Energy Center Unit 1
Name
- 3277 DAEC Rd. Palo, IA 52324 PMAR #1045060, P.O. 51155
Address Repair Organization P.O.No., Job No.
3. Work Performed by Iowa Electric Type Code Symbol Stamp None
Name
- Authorization No. None
- 3277 DAEC Road Palo, IA 52324 Expiration Date None
Address
4. Identification of System HPCI-STEAM SIDE (CLASS 1)
5. (a) Applicable Const. Code ANSI B31.7 19 69 Edition, NONE Addenda, NONE Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 1980 W81
 (c) Construction code of Replacement ITEM Section III 19 74 Edition, W76 Addenda 1644-5 Code Case*
 *Item replaced built to this construction code
6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacture	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired Replaced, or Replacement	ASME Code Stampet (Yes or No)
Mechanical Snubber	Pacific-Scientific	SN1889	N/A	DLA-003-SS-003	1977	Replaced	No
Mechanical Snubber	Pacific-Scientific	SN26375	N/A	DLA-003-SS-003	1983	Replacement	No

7. Description of Work Replace snubber for functional test.
8. Tests Conducted: Hydrostatic ☐ Pneumatic ☐ Nominal Operation Pressure ☐
 Other ☐ Pressure N/A psi Test Temp. N/A °F

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8 1/2 in. x 11 in., (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.



FORM NIS-2 (Back)

sheet 2 of 2

9. Remarks Replacement of snubber (PSA-3) with new one for functional testing purposes. New snubber never been
Applicable Manufacturer's Data Reports to be attached
installed before, Vt-3/4 preservice examination performed reference inspection 90-179.

CERTIFICATE OF COMPLIANCE

We certify that the statements made in the report are correct and this replacement conforms
to the rules of the ASME Code, Section XI. repair or replacement

Type Code Symbol Stamp None

Certificate of Authorization No. None Expiration Date _____

Signed Sunder Shaugan Codes & Materials, TGL Date 8-25-, 19 90
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Iowa and employed by Hartford Steam Boiler I&I Co of Hartford, Connecticut have inspected the components described in this Owner's Report during the period 5-21-90 to 9-2-90, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in the Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Scott Lester Commissions NB 8829(I)(N) 941-1A
Inspectors Signature National Board, State, Province, and Endorsements

Date 9-2 19 90

FORM NIS-2 (Back)

sheet 2 of 2

9. Remarks A 3/8" and a 1/4" long indication was discovered during an ISI (MT) inspection of Main Steam Bypass weld
Applicable Manufacturer's Data Reports to be attached
- MSE-CF009. Repaired weld by grinding out indications. Inspected under same ISI number 89-381. Minimum wall
thickness was verified by UT, minimum wall required .602"; as left .638".

CERTIFICATE OF COMPLIANCE

We certify that the statements made in the report are correct and this repair conforms
 to the rules of the ASME Code, Section XI. repair or replacement

Type Code Symbol Stamp NoneCertificate of Authorization No. None

Expiration Date _____

Signed Sunder Shaugai Codes & Materials, TGL Date 8-28-90, 19 90
 Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Iowa and employed by Hartford Steam Boiler I&I Co of Hartford, Connecticut have inspected the components described in this Owner's Report during the period 7-26-90 to 8-30-90, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in the Owner's Report in accordance with the requirements of the ASME Code, Section XI.


By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Scott Pender Commissions NB 8829(I)(N) 941-1A
 Inspectors Signature National Board, State, Province, and Endorsements

Date 8-30 19 90

[illegible]

1



FORM NIS-2 (Back)

sheet 2 of 2

9. Remarks Two 5/16" long indications was discovered during an ISI(MT) inspection of Main Steam Bypass weld MSE-CF006
Applicable Manufacturer's Data Reports to be attached
- Weld was repaired by grinding out indications. Inspected under same ISI number 90-281. Minimum wall thickness was
verified by UT, minimum wall required .602"; as left .628".

CERTIFICATE OF COMPLIANCE

We certify that the statements made in the report are correct and this repair conforms
 to the rules of the ASME Code, Section XI. repair or replacement

Type Code Symbol Stamp NoneCertificate of Authorization No. None Expiration Date _____

Signed Surinder Shaurani Codes & Materials, TGL Date 8-28-, 19 90
 Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Iowa and employed by Hartford Steam Boiler I&I Co
 of Hartford, Connecticut have inspected the components described in
 this Owner's Report during the period 8-13-92 to 8-22-92
 , and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective
 measures described in the Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Scott Presler Commissions NB 8829(I)(N) 941-1A
 Inspectors Signature National Board, State, Province, and Endorsements

Date 8-29 19 90

FORM NIS-2 (Back)

sheet 2 of 2

9. Remarks A 3" long indications was discovered during an ISI(MT) inspection of the Main Steam Bypass weld MSE-CF-010
Applicable Manufacturer's Data Reports to be attached
- Weld was repaired by grinding out indications. Inspected under same ISI number 90-280. Minimum wall thickness was
verified by UT, minimum wall required .602"; as left .638".

CERTIFICATE OF COMPLIANCE

We certify that the statements made in the report are correct and this repair conforms
 to the rules of the ASME Code, Section XI. repair or replacement

Type Code Symbol Stamp NoneCertificate of Authorization No. None Expiration Date _____

Signed Surindu Shargan Codes & Materials, TGL Date 8-28, 19 90
 Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel
 Inspectors and the State or Province of Iowa and employed by Hartford Steam Boiler I&I Co
 of Hartford, Connecticut have inspected the components described in
 this Owner's Report during the period 8-13-90 to 8-30-90
 , and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective
 measures described in the Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied,
 concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the
 Inspector nor his employer shall be liable in any manner for any personnel injury or property damage or a loss of
 any kind arising from or connected with this inspection.

Scott Presler
 Inspectors Signature

Commissions NB 8829(I)(N) 941-1A
 National Board, State, Province, and Endorsements

Date 8-30 19 90

FORM NIS-2 (Back)

sheet 2 of 2

9. Remarks When MQ-1934 was disassembled for inspection, it was discovered that the valve body, guide ribs, and disc
Applicable Manufacturer's Data Reports to be attached
required repair. The valve body was blended and MT inspected and found accepted. A UT inspection was performed to
verify wall thickness (min.1.01"). A weld buildup was performed on the disc and guide ribs. The weld areas were
machined to the proper dimensions. A final surface exam (MT/PT) was performed and accepted.

CERTIFICATE OF COMPLIANCE

We certify that the statements made in the report are correct and this repair conforms
 to the rules of the ASME Code, Section XI. repair or replacement

Type Code Symbol Stamp None

Certificate of Authorization No. None Expiration Date _____

Signed Sunder Shargan Codes & Materials, TGL Date 9-6-, 19 90
 Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel
 Inspectors and the State or Province of Iowa and employed by Hartford Steam Boiler I&I Co
 of Hartford, Connecticut have inspected the components described in
 this Owner's Report during the period 7-26-90 to 9-11-90
 , and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective
 measures described in the Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied,
 concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the
 Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of
 any kind arising from or connected with this inspection.

Scott Puckner Commissions NB 8829(I)(N) 941-IA
 Inspectors Signature National Board, State, Province, and Endorsements

Date 9-11 19 90

FORM NIS-2 (Back)

sheet 2 of 2

9. Remarks Replacement of snubber pin on Pump side for proper fit. Vt- 3/4 preservice inspection performed reference
Applicable Manufacturer's Data Reports to be attached
ISI inservice inspection report 90-205.

CERTIFICATE OF COMPLIANCE

We certify that the statements made in the report are correct and this replacement conforms to the rules of the ASME Code, Section XI. repair or replacement

Type Code Symbol Stamp NoneCertificate of Authorization No. None Expiration Date _____

Signed Sumner Shaugan Codes & Materials, TGL Date 8 - 28 -, 19 90
 Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Iowa and employed by Hartford Steam Boiler I&I Co of Hartford, Connecticut have inspected the components described in this Owner's Report during the period 8-21-90 to 8-30-90, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in the Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Scott Presler Commissions NB 8829(I)(N) 941-1A
 Inspectors Signature National Board, State, Province, and Endorsements

Date 8-30 19 90

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

- Owner Iowa Electric Light and Power Date August 27, 1990
 Name _____
- P.O.Box 351, Cedar Rapids, IA 52406 Sheet 1 of 2
 Address _____
2. Plant Duano Arnold Energy Center Unit 1
 Name _____
- 3277 DAEC Rd. Palo, IA 52324 PMAR #1046777, P.O. 15066
 Address Repair Organization P.O.No., Job No. _____
3. Work Performed by Iowa Electric Type Code Symbol Stamp None
 Name _____ Authorization No. None
- 3277 DAEC Road Palo, IA 52324 Expiration Date None
 Address _____
4. Identification of System Recirc Pump 'B' (CLASS 1)
5. (a)Applicable Const. Code ANSI B31.7 19 69 Edition, NONE Addenda, NONE Code Case
 (b)Applicable Edition of Section XI Utilized for Repairs or Replacements 1980 W81
 (c)Construction code of Replacement ITEM Section III 19 74 Edition, W76 Addenda 1644-5 Code Case*
 *Item replaced built to this construction code
6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacture	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired Replaced, or Replacement	ASME Code Stamped (Yes or No)
Mechanical Snubber	Pacific-Scientific	SN352	N/A	DCA-004-SSB-004	1977	Replaced	No
Mechanical Snubber	Pacific-Scientific	SN101	N/A	DCA-004-SSB-004	1984	Replacement	No

7. Description of Work Replace snubber for functional test.
8. Tests Conducted: Hydrostatic ☐ Pneumatic ☐ Nominal Operation Pressure ☐
 Other ☐ Pressure N/A psi Test Temp. N/A °F

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8½ in. x 11 in., (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.



AP
 9-4-90

FORM NIS-2 (Back)

sheet 2 of 2

9. Remarks Replacement of snubber (PSA-100) with new one for functional testing purposes. New snubber never been
Applicable Manufacturer's Data Reports to be attached
installed before. Vt-3/4 preservice examination performed reference inspection 90-203.

CERTIFICATE OF COMPLIANCE

We certify that the statements made in the report are correct and this replacement conforms
to the rules of the ASME Code, Section XI. repair or replacement

Type Code Symbol Stamp NoneCertificate of Authorization No. None Expiration Date _____

Signed Sumner Shaugan Codes & Materials, TGL Date 8-30-, 19 90
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel
Inspectors and the State or Province of Iowa and employed by Hartford Steam Boiler I&I Co
of Hartford, Connecticut have inspected the components described in
this Owner's Report during the period 7-28-92 to 7-4-92
, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective
measures described in the Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied,
concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the
Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of
any kind arising from or connected with this inspection.

Scott Keshler Commissions NB 8829(I)(N) 941-IA
Inspectors Signature National Board, State, Province, and Endorsements

Date 8-4 19 92

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Iowa Electric Light and Power Date September 3, 1990
Name
P.O.Box 351, Cedar Rapids, IA 52406 Sheet 1 of 2
Address

2. Plant Duane Arnold Energy Center Unit 1
Name
3277 DAEC Rd. Palo, IA 52324 DCP 1499 up to and including FCN 1 DCN 0
Address Repair Organization P.O.No., Job No.

3. Work Performed by Iowa Electric Type Code Symbol Stamp None
Name
Authorization No. None
3277 DAEC Road Palo, IA 52324 Expiration Date None
Address

4. Identification of System RHR line 10" EBB-16 (class 2)

5. (a) Applicable Const. Code ANSI 831.7 19 69 Edition, 1971 Addenda, NONE Code Case
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements 1980 W81

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacture	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired Replaced, or Replacement	ASME Code Stamped (Yes or No)
10" Pipe(misc.)	Bechtel	EBB-16-1	N/A	10"-EBB-16	1971	Replaced	No
10" valve	Anchor Valve	10"EBB-GT	N/A	MO 2298	1971	Replaced	Yes
Snubber	Bergen-Paterson	DA10	N/A	EBB-16-SS-231	1982	Replaced	No
Hanger	Bergen-Paterson	VSIF	N/A	EBB-16-H-17	1973	Replaced	No
10" Pipe (Cap)	Tioga Pipe Co.	HT 7815A	N/A	10"-EBB-16	1990	Replacement	No
Weld RHD-CF-50R	Iowa Electric	N/A	N/A	FW-1A	1990	Replacement	No

7. Description of Work Removed cross tie line 10"-EBB-16, Capped off line (RHR side)

8. Tests Conducted: Hydrostatic ☒ Pneumatic ☐ Nominal Operation Pressure ☐
Other ☐ Pressure 469 psi Test Temp. min. 60 °F

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8½ in. x 11 in., (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

AF
11-14-90

FORM NIS-2 (Back)

sheet 2 of 2

9. Remarks Replacement crosstie line 10"-EBB-16 with cap on RHR side (see NIS-2 109020 for HPCI side). Performed the
Applicable Manufacturer's Data Reports to be attached
following NDE: preservice UT for weld RND-CF-50R, ISI Report # 90-329, 90-330; preservice MT ISI Report # 90-331;
RT of weld per construction code. VT-2 performed under procedure GMP-Test-001 and report # 90-358.

CERTIFICATE OF COMPLIANCE

We certify that the statements made in the report are correct and this replacement conforms
 to the rules of the ASME Code, Section XI. repair or replacement

Type Code Symbol Stamp NoneCertificate of Authorization No. None Expiration Date _____

Signed [Signature] Codes & Materials, TGL Date 11-13-90
 Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel
 Inspectors and the State or Province of Iowa and employed by Hartford Steam Boiler I&I Co
 of Hartford, Connecticut have inspected the components described in
 this Owner's Report during the period 7-28-90 to 11-14-90
 , and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective
 measures described in the Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied,
 concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the
 Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of
 any kind arising from or connected with this inspection.

[Signature]
 Inspectors Signature

Commissions NB 8829(I)(N) 941-1A
 National Board, State, Province, and Endorsements

Date Nov-14-1990

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Iowa Electric Light and Power Date September 3, 1990
 Name
P.O.Box 351, Cedar Rapids, IA 52406 Sheet 1 of 2
 Address
2. Plant Duane Arnold Energy Center Unit 1
 Name
3277 DAEC Rd. Palo, IA 52324 DCP 1499 up to and including FCN 1 DCN 0
 Address Repair Organization P.O.No., Job No.
3. Work Performed by Iowa Electric Type Code Symbol Stamp None
 Name
 Authorization No. None
3277 DAEC Road Palo, IA 52324 Expiration Date None
 Address
4. Identification of System HPCI line 10" EBB-14 (class 2)
5. (a)Applicable Const. Code ANSI B31.7 19 69 Edition, 1971 Addenda, NONE Code Case
 (b)Applicable Edition of Section XI Utilized for Repairs or Replacements 1980 W81
6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacture	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired Replaced, or Replacement	ASME Code Stamped (Yes or No)
10" Pipe(tee)	Bechtel	EBB-16-1	N/A	10"-EBB-14	1971	Replaced	No
Hanger	Bergen-Patterson	N/A	N/A	EBB-14-SR-17	1973	Replaced	No
10" Pipe(elbow)	Tioga Pipe Co.	HT7814A	N/A	10"-EBB-14	1990	Replacement	No
Weld HPC-CF55R	Iowa Electric	N/A	N/A	FW-3A	1990	Replacement	No
Weld HPC-CF57R	Iowa Electric	N/A	N/A	FW-1A	1990	Replacement	No
Weld HPC-CF56R	Iowa Electric	N/A	N/A	FW-2A	1990	Replacement	No

5/8"x4" bolt Cardinal A2213-A2 N/A EBB-14-H8 1986 Replacement No
 5/8"x3" bolt Cardinal HT D66732 N/A EBB-14-H8 1988 Replacement No

7. Description of Work Removed cross tie line 10"-EBB-16, Replace with Elbow (HPCI side)
8. Tests Conducted: Hydrostatic ☒ Pneumatic ☐ Nominal Operation Pressure ☐
 Other ☐ Pressure 1430 psi Test Temp. 75 °F

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8 1/2 in. x 11 in., (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

FORM NIS-2 (Back)

sheet 2 of 2

9. Remarks Replacement crosstie line 10"-EBB-16 with elbow and pipe on HPCI side (see NIS-2 109019 for RHR side)

Applicable Manufacturer's Data Reports to be attached

following NDE: preservice UT for weld HPC-CF55R, ISI Report #90-335, #90-336; preservice MT ISI Report #90-337.

Preservice UT for weld HPC-CF56R #90-338, #90-339; preservice MT #90-340. Preservice UT for weld HPC-CF57R 90-332,

90-333; Preservice MT #90-334. RT of each weld per construction code. VT-2 performed under procedure STP46G010.**

CERTIFICATE OF COMPLIANCE

We certify that the statements made in the report are correct and this replacement conforms to the rules of the ASME Code, Section XI. repair or replacement

Type Code Symbol Stamp None

Certificate of Authorization No. None Expiration Date

Signed S. Sherry Codes & Materials, TGL Date 11-13-
Owner or Owner's Designee Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Iowa and employed by Hartford Steam Boiler I&I Co of Hartford, Connecticut have inspected the components described in this Owner's Report during the period 7-28-90 to 11-14-90, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in the Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Keith Cooper Commissions NB 8829(I)(N) 941-1A
Inspectors Signature National Board, State, Province, and Endorsements

Date Nov 14 1990

**Preservice VT-3/4 on EBD-14-W8 was performed under ISI No. 90-012.

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

- Owner Iowa Electric Light and Power Date August 27, 1990
 Name
- P.O.Box 351, Cedar Rapids, IA 52406 Sheet 1 of 2
 Address
2. Plant Duane Arnold Energy Center Unit 1
 Name
- 3277 DAEC Rd. Palo, IA 52324 PMAR #1046774, P.O. S34267
 Address Repair Organization P.O.No., Job No.
3. Work Performed by Iowa Electric Type Code Symbol Stamp None
 Name
- 3277 DAEC Road Palo, IA 52324 Authorization No. None
 Address Expiration Date None
4. Identification of System Recirc Pump 'A' (CLASS 1)
5. (a) Applicable Const. Code ANSI B31.7 19 69 Edition, 1971 Addenda, NONE Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 1980 W81
6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacture	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired Replaced, or Replacement	ASME Code Stamped (Yes or No)
Snubber Pin	Iowa Electric	**	N/A	DCA-004-SSA-001	1987	Replaced	No
Snubber Pin	Bergen-Paterson	P1165721	N/A	DCA-004-SSA-001	1987	Replacement	No

** Fabricated from 1 1/2" SA-564-T-640 round bar stock

7. Description of Work Replace snubber pin for proper fit.

8. Tests Conducted: Hydrostatic ☐ Pneumatic ☐ Nominal Operation Pressure ☐

Other ☐
 Pressure N/A psi ☐
 Test Temp. N/A °F ☐

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8 1/2 in. x 11 in., (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.



FORM NIS-2 (Back)

sheet 2 of 2

9. Remarks Replacement of snubber pin on Pump side for proper fit. Vt- 3/4 preservice inspection performed reference
Applicable Manufacturer's Data Reports to be attached
ISI inservice inspection report 90-206.

CERTIFICATE OF COMPLIANCE

We certify that the statements made in the report are correct and this replacement conforms to the rules of the ASME Code, Section XI. repair or replacement

Type Code Symbol Stamp NoneCertificate of Authorization No. None

Expiration Date _____

Signed Suminder Shargain
 Owner or Owner's Designee, Title

Codes & Materials, TGL Date 8-28-, 19 90

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Iowa and employed by Hartford Steam Boiler I&I Co of Hartford, Connecticut have inspected the components described in this Owner's Report during the period 8-21-90 to 8-29-90, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in the Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Scott Pender
 Inspectors Signature

Commissions NB 8829(I)(N) 941-1A
 National Board, State, Province, and Endorsements

Date 8-29 19 90

FORM NIS-2 (Back)

sheet 2 of 2

9. Remarks After disassembly of MO-1905 it was necessary to replace the stem. The disc tee slot and guide saddle
Applicable Manufacturer's Data Reports to be attached
required machining to correct misalignment. In addition, because of stem hole bushing wear a replacement was
required which was seal welded to bonnet.

CERTIFICATE OF COMPLIANCE

We certify that the statements made in the report are correct and this repair conforms
 to the rules of the ASME Code, Section XI. repair or replacement

Type Code Symbol Stamp NoneCertificate of Authorization No. None Expiration Date _____

Signed Sumner Shaugan Codes & Materials, TGL Date 10-1-, 19 90
 Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel
 Inspectors and the State or Province of Iowa and employed by Hartford Steam Boiler I&I Co
 of Hartford, Connecticut have inspected the components described in
 this Owner's Report during the period 7-11-92 to 10-24-92
 , and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective
 measures described in the Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied,
 concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the
 Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of
 any kind arising from or connected with this inspection.

Scott Kessler Commissions NB 8829(I)(N) 941-1A
 Inspectors Signature National Board, State, Province, and Endorsements

Date Oct 29 19 92

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

- Owner Iowa Electric Light and Power Date August 30, 1990
 Name _____
- P.O.Box 351, Cedar Rapids, IA 52406 Sheet 1 of 2
 Address _____
2. Plant Duane Arnold Energy Center Unit 1
 Name _____
- 3277 DAEC Rd. Palo, IA 52324 PMAR #1045051, P.O. 5082
 Address _____ Repair Organization P.O.No., Job No. _____
3. Work Performed by Iowa Electric Type Code Symbol Stamp None
 Name _____ Authorization No. None
- 3277 DAEC Road Palo, IA 52324 Expiration Date None
 Address _____
4. Identification of System RCIC STEAM SUPPLY (Class 1)
5. (a) Applicable Const. Code ANSI B31.7 19 69 Edition, NONE Addenda, NONE Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 1980 W81
 (c) Construction code of Replacement ITEM Section III 19 74 Edition, W76 Addenda 1644-5 Code Case*
 *Item replaced built to this construction code
6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacture	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired Replaced, or Replacement	ASME Code Stamped (Yes or No)
Mechanical Snubber	Pacific-Scientific	SN604	H/A	DBA-004-SS-036	1977	Replaced	No
Mechanical Snubber	Pacific-Scientific	SN1904	H/A	DBA-004-SS-036	1977	Replacement	No

7. Description of Work Replace snubber for functional test.
8. Tests Conducted: Hydrostatic ☐ Pneumatic ☐ Nominal Operation Pressure ☐
 Other ☐ Pressure N/A psi Test Temp. N/A °F

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8 1/2 in. x 11 in., (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.



FORM NIS-2 (Back)

sheet 2 of 2

9. Remarks Replacement of snubber (PSA-3) with new one for functional testing purposes. New snubber never been
Applicable Manufacturer's Data Reports to be attached
installed before. Vt-3/4 preservice examination performed reference inspection 90-176.

CERTIFICATE OF COMPLIANCE

We certify that the statements made in the report are correct and this replacement conforms
 to the rules of the ASME Code, Section XI. repair or replacement

Type Code Symbol Stamp NoneCertificate of Authorization No. None Expiration Date _____

Signed Surinder Shangan Codes & Materials, TGL Date 8-30-, 19 90
 Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel
 Inspectors and the State or Province of Iowa and employed by Hartford Steam Boiler I&I Co
of Hartford, Connecticut have inspected the components described in
 this Owner's Report during the period 5-31-90 to 9-4-90
 , and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective
 measures described in the Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied,
 concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the
 Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of
 any kind arising from or connected with this inspection.

Scott Prudner Commission NB 8829(I)(N) 941-1A
 Inspectors Signature National Board, State, Province, and Endorsements

Date 9-4 19 90

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Iowa Electric Light and Power Date August 29, 1990
 Name
P.O.Box 351, Cedar Rapids, IA 52406 Sheet 1 of 2
 Address
2. Plant Duane Arnold Energy Center Unit 1
 Name
3277 DAEC Rd. Palo, IA 52324 CMAR #A01862 CSR A
 Address Repair Organization P.O.No., Job No.
3. Work Performed by Iowa Electric Type Code Symbol Stamp None
 Name
 Authorization No. None
3277 DAEC Road Palo, IA 52324 Expiration Date None
 Address
4. Identification of System RHR line 24"-HLE-7 (Class 2)
5. (a)Applicable Const. Code ASME PUMP & VALVE CODE 19 68 Edition, Addenda, N/A Code
 Case EXTENSION OF CONTAINMENT ASME CODE CASE 1427
 (b)Applicable Edition of Section XI Utilized for Repairs or Replacements 1980 W81 class 2
6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacture	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired Replaced, or Replacement	ASME Code Stamped (Yes or No)
MO-1989	ANCHOR Valve	UNKNOWN	N/A	24"-HLE-GT	1971	REPAIRED	YES
3-STUDS	Daniel Bolt	HTCODE 213	N/A	MO 1989	1979	Replacement	NO

7. Description of Work Welding of guide ribs Also replaced 3 studs.
8. Tests Conducted: Hydrostatic ☐ Pneumatic ☐ Nominal Operation Pressure ☐
 Other ☐ Pressure N/A psi Test Temp. N/A °F

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8 1/2 in. x 11 in., (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.



FORM NIS-2 (Back)

sheet 2 of 2

9. Remarks When MQ-1989 was disassembled for inspection, it was discovered that the guide ribs required repairs.
Applicable Manufacturer's Data Reports to be attached

A weld buildup for proper alignment was performed on the guide ribs. The weld areas were machined to proper dimensions. Replacement of studs were of A193 grade B7 material (P.O. F16625)

CERTIFICATE OF COMPLIANCE

We certify that the statements made in the report are correct and this repair conforms to the rules of the ASME Code, Section XI. repair or replacement

Type Code Symbol Stamp None

Certificate of Authorization No. None Expiration Date

Signed Suresh Shaujan Codes & Materials, TGL Date 8-31-, 19 90
 Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Iowa and employed by Hartford Steam Boiler I&I Co of Hartford, Connecticut have inspected the components described in this Owner's Report during the period 7-30-90 to 7-7-90, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in the Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Scott A. Bunker
 Inspector's Signature

Commissions NB 8829(I)(N) 941-1A

National Board, State, Province, and Endorsements

Date 9-2 19 90

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Iowa Electric Light and Power Date August 30, 1990
Name
- P.O.Box 351, Cedar Rapids, IA 52406 Sheet 1 of 2
Address
2. Plant Duane Arnold Energy Center Unit 1
Name
- 3277 DAEC Rd. Palo, IA 52324 DCP 1461
Address Repair Organization P.O.No., Job No.
3. Work Performed by Iowa Electric Type Code Symbol Stamp None
Name
- 3277 DAEC Road Palo, IA 52324 Authorization No. None
Address Expiration Date None
4. Identification of System HPCI line 1" EBB-14 (class 2)
5. (a) Applicable Const. Code ANSI B31.7 19 69 Edition, Addenda, Code Case
- (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 1980 W81 CLASS 2
6. Identification of Components Ropeired or Replaced and Replacement Components

Name of Component	Name of Manufacture	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Ropeired Replaced, or Replacement	ASME Code Stamped (Yes or No)
1" 6000# Sockolet	Unknown	N/A	N/A	1"-EBB-14	1971	Replaced	No
10" x 1 1/2" 6000# Sockolet	Energy Steel	HT# Z-295	N/A		1990	Replacement	No
1" sch 160 Pipe	Unknown	N/A	N/A	1"-EBB-14	1971	(Removed) Replaced	No
1 1/2" sch 160 Pipe	Chicago Tube & Iron	HT# 282792	N/A		1987	Replacement	No
1 1/2" 600# Flange	Hub Inc.	HT# 194SNF	N/A		1990	Replacement	No
1 1/2" 600# Flange	Hub Inc.	HT# 323RNF	N/A		1990	Replacement	No

7. Description of Work Modification of Line 1"-EBB-14 to LE 2206
8. Tests Conducted: Hydrostatic ☒ Pneumatic ☐ Nominal Operation Pressure ☐
- Other ☐ Pressure 1430 psi Test Temp. 75 °F

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8 1/2 in. x 11 in., (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.



FORM NIS-2 (Back)

sheet 2 of 2

9. Remarks DCP 1461 was completed which modified the HPCI Steam Trap Drain Lines. This included the replacement of theApplicable Manufacturer's Data Reports to be attached1" sockolet and 1" piping with a 10"x1 1/2" sockolet, 1 1/2" piping and 1 1/2" 600 # flanges. All welds were liquid penetrant inspected and accepted. A hydro was also performed and accepted. An NCR 90-056 was written on the fit-upfor weld 10 and dispositioned "use as is". Note: this modification also changed the ISI Section XI boundaries.

CERTIFICATE OF COMPLIANCE

We certify that the statements made in the report are correct and this replacement conforms to the rules of the ASME Code, Section XI. repair or replacementType Code Symbol Stamp NoneCertificate of Authorization No. None

Expiration Date _____

Signed Sunder Shargai Codes & Materials, TGL Date 8-31-, 19 90
Owner or Owner's Designee, Title G

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Iowa and employed by Hartford Steam Boiler I&I Co of Hartford, Connecticut have inspected the components described in this Owner's Report during the period 6-28-90 to 7-1-90, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in the Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Scott Presler Commissions NB 8829(I)(N) 941-IA
Inspectors Signature National Board, State, Province, and EndorsementsDate 9-7 19 90

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

- Owner Iowa Electric Light and Power Date August 30, 1990
 Name
- P.O.Box 351, Cedar Rapids, IA 52406 Sheet 1 of 2
 Address
2. Plant Duane Arnold Energy Center Unit 1
 Name
- 3277 DAEC Rd. Palo, IA 52324 PMAR #1045050, P.O. 51155
 Address Repair Organization P.O.No., Job No.
3. Work Performed by Iowa Electric Type Code Symbol Stamp None
 Name
- Authorization No. None
- 3277 DAEC Road Palo, IA 52324 Expiration Date None
 Address
4. Identification of System MSIV Leakage Control System (Class 1)
5. (a) Applicable Const. Code ANSI B31.7 19 67 Edition, Addenda, N/A Code Case
- (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 1980 W81
- (c) Construction Code of Replacement item Section III 1974 Edition, W76 Addenda with Code Case 1644-5*
 *item replaced same code of construction
6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacture	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired Replaced, or Replacement	ASME Code Stamped (Yes or No)
Mechanical Snubber	Pacific-Scientific	SN21141	N/A	DBA-004-SS-001	1983	Replaced	No
Mechanical Snubber	Pacific-Scientific	SN21145	N/A	DBA-004-SS-001	1982	Replacement	No

7. Description of Work Replaced snubber for functional testing
8. Tests Conducted: Hydrostatic ☐ Pneumatic ☐ Nominal Operation Pressure ☐
- Other ☐ Pressure N/A psi Test Temp. N/A °F

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8 1/2 in. x 11 in., (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.



FORM NIS-2 (Back)

sheet 2 of 2

9. Remarks Replacement of snubber (PSA-1) with new one for functional testing purposes. New snubber never been
Applicable Manufacturer's Data Reports to be attached
installed before. VT 3/4 preservice examination performed, reference inspection 90-175.

CERTIFICATE OF COMPLIANCE

We certify that the statements made in the report are correct and this replacement conforms
to the rules of the ASME Code, Section XI. repair or replacement

Type Code Symbol Stamp NoneCertificate of Authorization No. None Expiration Date _____

Signed Suminder Shargan Codes & Materials, TGL Date 9-1-, 19 90
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel
Inspectors and the State or Province of Iowa and employed by Hartford Steam Boiler I&I Co
of Hartford, Connecticut have inspected the components described in
this Owner's Report during the period 5-11-90 to 7-4-90
, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective
measures described in the Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied,
concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the
Inspector nor his employer shall be liable in any manner for any personnel injury or property damage or a loss of
any kind arising from or connected with this inspection.

Scott Presler Commissions NB 8829(I)(N) 941-1A
Inspectors Signature National Board, State, Province, and Endorsements

Date 9-4 19 90

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

- Owner Iowa Electric Light and Power Date August 31, 1990
 Name
- P.O.Box 351, Cedar Rapids, IA 52406 Sheet 1 of 2
 Address
2. Plant Duane Arnold Energy Center Unit 1
 Name
- 3277 DAEC Rd. Palo, IA 52324 PMAR #1045052, P.O. 29612
 Address Repair Organization P.O.No., Job No.
3. Work Performed by Iowa Electric Type Code Symbol Stamp None
 Name Authorization No. None
- 3277 DAEC Road Palo, IA 52324 Expiration Date None
 Address
4. Identification of System Reactor Vessel Head Vent (class 1)
5. (a)Applicable Const. Code ANSI B31.7 19 67 Edition, None Addenda, N/A Code Case
 (b)Applicable Edition of Section XI Utilized for Repairs or Replacements 1980 W81
 (c)Construction Code of Replacement item Section III 1974 Edition, W76 Addenda with Code Case 1644-5*
 *item replaced same code of construction
6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacture	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired Replaced, or Replacement	ASME Code Stamped (Yes or No)
Mechanical Snubber	Pacific-Scientific	SN 1311	N/A	DBA-009-SS-002B	1977	Replaced	No
Mechanical Snubber	Pacific-Scientific	SN 2237	N/A	DBA-009-SS-002B	1986	Replacement	No

7. Description of Work Replaced snubber for functional testing
8. Tests Conducted: Hydrostatic ☐ Pneumatic ☐ Nominal Operation Pressure ☐
 Other ☐ Pressure N/A psi Test Temp. N/A °F

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8½ in. x 11 in., (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.



FORM NIS-2 (Back)

sheet 2 of 2

9. Remarks Replacement of snubber (PSA-1) with new one for functional testing purposes. New snubber never been
Applicable Manufacturer's Data Reports to be attached
installed before. VT 3/4 preservice examination performed, reference inspection 90-166.

CERTIFICATE OF COMPLIANCE

We certify that the statements made in the report are correct and this replacement conforms to the rules of the ASME Code, Section XI. repair or replacement

Type Code Symbol Stamp NonsCertificate of Authorization No. None Expiration Date _____

Signed Sunder Shaugan Codes & Materials, TGL Date 8-31-, 19 90
 Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Iowa and employed by Hartford Steam Boiler I&I Co of Hartford, Connecticut have inspected the components described in this Owner's Report during the period 5-31-90 to 9-4-90, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in the Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Scott Foster Commissions NB 8829(I)(N) 941-1A
 Inspectors Signature National Board, State, Province, and Endorsements

Date 9-4 19 90

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

Owner Iowa Electric Light and Power Date September 18, 1990
 Name

P.O.Box 351, Cedar Rapids, IA 52406 Sheet 1 of 2
 Address

2. Plant Duane Arnold Energy Center Unit 1
 Name

3277 DAEC Rd. Palo, IA 52324 CMAR #A 02662, P.O. 45327
 Address Repair Organization P.O.No., Job No.

3. Work Performed by Iowa Electric Type Code Symbol Stamp None
 Name Authorization No. None

3277 DAEC Road Palo, IA 52324 Expiration Date None
 Address

4. Identification of System RHR Fuel Pool Cooling (Class 2)

5. (a) Applicable Const. Code ANSI B31.7 19 67 Edition, Addenda, N/A Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 1980 W81
 (c) Construction Code of Replacement item Section III 1986 Edition, 86 Addenda with Code Case

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacture	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired Replaced, or Replacement	ASME Code Stamped (Yes or No)
Base plate of Variable Support	Bethlehem Steel	HT411P3471	N/A	H88-25-H163	1988	Replacement	No

7. Description of Work Replaced base and shim plate for variable support

8. Tests Conducted: Hydrostatic ☐ Pneumatic ☐ Nominal Operation Pressure ☐
 Other ☐ Pressure N/A psi Test Temp. N/A °F

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8 1/2 in. x 11 in., (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.



FORM NIS-2 (Back)

sheet 2 of 2

9. Remarks Hanger base plate was found with slippage from concrete. Replaced old base plate with a new base plate & Applicable Manufacturer's Data Reports to be attached
a new shim plate. VT 3/4 preservice examination performed, reference inspection 90-212. Clearance from hanger and line 4"-G88-17 is at least 5/8".

CERTIFICATE OF COMPLIANCE

We certify that the statements made in the report are correct and this replacement conforms to the rules of the ASME Code, Section XI. repair or replacement.

Type Code Symbol Stamp NoneCertificate of Authorization No. None Expiration Date _____

Signed Steven J. L... Codes & Materials, TGL Date 11-1-90, 19 90
 Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Iowa and employed by Hartford Steam Boiler I&I Co of Hartford, Connecticut have inspected the components described in this Owner's Report during the period 5-12-90 to 9-21-90, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in the Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Scott Parker Commissions NB 8829(I)(N) 941-IA
 Inspectors Signature National Board, State, Province, and Endorsements

Date Sept 21 19 90


FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

- Owner Iowa Electric Light and Power Date September 13, 1990
 Name _____
- P.O.Box 351, Cedar Rapids, IA 52406 Sheet 1 of 2
 Address _____
2. Plant Duane Arnold Energy Center Unit 1
 Name _____
- 3277 DAEC Rd. Palo, IA 52324 CMAR #91614, P.O. S49899
 Address _____ Repair Organization P.O.No., Job No. _____
3. Work Performed by Iowa Electric Type Code Symbol Stamp None
 Name _____ Authorization No. None
- 3277 DAEC Road Palo, IA 52324 Expiration Date None
 Address _____
4. Identification of System Main Steam Line 3"-EBD-5 (class 2)
5. (a) Applicable Const. Code ANSI B 31.1 19 67 Edition, N/A Addenda, N/A Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 1980 W81 class 2
6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacture	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired Replaced, or Replacement	ASME Code Stamped (Yes or No)
Valve Bonnet	ANCHOR Darling	C31745	N/A	V03-0005	1990	Replacement	No
Valve Disk	ANCHOR Darling	S/N U5212	N/A	V03-0005	1990	Replacement	NO

7. Description of Work Replaced valve bonnet and valve disk.
8. Tests Conducted: Hydrostatic ☐ Pneumatic ☐ Nominal Operation Pressure ☒
 Other ☐ Pressure 960 psi Test Temp. 517 °F

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8½ in. x 11 in., (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.



FORM NIS-2 (Back)

sheet 2 of 2

9. Remarks When V03-0005 was disassembled for inspection, it was discovered that the stem, disc, bonnet needed to be
Applicable Manufacturer's Data Reports to be attached
replaced and that seat machining was required. Replacements were performed and the disc was machined to a proper
fit. VT-2 inservice test was performed under ISI No. 90-361.

CERTIFICATE OF COMPLIANCE

We certify that the statements made in the report are correct and this replacement conforms
to the rules of the ASME Code, Section XI. repair or replacement

Type Code Symbol Stamp NonsCertificate of Authorization No. Nons Expiration Date _____

Signed *Sturges* Codes & Materials, TGL Date 9-3-, 19 90
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel
Inspectors and the State or Province of Iowa and employed by Hartford Steam Boiler I&I Co
of Hartford, Connecticut have inspected the components described in
this Owner's Report during the period 4-6-90 to 7-21-90
, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective
measures described in the Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied,
concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the
Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of
any kind arising from or connected with this inspection.

Keith Presler
Inspectors Signature

Commissions NB 8829(I)(N) 941-1A
National Board, State, Province, and Endorsements

Date Sept 21 19 90

FORM NIS-2 (Back)

sheet 2 of 2

9. Remarks When V03-0004 was disassembled for inspection, it was discovered that the stem, disc, bonnet needed to be
Applicable Manufacturer's Data Reports to be attached
replaced and that seat machining was required. Replacements were performed and the disc was machined to a proper
fit. VT-2 was performed under ISI No. 90-361.

CERTIFICATE OF COMPLIANCE

We certify that the statements made in the report are correct and this replacement conforms
 to the rules of the ASME Code, Section XI. repair or replacement

Type Code Symbol Stamp NoneCertificate of Authorization No. None Expiration Date _____

Signed Sumner Shauger Codes & Materials, TGL Date 9-18-90, 19 90
 Owner or Owner's Designee, Title U

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel
 Inspectors and the State or Province of Iowa and employed by Hartford Steam Boiler I&I Co
 of Hartford, Connecticut have inspected the components described in
 this Owner's Report during the period 4-6-90 to 5-21-90
 , and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective
 measures described in the Owner's Report in accordance with the requirements of the ASME Code, Section XI.


By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied,
 concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the
 Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of
 any kind arising from or connected with this inspection.

Scott Kunkin Commission NB 8829(I)(N) 941-1A
 Inspectors Signature National Board, State, Province, and Endorsements

Date Sept 21 1990

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Iowa Electric Light and Power Date August 31, 1990
Name
P.O.Box 351, Cedar Rapids, IA 52406 Sheet 1 of 2
Address
2. Plant Duane Arnold Energy Center Unit 1
Name
3277 DAEC Rd. Palo, IA 52324 CMAR #98669 (EMA)
Address Repair Organization P.O.No., Job No.
3. Work Performed by Iowa Electric Type Code Symbol Stamp None
Name
Authorization No. None
3277 DAEC Road Palo, IA 52324 Expiration Date None
Address
4. Identification of System RHR Line 2"-GBB-3 (class 2)
5. (a) Applicable Const. Code ASME Section III 19 71 Edition, W72 Addenda, N/A Code Case
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements 1980 W81 class 2
6. Identification of Components Repaired or Replaced and Replacement Components

 Name of Component	Name of Manufacture	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired Replaced, or Replacement	ASME Code Stamped (Yes or No)
Valve V-19-46	Velan Valve Co.	38.1	N/A	2" EBB-GT	1974	Replacement	YES
Weld 4C1	Iowa Electric	N/A	N/A	2" GBB-3	1990	Replacement	NO
Weld 5C1 *	Iowa Electric	N/A	N/A	2" GBB-3	1990	Replacement	NO

7. Description of Work Replaced valve V-19-46. *Nonclass weld attached to class 2 valve (FYI)
8. Tests Conducted: Hydrostatic ☒ Pneumatic ☐ Nominal Operation Pressure ☐
Other ☐ Pressure 533 psi Test Temp. 82 °F

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8½ in. x 11 in., (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.



FORM NIS-2 (Back)

sheet 2 of 2

9. Remarks Replaced valve due to extrema internal galling. Performed PT on welds 4C1 and 6C1. VT-2 with hydrostatic
Applicable Manufacturer's Data Reports to be attached
test under ISI report # 90-301.

CERTIFICATE OF COMPLIANCE

We certify that the statements made in the report are correct and this replacement conforms
to the rules of the ASME Code, Section XI. repair or replacement

Type Code Symbol Stamp NoneCertificate of Authorization No. None Expiration Date _____

Signed Surinder Shaugan Codes & Materials, TGL Date 9-1- 19 90
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel
Inspectors and the State or Province of Iowa and employed by Hartford Steam Boiler I&I Co
of Hartford, Connecticut have inspected the components described in
this Owner's Report during the period 8-2-90 to 9-5-90
, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective
measures described in the Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied,
concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the
Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of
any kind arising from or connected with this inspection.

Scott Kishner Commissions NB 8829(I)(N) 941-IA
Inspectors Signature National Board, State, Province, and Endorsements

Date 9-5 19 90

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Iowa Electric Light and Power Date September 12, 1990
Name
P.O.Box 351, Cedar Rapids, IA 52406 Sheet 1 of 2
Address
2. Plant Duane Arnold Energy Center Unit 1
Name
3277 DAEC Rd. Palo, IA 52324 DCP 1464, CMAR #A 03257
Address Repair Organization P.O.No., Job No.
3. Work Performed by Iowa Electric Type Code Symbol Stamp None
Name
3277 DAEC Road Palo, IA 52324 Authorization No. None
Address Expiration Date None
4. Identification of System Reactor Water Cleanup line (4" DCA- 6 & 4" DCA-14) (Class 1)
5. (a) Applicable Const. Code ANSI B31.7 19 69 Edition, 1971 Addenda, N/A Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 1980 W81
6. Identification of Components Repaired or Replaced and Replacement Components

<small>Name of Component</small>	<small>Name of Manufacturer</small>	<small>Manufacturer Serial No.</small>	<small>National Board No.</small>	<small>Other Identification</small>	<small>Year Built</small>	<small>Repaired Replaced, or Replacement</small>	<small>ASME Code Stamped (Yes or No)</small>
Weld CUA-A-01	Iowa Electric	N/A	N/A	FW-1	1990	Replacement	No
Weld CUB-A-01	Iowa Electric	N/A	N/A	FW-14	1990	Replacement	No
Variable Support	Bergen-Patterson	(pert no.) VS18-6	N/A	DCA-14-H-A2	1971	Replaced	No
Sway Strut	NPS Industries	SR5-06-RO	N/A	DCA-14-SR-A2	1990	Replacement	No
Variable Support	Bergan-Paterson	(pert no.) VS18-6	N/A	DCA-14-H33	1990	Modified	No

7. Description of Work Replaced Non-class RWCU line and modified two class 1 supports
8. Tests Conducted: Hydrostatic ☒ Pneumatic ☐ Nominal Operation Pressure ☐
 Other ☐ Pressure 1175 psi Test Temp. >100 °F

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8½ in. x 11 in., (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.



FORM NIS-2 (Back)

sheet 2 of 2

9. Remarks Replacement of non-class RWCU line added two welds ajoining class 1 valves MO 2701 & MO 2740. Also two
Applicable Manufacturer's Data Reports to be attachad
hangers were modified for better supporting purposes. Welds were RT, PT and UT(90-66 & 90-81) preserviced examined.
Hanger DCA-14-SR-A2 was VT-3/4 preservice examined (90-351) as was DCA-14-H33 (90-352). VT-2 was performed under
ISI # 90-365.

CERTIFICATE OF COMPLIANCE

We certify that the statements made in the report are correct and this repair conforms
 to the rules of the ASME Code, Section XI. repair or replacement

Type Code Symbol Stamp NoneCertificate of Authorization No. None Expiration Date _____

Signed Sumner Shaujan Codes & Materials, TGL Date 9-14-, 19 90
 Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel
 Inspectors and the State or Province of Iowa and employed by Hartford Steam Boiler I&I Co
 of Hartford, Connecticut have inspected the components described in
 this Owner's Report during the period 7-3-90 to 9-18-90
 , and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective
 measures described in the Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate noither the Inspector nor his employer makes any warranty, expressad or implied,
 concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the
 Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of
 any kind arising from or connected with this inspection.

Scott Bursler Commissions NB 8829(I)(N) 941-IA
 Inspectors Signature National Board, State, Province, and Endorsements

Date 9-18 19 90

FORM NIS-2 (Back)

sheet 2 of 2

9. Remarks Replaced disk and remachined bonnet for proper fit. A Vt-3 inspection was performed under ISI report no. 89-20. A VT-2 inspection was performed under 89-13.

CERTIFICATE OF COMPLIANCE

We certify that the statements made in the report are correct and this repair conforms to the rules of the ASME Code, Section XI. repair or replacement

Type Code Symbol Stamp None

Certificate of Authorization No. None Expiration Date

Signed Sumedee Shanyan Codes & Materials, TGL Date 10-25-, 1990
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Iowa and employed by Hartford Steam Boiler I&I Co of Hartford, Connecticut have inspected the components described in this Owner's Report during the period 6-26-90 to 12-29-90, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in the Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Scott L. Miller Commissions NB 8829(I)(N) 941-1A
Inspectors Signature National Board, State, Province, and Endorsements

Date Oct 29 1990

**FORM N-2 CERTIFICATE HOLDERS' DATA REPORT FOR IDENTICAL
NUCLEAR PARTS AND APPURTENANCES***

**As Required by the Provisions of the ASME Code, Section III
Not to Exceed One Day's Production**

Pg. 1 of 2

Manufactured and certified by Anchor/Darling Valve Co., 701 First St., Williamsport, PA 17701
(name and address of NPT Certificate Holder)

Manufactured for Iowa Electric Light & Power Co., P.O. Box 351, Cedar Rapids, Iowa 52406
(name and address of Purchaser)

Location of installation Duane Arnold Energy Center, 3277 Daec Road, Palo, Iowa 52324
(name and address)

Type: D8032 SA216-WCB 70,000 N/A 1990
(drawing no.) (mat'l. spec. no.) (tensile strength) (CRN) (year built)

ASME Code, Section III, Division 1: 1986 1988 1 N/A
(edition) (addenda date) (class) (Code Case no.)

Fabricated in accordance with Const. Spec. (Div. 2 only) N/A Revision N/A Date N/A
(no.)

Remarks: 12"-900#-Gate

A/DV Shop Order P-F650-1

Note: No Disc Hydro Performed

Nom. thickness (in.) 3-3/4 Min. design thickness (in.) 1.25 Dia. ID (ft & in.) N/A Length overall (ft & in.) N/A

When applicable, Certificate Holders' Data Reports are attached for each item of this report:

Part or Appurtenance Serial Number	National Board No. in Numerical Order	Part or Appurtenance Serial Number	National Board No. in Numerical Order
U5107	N/A	(26)	
(2)		(27)	
(3)		(28)	
(4)		(29)	
(5)		(30)	
(6)		(31)	
(7)		(32)	
(8)		(33)	
(9)		(34)	
(10)		(35)	
(11)		(36)	
(12)		(37)	
(13)		(38)	
(14)		(39)	
(15)		(40)	
(16)		(41)	
(17)		(42)	
(18)		(43)	
(19)		(44)	
(20)		(45)	
(21)		(46)	
(22)		(47)	
(23)		(48)	
(24)		(49)	
(25)		(50)	

Design pressure 2220 psi. Temp. 100 °F. Hydro. test pressure N/A at temp. °F
(when applicable)

Supplemental information in the form of lists, sketches, or drawings may be used provided (1) size is 8 1/2 x 11, (2) information in items 2 and 3 on this Data Report included on each sheet, (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

2/88)

This form (E00040) may be obtained from the Order Dept., ASME, 22 Law Drive, Box 2300, Fairfield, NJ 07007-2300.

Certificate Holder's Serial Nos. U5107 through ---

CERTIFICATION OF DESIGN

Design specifications certified by N/A P.E. State --- Reg. no. ---
(when applicable)Design report* certified by N/A P.E. State --- Reg. no. ---
(when applicable)

CERTIFICATE OF COMPLIANCE

I certify that the statements made in this report are correct and that this (these) Disc
conforms to the rules of construction of the ASME Code, Section III, Division 1.Certificate of Authorization No. N1713 Expires 4/15/92
2/23/90 Name Anchor/Darling Valve Company Signed R L Stannett
(NPT Certificate Holder) (authorized representative)

CERTIFICATE OF INSPECTION

I, undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State of ~~Pennsylvania~~ Pennsylvania and employed by Commercial Union Insurance Company
Boston, Mass. have inspected these items described in this Data Report on 10-23-89 thru 2-23-90 and state that to thebest of my knowledge and belief, the Certificate Holder has fabricated these parts or appurtenances in accordance with the ASME Code, Section
Division 1. Each part listed has been authorized for stamping on the date shown above.By signing this certificate, neither the inspector nor his employer makes any warranty, expressed or implied, concerning the equipment described
in this Data Report. Furthermore, neither the inspector nor his employer shall be liable in any manner for any personal injury or property damage
of any kind arising from or connected with this inspection.2-23-90 Signed Charles Young Commissions Pennsylvania 2392
(Authorized Inspector) (Nat'l. Bd. (incl. endorsements) and state or prov. and no.)
Charles Young

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Iowa Electric Light and Power Date September 13, 1990
 Name
P.O.Box 351, Cedar Rapids, IA 52406 Sheet 1 of 3
 Address
2. Plant Duane Arnold Energy Center Unit 1
 Name
3277 DAEC Rd. Palo, IA 52324 see CRD table op cyc 10/11
 Address Repair Organization P.O.No., Job No.
3. Work Performed by Iowa Electric Type Code Symbol Stamp None
 Name
 Authorization No. None
3277 DAEC Rd. Palo, IA 52324 Expiration Date None
 Address

4. Identification of System Control Rod Drives (Class 1)
5. (a) Applicable Const. Code ASME Section III 1974 Edition, w75 Addenda, 1361-2 Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 1980 W81
 (c) Original Construction Code ASME III 1968 Edition W68 Addenda per GE Construction Quality Requirements 22A2534

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacture	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired Replaced, or Replacement	ASME Code Stamped (Yes or No)
CRD Housing	General Electric	see CRD Table op cyc 10/11	NA	see CRD Table op cyc 10/11	1990	Replacement	Yes
CRD Bolting(8 each)	Rockford	Ht No. 72M100	NA	see * on page 3	1972	Replacement	No

7. Description of Work Replacement of CRD Housing
8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure ☒
 Other Pressure 1026 psi Test Temp. 206 °F

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8 1/2 in. x 11 in., (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.



AP
10-1-90

FORM NIS-2 (Back)

sheet 2 of 3

9. Remarks Replacement of CRD Housing. VT-2 of the pressure retaining components were performed under ISI report
Applicable Manufacturer's Data Reports to be attached
- # 89-13. VT-1 NDE is listed in table CRD op cyc 10/11.

CERTIFICATE OF COMPLIANCE

We certify that the statements made in the report are correct and this replacement conforms to the rules of the ASME Code, Section XI. repair or replacement

Type Code Symbol Stamp NoneCertificate of Authorization No. None Expiration Date None

Signed Sunder Shaugi Codes & Materials, TGL Date 9-26-90, 19 90
 Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of IOWA and employed by Hartford Steam Boiler I&I Co. of Hartford, Connecticut have inspected the components described in this Owner's Report during the period 7-18-90 to 8-1-90, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in the Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personnel injury or property damage or a loss of any kind arising from or connected with this inspection.

Scott Presler Commissions NB 8829(I)(N) 941-IA
 Inspectors Signature National Board, State, Province, and
 Endorsements

Date Oct. 1 19 90

1. Owner Iowa Electric Light & Power Date September 13, 1990
 Name
P.O. Box 351, Cedar Rapids, IA 52406 Sheet 3 of 3
 Address
 Plant Duane Arnold Energy Center Unit 1
 Name
3277 DAEC Road, Palo, IA 52324 See below, P.O. S51281 (P.O. KE1069)
 Address Repair Organ. P.O. No., Job No. etc.
 3. Work performed by Iowa Electric Type Code Symbol Stamp N/A
 Name Authorization No. N/A
3277 DAEC Road, Palo, IA 52324 Expiration Date N/A
 Address
 4. Identification of System see below
 5. (a) Applicable Const. Code ASME III 1974 Edition, W75 Addenda 1361-2 Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacement
1980 W/81
 (c) Original Construction Code ASME III 1968 Edition W68 Addenda per GE
Construction Quality Requirements 22A2534
 6. Identification of Components Repaired or Replaced and Replacement
 Components

Name of Comp.	Name of Manufac.	Board No.	Other Identif.	Year Built (Rep.)	ASME Code Repaired Replaced or Replacement	Stamped (Yes or No)
CRD Housing	General Electric	None	See Below	1990	Replacement	Yes

Table CRD-op cyc 10/11 (class1)

Installation Organization	Manufac. Serial No. (Replaced)	Manufac. Serial No. (Replacement)	Other Identification	Preservice VT-1 Bolting
1044234	S/N A3267	S/N A4549	IR215 (38-11)	ISI #90-50
*PMAR 1044019	S/N A4448	S/N A4018	IR215 (02-19)	ISI #90-36
*PMAR 1044137	S/N A4777	S/N A5075	IR215 (34-15)	ISI #90-291
PMAR 1044030	S/N A4796	S/N A4619	IR215 (10-11)	ISI #90-45
PMAR 1044032	S/N A4016	S/N A4286	IR215 (10-19)	ISI #90-32
PMAR 1044034	S/N A4022	S/N A3994	IR215 (10-27)	ISI #90-46
PMAR 1044036	S/N A3945	S/N A2552	IR215 (10-35)	ISI #90-33
PMAR 1044037	S/N A4591	S/N A8882	IR215 (10-39)	ISI #90-38
PMAR 1044040	S/N A4442	S/N A4493	IR215 (14-15)	ISI #90-39
PMAR 1044063	S/N A3975	S/N A4464	IR215 (22-23)	ISI #90-47
PMAR 1044068	S/N A4539	S/N A8883	IR215 (22-43)	ISI #90-29
PMAR 1044072	S/N A4480	S/N A5623	IR215 (26-19)	ISI #90-48
PMAR 1044083	S/N A4516	S/N A4291	IR215 (30-23)	ISI #90-41
PMAR 1044090	S/N A3818	S/N A5685	IR215 (34-31)	ISI #90-31
PMAR 1044100	S/N A4549	S/N A3813	IR215 (42-19)	ISI #90-35
PMAR 1044020	S/N A4017	S/N A4525	IR215 (02-23)	ISI #90-44
PMAR 1044101	S/N A4494	S/N A2122	IR215 (42-23)	ISI #90-43
A01953	S/N A4589	S/N A5538	IR215 (18-15)	ISI #90-271
PMAR 1044022	S/N A4562	S/N A2182	IR215 (06-11)	ISI #90-37



FORM N-2 NPT CERTIFICATE HOLDERS' DATA REPORT FOR NUCLEAR PART AND APPURTENANCE
As required by the Provision of the ASME Code Rules, Section III, Div. 1

1. Manufactured & Certified by: GE Company, 2117 Castle Hayne Rd., Wilmington, N.C. 28405
(Name and Address of NPT Certificate Holder)
(c) Manufactured for: Duane Arnold Palo, Iowa 52062
(Name and Address of N Certificate Holder for completed nuclear component)
2. Identification-Certificate Holders's S/N of Part: A5538 Nat'l Bd. No. N 284
(a) Constructed According to Drawing No: 761E387G012 Rev 21 Dwg. Prepared by D. L. Peterson
(b) Description of Part Inspected: CONTROL ROD DRIVE, MODEL # 7RDB144EG001
(c) Applicable ASME Code: Section III, Edition 1974, Addenda Date W'75, Case No. 1361-2 C
3. REMARKS: Standard part for use with Reactor. Hydrostatically tested at 1825 psi. min.
(Brief description of service for which component was designed)

We certify that the statements in this report are correct and this vessel part or appurtenance as defined in the code conforms to the rules of construction of the ASME Code Section III (The applicable Designed Specification and Stress Report are not the responsibility of the Certificate Holder for parts. An NPT Certification Holder for appurtenances is responsible for furnishing a separate Design Specification and Stress Report if the appurtenance is included in the component Design Specification and Stress Report).

DATE: 5/17, 19 90 Signed GE-NEEG-NF&CM-QA By [Signature]
(NPT Certificate Holder) (SOO-QA REPRESENTATIVE)

Certificate of Authorization Expires: 6/16/90 Certification of Authorization No.: NPT N-284

CERTIFICATION OF DESIGN FOR APPURTENANCE

Design information on file at GE COMPANY, SAN JOSE, CALIFORNIA

Stress analysis report on file at GE COMPANY, SAN JOSE, CALIFORNIA

DC22A6253 Rev. 0

Design specification certified by BJORN HAABERG Prof. Eng. State CALIF. Reg. No. 15

DC22A6254 Rev. 1

Stress analysis report certified by EDWARD YOSHIO Prof. Eng. State CALIF. Reg. No. MO

CERTIFICATION OF SHOP INSPECTION

I, the undersigned, holding a valid commission by the National Board of Boiler and Pressure Vessel Inspectors and/or the State or Province of NORTH CAROLINA and employed by DEPARTMENT OF LABOR of STATE OF NORTH CAROLINA have inspected the part of a pressure vessel described in the Partial Data Report on 5-17 1990, and state that to the best of my knowledge and belief, the NPT Certificate Holder has constructed this part in accordance with the ASME Code Section III.

By signing this certificate, neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the part described in the Partial Data Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damages or a loss of any kind arising from or connected with this inspection.

DATE: 5-17, 1990 [Signature] N.C. 1231
Inspector's Signature National Board, State, Province and Country

Supplemental sheets in form of lists, sketches or drawing may be used provided (1) each sheet is numbered and number of sheets is recorded in Item 3. "REMARKS"

4. Shell: Material T.S. Thickness in. Allowance in Dia. ft. in. Length ft. in.
(Kind & Spec. No) (Min. or Range Specified)

6. Needs: (a) Material _____ Girth _____ M.F.¹ _____ R.F. _____ No. of Courses _____
(b) Material _____ I.S. _____ (c) Material _____ I.S. _____

If removable, bolts used _____ Other fastening _____
(Material, Spec. No., T.S. Size Number) (Describe or attach sketch)

8. Design Pressure ² 1250 psi at 575 °F

Drop Weight _____
Charpy Impact _____ ft-lb
at temp. of _____ °F

10. Tubes: Material _____ O.D. _____ in. Thickness _____ or gage. Number _____ Type _____
(Str. or U)

11. Shell: Material T.S. Thickness in. Allowance in. Dia. ft. in. Length ft. in.
(Kind & Spec. No.) (Min. or Range Specified)

(b) Channel									
If removable, bolts used (a)	(b)	(c)	Other fastening						

14. Design pressure² _____ psi at _____ °F

(Describe or attach sketch)

Drop Weight _____

Charpy Impact _____ ft-lb

at temp. of _____ °F

[illegible]

18. Supports: Shirt _____ Lugs _____ Lugs _____ Other _____ Attached _____
(Yes or No) (Number) (Number) (Describe) (Where & How)

2 List other internal or external pressure with coincident temperature when applicable.


FORM N-2 NPT CERTIFICATE HOLDERS' DATA REPORT FOR NUCLEAR PART AND APPURTENANCE
As required by the Provision of the ASME Code Rules, Section III, Div. I

1. Manufactured & Certified by: GE Company, 2117 Castle Hayne Rd., Wilmington, N.C. 28.
(Name and Address of NPT Certificate Holder)
(b) Manufactured for: Duane Arnold Palo, Iowa 52244
(Name and Address of N Certificate Holder for completed nuclear comp)
2. Identification-Certificate Holders's S/N of Part: A5538 Nat'l Bd. N. N/
- (a) Constructed According to Drawing No: 761E387G012 Rev 21 Dwg. Prepared by D. L. Pet
- (b) Description of Part Inspected: CONTROL ROD DRIVE, MODEL # 7RDB144EG001 N207
- (c) Applicable ASME Code: Section III, Edition 1974, Addenda Date W'75, Case No. 1361-2 C

Sheet 2 of 2

1. Cap 167A2343P1
SA182-F304
3/8 thick X 1 1/16 OD
2. Indicator Tube 104B1336P3
SA312-TP316
3/4 sch 40-seamless pipe
0.113 wall thickness
1.065 max. dia.
3. Plug 159A1176P1
SA182-F304
1/4 thick x 0.812 OD
4. Flange 919D610P1 (719E474)
SA182-F304
3.37 thick x 9 5/8 OD
5. Head 129B3539P3,P5
SA182-F304
3.0 OD x .884 ID
6. Ring Flange 114B5122P2
SA182-F304
1" thick x 5.0 OD x 1.75 ID
7. Cap Screw 117C4516P2
SA193-B6
6 ea. 1/2 dia. on 4 1/8 bolt circle
8. Plug 175A7961P1
SA182-F304
0.38 thick x 1.307 dia.
9. Nut 114B5460P1
SA193-B8A
1.30 thick x 2.62 dia.

CONTROL ROD DRIVE
DWG - 761E387



FORM N-2 NPT CERTIFICATE HOLDERS' DATA REPORT FOR NUCLEAR PART AND APPURTENANCES*
As required by the Provision of the ASME Code Rules, Section III, Div. I

1. Manufactured & Certified by: GE Company, 2117 Castle Hayne Rd., Wilmington, N.C. 28401
(Name and Address of NPT Certificate Holder)
Manufactured for: DUANE ARNOLD PALO, IOWA 52324
(Name and Address of N Certificate Holder for completed nuclear component)
2. Identification-Certificate Holders's S/N of Part: A2182 Nat'l Bd. No. N/A
(a) Constructed According to Drawing No: 761E387G012 Dwg. Prepared by D. L. Petersen
(b) Description of Part Inspected: CONTROL ROD DRIVE, MODEL # CRDEL44EG001
(c) Applicable ASME Code: Section III, Edition 1974, Addenda Date W'75, Case No. 1361-2 Class N207
3. REMARKS: Standard part for use with Reactor. Hydrostatically tested at 1825 psi. min.
(Brief description of service for which component was designed)

Sheet 1 of 2

We certify that the statements in this report are correct and this vessel part or appurtenance as defined in the code conforms to the rules of construction of the ASME Code Section II (The applicable Designed Specification and Stress Report are not the responsibility of the NPT Certificate Holder for parts. An NPT Certification Holder for appurtenances is responsible for furnishing a separate Design Specification and Stress Report if the appurtenance is not included in the component Design Specification and Stress Report).

DATE: 3/30, 19 90 Signed GE-NEEG-NF&CM-QA By J. Y. Jara
(NPT Certificate Holder) (SCO-QA REPRESENTATIVE)

Certificate of Authorization Expires: 6/16/90 Certification of Authorization No.: NPT N-115

CERTIFICATION OF DESIGN FOR APPURTENANCE

Design information on file at GE COMPANY, SAN JOSE, CALIFORNIA

Stress analysis report on file at GE COMPANY, SAN JOSE, CALIFORNIA

DC22A6253 Rev. 0

Design specification certified by BJORN HAABERG Prof. Eng. State CALIF. Reg. No. 15570

DC22A6254 Rev. 0.

Stress analysis report certified by EDWARD YOSHIO Prof. Eng. State CALIF. Reg. No. M0186

CERTIFICATION OF SHOP INSPECTION

I, the undersigned, holding a valid commission by the National Board of Boiler and Pressure Inspectors and/or the State or Province of NORTH CAROLINA and employed by DEPARTMENT OF LABOR of STATE OF NORTH CAROLINA have inspected the part of a pressure vessel described in this Partial Data Report on 3/30 1990, and state that to the best of my knowledge and belief, the NPT Certificate Holder has constructed this part in accordance with the ASME Code Section III.

By signing this certificate, neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the part described in the Partial Data Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damages or a loss of any kind arising from or connected with this inspection.

DATE 3/30, 1990 Inspector's Signature James P. Evans NC 1231
National Board, State, Province and NC

*Supplemental sheets in form of lists, sketches or drawing may be used provided (1) size is X 11", (2) information in 1-2 on this Data Report is included on each sheet, and (3) each sheet is numbered and number of sheets is recorded in Item 3. "REMARKS"

FORM M-2 (back)

Items 4-8 incl. to be completed for single well vessels, jacketed vessels, or shells of heat exchangers.

4. Shell: Material _____ T.S. _____ Thickness _____ in. Allowance _____ in. Dia. _____ ft. _____ in. Length _____ ft. _____ in.
(Kind & Spec. No.) (Min. of Range Specified)
5. Seams: Long _____ M.T.¹ _____ R.T. _____ Efficiency _____ %
Girth _____ M.T.¹ _____ R.T. _____ No. of Courses _____
6. Heads: (a) Material _____ T.S. _____ (b) Material _____ T.S. _____
Location (Top Bottom, Ends) Thickness _____ Crown Radius _____ Knuckle Radius _____ Elliptical Ratio _____ Conical Apex Angle _____ Hemispherical Radius _____ Flat Diameter _____ Side to Press. (conv. or conc.)
(a) _____
(b) _____
If removable, bolts used _____ Other fastening _____
(Material, Spec. No., T.S. Size Number) (Describe or attach sketch)
7. Jacket Closure: _____
(Describe as open and weld, bar, etc. If bar give dimensions, if bolts, describe or sketch)
8. Design Pressure ² _____ psi at _____ °F Drop Weight _____
Charpy Impact _____ ft-lb
at temp. of _____ °F

Items 9 and 10 to be completed for tube sections.

9. Tube Sheets: Stationary Mat'l. _____ Dia. _____ Thickness _____ in. Attachment _____
(Kind of Spec. No.) (Subj. to Press.) (Welded, Bolted)
Floating. Material _____ Dia. _____ Thickness _____ in. Attachment _____
10. Tubes: Material _____ O.D. _____ in. Thickness _____ or gage. Number _____ Type _____
(Str. or U)

Items 11-14 incl. to be completed for inner chambers of jacketed vessels, or channels of heat exchangers.

11. Shell: Material _____ T.S. _____ Thickness _____ in. Allowance _____ in. Dia. _____ ft. _____ in. Length _____ ft. _____ in.
(Kind & Spec. No.) (Min. of Range Specified)
12. Seams: Long _____ M.T.¹ _____ R.T. _____ Efficiency _____ %
Girth _____ M.T.¹ _____ R.T. _____ No. of Courses _____
13. Heads: (a) Material _____ T.S. _____ (b) Material _____ T.S. _____
Location (a) Top, Bottom, End Thickness _____ Crown Radius _____ Knuckle Radius _____ Elliptical Ratio _____ Conical Apex Angle _____ Hemispherical Radius _____ Flat Diameter _____ Side to Press. (Conv. or Conc.)
(b) Channel _____
If removable, bolts used (a) _____ (b) _____ (c) _____ Other fastening _____
(Describe or attach sketch)
Drop Weight _____
Charpy Impact _____ ft-lb
at temp. of _____ °F
14. Design pressure ² _____ psi at _____ °F

Items below to be completed for all vessels where applicable.

15. Safety Valve Outlet: Number _____ Size _____ Location _____
16. Nozzles:
Purpose (Inlet Outlet, Drain) Number Dia or Size Type Material Thickness Reinforcement Material Attached
17. Inspection Manholes, No. _____ Size _____ Location _____
Openings: Handholes, No. _____ Size _____ Location _____
Threaded, No. _____ Size _____ Location _____
18. Supports: Shirt _____ Lugs _____ Legs _____ Other _____ Attached _____
(Yes or No) (Number) (Number) (Describe) (Where & How)

¹ If Postweld Heat-Treated.

² List other internal or external pressure with coincident temperature when applicable.


FORM N-2 NPT CERTIFICATE HOLDERS' DATA REPORT FOR NUCLEAR PART AND APPURTENANCES*
As required by the Provision of the ASME Code Rules, Section III, Div. I

1. Manufactured & Certified by: GE Company, 2117 Castle Hayne Rd., Wilmington, N.C. 28401
(Name and Address of NPT Certificate Holder)
- (b) Manufactured for: DUANE ARNOLD PALO, IOWA 52324
(Name and Address of N Certificate Holder for completed nuclear component)
2. Identification-Certificate Holders's S/N of Part: A2182 Nat'l Bd. N. N/A
- (a) Constructed According to Drawing No: 76LE387G012 Dwg. Prepared by D. L. Peterson
- (b) Description of Part Inspected: CONTROL ROD DRIVE, MODEL # 7RDB144EG001
- (C) Applicable ASME Code: Section III, Edition 1974, Addenda Date W'75, Case No. 1361-2 Class N207

Sheet 2 of 2

1. Cap 167A2343P1
SA182-F304
3/8 thick x 1 1/16 OD
2. Indicator Tube 104B1336P3
SA312-TP316
3/4 sch 40-seamless pipe
0.113 wall thickness
1.065 max. dia.
3. Plug 159A1176P1
SA182-F304
1/4 thick x 0.812 OD
4. Flange 919D610P1 (719E474)
SA182-F304
3.37 thick x 9 5/8 OD
5. Head 129B3539P3, P5
SA182-F304
3.0 OD x .884 ID
6. Ring Flange 114B5122P2
SA182-F304
1" thick x 5.0 OD x 1.75 ID
7. Cap Screw 117C4516P2
SA193-B6
6 ea. 1/2 dia. on 4 1/8 bolt circle
8. Plug 175A7961P1
SA182-F304
0.38 thick x 1.307 dia.
9. Plug 114B5460P1
SA193-B8A
1.30 thick x 2.62 dia.

CONTROL ROD DRIVE
DWG - 76LE387



FORM 4-2 NPT CERTIFICATE HOLDERS' DATA REPORT FOR NUCLEAR PART AND APPURTENANCES
As required by the Provision of the ASME Code Rules, Section III, Div. I

Manufactured & Certified by: GE Company, 2117 Castle Hayne Rd., Wilmington, N.C. 28401
(Name and Address of NPT Certificate Holder)
(b) Manufactured for: DUANE ARNOLD PALO, IOWA 52324
(Name and Address of NPT Certificate Holder for completed nuclear component)
Identification-Certificate Holders's S/N of Part: A2122 Nat'l Bd. No. N/
(a) Constructed According to Drawing No: 761E387G012 Dwg. Prepared by D. L. Peter
(b) Description of Part Inspected: CONTROL ROD DRIVE, MODEL # 7RDB144EG001
N207
(c) Applicable ASME Code: Section III, Edition 1974, Addenda Date W'75, Case No. 1361-2 Class
REMARKS: Standard part for use with Reactor. Hydrostatically tested at 1825 psi. min.
(Brief description of service for which component was designed)

Sheet 1 of 1

We certify that the statements in this report are correct and this vessel part or appurtenance as defined in the code conforms to the rules of construction of the ASME Code Section III. The applicable Design Specification and Stress Report are not the responsibility of the Certificate Holder for parts. An NPT Certification Holder for appurtenances is responsible for furnishing a separate Design Specification and Stress Report if the appurtenance is included in the component Design Specification and Stress Report).

DATE: 3/30, 19 90 Signed GE-NEBG-NF&CM-QA By J. J. Josen
(NPT Certificate Holder) SOO-QA REPRESENTATIVE

Certificate Of Authorization Expires: 6/16/90 Certification of Authorization No.: NPT N-

CERTIFICATION OF DESIGN FOR APPURTENANCE

Design information on file at GE COMPANY, SAN JOSE, CALIFORNIA
Stress analysis report on file at GE COMPANY, SAN JOSE, CALIFORNIA
DC22A6253 Rev. 0
Design specification certified by BJORN HAABERG Prof. Eng. State CALIF. Reg. No. 15
DC22A6254 Rev. 0.
Stress analysis report certified by EDWARD YOSHIO Prof. Eng. State CALIF. Reg. No. M0

CERTIFICATION OF SHOP INSPECTION

I, the undersigned, holding a valid commission by the National Board of Boiler and Pressure Vessel Inspectors and/or the State or Province of NORTH CAROLINA and employed by DEPARTMENT OF LABOR of STATE OF NORTH CAROLINA have inspected the part of a pressure vessel described in Partial Data Report on 3/30 1990, and state that to the best of my knowledge and belief, the NPT Certificate Holder has constructed this part in accordance with the ASME Code Section III.

By signing this certificate, neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the part described in the Partial Data Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damages or a loss of any kind arising from or connected with this inspection.

DATE 3/10, 1990 Inspector's Signature James P. Evers NC 1231
National Board, State, Province and Country

Supplemental sheets in form of lists, sketches or drawing may be used provided (1) size is 8-1/2" X 11", (2) information in 1-2 on this Data Report is included on each sheet and (3) each sheet is numbered and number of sheets is recorded in Item 3. "REMARKS"

Items 4-6 incl. to be completed for single well vessels, jacketed vessels, or shells of heat exchangers.

4. Shell: Material _____ T.S. _____ Nominal Thickness _____ in. Corrosion Allowance _____ in. Dia. _____ ft. _____ in. Length _____ ft. _____ in.
(Kind & Spec. No.) (Min. of Range Specified)
5. Seams: Long _____ M.T.¹ _____ R.T. _____ Efficiency _____ %
Girth _____ M.T.¹ _____ R.T. _____ No. of Courses _____
6. Heads: (a) Material _____ T.S. _____ (b) Material _____ T.S. _____
Location (Top Bottom, Ends) Thickness Crown Radius Knuckle Radius Elliptical Ratio Conical Apex Angle Hemispherical Radius Flat Diameter Side to Press. (conv. or conc.)
(a) _____
(b) _____
If removable, bolts used _____ Other fastening _____
(Material, Spec. No., T.S. Size Number) (Describe or attach sketch)
7. Jacket Closure: _____
(Describe as open end weld, bar, etc. If bar give dimensions, if bolts, describe or sketch)
8. Design Pressure ² _____ psi at _____ °F Drop Weight _____
Charpy Impact _____ ft-lb
at temp. of _____ °F

Items 9 and 10 to be completed for tube sections.

9. Tube Sheet: Stationary Mat'l. _____ Dia. _____ Thickness _____ in. Attachment _____
(Kind of Spec. No.) (Subj. to Press.) (Welded, Bolted)
Floating. Material _____ Dia. _____ Thickness _____ in. Attachment _____
Inches
10. Tubes: Material _____ O.D. _____ in. Thickness _____ or gage. Number _____ Type _____
(Str. or U)

Items 11-14 incl. to be completed for inner chambers of jacketed vessels, or channels of heat exchangers

11. Shell: Material _____ T.S. _____ Nominal Thickness _____ in. Corrosion Allowance _____ in. Dia. _____ ft. _____ in. Length _____ ft. _____ in.
(Kind & Spec. No.) (Min. of Range Specified)
12. Seams: Long _____ M.T.¹ _____ R.T. _____ Efficiency _____ %
Girth _____ M.T.¹ _____ R.T. _____ No. of Courses _____
13. Heads: (a) Material _____ T.S. _____ (b) Material _____ T.S. _____
Location (a) Top, Bottom, Ends Thickness Crown Radius Knuckle Radius Elliptical Ratio Conical Apex Angle Hemispherical Radius Flat Diameter Side to Press. (conv. or conc.)
(b) Channel _____
If removable, bolts used (a) _____ (b) _____ (c) _____ Other fastening _____
(Describe or attach sketch)
Drop Weight _____
Charpy Impact _____ ft-lb
at temp. of _____ °F
14. Design pressure ² _____ psi at _____ °F

Items below to be completed for all vessels where applicable.

15. Safety Valve Outlet: Number _____ Size _____ Location _____
16. Nozzles:
Purpose (Inlet Outlet, Drain) Number Dia or Size Type Material Thickness Reinforcement Material Attached
17. Inspection Manholes, No. _____ Size _____ Location _____
Openings: Handies, No. _____ Size _____ Location _____
Threaded, No. _____ Size _____ Location _____
18. Supports: Shift _____ Lugs _____ Legs _____ Other _____ Attached _____
(Yes or No) (Number) (Number) (Describe) (Where & How)

¹ If Postweld Heat-Treated.

² List other internal or external pressure with coincident temperature when applicable.

Form N-2 NPT CERTIFICATE HOLDERS' DATA REPORT FOR NUCLEAR PART AND APPURTENANCES
As required by the Provision of the ASME Code Rules, Section III, Div. I

Manufactured & Certified by: GE Company, 2117 Castle Hayne Rd., Wilmington, N.C. 2840

(Name and Address of NPT Certificate Holder)

(b) Manufactured for: DUANE ARNOLD PALO, IOWA 52324

(Name and Address of N Certificate Holder for completed nuclear component)

2. Identification-Certificate Holders's S/N of Part: A2122 Nat'l Bd. N. N/A

(a) Constructed According to Drawing No: 76LE387G012 Dwg. Prepared by D. L. Pete


(b) Description of Part Inspected: CONTROL ROD DRIVE, MODEL # 7RDB144EG001

N207

(c) Applicable ASME Code: Section III, Edition 1974, Addenda Date W'75, Case No. 1361-2 Cl.

Sheet 2 of 2

1. Cap 167A2343P1
SA182-F304
3/8 thick x 1 1/16 OD
2. Indicator Tube 104B1336P3
SA312-TP316
3/4 sch 40-seamless pipe
0.113 wall thickness
1.065 max. dia.
3. Plug 159A1176P1
SA182-F304
1/4 thick x 0.812 OD
4. Flange 919D610P1 (719E474)
SA182-F304
3.37 thick x 9 5/8 OD
5. Head 129B3539P3,P5
SA182-F304
3.0 OD x .884 ID
6. Ring Flange 114B5122P2
SA182-F304
1" thick x 5.0 OD x 1.75 ID
7. Cap Screw 117C4516P2
SA193-B6
6 ea. 1/2 dia. on 4 1/8 bolt circle
8. Plug 175A7961P1
SA182-F304
0.38 thick x 1.307 dia.
9. Nut 114B5460P1
SA193-B8A
1.30 thick x 2.62 dia.



FORM N-2 NPT CERTIFICATE HOLDERS' DATA REPORT FOR NUCLEAR PART AND APPURTENANCES*
As required by the Provision of the ASME Code Rules, Section III, Div. I

Manufactured & Certified by: GE Company, 2117 Castle Hayne Rd., Wilmington, N.C. 28401
(Name and Address of NPT Certificate Holder)
(b) Manufactured for: Duane Arnold Paio, Iowa 52324
(Name and Address of N Certificate Holder for completed nuclear component)

Identification-Certificate Holders's S/N of Part: A4525 Nat'l Bd. No. N/A

(a) Constructed According to Drawing No: 761E387G012 Rev 21 Dwg. Prepared by D. L. Peterson

(b) Description of Part Inspected: CONTROL ROD DRIVE, MODEL # 7RDB144EG001

(c) Applicable ASME Code: Section III, Edition 1974, Addenda Date W'75, Case No. 1361-2 Class 1

REMARKS: Standard part for use with Reactor. Hydrostatically tested at 1825 psi. min.
(Brief description of service for which component was designed)

Sheet 1 of 2

I certify that the statements in this report are correct and this vessel part or appurtenance defined in the code conforms to the rules of construction of the ASME Code Section III. The applicable Designed Specification and Stress Report are not the responsibility of the NPT Certificate Holder for parts. An NPT Certification Holder for appurtenances is responsible for furnishing a separate Design Specification and Stress Report if the appurtenance is not included in the component Design Specification and Stress Report).

FE: 5/29, 19 90 Signed GE-NEEG-NF&OM-QA By [Signature]
(NPT Certificate Holder) SOO-QA REPRESENTATIVE

Certificate Of Authorization Expires: 6/16/90 Certification of Authorization No.: NPT N-1151

CERTIFICATION OF DESIGN FOR APPURTENANCE

Design information on file at GE COMPANY, SAN JOSE, CALIFORNIA

Stress analysis report on file at GE COMPANY SAN JOSE CALIFORNIA

22A6253 Rev. 0

Design specification certified by BJORN HAABERG Prof. Eng. State CALIF. Reg. No. 15570

22A6254 Rev. 1

Stress analysis report certified by EDWARD YOSHIO Prof. Eng. State CALIF. Reg. No. M0186

CERTIFICATION OF SHOP INSPECTION

I, the undersigned, holding a valid commission by the National Board of Boiler and Pressure Vessels Inspectors and/or the State or Province of NORTH CAROLINA and employed by DEPARTMENT OF LABOR STATE OF NORTH CAROLINA have inspected the part of a pressure vessel described in this Partial Data Report on 5-29 1990, and state that to the best of my knowledge and belief, the NPT Certificate Holder has constructed this part in accordance with the ASME Code Section III.

By signing this certificate, neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the part described in the Partial Data Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damages or a loss of any kind arising from or connected with this inspection.

5-29, 1990 [Signature] N.C. 1231
Inspector's Signature National Board, State, Province and No.

Supplemental sheets in form of lists, sketches or drawing may be used provided (1) size is 8 1/2" x 11", (2) information in 1-2 on this Data Report is included on each sheet, and (3) sheets are numbered and number of sheets is recorded in Item 3. "REMARKS"

FORM B-2 (back)

Items 4-8 incl. to be completed for single well vessels, jacketed vessels, or shells of heat exchangers.

4. Shell: Material _____ T.S. _____ Thickness _____ in. Allowance _____ in. Dia. _____ ft. _____ in. Length _____ ft. _____ in.
(Kind & Spec. No.) (Min. of Range Specified)

5. Seams: Long _____ M.T.¹ _____ R.T. _____ Efficiency _____ %

Girth _____ M.T.¹ _____ R.T. _____ No. of Courses _____
6. Heads: (a) Material _____ T.S. _____ (b) Material _____ T.S. _____

Location (Top Bottom, Ends)	Thickness	Crown Radius	Knuckle Radius	Elliptical Ratio	Conical Apex Angle	Hemispherical Radius	Flat Diameter	Side to Press. (conv. or conc.)
(a)	_____	_____	_____	_____	_____	_____	_____	_____
(b)	_____	_____	_____	_____	_____	_____	_____	_____

If removable, bolts used _____ Other fastening _____
(Material, Spec. No., T.S. Size Number) (Describe or attach sketch)

7. Jacket Closure: _____
(Describe as gage and weld, bar, etc. If bar give dimensions, if bolts, describe or sketch)

8. Design Pressure ² _____ psi at _____ °F Drop Weight _____
Charpy Impact _____ ft.-lb
at temp. of _____ °F

Items 9 and 10 to be completed for tube sections.

9. Tube Sheets: Stationary Mat'l. _____ Dia. _____ Thickness _____ in. Attachment _____
(Kind of Spec. No.) (Subj. to Press.) (Welded, Bolted)
Floating. Material _____ Dia. _____ Thickness _____ in. Attachment _____

10. Tubes: Material _____ O.D. _____ in. Thickness _____ or gage. Number _____ Type _____
(Str. or U)

Items 11-14 incl. to be completed for inner chambers of jacketed vessels, or channels of heat exchangers.

11. Shell: Material _____ T.S. _____ Thickness _____ in. Allowance _____ in. Dia. _____ ft. _____ in. Length _____ ft. _____ in.
(Kind & Spec. No.) (Min. of Range Specified)

12. Seams: Long _____ M.T.¹ _____ R.T. _____ Efficiency _____ %
Girth _____ M.T.¹ _____ R.T. _____ No. of Courses _____

13. Heads: (a) Material _____ T.S. _____ (b) Material _____ T.S. _____

Location	Thickness	Crown Radius	Knuckle Radius	Elliptical Ratio	Conical Apex Angle	Hemispherical Radius	Flat Diameter	Side to Press. (Conv. or Conc.)
(a) Top, Bottom, End	_____	_____	_____	_____	_____	_____	_____	_____
(b) Channel	_____	_____	_____	_____	_____	_____	_____	_____

If removable, bolts used (a) _____ (b) _____ (c) _____ Other fastening _____
(Describe or attach sketch)

14. Design pressure ² _____ psi at _____ °F Drop Weight _____
Charpy Impact _____ ft.-lb
at temp. of _____ °F

Items below to be completed for all vessels where applicable.

15. Safety Valve Outlets: Number _____ Size _____ Location _____

16. Nozzles:

Purpose (Inlet Outlet, Drain)	Number	Size or Size	Type	Material	Thickness	Reinforcement Material	Attached
_____	_____	_____	_____	_____	_____	_____	_____
_____	_____	_____	_____	_____	_____	_____	_____

17. Inspection Manholes, No. _____ Size _____ Location _____
Openings: Handles, No. _____ Size _____ Location _____
Threaded, No. _____ Size _____ Location _____

18. Supports: Shift _____ Lugs _____ Lugs _____ Other _____ Attached _____
(Yes or No) (Number) (Number) (Describe) (Where & How)

¹ If Postweld Heat-Treated.

² List other internal or external pressure with coincident temperature when applicable.

FORM N-2 NPT CERTIFICATE HOLDERS' DATA REPORT FOR NUCLEAR PART AND APPURTENANCES*
As required by the Provision of the ASME Code Rules, Section III, Div. I

Manufactured & Certified by: GE Company, 2117 Castle Hayne Rd., Wilmington, N.C. 28401
(Name and Address of NPT Certificate Holder)

(b) Manufactured for: Duane Arnold Palo, Iowa 52324
(Name and Address of N Certificate Holder for completed nuclear component)

Identification-Certificate Holders's S/N of Part: A4525 Nat'l Bd. N. N/A

(a) Constructed According to Drawing No: 761E387G012 Rev 21 Dwg. Prepared by D. L. Peters

(b) Description of Part Inspected: CONTROL ROD DRIVE, MODEL # 7RDB144EG001

N207

(c) Applicable ASME Code: Section III, Edition 1974, Addenda Date W'75, Case No. 1361-2 Clas 1

Sheet 2 of 2

Cap 167A2343P1
SA182-F304
3/8 thick x 1 1/16 OD

Indicator Tube 104B1336P3
SA312-TP316
3/4 sch 40-seamless pipe
3 wall thickness
max. dia.

Plug 159A1176P1
SA182-F304
1/4 thick x 0.812 OD

Flange 919D610P1 (719E474)
SA182-F304
3.37 thick x 9 5/8 OD

Head 129B3539P3,P5
SA182-F304
3.0 OD x .884 ID


Ring Flange 114B5122P2
SA182-F304
1" thick x 5.0 OD x 1.75 ID

Cap Screw 117C4516P2
SA193-B6
6 ea. 1/2 dia. on 4 1/8 bolt circle

Plug 175A7961P1
SA182-F304
0.38 thick x 1.307 dia.

Plug 175A7961P1
SA193-B8A
1.30 thick x 2.62 dia.

CONTROL ROD DRIVE
DWG - 761E387



FORM N-2 NPT CERTIFICATE HOLDERS' DATA REPORT FOR NUCLEAR PART AND APPURTENANCES*
As required by the Provision of the ASME Code Rules, Section III, Div. 1

1. Manufactured & Certified by: GE Company, 2117 Castle Hayne Rd., Wilmington, NC 28403
(b) Manufactured for: Duane Arnold, Palo, Iowa 52424
(Name and Address of NPT Certificate Holder for completed nuclear component)
2. Identification-Certificate Holders's S/N of Part: A3813 Nat'l Bd. No. N/A
(a) Constructed According to Drawing No: 76LE387G012 Rev 21 Dwg. Prepared by G. Peterson
(b) Description of Part Inspected: CONTROL ROD DRIVE, MODEL # 7RDB144EGC
(c) Applicable ASME Code: Section III, Edition 1974, Addenda Date W'75, Case No. 1-2 Class 1
3. REMARKS: Standard part for use with Reactor. Hydrostatically tested at 1825 p.s.i. min.
(Brief description of service for which component was designed)

We certify that the statements in this report are correct and this vessel part conforms as defined in the code conforms to the rules of construction of the ASME Code Section III. (The applicable Designed Specification and Stress Report are not the responsibility of the NPT Certificate Holder for parts. An NPT Certification Holder for appurtenances is responsible for furnishing a separate Design Specification and Stress Report if the appurtenance is not included in the component Design Specification and Stress Report).

DATE: 5/29, 19 90 Signed GE-NEEG-NF&OM-QA By [Signature]
(NPT Certificate Holder) SCQ QA REPRESENTATIVE

Certificate of Authorization Expires: 6/16/90 Certification of Authorization No. NPT N-1151

CERTIFICATION OF DESIGN FOR APPURTENANCE

Design information on file at GE COMPANY, SAN JOSE, CALIFORNIA
Stress analysis report on file at GE COMPANY, SAN JOSE, CALIFORNIA
DC22A6253 Rev. 0
Design specification certified by BJORN HAABERG Prof. Eng. State CALIF. Reg. No. 5570
DC22A6254 Rev. 1
Stress analysis report certified by EDWARD YOSHIO Prof. Eng. State CALIF. Reg. No. 4018646

CERTIFICATION OF SHOP INSPECTION

I, the undersigned, holding a valid commission by the National Board of Boiler and Pressure Vessel Inspectors and/or the State or Province of NORTH CAROLINA and employed by DEPARTMENT OF LABOR of STATE OF NORTH CAROLINA have inspected the part of a pressure vessel described in this Partial Data Report on S-29 1990, and state that to the best of my knowledge and belief, the NPT Certificate Holder has constructed this part in accordance with the ASME Code Section III.

By signing this certificate, neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the part described in the Partial Data Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damages or a loss of any kind arising from or connected with this inspection.

DATE: 5-29, 1990 Inspector's Signature [Signature] National Board, State, Province and No. N.C. 1231

Supplemental sheets in form of lists, sketches or drawing may be used provided (1) sheet is 8-1/2" X 11", (2) information in 1-2 on this Data Report is included on each sheet, and (3) each sheet is numbered and number of sheets is recorded in Item 3. "REMARKS"

FORM B-2 (back)

Items 4-8 incl., to be completed for single wall vessels, jacketed vessels, or shells of heat exchangers.

4. Shell: Material T.S. Thickness in. Allowance in. Dia. ft. in. Length ft. in.
(Kind & Spec. No.) (Min. of Range Specified)
5. Seams: Long M.T. R.T. Efficiency %
Girth M.T. R.T. No. of Courses
6. Heads: (a) Material T.S. (b) Material T.S.
Location (Top Crown Knuckle Elliptical Conical Hemispherical Flat Side to Press.
Bottom, End) Thickness Radius Radius Ratio Apex Angle Radius Diamet.: (conv. or conc.)
(e)
(b)
If removable, bolts used Other fastening
(Material, Spec. No., T.S. Size Number) (Describe or attach sketch)
7. Jacket Closure:
(Describe as open end weld, bar, etc. If bar give dimensions, if bolts, describe or sketch)
8. Design Pressure ² psi at °F Drop Weight
Charpy Impact ft-lb
at temp. of °F

Items 9 and 10 to be completed for tube sections.

9. Tube Sheets: Stationary Mat'l. Dia. Thickness in. Attachment
(Kind of Spec. No.) (Subj. to Press.) (Welded, Bolted)
Fastening. Material Dia. Thickness in. Attachment
Inches
10. Tubes: Material O.D. in. Thickness or gage. Number Type
(Str. or U)

Items 11-14 incl., to be completed for inner chambers of jacketed vessels, or channels of heat exchangers.

11. Shell: Material T.S. Thickness in. Allowance in. Dia. ft. in. Length ft. in.
(Kind & Spec. No.) (Min. of Range Specified)
12. Seams: Long M.T. R.T. Efficiency %
Girth M.T. R.T. No. of Courses
13. Heads: (a) Material T.S. (b) Material T.S.
Location Crown Knuckle Elliptical Conical Hemispherical Flat Side to Press.
(a) Top, Bottom, Thickness Radius Radius Ratio Apex Angle Radius Diameter (Conv. or Conc.)
End
(b) Channel
If removable, bolts used (a) (b) (c) Other fastening
(Describe or attach sketch)
Drop Weight
Charpy Impact ft-lb
at temp. of °F
14. Design pressure ² psi at °F at temp. of °F

Items below to be completed for all vessels where applicable.

15. Safety Valve Outlets: Number Size Location
16. Nozzles:
Purpose (Inlet Outlet, Drain) Number Size or Size Type Material Thickness Reinforcement Material Attached
17. Inspection Manholes, No. Size Location
Openings: Handles, No. Size Location
Threaded, No. Size Location
- Supports: Shirt Legs Legs Other Attached
(Yes or No) (Number) (Number) (Describe) (Where & How)

¹ If Postweld Heat-Treated.

² List other internal or external pressure with coincident temperature when applicable.

FORM N-2 NPT CERTIFICATE HOLDERS' DATA REPORT FOR NUCLEAR PART AND APPURTENANCES
As required by the Provision of the ASME Code Rules, Section III, D.

Manufactured & Certified by: GE Company, 2117 Castle Hayne Rd., Wilmington, N.C.

(b) Manufactured for: Duane Arnold (Name and Address of NPT Certificate Holder)
Palo, Iowa 520

Name and Address of N Certificate Holder for completed nuclear

2. Identification-Certificate Holders's S/N of Part: A3813 Nat'l Bd. N.

(a) Constructed According to Drawing No: 76LE387G012 Rev 21 Dwg. Prepared by D.

(b) Description of Part Inspected: CONTROL ROD DRIVE, MODEL # 7RDB144EG001

(c) Applicable ASME Code: Section III, Edition 1974, Addenda Date W'75, Case No. 136 N2C

Sheet 2

1. Cap 167A2343P1
SA182-F304
3/8 thick x 1 1/16 OD

2. Indicator Tube 114B1336P3
SA312-TP316
3/4 sch 40-seamless pipe
0.113 wall thickness
1.065 max. dia.

3. Plug 159A1176P1
SA182-F304
1/4 thick x 0.812 OD

4. Flange 919D610P1 (719E474)
SA182-F304
3.37 thick x 9 5/8 OD

5. Head 129B3539P3, P
SA182-F304
3.0 OD x .884 ID


6. Ring Flange 114B5112P2
SA182-F304
1" thick x 5.0 OD x 1.75 ID

7. Cap Screw 117C451122
SA193-B6
6 ea. 1/2 dia. on 1 1/8 bolt circle

8. Plug 175A7961P1
SA182-F304
0.38 thick x 1.307 dia.

9. Nut 114B5460P1
SA193-B8A
1.30 thick x 2.62 dia.

CONTROL ROD DRIVE
DWG - 76LE387



FORM N-2 NPT CERTIFICATE HOLDERS' DATA REPORT FOR NUCLEAR PART AND APPURTENANCES*
As required by the Provision of the ASME Code Rules, Section III, Div. I

Manufactured & Certified by: GE Company, 2117 Castle Hayne Rd., Wilmington, N.C. 28401
(Name and Address of NPT Certificate Holder)
(b) Manufactured for: Duane Arnold, Palo, Iowa 52324
(Name and Address of N Certificate Holder for completed nuclear component)
Identification-Certificate Holders's S/N of Part: A5685 Nat'l Id. No. N/A
(a) Constructed According to Drawing No: 761E387G012 Rev 21 Dwg. Prepared by: D. L. Peterson
(b) Description of Part Inspected: CONTROL ROD DRIVE, MODEL # 7RDL-44-0001
(c) Applicable ASME Code: Section III, Edition 1974, Addenda Date W'75, Case No. 1361-2 Class 1
REMARKS: Standard part for use with Reactor. Hydrostatically tested at 1800 psi. min.
(Brief description of service for which component was designed)

Sheet 1 of 2

I certify that the statements in this report are correct and this vessel part or appurtenance as defined in the code conforms to the rules of construction of the ASME Code, Section III. The applicable Designed Specification and Stress Report are not the responsibility of the NPT Certificate Holder for parts. An NPT Certification Holder for appurtenances is responsible for furnishing a separate Design Specification and Stress Report if the appurtenance is not included in the component Design Specification and Stress Report).

DATE: 5/29, 19 90 Signed GE-NEEG-NF&CM-QA By [Signature]
(NPT Certificate Holder) (QA REPRESENTATIVE)
Certificate Of Authorization Expires: 6/16/90 Certification of Authorization No.: NPT N-1151

CERTIFICATION OF DESIGN FOR APPURTENANCE

Design information on file at GE COMPANY, SAN JOSE, CALIFORNIA
Stress analysis report on file at GE COMPANY, SAN JOSE, CALIFORNIA
C22A6253 Rev. 0
Design specification certified by BJORN HAABERG Prof. Eng. State CALIF. Reg. No. 15570
C22A6254 Rev. 1
Stress analysis report certified by EDWARD YOSHIO Prof. Eng. State CALIF. Reg. No. M018646

CERTIFICATION OF SHOP INSPECTION

I, the undersigned, holding a valid commission by the National Board of Boiler and Pressure Vessel Inspectors and/or the State or Province of NORTH CAROLINA and employed by STATE OF NORTH CAROLINA have inspected the part of a pressure vessel described in this Partial Data Report on 5-29 1990, and state that to the best of my knowledge and belief, the NPT Certificate Holder has constructed this part in accordance with the ASME Code Section III.

By signing this certificate, neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the part described in the Partial Data Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damages or a loss of any kind arising from or connected with this inspection.

5-29 1990 [Signature] N.C. 1231
Inspector's Signature National Board, State or Province and No.

Supplemental sheets in form of lists, sketches or drawing may be used providing: (1) size is 8 1/2" x 11", (2) information in 1-2 on this Data Report is included on each sheet, and (3) sheet is numbered and number of sheets is recorded in Item 3. "REMARKS"

FORM M-2 (back)

Items 4-8 incl. to be completed for single wall vessels, jacketed vessels, or shells of heat exchangers.

4. Shell: Material T.S. Thickness in. Allowance in. Dia. ft. in. Length ft. in.
(Kind & Spec. No.) (Min. or Range Specified)

5. Seams: Long N.T.¹ R.T. Efficiency %

Girth N.T.¹ R.T. No. of Courses
6. Heads: (a) Material T.S. (b) Material T.S.

Location (Top Bottom, Ends)	Thickness	Crown Radius	Knuckle Radius	Elliptical Ratio	Conical Apex Angle	Hemispherical Radius	Flat Diameter	Side to Pro. (conv. or conc.)
(a) <u> </u>	<u> </u>	<u> </u>	<u> </u>	<u> </u>	<u> </u>	<u> </u>	<u> </u>	<u> </u>
(b) <u> </u>	<u> </u>	<u> </u>	<u> </u>	<u> </u>	<u> </u>	<u> </u>	<u> </u>	<u> </u>

If removable, bolts used Other fastening
(Material, Spec. No., T.S. Size Number) (Describe or attach sketch)

7. Jacket Closure:
(Describe as gage and weld, bar, etc. If bar give dimensions, if bolts, describe or attach sketch)

8. Design Pressure ² 1250 psi at 575 °F Drop Weight
Charpy Impact ft-lb
at temp. of °F

Items 9 and 10 to be completed for tube sections.

9. Tube Sheets: Stationary Mat'l. Dia. Thickness in. Attachment
(Kind of Spec. No.) (Subj. to Press.) (Welded, Bolted)
Floating. Material Dia. Thickness in. Attachment

10. Tubes: Material O.D. in. Thickness or gage. Number Type
(Str. or U)

Items 11-14 incl. to be completed for inner chambers of jacketed vessels, or channels of heat exchanger.

11. Shell: Material T.S. Thickness in. Allowance in. Dia. ft. in. Length ft. in.
(Kind & Spec. No.) (Min. or Range Specified)

12. Seams: Long N.T.¹ R.T. Efficiency %
Girth N.T.¹ R.T. No. of Courses

13. Heads: (a) Material T.S. (b) Material T.S.
Location Crown Radius Knuckle Radius Elliptical Ratio Conical Apex Angle Hemispherical Radius Flat Diameter Side to Pro.
(a) Top, Bottom, End Thickness Radius Radius Ratio Apex Angle Radius Diameter (Conv. or Conc.)
(b) Channel
If removable, bolts used (a) (b) (c) Other fastening
(Describe or attach sketch)

14. Design pressure ² psi at °F Drop Weight
Charpy Impact ft-lb
at temp. of °F

Items below to be completed for all vessels where applicable.

15. Safety Valve Outlets: Number Size Location

16. Nozzles:

Purpose (Inlet Outlet, Drain)	Number	Dia or Size	Type	Material	Thickness	Reinforcement Material	Attachment
<u> </u>	<u> </u>	<u> </u>	<u> </u>	<u> </u>	<u> </u>	<u> </u>	<u> </u>
<u> </u>	<u> </u>	<u> </u>	<u> </u>	<u> </u>	<u> </u>	<u> </u>	<u> </u>

17. Inspection Openings: Manholes, Re. Size Location
Handles, We. Size Location
Threaded, No. Size Location

18. Supports: Shirt Lugs Lugs Other Attached
(Yes or No) (Number) (Number) (Describe) (Where & How)

¹ If Postmild Heat-Treated.

² List other internal or external pressure with coincident temperature when applicable.

FORM N-2 NPT CERTIFICATE HOLDERS' DATA REPORT FOR NUCLEAR PART AND APPOR.
As required by the Provision of the ASME Code Rules, Section III,

NCORS*

. I


Manufactured & Certified by: GE Company, 2117 Castle Hayne Rd., Wilmington, N. 28401
(b) Manufactured for: Duane Arnold (Name and Address of NPT Certificate Holder)
Palo, Iowa (Name and Address of N Certificate Holder for completed nuclear component)

Identification-Certificate Holders's S/N of Part: A5685 Nat'l Bd. N/A
(a) Constructed According to Drawing No: 76LE387G012 Rev 21 Dwg. Prepared by D. Peterson
(b) Description of Part Inspected: CONTROL ROD DRIVE, MODEL # 7RDB144EG001
(c) Applicable ASME Code: Section III, Edition 1974, Addenda Date W'75, Case No. 1 -2 Class 1

Sheet 1 of 2

1. Cap 167A2343P1
SA182-F304
3/8 thick x 1 1/16 OD
2. Indicator Tube 104B1336P3
SA312-TP316
3/4 sch 40-seamless pipe
3 wall thickness
5 max. dia.
3. Plug 159A1176P1
SA182-F304
1/4 thick x 0.812 OD
4. Flange 919D610P1 (719E474)
SA182-F304
3.37 thick x 9 5/8 OD
5. Head 129B3539P3, P5
SA182-F304
3.0 OD x .884 ID
6. Ring Flange 114B5122P2
SA182-F304
1" thick x 5.0 OD x 1.75 ID
7. Cap Screw 117C4516P2
SA193-B6
6 ea. 1/2 dia. on 4 1/8 bolt circle
8. Plug 175A7961P1
SA182-F304
0.38 thick x 1.307 dia.
9. Nut 104B5460P1
SA193-B8A
1.30 thick x 2.62 dia.

CONTROL ROD DRIVE
DWG - 76LE387



FORM N-2 NPT CERTIFICATE HOLDERS' DATA REPORT FOR NUCLEAR PART AND APPURTENANCE
As required by the Provision of the ASME Code Rules, Section III, Div. I

1. Manufactured & Certified by: GE Company, 2117 Castle Hayne Rd., Wilmington, N.C. 284
(b) Manufactured for: Duane Arnold (Name and Address of NPT Certificate Holder)
Palo, Iowa 52
(Name and Address of N Certificate Holder for completed nuclear comp)
2. Identification-Certificate Holders's S/N of Part: A4291 Nat'l Bd. No. N
(a) Constructed According to Drawing No: 761E387G012 Rev 21 Dwg. Prepared by D. L. Pete
(b) Description of Part Inspected: CONTROL ROD DRIVE, MODEL # 7RDB144EG001
(c) Applicable ASME Code: Section III, Edition 1974, Addenda Date W'75, Case No. 1361-2 C
3. REMARKS: Standard part for use with Reactor. Hydrostatically tested at 1825 psi. min.
(Brief description of service for which component was designed)

Sheet 1 c

We certify that the statements in this report are correct and this vessel part or appurtenance as defined in the code conforms to the rules of construction of the ASME Code Section (The applicable Designed Specification and Stress Report are not the responsibility of the Certificate Holder for parts. An NPT Certification Holder for appurtenances is responsible for furnishing a separate Design Specification and Stress Report if the appurtenance is included in the component Design Specification and Stress Report).

DATE: 5/17, 19 90 Signed GE-NEEG-NF&OM-QA By [Signature]
(NPT Certificate Holder) SCC-QA REPRESENTATIVE

Certificate of Authorization Expires: 6/16/90 Certification of Authorization No.: NPT N-

CERTIFICATION OF DESIGN FOR APPURTENANCE

Design information on file at GE COMPANY, SAN JOSE, CALIFORNIA
Stress analysis report on file at GE COMPANY, SAN JOSE, CALIFORNIA
DC22A6253 Rev. 0
Design specification certified by BJORN HAABERG Prof. Eng. State CALIF. Reg. No. 15
DC22A6254 Rev. 1
Stress analysis report certified by EDWARD YOSHIO Prof. Eng. State CALIF. Reg. No. MO

CERTIFICATION OF SHOP INSPECTION

I, the undersigned, holding a valid commission by the National Board of Boiler and Pressure Vessel Inspectors and/or the State or Province of NORTH CAROLINA and employed by DEPARTMENT OF LABOR of STATE OF NORTH CAROLINA have inspected the part of a pressure vessel described in the Partial Data Report on 5-17 1990, and state that to the best of my knowledge and belief, the NPT Certificate Holder has constructed this part in accordance with the ASME Code Section III.

By signing this certificate, neither the Inspector nor his employer makes any warranty expressed or implied, concerning the part described in the Partial Data Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damages or a loss of any kind arising from or connected with this inspection.

DATE 5-17, 1990 Inspector's Signature [Signature] National Board, State, Province and N.C. 1231

Supplemental sheets in form of lists, sketches or drawing may be used provided (1) is 11 1/2" X 11", (2) information in 1-2 on this Data Report is included on each sheet, (3) each sheet is numbered and number of sheets is recorded in Item 3. "REMARKS"

Items 4-8 incl. to be completed for single wall vessels, jacketed vessels, or shells of heat exchangers.

4. Shell: Material T.S. Thickness in. Allowance in. Dia. ft. in. Length ft. in.
(Kind & Spec. No.) (Min. of Range Specified)

5. Seams: Long M.T.¹ R.T. Efficiency %

6. Heads: (a) Material T.S. Girth M.T.¹ R.T. No. of Courses
(b) Material T.S.

Location (Top Bottom, End)	Thickness	Crown Radius	Knuckle Radius	Elliptical Ratio	Conical Apex Angle	Hemispherical Radius	Flat Diameter	Side to Press. (conv. or conc.)
(a)	<u> </u>	<u> </u>	<u> </u>	<u> </u>	<u> </u>	<u> </u>	<u> </u>	<u> </u>
(b)	<u> </u>	<u> </u>	<u> </u>	<u> </u>	<u> </u>	<u> </u>	<u> </u>	<u> </u>

If removable, bolts used Other fastening
(Material, Spec. No., T.S. Size Number) (Describe or attach sketch)

7. Jacket Closure:
(Describe as open and weld, bar, etc. If bar give dimensions, if bolts, describe or sketch)

8. Design Pressure ² 1250 psi at 575 °F Drop Weight
Charpy Impact ft-lb
at temp. of °F

Items 9 and 10 to be completed for tube sections.

9. Tube Sheets: Stationary Mat'l. Dia. Thickness in. Attachment
(Kind of Spec. No.) (Subj. to Press.) (Welded, Bolted)
Floating. Material Dia. Thickness in. Attachment

10. Tubes: Material O.D. in. Thickness or gage. Number Type
(Str. or U)

Items 11-14 incl. to be completed for inner chambers of jacketed vessels, or channels of heat exchangers

11. Shell: Material T.S. Thickness in. Allowance in. Dia. ft. in. Length ft. in.
(Kind & Spec. No.) (Min. of Range Specified)

12. Seams: Long M.T.¹ R.T. Efficiency %
Girth M.T.¹ R.T. No. of Courses

13. Heads: (a) Material T.S. (b) Material T.S.
Location Crown Radius Knuckle Radius Elliptical Ratio Conical Apex Angle Hemispherical Radius Flat Diameter Side to Press. (Conv. or Conc.)
(a) Top, Bottom, End

(b) Channel
If removable, bolts used (a) (b) (c) Other fastening

(Describe or attach sketch)
Drop Weight
Charpy Impact ft-lb
at temp. of °F

14. Design pressure ² psi at °F

Items below to be completed for all vessels where applicable.

15. Safety Valve Outlets: Number Size Location

Purpose (Inlet Outlet, Drain)	Number	Dia or Size	Type	Material	Thickness	Reinforcement Material	Attached
<u> </u>	<u> </u>	<u> </u>	<u> </u>	<u> </u>	<u> </u>	<u> </u>	<u> </u>
<u> </u>	<u> </u>	<u> </u>	<u> </u>	<u> </u>	<u> </u>	<u> </u>	<u> </u>

17. Inspection Openings: Manholes, No. Size Location
Handles, No. Size Location
Threaded, No. Size Location

18. Supports: Shirt Lugs Lugs Other Attached
(Yes or No) (Number) (Number) (Describe) (Where & How)

¹ IF Postweld Heat-Treated.

² List other internal or external pressure with coincident temperature when applicable.

FORM N-2 NPT CERTIFICATE HOLDERS' DATA REPORT FOR NUCLEAR PART AND APPURTENANCES
As required by the Provision of the ASME Code Rules, Section III, Div. I

Manufactured & Certified by: GE Company, 2117 Castle Hayne Rd., Wilmington, N.C. 2840

(Name and Address of NPT Certificate Holder)

(b) Manufactured for: Duane Arnold Palo, Iowa 52324

(Name and Address of N Certificate Holder for completed nuclear po

2. Identification-Certificate Holders's S/N of Part: A4291 Nat'l Bd. N. N/A

(a) Constructed According to Drawing No: 761E387G012 Rev 21 Dwg. Prepared by D. L. Pete

(b) Description of Part Inspected: CONTROL ROD DRIVE, MODEL # 7RDB144EG001


N207

(c) Applicable ASME Code: Section III, Edition 1974, Addenda Date W'75, Case No. 1361-2 Cl

Sheet 2 of 2

1. Cap 167A2343P1
SA182-F304
3/8 thick x 1 1/16 OD
2. Indicator Tube 104B1336P3
SA312-TP316
3/4 sch 40-seamless pipe
0.113 wall thickness
1.065 max. dia.
3. Plug 159A1176P1
SA182-F304
1/4 thick x 0.812 OD
4. Flange 919D610P1 (719E474)
SA182-F304
3.37 thick x 9 5/8 OD
5. Head 129B3539P3,P5
SA182-F304
3.0 OD x .884 ID
6. Ring Flange 114B5122P2
SA182-F304
1" thick x 5.0 OD x 1.75 ID
7. Cap Screw 117C4516P2
SA193-B6
6 ea. 1/2 dia. on 4 1/8 bolt circle
8. Plug 175A7961P1
SA182-F304
0.38 thick x 1.307 dia.
9. Nut 114B5460P1
SA193-B8A
1.30 thick x 2.62 dia.

CONTROL ROD DRIVE
DWG - 761E387



FORM N-2 NPT CERTIFICATE HOLDERS' DATA REPORT FOR NUCLEAR PART AND APPURTENANCES*
As required by the Provision of the ASME Code Rules, Section III, Div. I

Manufactured & Certified by: GE Company, 2117 Castle Hayne Rd., Wilmington, N.C. 28401
(b) Manufactured for: Duane Arnold (Name and Address of NPT Certificate Holder)
Palo, Iowa 52324
(Name and Address of N Certificate Holder for completed nuclear component)
Identification-Certificate Holders's S/N of Part: A5623 Nat'l Bd. No. N/A
(a) Constructed According to Drawing No: 761E387G012 Rev 21 Dwg. Prepared by D. L. Peterson
(b) Description of Part Inspected: CONTROL ROD DRIVE, MODEL # 7RDB144EG001
(c) Applicable ASME Code: Section III, Edition 1974, Addenda Date W'75, Case No. 1361-2 Class 1
REMARKS: Standard part for use with Reactor. Hydrostatically tested at 1825 psi. min.
(Brief description of service for which component was designed)

Sheet 1 of 2

I certify that the statements in this report are correct and this vessel part or appurtenance defined in the code conforms to the rules of construction of the ASME Code Section III. The applicable Designed Specification and Stress Report are not the responsibility of the NPT Certificate Holder for parts. An NPT Certification Holder for appurtenances is responsible for furnishing a separate Design Specification and Stress Report if the appurtenance is not included in the component Design Specification and Stress Report).

DATE: 5/29, 19 90 Signed GE-NEEG-NF&OM-QA By [Signature]
(NPT Certificate Holder) (SQ-QA REPRESENTATIVE)

Certificate Of Authorization Expires: 6/16/90 Certification of Authorization No.: NPT N-1151

CERTIFICATION OF DESIGN FOR APPURTENANCE

Design information on file at GE COMPANY, SAN JOSE, CALIFORNIA
Stress analysis report on file at GE COMPANY, SAN JOSE, CALIFORNIA
222A6253 Rev. 0
Design specification certified by BJORN HAABERG Prof. Eng. State CALIF. Reg. No. 15570
222A6254 Rev. 1
Stress analysis report certified by EDWARD YOSHIO Prof. Eng. State CALIF. Reg. No. M018646

CERTIFICATION OF SHOP INSPECTION

I, the undersigned, holding a valid commission by the National Board of Boiler and Pressure Inspectors and/or the State or Province of NORTH CAROLINA and employed by DEPARTMENT OF LABOR, STATE OF NORTH CAROLINA have inspected the part of a pressure vessel described in this Partial Data Report on 5-27 19 90, and state that to the best of my knowledge and belief, the NPT Certificate Holder has constructed this part in accordance with the ASME Code Section III.

By signing this certificate, neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the part described in the Partial Data Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury, property damages or a loss of any kind arising from or connected with this inspection.

5-27, 19 90 [Signature] N.C. 1231
Inspector's Signature National Board, State, Province and No.

Supplemental sheets in form of lists, sketches or drawing may be used provided (1) size is 11", (2) information in 1-2 on this Data Report is included on each sheet, and (3) sheet is numbered and number of sheets is recorded in Item 3. "REMARKS"

FORM M-2 (back)

Items 4-8 incl. to be completed for single wall vessels, jacketed vessels, or shells of heat exchangers.

4. Shell: Material _____ T.S. _____ Nominal Thickness _____ in. Allowance _____ in. Dia. _____ ft. _____ in. Length _____ ft. _____ in.
(Kind & Spec. No.) (Min. or Range Specified)

5. Seams: Long _____ M.T.¹ _____ R.T. _____ Efficiency _____ %

6. Heads: (a) Material _____ T.S. _____ Girth _____ M.T.¹ _____ R.T. _____ No. of Courses _____
(b) Material _____ T.S. _____

Location (Top Bottom, End)	Thickness	Crown Radius	Knuckle Radius	Elliptical Ratio	Conical Apex Angle	Hemispherical Radius	Flat Diameter	Side to Press. (conv. or conc.)
(a)								
(b)								

If removable, bolts used _____ Other fastening _____
(Material, Spec. No., T.S. Size Number) (Describe or attach sketch)

7. Jacket Closure: _____
(Describe as open and weld, bar, etc. If bar give dimensions, if bolts, describe or sketch)

8. Design Pressure ² _____ psi at _____ °F Drop Weight _____
Charpy Impact _____ ft.-lb
at temp. of _____ °F

Items 9 and 10 to be completed for tube sections.

9. Tube Sheets: Stationary Mat'l. _____ Dia. _____ Thickness _____ in. Attachment _____
(Kind of Spec. No.) (Subj. to Press.) (Welded, Bolted)

Floating. Material _____ Dia. _____ Thickness _____ in. Attachment _____

10. Tubes: Material _____ O.D. _____ in. Thickness _____ or gage. Number _____ Type _____
(Str. or U)

Items 11-18 incl. to be completed for inner chambers of jacketed vessels, or channels of heat exchangers

11. Shell: Material _____ T.S. _____ Nominal Thickness _____ in. Allowance _____ in. Dia. _____ ft. _____ in. Length _____ ft. _____ in.
(Kind & Spec. No.) (Min. or Range Specified)

12. Seams: Long _____ M.T.¹ _____ R.T. _____ Efficiency _____ %

Girth _____ M.T.¹ _____ R.T. _____ No. of Courses _____

13. Heads: (a) Material _____ T.S. _____ (b) Material _____ T.S. _____

Location (a) Top, Bottom, End	Thickness	Crown Radius	Knuckle Radius	Elliptical Ratio	Conical Apex Angle	Hemispherical Radius	Flat Diameter	Side to Press. (Conv. or Conc.)
(a)								
(b) Channel								

If removable, bolts used (a) _____ (b) _____ (c) _____ Other Fastening _____
(Describe or attach sketch)

14. Design pressure ² _____ psi at _____ °F Drop Weight _____
Charpy Impact _____ ft.-lb
at temp. of _____ °F

Items below to be completed for all vessels where applicable.

15. Safety Valve Outlets: Number _____ Size _____ Location _____

Purpose (Inlet Outlet, Drain)	Number	Size or Size	Type	Material	Thickness	Reinforcement Material	Attached

17. Inspection Openings: Manholes, No. _____ Size _____ Location _____
Handholes, No. _____ Size _____ Location _____
Threaded, No. _____ Size _____ Location _____

18. Supports: Sht _____ Lugs _____ Lugs _____ Other _____ Attached _____
(Yes or No) (Number) (Number) (Describe) (Where & How)

¹ If Postweld Heat-Treated.

² List other internal or external pressure with coincident temperature when applicable.

FORM N-2 NPT CERTIFICATE HOLDERS' DATA REPORT FOR NUCLEAR PART AND APPURTENANCES
As required by the Provision of the ASME Code Rules, Section III, Div. I

Manufactured & Certified by: GE Company, 2117 Castle Hayne Rd., Wilmington, N.C. 2840
(Name and Address of NPT Certificate Holder)

(B) Manufactured for: Duane Arnold Palo, Iowa 52324

(Name and Address of N Certificate Holder for completed nuclear component)

Identification-Certificate Holders's S/N of Part: A5623 Nat'l Bd. N. N/A

(a) Constructed According to Drawing No: 761E387G012 Rev 21 Dwg. Prepared by D. L. Peter

(b) Description of Part Inspected: CONTROL ROD DRIVE, MODEL # 7RDB144EG001

(C) Applicable ASME Code: Section III, Edition 1974, Addenda Date W'75, Case No. 1361-2 Class 1
N207

Sheet 2 of 2

Cap 167A2343P1
SA182-F304
3/8 thick x 1 1/16 OD

Indicator Tube 104B1336P3
SA312-TP316
3/4 sch 40-seamless pipe
0.113 wall thickness
max. dia.

Plug 159A1176P1
SA182-F304
1/4 thick x 0.812 OD

Flange 919D610P1 (7L9E474)
SA182-F304
3.37 thick x 9 5/8 OD

Head 129B3539P3,P5
SA182-F304
3.0 OD x .884 ID


Ring Flange 114B5111P2
SA182-F304
1" thick x 5.0 OD x 1.75 ID

Cap Screw 117C4516P2
SA193-B6
6 ea. 1/2 dia. on 1/8 bolt circle

Plug 175A7961P1
SA182-F304
0.38 thick x 1.307 dia.

SA182-B5460P1
SA182-B8A
1.30 thick x 2.62 dia.

CONTROL ROD DRIVE
DWG - 761E387



FORM N-2 NPT CERTIFICATE HOLDERS' DATA REPORT FOR NUCLEAR PART AND APPURTENANCE
As required by the Provision of the ASME Code Rules, Section III, Div. I

1. Manufactured & Certified by: GE Company, 2117 Castle Hayne Rd., Wilmington, N.C. 2840
(Name and Address of NPT Certificate Holder)
(1) Manufactured for: DUANE ARNOLD PALO, IOWA 52324
(Name and Address of N Certificate Holder for completed nuclear component)
2. Identification-Certificate Holders's S/N of Part: A8883 Nat'l Bd. No. N/
(a) Constructed According to Drawing No: 761E387G012 Dwg. Prepared by D. L. Pete
(b) Description of Part Inspected: CONTROL ROD DRIVE, MODEL # 7RDB144EG001
(c) Applicable ASME Code: Section III, Edition 1974, Addenda Date W'75, Case No. 1361-2 CL
3. REMARKS: Standard part for use with Reactor. Hydrostatically tested at 1825 psi. min.
(Brief description of service for which component was designed)

Sheet 1 of

We certify that the statements in this report are correct and this vessel part or appurtenance as defined in the code conforms to the rules of construction of the ASME Code Section III. (The applicable Designed Specification and Stress Report are not the responsibility of the Certificate Holder for parts. An NPT Certification Holder for appurtenances is responsible for furnishing a separate Design Specification and Stress Report if the appurtenance is included in the component Design Specification and Stress Report).

DATE: 3/30, 19 90 Signed GE-NEEG-NF&OM-QA By J. J. Jose
(NPT Certificate Holder) (SCO-QA REPRESENTATIVE)

Certificate Of Authorization Expires: 6/16/90 Certification of Authorization No.: NPT N-

CERTIFICATION OF DESIGN FOR APPURTENANCE

Design information on file at GE COMPANY, SAN JOSE, CALIFORNIA

Stress analysis report on file at GE COMPANY, SAN JOSE, CALIFORNIA

DC22A6253 Rev. 0

Design specification certified by BJORN HAABERG Prof. Eng. State CALIF. Reg. No. 15

DC22A5254 Rev. 0.

Stress analysis report certified by EDWARD YOSHIO Prof. Eng. State CALIF. Reg. No. MO

CERTIFICATION OF SHOP INSPECTION

I, the undersigned, holding a valid commission by the National Board of Boiler and Pressure Vessel Inspectors and/or the State or Province of NORTH CAROLINA and employed by DEPARTMENT OF LABOR of STATE OF NORTH CAROLINA have inspected the part of a pressure vessel described in the Partial Data Report on 3-30 1990, and state that to the best of my knowledge and belief, the NPT Certificate Holder has constructed this part in accordance with the ASME Code Section III.

By signing this certificate, neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the part described in the Partial Data Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damages or a loss of any kind arising from or connected with this inspection.

DATE 3/30, 1990 Inspector's Signature James P. Evers NC 1231
National Board, State, Province and

Supplemental sheets in form of lists, sketches or drawing may be used provided (1) sheet is 1/2" X 11", (2) information in 1-2 on this Data Report is included on each sheet, (3) each sheet is numbered and number of sheets is recorded in Item 3. "REMARKS"

FORM H-2 (back)

Items 4-8 incl. to be completed for single wall vessels, jackets vessels, or shells of heat exchangers.

4. Shell: Material _____ T.S. _____ Nominal Thickness _____ in. Allowance _____ in. Dia. _____ ft. _____ in. Length _____ ft. _____ in.
(Kind & Spec. No.) (Min. of Range Specified)

5. Seams: Long _____ M.T.¹ _____ R.T. _____ Efficiency _____ %
Girth _____ M.T.¹ _____ R.T. _____ No. of Courses _____

6. Heads: (a) Material _____ T.S. _____ (b) Material _____ T.S. _____
Location (Top Bottom, Endo) Thickness _____ Crown Radius _____ Knuckle Radius _____ Elliptical Ratio _____ Conical Apex Angle _____ Hemispherical Radius _____ Flat Diameter _____ Side to Press. (conv. or conc.)
(a) _____
(b) _____
If removable, bolts used _____ Other Fastening _____
(Material, Spec. No., T.S. Size Number) (Describe or attach sketch)

7. Jacket Closure: _____
(Describe as gage and weld, bar, etc. If bar give dimensions, if bolts, describe or sketch)

8. Design Pressure ² _____ psi at _____ °F Drop Weight _____
Charpy Impact _____ ft-lb
at temp. of _____ °F

Items 9 and 10 to be completed for tube sections.

9. Tube Sheet: Stationary Mat'l. _____ Dia. _____ Thickness _____ in. Attachment _____
(Kind of Spec. No.) (Subj. to Press.) (Welded, Bolted)
Floating. Material _____ Dia. _____ Thickness _____ in. Attachment _____
Inches

10. Tubes: Material _____ O.D. _____ in. Thickness _____ or gage. Number _____ Type _____
(Str. or U)

Items 11-14 incl. to be completed for inner chambers of jacketed vessels, or channels of heat exchangers.

11. Shell: Material _____ T.S. _____ Nominal Thickness _____ in. Allowance _____ in. Dia. _____ ft. _____ in. Length _____ ft. _____ in.
(Kind & Spec. No.) (Min. of Range Specified)

12. Seams: Long _____ M.T.¹ _____ R.T. _____ Efficiency _____ %
Girth _____ M.T.¹ _____ R.T. _____ No. of Courses _____

13. Heads (a) Material _____ T.S. _____ (b) Material _____ T.S. _____
Location (a) Top, Bottom, Thickness _____ Crown Radius _____ Knuckle Radius _____ Elliptical Ratio _____ Conical Apex Angle _____ Hemispherical Radius _____ Flat Diameter _____ Side to Press. (Conv. or Conc.)
(b) Channel _____
If removable, bolts used (a) _____ (b) _____ (c) _____ Other Fastening _____
(Describe or attach sketch)

14. Design pressure ² _____ psi at _____ °F Drop Weight _____
Charpy Impact _____ ft-lb
at temp. of _____ °F

Items below to be completed for all vessels where applicable.

15. Safety Valve Outlet: Number _____ Size _____ Location _____

16. Nozzles:
Purpose (Inlet Outlet, Drain) Number Dia or Size Type Material Thickness Reinforcement Material Attached

17. Inspection Openings: Manholes, No. _____ Size _____ Location _____
Handholes, No. _____ Size _____ Location _____
Threaded, No. _____ Size _____ Location _____

18. Supports: Shirt _____ Lugs _____ Legs _____ Other _____ Attached _____
(Yes or No) (Number) (Number) (Describe) (Where & How)

¹ If Postweld Heat-Treated.

² List other internal or external pressure with coincident temperature when applicable.

FORM N-2 NPT CERTIFICATE HOLDERS' DATA REPORT FOR NUCLEAR PART AND APPURTENANCES
As required by the Provision of the ASME Code Rules, Section III, Div. I

Manufactured & Certified by: GE Company, 2117 Castle Hayne Rd., Wilmington, N.C. 2840
(Name and Address of NPT Certificate Holder)

(b) Manufactured for: DUANE ARNOLD PALO, IOWA 52324
(Name and Address of N Certificate Holder for completed nuclear type)

2. Identification-Certificate Holders's S/N of Part: A8883 Nat'l Bd. N. N/A

(a) Constructed According to Drawing No: 761E387G012 Dwg. Prepared by D. L. Pete


(b) Description of Part Inspected: CONTROL ROD DRIVE, MODEL # 7RDB144EG001

N207

(C) Applicable ASME Code: Section III, Edition 1974, Addenda Date W'75, Case No. 1361-2 Cl

Sheet 2 of 2

1. Cap 167A2343P1
SA182-F304
3/8 thick x 1 1/16 OD
2. Indicator Tube 104B1336P3
SA312-TP316
3/4 sch 40-seamless pipe
0.113 wall thickness
1.065 max. dia.
3. Plug 159A1176P1
SA182-F304
1/4 thick x 0.812 OD
4. Flange 919D610P1 (719E474)
SA182-F304
3.37 thick x 9 5/8 OD
5. Head 129B3539P3,P5
SA182-F304
3.0 OD x .884 ID
6. Ring Flange 114B5122P2
SA182-F304
1" thick x 5.0 OD x 1.75 ID
7. Cap Screw 117C4516P2
SA193-B6
6 ea. 1/2 dia. on 4 1/8 bolt circle
8. Plug 175A7961P1
SA182-F304
0.38 thick x 1.307 dia.
9. Nut 114B5460P1
SA193-B8A
1.30 thick x 2.62 dia.



FORM N-2 NPT CERTIFICATE HOLDERS' DATA REPORT FOR NUCLEAR PART AND APPURTENANCES*
As required by the Provision of the ASME Code Rules, Section III, Div. I

1. Manufactured & Certified by: GE Company, 2117 Castle Hayne Rd., Wilmington, N.C. 28401
(Name and Address of NPT Certificate Holder)
Manufactured for: DUANE ARNOLD PALO, IOWA 52324
(Name and Address of N Certificate Holder for completed nuclear component)
2. Identification-Certificate Holders's S/N of Part: A4464 Nat'l Bd. No. N/A
(a) Constructed According to Drawing No: 761E387G012 Dwg. Prepared by D. L. Petersor
(b) Description of Part Inspected: CONTROL ROD DRIVE, MODEL # 7RDB144EG001
N207
(c) Applicable ASME Code: Section III, Edition 1974, Addenda Date W'75, Case No. 1361-2 Class.
3. REMARKS: Standard part for use with Reactor. Hydrostatically tested at 1825 psi. min.
(Brief description of service for which component was designed)

Sheet 1 of 2

We certify that the statements in this report are correct and this vessel part or appurtenance as defined in the code conforms to the rules of construction of the ASME Code Section III (The applicable Designed Specification and Stress Report are not the responsibility of the NPT Certificate Holder for parts. An NPT Certification Holder for appurtenances is responsible for furnishing a separate Design Specification and Stress Report if the appurtenance is not included in the component Design Specification and Stress Report).

DATE: 3/30, 19 90 Signed GE-NEEG-NF&OM-QA By [Signature]
(NPT Certificate Holder) (SCO-QA REPRESENTATIVE)

Certificate of Authorization Expires: 6/16/90 Certification of Authorization No.: NPT N-1151

CERTIFICATION OF DESIGN FOR APPURTENANCE

Design information on file at GE COMPANY, SAN JOSE, CALIFORNIA
Stress analysis report on file at GE COMPANY, SAN JOSE, CALIFORNIA
DC22A62 Rev. 0
Design specification certified by BJORN HAABERG Prof. Eng. State CALIF. Reg. No. 15570
DC22A62 Rev. 0.
Stress analysis report certified by EDWARD YOSHIO Prof. Eng. State CALIF. Reg. No. M01864

CERTIFICATION OF SHOP INSPECTION

I, the undersigned, holding a valid commission by the National Board of Boiler and Pressure Vessels and/or the State or Province of NORTH CAROLINA and employed by DEPARTMENT OF LABOR of STATE OF NORTH CAROLINA have inspected the part of a pressure vessel described in this Partial Data Report on 3/30 1990, and state that to the best of my knowledge and belief, the NPT Certificate Holder has constructed this part in accordance with the ASME Code Section III.

By signing this certificate, neither the Inspector nor his employer makes any warranty, express or implied, concerning the part described in the Partial Data Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damages or a loss of any kind arising from or connected with this inspection.

DATE 3/30, 1990 [Signature] NC 1231
Inspector's Signature National Board, State, Province and No

Additional sheets in form of lists, sketches or drawing may be used provided (1) size is 11", (2) information in 1-2 on this Data Report is included on each sheet, and (3) each sheet is numbered and number of sheets is recorded in Item 3. "REMARKS"

FORM M-2 (back)

Items 4-8 incl. to be completed for single wall vessels, jackets vessels, or shells of heat exchangers.

4. Shell: Material _____ T.S. _____ Thickness _____ in. Allowance _____ in. Dia. _____ ft. _____ in. Length _____ ft. _____ in.
(Kind & Spec. No.) (Min. of Range Specified)
5. Seams: Long _____ M.T.¹ _____ R.T. _____ Efficiency _____ %
Girth _____ M.T.¹ _____ R.T. _____ No. of Courses _____
6. Heads: (a) Material _____ T.S. _____ (b) Material _____ T.S. _____
Location (Top _____ Bottom, Ends) _____ Thickness _____ Crown Radius _____ Knuckle Radius _____ Elliptical Ratio _____ Conical Apex Angle _____ Hemispherical Radius _____ Flat Diameter _____ Side to Press. (conv. or conc.)
(a) _____
(b) _____
If removable, bolts used _____ Other Fastening _____
(Material, Spec. No., T.S. Size Number) (Describe or attach sketch)
7. Jacket Closure: _____
(Describe as open and weld, bar, etc. If bar give dimensions, if bolts, describe or sketch)
8. Design Pressure ² _____ psi at _____ °F Drop Weight _____
Charpy Impact _____ ft.-lb
at temp. of _____ °F

Items 9 and 10 to be completed for tube sections.

9. Tube Sheet: Stationary Mat'l. _____ Dia. _____ Thickness _____ in. Attachment _____
(Kind of Spec. No.) (Subj. to Press.) (Welded, Bolted)
Floating. Material _____ Dia. _____ Thickness _____ in. Attachment _____
Inches
10. Tubes: Material _____ O.D. _____ in. Thickness _____ or gage. Number _____ Type _____
(Str. or U)

Items 11-14 incl. to be completed for inner chambers of jacketed vessels, or channels of heat exchangers.

11. Shell: Material _____ T.S. _____ Thickness _____ in. Allowance _____ in. Dia. _____ ft. _____ in. Length _____ ft. _____ in.
(Kind & Spec. No.) (Min. of Range Specified)
12. Seams: Long _____ M.T.¹ _____ R.T. _____ Efficiency _____ %
Girth _____ M.T.¹ _____ R.T. _____ No. of Courses _____
13. Heads (a) Material _____ T.S. _____ (b) Material _____ T.S. _____
Location (a) Top, Bottom, Thickness _____ Crown Radius _____ Knuckle Radius _____ Elliptical Ratio _____ Conical Apex Angle _____ Hemispherical Radius _____ Flat Diameter _____ Side to Press. (conv. or conc.)
(b) Channel _____
If removable, bolts used (a) _____ (b) _____ (c) _____ Other Fastening _____
(Describe or attach sketch)
Drop Weight _____
Charpy Impact _____ ft.-lb
at temp. of _____ °F
14. Design pressure ² _____ psi at _____ °F at temp. of _____ °F

Items below to be completed for all vessels where applicable.

15. Safety Valve Outlets: Number _____ Size _____ Location _____
16. Nozzles:
Purpose (Inlet _____ Outlet, Drain) _____ Number _____ Dia. or Size _____ Type _____ Material _____ Thickness _____ Reinforcement Material _____ Attached _____
17. Inspection Manholes, No. _____ Size _____ Location _____
Openings: Handlax, No. _____ Size _____ Location _____
Threaded, No. _____ Size _____ Location _____
18. Support: Shirt _____ Lugs _____ Legs _____ Other _____ Attached _____
(Yes or No) (Number) (Number) (Describe) (Where & How)

¹ If Postweld Heat-Treated.

² List other internal or external pressure with coincident temperature when applicable.


FORM N-2 NPT CERTIFICATE HOLDERS' DATA REPORT FOR NUCLEAR PART AND APPURTENANCES*
As required by the Provision of the ASME Code Rules, Section III, Div. I

1. Manufactured & Certified by: GE Company, 2117 Castle Hayne Rd., Wilmington, N.C. 28401
(Name and Address of NPT Certificate Holder)
- Manufactured for: DUANE ARNOLD PALO, IOWA 52324
(Name and Address of N Certificate Holder for completed nuclear component)
2. Identification-Certificate Holders's S/N of Part: A4464 Nat'l Bd. N. N/A
- (a) Constructed According to Drawing No: 761E387G012 Dwg. Prepared by D. L. Petersen
- (b) Description of Part Inspected: CONTROL ROD DRIVE, MODEL # 7RDB144EG001
N207
- (c) Applicable ASME Code: Section III, Edition 1974, Addenda Date W'75, Case No. 1361-2 Class

Sheet 2 of 2

1. Cap 167A2343P1
SA182-F304
3/8 thick x 1 1/16 OD
2. Indicator Tube 104B1336P3
SA312-TP316
1/4 sch 40-seamless pipe
1.113 wall thickness
0.65 max. dia.
3. Plug 159A1176P1
SA182-F304
1/4 thick x 0.812 OD
4. Flange 919D610P1 (719E474)
SA182-F304
1.37 thick x 9 5/8 OD
5. Head 129B3539P3, P5
SA182-F304
3.0 OD x .884 ID
6. Ring Flange 114B5122P2
SA182-F304
1" thick x 5.0 OD x 1.75 ID
7. Cap Screw 117C4516P2
SA193-B6
6 ea. 1/2 dia. on 4 1/8 bolt circle
8. Plug 175A7961P1
SA182-F304
0.38 thick x 1.307 dia.
9. Nut 114B5460P1
SA193-B8A
1.30 thick x 2.62 dia.

CONTROL ROD DRIVE
DWG - 761E387



FORM N-2 NPT CERTIFICATE HOLDERS' DATA REPORT FOR NUCLEAR PART AND APPURTENANCE
As required by the Provision of the ASME Code Rules, Section III, Div. I

1. Manufactured & Certified by: GE Company, 2117 Castle Hayne Rd., Wilmington, N.C. 28401
Manufactured by: Duane Arnold (Name and Address of NPT Certificate Holder)
Palo, Iowa 521
Name and Address of NPT Certificate Holder for completed nuclear component
2. Identification-Certificate Holders's S/N of Part: A4493 Nat'l Bd. No. N/
(a) Constructed According to Drawing No: 761E387G012 Rev 21 Dwg. Prepared by D. L. Pete
(b) Description of Part Inspected: CONTROL ROD DRIVE, MODEL # 7RDB144EG001
(c) Applicable ASME Code: Section III, Edition 1974, Addenda Date W'75, Case No. 1361-2 Cl N207
3. REMARKS: Standard part for use with Reactor. Hydrostatically tested at 1825 psi. min.
(Brief description of service for which component was designed)

We certify that the statements in this report are correct and this vessel part or appurtenance as defined in the code conforms to the rules of construction of the ASME Code Section III. (The applicable Design Specification and Stress Report are not the responsibility of the Certificate Holder for parts. An NPT Certification Holder for appurtenances is responsible for furnishing a separate Design Specification and Stress Report if the appurtenance is included in the component Design Specification and Stress Report).

DATE: 5/17, 19 90 Signed GE-NEBG-NF&CM-QA By [Signature]
(NPT Certificate Holder) SOG-QA REPRESENTATIVE

Expiration Date of Authorization Expires: 6/16/90 Certification of Authorization No.: NPT N-

CERTIFICATION OF DESIGN FOR APPURTENANCE

Design information on file at GE COMPANY, SAN JOSE, CALIFORNIA
Stress analysis report on file at GE COMPANY, SAN JOSE, CALIFORNIA
DC22-253 Rev. 0
Design specification certified by BJORN HAABERG Prof. Eng. State CALIF. Reg. No. 155
DC22-254 Rev. 1
Stress analysis report certified by EDWARD YOSHIO Prof. Eng. State CALIF. Reg. No. M01

CERTIFICATION OF SHOP INSPECTION

I, the undersigned, holding a valid commission by the National Board of Boiler and Pressure Vessels Inspectors and/or the State or Province of NORTH CAROLINA and employed by DEPARTMENT OF LABOR of STATE OF NORTH CAROLINA have inspected the part of a pressure vessel described in the Partial Data Report of 5-17 1990, and state that to the best of my knowledge and belief, the NPT Certificate Holder has constructed this part in accordance with the ASME Code Section III.

By signing this certificate, neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the part described in the Partial Data Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damages or a loss of any kind arising from or connected with this inspection.

DATE: 5-17, 1990 [Signature] N.C. 1231
Inspector's Signature National Board, State, Province and

Supplemental sheets in form of lists, sketches or drawing may be used provided (1) sheets are 11" X 11", (2) information in 1-2 on this Data Report is included on each sheet, (3) each sheet is numbered and number of sheets is recorded in Item 3. "REMARKS"

Items 4-8 incl. to be completed for single wall vessels, jackets vessels, or shells of heat exchangers.

4. Shell: Material _____ T.S. _____ Thickness _____ in. Allowance _____ in. Dia. _____ ft. _____ in. Length _____ ft. _____ in.
(Kind & Spec. No.) (Min. of Range Specified)
5. Seams: Long _____ M.T.¹ _____ R.T. _____ Efficiency _____ %
Girth _____ M.T.¹ _____ R.T. _____ No. of Courses _____
6. Heads: (a) Material _____ T.S. _____ (b) Material _____ T.S. _____
Location (Top _____ Bottom, Ends) _____ Thickness _____ Crown Radius _____ Knuckle Radius _____ Elliptical Ratio _____ Conical Apex Angle _____ Hemispherical Radius _____ Flat Diameter _____ Side to Press. (conv. or conc.)
(a) _____
(b) _____
If removable, bolts used _____ Other fastening _____
(Material, Spec. No., T.S. Size Number) (Describe or attach sketch)
7. Jacket Closures _____
(Describe as gage and weld, bol, etc. If bol give dimensions, if bolts, describe or sketch)
8. Design Pressure ² _____ psi at _____ °F Drop Weight _____
Charpy Impact _____ ft-lb
at temp. of _____ °F

Items 9 and 10 to be completed for tube sections.

9. Tube Sheets: Stationary Mat'l. _____ Dia. _____ Thickness _____ in. Attachment _____
(Kind of Spec. No.) (Subj. to Press.) (Welded, Bolted)
Floating. Material _____ Dia. _____ Thickness _____ in. Attachment _____
10. Tubes: Material _____ O.D. _____ in. Thickness _____ or gage. Number _____ Type _____
(Str. or U)

Items 11-14 incl. to be completed for inner chambers of jacketed vessels, or channels of heat exchangers

11. Shell: Material _____ T.S. _____ Thickness _____ in. Allowance _____ in. Dia. _____ ft. _____ in. Length _____ ft. _____ in.
(Kind & Spec. No.) (Min. of Range Specified)
12. Seams: Long _____ M.T.¹ _____ R.T. _____ Efficiency _____ %
Girth _____ M.T.¹ _____ R.T. _____ No. of Courses _____
13. Heads: (a) Material _____ T.S. _____ (b) Material _____ T.S. _____
Location _____ Crown Radius _____ Knuckle Radius _____ Elliptical Ratio _____ Conical Apex Angle _____ Hemispherical Radius _____ Flat Diameter _____ Side to Press. (Conv. or Conc.)
(a) Top, Bottom, End _____
(b) Channel _____
If removable, bolts used (a) _____ (b) _____ (c) _____ Other Fastening _____
(Describe or attach sketch)
Drop Weight _____
Charpy Impact _____ ft-lb
at temp. of _____ °F
14. Design pressure ² _____ psi at _____ °F

Items below to be completed for all vessels where applicable.

15. Safety Valve Outlets: Number _____ Size _____ Location _____
16. Nozzles:
Purpose (Inlet _____ Outlet, Drain) _____
Number _____ Dia or Size _____ Type _____ Material _____ Thickness _____ Reinforcement Material _____ Attached _____
17. Inspection Manholes, No. _____ Size _____ Location _____
Openings: Handhole, No. _____ Size _____ Location _____
Threaded, No. _____ Size _____ Location _____
18. Supports: Shirt _____ Lugs _____ Legs _____ Other _____ Attached _____
(Yes or No) (Number) (Number) (Describe) (Where & How)
- ¹ If Postweld Heat-Treated.
- ² List other internal or external pressure with coincident temperature when applicable.

FORM N-2 NPT CERTIFICATE HOLDERS' DATA REPORT FOR NUCLEAR PART AND APPURTENANCES
As required by the Provision of the ASME Code Rules, Section III, Div. I

Manufactured & Certified by: GE Company, 2117 Castle Hayne Rd., Wilmington, N.C. 28401

(Name and Address of NPT Certificate Holder)

(b) Manufactured for: Duane Arnold Palo, Iowa 52374

(Name and Address of N Certificate Holder for completed nuclear component)

2. Identification-Certificate Holders's S/N of Part: A4493 Nat'l Bd. N. N/A

(a) Constructed According to Drawing No: 761E387G012 Rev 21 Dwg. Prepared by D. L. Pete

(b) Description of Part Inspected: CONTROL ROD DRIVE, MODEL # 7RDB144EG001

N207

(c) Applicable ASME Code: Section III, Edition 1974, Addenda Date W'75, Case No. 1361-2 Cl

Sheet 2 of 2

1. Cap 167A2343P1
SA182-F304
3/8 thick x 1 1/16 OD

2. Indicator Tube 104B1336P3
SA312-TP316
3/4 sch 40-seamless pipe
0.113 wall thickness
1.065 max. dia.

3. Plug 159A1176P1
SA182-F304
1/4 thick x 0.812 OD

4. Flange 919D610P1 (719E474)
SA182-F304
3.37 thick x 9 5/8 OD

5. Head 129B3539P3,P5
SA182-F304
3.0 OD x .884 ID


6. Ring Flange 114B5122P2
SA182-F304
1" thick x 5.0 OD x 1.75 ID

7. Cap Screw 117C4516P2
SA193-B6
6 ea. 1/2 dia. on 4 1/8 bolt circle

8. Plug 175A7961P1
SA182-F304
0.38 thick x 1.307 dia.

9. Nut 114B5460P1
SA193-B8A
1.30 thick x 2.62 dia.

CONTROL ROD DRIVE
DWG - 761E387



FORM N-2 NPT CERTIFICATE HOLDERS' DATA REPORT FOR NUCLEAR PARTS AND APPURTENANCES*
As required by the Provision of the ASME Code Rules, Section III, Div. I

1. Manufactured & Certified by: GE Company, 2117 Castle Hayne Rd., Wilmington, N.C. 28401
(Name and Address of NPT Certificate Holder)
Manufactured for: DUANE ARNOLD
(Name and Address of N Certificate Holder for component)
2. Identification-Certificate Holders's S/N of Part: A8882
(a) Constructed According to Drawing No: 76LE387G012 Dwg. Prepared by D. L. Peterson
(b) Description of Part Inspected: CONTROL ROD DRIVE, MODEL # DBL44EG001
(c) Applicable ASME Code: Section III, Edition 1974, Addenda Date W'77 N207
3. REMARKS: Standard part for use with Reactor. Hydrostatically tested at 1825 psi. min.
(Brief description of service for which component is designed)

Sheet 1 of 2

We certify that the statements in this report are correct and this vessel as described in the code conforms to the rules of construction of the ASME Code Section III. (The applicable Designed Specification and Stress Report are not the responsibility of the NPT Certificate Holder for parts. An NPT Certification Holder for appurtenances is responsible for furnishing a separate Design Specification and Stress Report if the appurtenance is not included in the component Design Specification and Stress Report).

DATE: 3/30, 19 90 Signed GE-NEEG-NF&CM-QA By [Signature]
(NPT Certificate Holder) (QA REPRESENTATIVE)

Certificate of Authorization Expires: 6/16/90 Certification of Authorization No.: NPT N-1151

CERTIFICATION OF DESIGN FOR APPURTENANCE

Design information on file at GE COMPANY, SAN JOSE, CALIFORNIA
Stress analysis report on file at GE COMPANY, SAN JOSE, CALIFORNIA
DC22-6253 Rev. 0
Design specification certified by BJORN HAABERG Prof. Eng. State ALIF. Reg. No. 15570
DC22-6254 Rev. 0
Stress analysis report certified by EDWARD YOSHIO Prof. Eng. State ALIF. Reg. No. M01864

CERTIFICATION OF SHOP INSPECTION

I, the undersigned, holding a valid commission by the National Board of Boiler and Pressure Vessel Inspectors and/or the State or Province of NORTH CAROLINA and employed by STATE OF NORTH CAROLINA have inspected the part of a pressure vessel described in this Partial Data Report on 3/30 1990, and state that to the best of my knowledge and belief, the NPT Certificate Holder has constructed this part in accordance with the ASME Code Section III.

By signing this certificate, neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the part described in the Partial Data Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damages or a loss of any kind arising from or connected with this inspection.

DATE: 3/30, 19 90 [Signature] NC 1231
Inspector's Signature National Board, State, Province and No.

Supplemental sheets in form of lists, sketches or drawing may be used provided (1) size is 8 1/2" X 11", (2) information in 1-2 on this Data Report is included on each sheet, and (3) each sheet is numbered and number of sheets is recorded in Item 3. "REMARKS"

FORM M-2 (back)

Items 4-8 incl., to be completed for single wall vessels, jacketed vessels, or shells of heat exchangers.

4. Shell: Material _____ T.S. _____ Nominal Thickness _____ in. Allowance _____ in. Dia. _____ ft. _____ in. Length _____ ft. _____ in.
(Kind & Spec. No.) (Min. of Range Specified)
5. Seams: Long _____ H.T. ¹ _____ R.T. _____ Efficiency _____ %
Girth _____ H.T. ¹ _____ R.T. _____ No. of Courses _____
6. Heads: (a) Material _____ T.S. _____ (b) Material _____ T.S. _____
Location (Top Bottom, Ends) Thickness _____ Crown Radius _____ Knuckle Radius _____ Elliptical Ratio _____ Conical Apex Angle _____ Hemispherical Radius _____ Flat Diameter _____ Side to Press. (conv. or conc.)
(a) _____
(b) _____
If removable, bolts used _____ Other fastening _____
(Material, Spec. No., T.S. Size Number) (Describe or attach sketch)
7. Jacket Closure: _____
(Describe as gage and weld, bar, etc. If bar give dimensions, if bolts, describe or sketch)
8. Design Pressure ² _____ psi at _____ °F Drop Weight _____
Charpy Impact _____ ft-lb
at temp. of _____ °F

Items 9 and 10 to be completed for tube sections.

9. Tube Sheets: Stationary Mat'l. _____ Dia. _____ Thickness _____ in. Attachment _____
(Kind of Spec. No.) (Subj. to Press.) (Welded, Bolted)
Floating. Material _____ Dia. _____ Thickness _____ in. Attachment _____
Inches
10. Tubes: Material _____ O.D. _____ in. Thickness _____ or gage. Number _____ Type _____
(Str. or U)

Items 11-14 incl., to be completed for inner chambers of jacketed vessels, or channels of heat exchangers.

11. Shell: Material _____ T.S. _____ Nominal Thickness _____ in. Allowance _____ in. Dia. _____ ft. _____ in. Length _____ ft. _____ in.
(Kind & Spec. No.) (Min. of Range Specified)
12. Seams: Long _____ H.T. ¹ _____ R.T. _____ Efficiency _____ %
Girth _____ H.T. ¹ _____ R.T. _____ No. of Courses _____
13. Heads: (a) Material _____ T.S. _____ (b) Material _____ T.S. _____
Location (a) Top, Bottom, Thickness _____ Crown Radius _____ Knuckle Radius _____ Elliptical Ratio _____ Conical Apex Angle _____ Hemispherical Radius _____ Flat Diameter _____ Side to Press. (Conv. or Conc.)
End _____
(b) Channel _____
If removable, bolts used (a) _____ (b) _____ (c) _____ Other fastening _____
(Describe or attach sketch)
Drop Weight _____
Charpy Impact _____ ft-lb
at temp. of _____ °F
14. Design pressure ² _____ psi at _____ °F

Items below to be completed for all vessels where applicable.

15. Safety Valve Outlets: Number _____ Size _____ Location _____
16. Nozzles:
Purpose (Inlet Outlet, Drain) Number Dia. or Size Type Material Thickness Reinforcement Material Attached
17. Inspection Openings: Manholes, No. _____ Size _____ Location _____
Handholes, No. _____ Size _____ Location _____
Threats, No. _____ Size _____ Location _____
18. Supports: Shirt _____ Lugs _____ Legs _____ Other _____ Attached _____
(Yes or No) (Number) (Number) (Describe) (Where & How)


¹ If Postweld Heat-Treated.

² List other internal or external pressure with coincident temperature when applicable.

1. Manufactured & Certified by: GE Company, 2117 Castle Hayne Rd., Wilmington, N.C. 28401
(Name and Address of NPT Certificate Holder)
- (a) Manufactured for: DUANE ARNOLD PALO, IOWA 52324
(Name and Address of N Certificate Holder for completed nuclear component)
2. Identification-Certificate Holders's S/N of Part: A8882 Nat'l Bd. N. N/A
- (a) Constructed According to Drawing No: 761E387G012 Dwg. Prepared by D. L. Peterson
- (b) Description of Part Inspected: CONTROL ROD DRIVE, MODEL # 7RDB144EG001
- (c) Applicable ASME Code: Section III, Edition 1974, Addenda Date W'75, Case No. 1361-2 Class N207

Sheet 2 of 2

1. Cap 167A2343P1
SA182-F304
5/8 thick x 1 1/16 OD
2. Indicator Tube 104B1336P3
SA312-TP316
1/4 sch 40-seamless pipe
.113 wall thickness
.065 max. dia.
3. Plug 159A1176P1
SA182-F304
1/4 thick x 0.812 OD
4. Flange 919D610P1 (719E474)
SA182-F304
.37 thick x 9 5/8 OD
5. Head 129B3539P3, P5
SA182-F304
2.0 OD x .884 ID
6. Ring Flange 114B5122P2
SA182-F304
1" thick x 5.0 OD x 1.75 ID
7. Cap Screw 117C4516P2
SA193-B6
6 ea. 1/2 dia. on 4 1/8 bolt circle
8. Plug 175A7961P1
SA182-F304
0.38 thick x 1.307 dia.
9. Plug 114B5460P1
SA193-B8A
1.30 thick x 2.62 dia.



FORM N-2 NPT CERTIFICATE HOLDERS' DATA REPORT FOR NUCLEAR PART AND APPURTENANCES
As required by the Provision of the ASME Code Rules, Section III, Div. I

1. Manufactured & Certified by: GE Company, 2117 Castle Hayne Rd., Wilmington, N.C. 2840
(b) Manufactured for: DUANE ARNOLD (Name and Address of NPT Certificate Holder)
PALO, IOWA 52324 (Name and Address of N Certificate Holder for completed nuclear compo)
2. Identification-Certificate Holders's S/N of Part: A2552 Nat'l Bd. No. N/
(a) Constructed According to Drawing No: 761E387G012 Dwg. Prepared by D. L. Pete
(b) Description of Part Inspected: CONTROL ROD DRIVE, MODEL # RDB144EG001
N207
(c) Applicable ASME Code: Section III, Edition 1974, Addenda Date W'75, Case No. 1361-2 CI
3. REMARKS: Standard part for use with Reactor. Hydrostatically tested at 1825 psi. min.
(Brief description of service for which component was designed)

Sheet 1 c

We certify that the statements in this report are correct and this vessel part or appurtenance as defined in the code conforms to the rules of construction of the ASME Code Section (The applicable Designed Specification and Stress Report are not the responsibility of the Certificate Holder for parts. An NPT Certification Holder for appurtenances is responsible for furnishing a separate Design Specification and Stress Report if the appurtenance is included in the component Design Specification and Stress Report).

DATE: 3/30, 19 90 Signed GE-NEEG-NF&OM-QA By [Signature]
(NPT Certificate Holder) (SCO-QA REPRESENTATIVE)

Certificate Of Authorization Expires: 6/16/90 Certification of Authorization No.: NPT N-

CERTIFICATION OF DESIGN FOR APPURTENANCES

Design information on file at GE COMPANY, SAN JOSE, CALIFORNIA
Stress analysis report on file at GE COMPANY, SAN JOSE, CALIFORNIA
DC22A6253 Rev. 0
Design specification certified by BJORN HAABERG Prof. Eng. State CALIF. Reg. No. 15
DC22A6254 Rev. 0.
Stress analysis report certified by EDWARD YOSHIO Prof. Eng. State CALIF. Reg. No. MO

CERTIFICATION OF SHOP INSPECTION

I, the undersigned, holding a valid commission by the National Board of Boiler and Pressure Vessel Inspectors and/or the State or Province of NORTH CAROLINA and employed by DEPARTMENT OF I of STATE OF NORTH CAROLINA have inspected the part of a pressure vessel described in Partial Data Report on 3/30 1990, and state that to the best of my knowledge and belief, the NPT Certificate Holder has constructed this part in accordance with the Code Section III.

By signing this certificate, neither the Inspector nor his employer makes any warranty expressed or implied, concerning the part described in the Partial Data Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damages or a loss of any kind arising from or connected with this inspection.

DATE 3/30, 1990 Inspector's Signature [Signature] NC 1231
National Board, State, Province and

Supplemental sheets in form of lists, sketches or drawing may be used provided (1) each sheet is 8-1/2" X 11", (2) information in 1-2 on this Data Report is included on each sheet, and (3) each sheet is numbered and number of sheets is recorded in Item 3. "REMARKS"

Items 4-8 incl. to be completed for single well vessels, jackets vessels, or shells of heat exchangers.

4. Shell: Material _____ T.S. _____ Nominal Thickness _____ in. Corrosion Allowance _____ in. Dia. _____ ft. _____ in. Length _____ ft. _____ in.
(Kind & Spec. No.) (Min. of Range Specified)

5. Seams: Long _____ H.T.¹ _____ R.T. _____ Efficiency _____ %
Girth _____ H.T.¹ _____ R.T. _____ No. of Courses _____

6. Heads: (a) Material _____ T.S. _____ (b) Material _____ T.S. _____
Location (Top Bottom, Ends) Thickness _____ Crown Radius _____ Knuckle Radius _____ Elliptical Ratio _____ Conical Apex Angle _____ Hemispherical Radius _____ Flat Diameter _____ Side to Press. (conv. or conc.)
(a) _____
(b) _____
If removable, bolts used _____ Other fastening _____
(Material, Spec. No., T.S. Size Number) (Describe or attach sketch)

7. Jacket Closure: _____
(Describe as open and weld, bar, etc. If bar give dimensions, if bolts, describe or sketch)

8. Design Pressure ² _____ psi at _____ °F Drop Weight _____
Charpy Impact _____ ft-lb
at temp. of _____ °F

Items 9 and 10 to be completed for tube sections.

9. Tube Sheet: Stationary Mat'l. _____ Dia. _____ Thickness _____ in. Attachment _____
(Kind of Spec. No.) (Subj. to Press.) (Welded, Bolted)
Floating. Material _____ Dia. _____ Thickness _____ in. Attachment _____
Inches

10. Tubes: Material _____ O.D. _____ in. Thickness _____ or gage. Number _____ Type _____
(Str. or U)

Items 11-14 incl. to be completed for inner chambers of jacketed vessels, or channels of heat exchangers

11. Shell: Material _____ T.S. _____ Nominal Thickness _____ in. Corrosion Allowance _____ in. Dia. _____ ft. _____ in. Length _____ ft. _____ in.
(Kind & Spec. No.) (Min. of Range Specified)

12. Seams: Long _____ H.T.¹ _____ R.T. _____ Efficiency _____ %
Girth _____ H.T.¹ _____ R.T. _____ No. of Courses _____

13. Heads: (a) Material _____ T.S. _____ (b) Material _____ T.S. _____
Location (a) Top, Bottom, Thickness _____ Crown Radius _____ Knuckle Radius _____ Elliptical Ratio _____ Conical Apex Angle _____ Hemispherical Radius _____ Flat Diameter _____ Side to Press. (Conv. or Conc.)
(b) Channel _____
If removable, bolts used (a) _____ (b) _____ (c) _____ Other fastening _____
(Describe or attach sketch)
Drop Weight _____
Charpy Impact _____ ft-lb
at temp. of _____ °F

14. Design pressure ² _____ psi at _____ °F

Items below to be completed for all vessels where applicable.

15. Safety Valve Outlet: Number _____ Size _____ Location _____

16. Nozzles:
Purpose (Inlet Outlet, Drain) Number Dia or Size Type Material Thickness Reinforcement Material Attached

Purpose (Inlet Outlet, Drain)	Number	Dia or Size	Type	Material	Thickness	Reinforcement Material	Attached
_____	_____	_____	_____	_____	_____	_____	_____
_____	_____	_____	_____	_____	_____	_____	_____

17. Inspection Openings: Manholes, No. _____ Size _____ Location _____
Hatches, No. _____ Size _____ Location _____
Threaded, No. _____ Size _____ Location _____

18. Support: Shirt _____ Lugs _____ Legs _____ Other _____ Attached _____
(Yes or No) (Number) (Number) (Describe) (Where & How)

¹ If Postweld Heat-Treated.

² List other internal or external pressure with coincident temperature when applicable.

FORM N-2 NPT CERTIFICATE HOLDERS' DATA REPORT FOR NUCLEAR PART AND APPURTENANCES
As required by the Provision of the ASME Code Rules, Section III, Div. I

Manufactured & Certified by: GE Company, 2117 Castle Hayne Rd., Wilmington, N.C. 2840

(Name and Address of NPT Certificate Holder)

(b) Manufactured for: DUANE ARNOLD PALO, IOWA 52324

(Name and Address of N Certificate Holder for completed nuclear component)

2. Identification-Certificate Holders's S/N of Part: A2552 Nat'l Bd. N. N/A

(a) Constructed According to Drawing No: 761E387G012 Dwg. Prepared by D. L. Peters

(b) Description of Part Inspected: CONTROL ROD DRIVE, MODEL # 7RDBL44EG001


N207

(c) Applicable ASME Code: Section III, Edition 1974, Addenda Date W'75, Case No. 1361-2 CI

Sheet 2 of 2

1. Cap 167A2343P1
SA182-F304
3/8 thick X 1 1/16 OD
2. Indicator Tube 104B1336P3
SA312-TP316
3/4 sch 40-seamless pipe
0.113 wall thickness
1.065 max. dia.
3. Plug 159A1176P1
SA182-F304
1/4 thick x 0.812 OD
4. Flange 919D610P1 (719E474)
SA182-F304
3.37 thick x 9 5/8 OD
5. Head 129B3539P3,P5
SA182-F304
3.0 OD x .884 ID
6. Ring Flange 114B5122P2
SA182-F304
1" thick x 5.0 OD x 1.75 ID
7. Cap Screw 117C4516P2
SA193-B6
6 ea. 1/2 dia. on 4 1/8 bolt circle
8. Plug 175A7961P1
SA182-F304
0.38 thick x 1.307 dia.
9. Nut 114B5460P1
SA193-B8A
1.30 thick x 2.62 dia.

CONTROL ROD DRIVE
DWG - 761E387



FORM N-2 NPT CERTIFICATE HOLDERS' DATA REPORT FOR NUCLEAR PART AND APPURTENANCES*
As required by the Provision of the ASME Code Rules, Section III, Div. I

Manufactured & Certified by: GE Company, 2117 Castle Hayne Rd., Wilmington, N.C. 28401
(Name and Address of NPT Certificate Holder)
() Manufactured for: Duane Arnold Palo, Iowa 52324
(Name and Address of N Certificate Holder for completed nuclear component)
2. Identification-Certificate Holders's S/N of Part: A3994 Nat'l Bd. No. N/A
(a) Constructed According to Drawing No: 761E387G012 Rev 21 Dwg. Prepared by D. L. Peter
(b) Description of Part Inspected: CONTROL ROD DRIVE, MODEL # 7RDB144EG001
(c) Applicable ASME Code: Section III, Edition 1974, Addenda Date W'75, Case No. 1361-2 Cla N207
3. REMARKS: Standard part for use with Reactor. Hydrostatically tested at 1825 psi. min.
(Brief description of service for which component was designed)

Sheet 1 of

We certify that the statements in this report are correct and this vessel part or appurtenance as defined in the code conforms to the rules of construction of the ASME Code Section III. (The applicable Designed Specification and Stress Report are not the responsibility of the Certificate Holder for parts. An NPT Certification Holder for appurtenances is responsible for furnishing a separate Design Specification and Stress Report if the appurtenance is included in the component Design Specification and Stress Report).

DATE 5/17, 19 90 Signed GE-NEEG-NF&CM-QA By [Signature]
(NPT Certificate Holder) (SCO-QA REPRESENTATIVE)

Certificate of Authorization Expires: 6/16/90 Certification of Authorization No.: NPT N-1

CERTIFICATION OF DESIGN FOR APPURTENANCE

Design information on file at GE COMPANY, SAN JOSE, CALIFORNIA
Stress analysis report on file at GE COMPANY, SAN JOSE, CALIFORNIA
DC2 A6253 Rev. 0
Design specification certified by BJORN HAABERG Prof. Eng. State CALIF. Reg. No. 155
DC2 A6254 Rev. 1
Stress analysis report certified by EDWARD YOSHIO Prof. Eng. State CALIF. Reg. No. M018

CERTIFICATION OF SHOP INSPECTION

I, the undersigned, holding a valid commission by the National Board of Boiler and Pressure Vessel Inspectors and/or the State or Province of NORTH CAROLINA and employed by DEPARTMENT OF LABOR of STATE OF NORTH CAROLINA have inspected the part of a pressure vessel described in the Partial Data Report on 5-17 1990, and state that to the best of my knowledge and belief, the NPT Certificate Holder has constructed this part in accordance with the ASME Code Section III.

In signing this certificate, neither the Inspector nor his employer makes any warranty expressed or implied, concerning the part described in the Partial Data Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damages or a loss of any kind arising from or connected with this inspection.

DATE 5-17, 1990 [Signature] National Board, State, Province and
Inspector's Signature

*Supplemental sheets in form of lists, sketches or drawing may be used provided (1) size is 8-1/2" X 11", (2) information in 1-2 on this Data Report is included on each sheet, and (3) each sheet is numbered and number of sheets is recorded in Item 3. "REMARKS"

FORM M-2 (back)

Items 4-8 incl. to be completed for single wall vessels, jacketed vessels, or shells of heat exchangers.

4. Shell: Material _____ T.S. _____ Nominal Thickness _____ in. Allowance _____ in. Dia. _____ ft. _____ in. Length _____ ft. _____ in.
(Kind & Spec. No.) (Min. or Range Specified)

5. Seams: Long _____ M.T.¹ _____ R.T. _____ Efficiency _____ %

6. Heads: (a) Material _____ T.S. _____ Girth _____ M.T.¹ _____ R.T. _____ No. of Courses _____
(b) Material _____ T.S. _____

Location (Top Bottom, Ends)	Thickness	Crown Radius	Knuckle Radius	Elliptical Ratio	Conical Apex Angle	Hemispherical Radius	Flat Diameter	Side to Press. (conv. or conc.)
(a) _____	_____	_____	_____	_____	_____	_____	_____	_____
(b) _____	_____	_____	_____	_____	_____	_____	_____	_____

If removable, bolts used _____ Other fastening _____
(Material, Spec. No., T.S. Size Number) (Describe or attach sketch)

7. Jacket Closures: _____
(Describe as open and weld, bar, etc. If bar give dimensions, if bolts, describe or sketch)

8. Design Pressure ² _____ psi at _____ °F Drop Weight _____
Charpy Impact _____ ft.-lb
at temp. of _____ °F

Items 9 and 10 to be completed for tube sections.

9. Tube Sheets: Stationary Mat'l. _____ Dia. _____ Thickness _____ in. Attachment _____
(Kind of Spec. No.) (Subj. to Press.) (Welded, Bolted)

Floating. Material _____ Dia. _____ Thickness _____ in. Attachment _____

10. Tubes: Material _____ O.D. _____ in. Thickness _____ in. or gage. Number _____ Type _____
(Str. or U)

Items 11-14 incl. to be completed for inner chambers of jacketed vessels, or channels of heat exchangers.

11. Shell: Material _____ T.S. _____ Nominal Thickness _____ in. Allowance _____ in. Dia. _____ ft. _____ in. Length _____ ft. _____ in.
(Kind & Spec. No.) (Min. or Range Specified)

12. Seams: Long _____ M.T.¹ _____ R.T. _____ Efficiency _____ %
Girth _____ M.T.¹ _____ R.T. _____ No. of Courses _____

13. Heads: (a) Material _____ T.S. _____ (b) Material _____ T.S. _____

Location (a) Top, Bottom, End	Thickness	Crown Radius	Knuckle Radius	Elliptical Ratio	Conical Apex Angle	Hemispherical Radius	Flat Diameter	Side to Press. (Conv. or Conc.)
(a) _____	_____	_____	_____	_____	_____	_____	_____	_____
(b) Channel	_____	_____	_____	_____	_____	_____	_____	_____

If removable, bolts used (a) _____ (b) _____ (c) _____ Other Fastening _____
(Describe or attach sketch)

Drop Weight _____
Charpy Impact _____ ft.-lb
at temp. of _____ °F

14. Design pressure ² _____ psi at _____ °F

Items below to be completed for all vessels where applicable.

15. Safety Valve Outlets: Number _____ Size _____ Location _____

16. Nozzles:

Purpose (Inlet Outlet, Drain)	Number	Dia or Size	Type	Material	Thickness	Reinforcement Material	Attached
_____	_____	_____	_____	_____	_____	_____	_____
_____	_____	_____	_____	_____	_____	_____	_____

17. Inspection Manholes, No. _____ Size _____ Location _____
Openings: Handhole, No. _____ Size _____ Location _____
Threaded, No. _____ Size _____ Location _____

18. Support: Skirt _____ Lugs _____ Legs _____ Other _____ Attached _____
(Yes or No) (Number) (Number) (Describe) (Where & How)

¹ If Postweld Heat-Treated.

² List other internal or external pressure with coincident temperature when applicable.

FORM N-2 NPT CERTIFICATE HOLDERS' DATA REPORT FOR NUCLEAR PART AND APPURTENANCES*
As required by the Provision of the ASME Code Rules, Section III, Div. I


Manufactured & Certified by: GE Company, 2117 Castle Hayne Rd., Wilmington, N.C. 28401
(Name and Address of NPT Certificate Holder)
Manufactured for: Duane Arnold Palo, Iowa 52324
(Name and Address of N Certificate Holder for completed nuclear component)

2. Identification-Certificate Holders's S/N of Part: A3994 Nat'l Bd. N. N/A
- (a) Constructed According to Drawing No: 761E387G012 Rev 21 Dwg. Prepared by D. L. Peter
- (b) Description of Part Inspected: CONTROL ROD DRIVE, MODEL # 7RDB144EG001
- (c) Applicable ASME Code: Section III, Edition 1974, Addenda Date W'75, Case No. 1361-2 Cla. N207

Sheet 2 of 2

1. Cap 167A2343P1
SA182-F304
3/8 thick x 1 1/16 OD
2. Indicator Tube 104B1336P3
SA312-TP316
1/4 sch 40-seamless pipe
.113 wall thickness
.065 max. dia.
3. Plug 159A1176P1
SA182-F304
1/4 thick x 0.812 OD
4. Flange 919D610P1 (719E474)
SA182-F304
3.37 thick x 9 5/8 OD
5. Head 129B3539P3,P5
SA182-F304
3.0 OD x .884 ID
6. Ring Flange 114B5122P2
SA182-F304
1 thick x 5.0 OD x 1.75 ID
7. Cap Screw 117C4516P2
S193-B6
6 ea. 1/2 dia. on 4 1/8 bolt circle
8. Plug 175A7961P1
SA182-F304
3/8 thick x 1.307 dia.
9. Nut 114B5460P1
SA193-B8A
1.30 thick x 2.62 dia.

CONTROL ROD DRIVE
DWG - 761E387



FORM N-2 NPT CERTIFICATE HOLDERS' DATA REPORT FOR NUCLEAR PART AND APPURTENANCE
As required by the Provision of the ASME Code Rules, Section III,

NCES*
I

1. Manufactured & Certified by: GE Company, 2117 Castle Hayne Rd., Wilmington, N.C. 28401
(b) Manufactured by: Duane Arnold (Name and Address of NPT Certificate Holder)
Palo, Iowa 52 (Name and Address of N Certificate Holder for completed nuclear component)
2. Identification-Certificate Holders's S/N of Part: A4286 Nat'l Bd. No. N/A
(a) Constructed According to Drawing No: 761E387G012 Rev 21 Dwg. Prepared by D. Peters
(b) Description of Part Inspected: CONTROL ROD DRIVE, MODEL # 7ROB144EG001
(c) Applicable ASME Code: Section III, Edition 1974, Addenda Date W'75, Case No. 1 2 Class
3. REMARKS: Standard part for use with Reactor. Hydrostatically tested at 1825 psi.
Chief description of service for which component was designed.

We certify that the statements in this report are correct and this vessel part or appurtenance conforms to the rules of construction of the ASME Code. The applicable Design Specification and Stress Report are not the responsibility of the NPT Certificate Holder for parts. An NPT Certificate Holder for appurtenances is responsible for furnishing a separate Design Specification and Stress Report if the appurtenance is included in the component Design Specification and Stress Report). 1 of 2

DATE: 5/29, 19 90 Signed GE-NEEG-NF&OM-QA By [Signature] (NPT Certificate Holder) SCOPE REPRESENTATIVE

Certificate of Authorization Expires: 6/16/90 Certification of Authorization No.: N-11

CERTIFICATION OF DESIGN FOR APPURTENANCE

Design information on file at GE COMPANY, SAN JOSE, CALIFORNIA
Stress analysis report on file at GE COMPANY, SAN JOSE, CALIFORNIA
DC22A6253 Rev. 0
Design specification certified by BJORN HAABERG Prof. Eng. State CALIF. Reg. 15570
DC22A6254 Rev. 1
Stress analysis report certified by EDWARD YOSHIO Prof. Eng. State CALIF. Reg. M0186

CERTIFICATION OF SHOP INSPECTION

I, the undersigned, holding a valid commission by the National Board of Boiler and Pressure Vessels Inspectors and/or the State or Province of NORTH CAROLINA and employed by DEPARTMENT OF LABOR of STATE OF NORTH CAROLINA have inspected the part of a pressure vessel described in this Partial Data Report as 5-29 1990, and state that to the best of my knowledge and belief, the NPT Certificate Holder has constructed this part in accordance with the ASME Code Section III.
By signing this certificate, neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the part described in the Partial Data Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damages or a loss of any kind arising from or connected with this inspection.

DATE 5-29, 19 90 [Signature] N.C. 123/
Inspector's Signature National Board, State, Province and No.

Supplemental sheets in form of lists, sketches or drawing may be used provided (1) sheet is 3-1/2" X 11", (2) information in 1-2 on this Data Report is included on each sheet, and (3) each sheet is numbered and number of sheets is recorded in Item 3. "REMARKSs"

FORM M-2 (back)

Items 4-8 incl. to be completed for single wall vessels, jacketed vessels, or shells of heat exchangers.

4. Shell: Material _____ T.S. _____ Nominal Thickness _____ in. Allowance _____ in. Dia. _____ ft. _____ in. Length _____ ft. _____ in.
(Kind & Spec. No.) (Min. of Range Specified)

5. Seams: Long _____ M.T.¹ _____ R.T. _____ Efficiency _____ %

6. Heads: (a) Material _____ T.S. _____ Girth _____ M.T.¹ _____ R.T. _____ No. of Courses _____
(b) Material _____ T.S. _____

Location (Top Bottom, End) Thickness Crown Radius Knuckle Radius Elliptical Ratio Conical Apex Angle Hemispherical Radius Flat Diameter Side to Press. (conv. or conc.)

(a) _____

(b) _____

If removable, bolts used _____ Other fastening _____
(Material, Spec. No., T.S. Size Number) (Describe or attach sketch)

7. Jacket Closure: _____
(Describe as gage and weld, bar, etc. If bar give dimensions, if bolts, describe or sketch)

8. Design Pressure ² _____ psi at _____ °F Drop Weight _____
Charpy Impact _____ ft.-lb
at temp. of _____ °F

Items 9 and 10 to be completed for tube sections.

9. Tube Sheets: Stationary Mat'l. _____ Dia. _____ Thickness _____ in. Attachment _____
(Kind of Spec. No.) (Subj. to Press.) (Welded, Bolted)
Floating. Material _____ Dia. _____ Thickness _____ in. Attachment _____

10. Tubes: Material _____ O.D. _____ in. Thickness _____ or gage. Number _____ Type _____
(Str. or U)

Items 11-14 incl. to be completed for inner chambers of jacketed vessels, or channels of heat exchangers.

11. Shell: Material _____ T.S. _____ Nominal Thickness _____ in. Allowance _____ in. Dia. _____ ft. _____ in. Length _____ ft. _____ in.
(Kind & Spec. No.) (Min. of Range Specified)

12. Seams: Long _____ M.T.¹ _____ R.T. _____ Efficiency _____ %
Girth _____ M.T.¹ _____ R.T. _____ No. of Courses _____

13. Heads (a) Material _____ T.S. _____ (b) Material _____ T.S. _____
Location Thickness Crown Radius Knuckle Radius Elliptical Ratio Conical Apex Angle Hemispherical Radius Flat Diameter Side to Press. (Conv. or Conc.)

(a) Top, Bottom, End _____

(b) Channel _____

If removable, bolts used (a) _____ (b) _____ (c) _____ Other Fastening _____

(Describe or attach sketch)

Drop Weight _____

Charpy Impact _____ ft.-lb

at temp. of _____ °F

14. Design pressure ² _____ psi at _____ °F

Items below to be completed for all vessels where applicable.

15. Safety Valve Outlets: Number _____ Size _____ Location _____

16. Nozzles:
Purpose (Inlet Outlet, Drain) Number Dia or Size Type Material Thickness Reinforcement Material Attached

17. Inspection Manholes, No. _____ Size _____ Location _____
Openings: Handles, No. _____ Size _____ Location _____
Threaded, No. _____ Size _____ Location _____

18. Supports: Shirt _____ Legs _____ Legs _____ Other _____ Attached _____
(Yes or No) (Number) (Number) (Describe) (Where & How)

¹ If Postweld Heat-Treated.

² List other internal or external pressure with coincident temperature when applicable.

FORM N-2 NPT CERTIFICATE HOLDERS' DATA REPORT FOR NUCLEAR PART A
As required by the Provision of the ASME Code Rules, Sect.

MAINTENANCES
I, Div. I

Manufactured & Certified by: GE Company, 2117 Castle Hayne Rd., Wilmi.

N.C. 284

(b) Manufactured for: Duane Arnold (Name and Address of NPT Certificate Holder)
Palo, Iowa

52324

Name and Address of N Certificate Holder for complete clear compo (t)

2. Identification-Certificate Holders's S/N of Part: A4286 Name: D. N. N/A

(a) Constructed According to Drawing No: 761E387G012 Rev 21 Dwg. Prepared: D. L. Pete

(b) Description of Part Inspected: CONTROL ROD DRIVE, MODEL # 7RDB144EG

N207

(C) Applicable ASME Code: Section III, Edition 1974, Addenda Date W'75, Case 1361-2 Cl 1

Sheet 2 of 2

1. Cap 167A2343P1
SA182-F304
3/8 thick x 1 1/16 OD

2. Indicator Tube 104B1336P3
SA312-TP316
3/4 sch 40-seamless pipe
0.113 wall thickness
1.065 max. dia.

3. Plug 159A1176P1
SA182-F304
1/4 thick x 0.812 ID

4. Flange 919D610P1 (719E474)
SA182-F304
3.37 thick x 9 5/8 OD

5. Head 129B3539P3,P5
SA182-F304
3.0 OD x .884 ID


6. Ring Flange 114B5122P2
SA182-F304
1" thick x 5.0 OD x 1.75 ID

7. Cap Screw 117C4516P2
SA193-B6
6 ea. 1/2 dia. on 1 1/8 bolt circle

8. Plug 175A7961P1
SA182-F304
0.38 thick x 1.307 dia.

9. Nut 114B5460P1
SA193-B8A
1.30 thick x 2.62 dia.

CONTROL ROD DRIVE
DWG - 761E387G012



FORM N-2 NPT CERTIFICATE HOLDERS' DATA REPORT FOR NUCLEAR PART AND APPURTENANCES*
As required by the Provision of the ASME Code Rules, Section III, Div. I

1. Manufactured & Certified by: GE Company, 2117 Castle Hayne Rd., Wilmington, N.C. 28401
(Name and Address of NPT Certificate Holder)
Manufactured for: DUANE ARNOLD PALO, IOWA 52324
(Name and Address of N Certificate Holder for completed nuclear component)
2. Identification-Certificate Holders's S/N of Part: A4619 Nat'l Bd. No. N/A
- (a) Constructed According to Drawing No: 76LE387G012 Dwg. Prepared by D. L. Peterso
- (b) Description of Part Inspected: CONTROL ROD DRIVE, MODEL # 7RDB144EG001
N207
- (c) Applicable ASME Code: Section III, Edition 1974, Addenda Date W'75, Case No. 1361-2 Class
3. REMARKS: Standard part for use with Reactor. Hydrostatically tested at 1825 psi. min.
(Brief description of service for which component was designed)

Sheet 1 of 2

We certify that the statements in this report are correct and this vessel part or appurtenance as defined in the code conforms to the rules of construction of the ASME Code Section II (The applicable Designed Specification and Stress Report are not the responsibility of the NPT Certificate Holder for parts. An NPT Certification Holder for appurtenances is responsible for furnishing a separate Design Specification and Stress Report if the appurtenance is not included in the component Design Specification and Stress Report).

DATE: 3/30, 19 90 Signed GE-NEEG-NF&CM-QA By J. J. J. J.
(NPT Certificate Holder) (SCO-QA REPRESENTATIVE)

Certificate Of Authorization Expires: 6/16/90 Certification of Authorization No.: NPT N-115

CERTIFICATION OF DESIGN FOR APPURTENANCE

Design information on file at GE COMPANY, SAN JOSE, CALIFORNIA

Stress analysis report on file at GE COMPANY, SAN JOSE, CALIFORNIA

DC22A6253 Rev. 0

Design specification certified by BJORN HAABERG Prof. Eng. State CALIF. Reg. No. 15570

DC22A6254 Rev. 0.

Stress analysis report certified by EDWARD YOSHIO Prof. Eng. State CALIF. Reg. No. M0186

CERTIFICATION OF SHOP INSPECTION

I, the undersigned, holding a valid commission by the National Board of Boiler and Pressure Inspectors and/or the State or Province of NORTH CAROLINA and employed by DEPARTMENT OF LABOR of STATE OF NORTH CAROLINA have inspected the part of a pressure vessel described in this Partial Data Report on 3/30 1990, and state that to the best of my knowledge and belief, the NPT Certificate Holder has constructed this part in accordance with the ASME Code Section III.

By signing this certificate, neither the Inspector nor his employer makes any warranty expressed or implied, concerning the part described in the Partial Data Report. Furthermore neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damages or a loss of any kind arising from or connected with this inspection.

DATE 3/30, 1990 Inspector's Signature James P. Evans NC 1231
National Board, State, Province and N

*Supplemental sheets in form of lists, sketches or drawing may be used provided (1) size is "X 11", (2) information in 1-2 on this Data Report is included on each sheet, and (3) each sheet is numbered and number of sheets is recorded in Item 3. "REMARKS"

FORM M-2 (back)

Items 4-8 incl., to be completed for single wall vessels, jacketed vessels, or shells of heat exchangers.

4. Shell: Material _____ T.S. _____ Nominal Thickness _____ in. Allowance _____ in. Dis. _____ ft. _____ in. Length _____ ft. _____ in.
(Kind & Spec. No.) (Min. of Range Specified)
5. Seams: Long _____ H.T.¹ _____ R.T. _____ Efficiency _____ %
Girth _____ H.T.¹ _____ R.T. _____ No. of Courses _____
6. Heads: (a) Material _____ T.S. _____ (b) Material _____ T.S. _____
Location (Top Bottom, End) Thickness _____ Crown Radius _____ Knuckle Radius _____ Elliptical Ratio _____ Conical Apex Angle _____ Hemispherical Radius _____ Flat Diameter _____ Side to Press. (conv. or conc.)
(a) _____
(b) _____
If removable, bolts used _____ Other Fastening _____
(Material, Spec. No., T.S. Size Number) (Describe or attach sketch)
7. Jacket Closure: _____
(Describe as gage and weld, bar, etc. If bar give dimensions, if bolts, describe or sketch)
8. Design Pressure ² _____ psi at _____ °F Drop Weight _____
Charpy Impact _____ ft-lb
at temp. of _____ °F

Items 9 and 10 to be completed for tube sections.

9. Tube Sheet: Stationary Mat'l. _____ Dis. _____ Thickness _____ in. Attachment _____
(Kind of Spec. No.) (Subj. to Press.) (Welded, Bolted)
Floating. Material _____ Dis. _____ Thickness _____ in. Attachment _____
Inches
10. Tubes: Material _____ O.D. _____ in. Thickness _____ or gage. Number _____ Type _____
(Str. or U)

Items 11-14 incl., to be completed for inner chambers of jacketed vessels, or channels of heat exchangers.

11. Shell: Material _____ T.S. _____ Nominal Thickness _____ in. Allowance _____ in. Dis. _____ ft. _____ in. Length _____ ft. _____ in.
(Kind & Spec. No.) (Min. of Range Specified)
12. Seams: Long _____ H.T.¹ _____ R.T. _____ Efficiency _____ %
Girth _____ H.T.¹ _____ R.T. _____ No. of Courses _____
13. Heads (a) Material _____ T.S. _____ (b) Material _____ T.S. _____
Location (a) Top, Bottom, Thickness _____ Crown Radius _____ Knuckle Radius _____ Elliptical Ratio _____ Conical Apex Angle _____ Hemispherical Radius _____ Flat Diameter _____ Side to Press. (Conv. or Conc.)
(b) Channel _____
If removable, bolts used (a) _____ (b) _____ (c) _____ Other Fastening _____
(Describe or attach sketch)
14. Design pressure ² _____ psi at _____ °F Drop Weight _____
Charpy Impact _____ ft-lb
at temp. of _____ °F

Items below to be completed for all vessels where applicable.

15. Safety Valve Outlets: Number _____ Size _____ Location _____
16. Nozzles:
Purpose (Inlet Outlet, Drain) Number Dis. or Size Type Material Thickness Reinforcement Material Attached
17. Inspection Manholes, No. _____ Size _____ Location _____
Openings: Handles, No. _____ Size _____ Location _____
Threaded, No. _____ Size _____ Location _____
18. Supports: Shirt _____ Lugs _____ Legs _____ Other _____ Attached _____
(Yes or No) (Number) (Number) (Describe) (Where & How)

¹ If Postweld Heat-Treated.


² List other internal or external pressure with coincident temperature when applicable.

FORM N-2 NPT CERTIFICATE HOLDERS' DATA REPORT FOR NUCLEAR PART AND APPURTENANCES*
As required by the Provision of the ASME Code Rules, Section III, Div. I

- .. Manufactured & Certified by: GE Company, 2117 Castle Hayne Rd., Wilmington, N.C. 28401
(Name and Address of NPT Certificate Holder)
- Manufactured for: DUANE ARNOLD PALO, IOWA 52324
(Name and Address of N Certificate Holder for completed nuclear component)
2. Identification-Certificate Holders's S/N of Part: A4619 Nat'l Bd. N. N/A
- (a) Constructed According to Drawing No: 76LE387G012 Dwg. Prepared by D. L. Peterson
- (b) Description of Part Inspected: CONTROL ROD DRIVE, MODEL # 7RDBL44EG001 N207
- (c) Applicable ASME Code: Section III, Edition 1974, Addenda Date W'75, Case No. 1361-2 Class.

Sheet 2 of 2

1. Cap 167A2343P1
SA182-F304
3/8 thick x 1 1/16 OD
2. Indicator Tube 104B1336P3
SA312-TP316
3/4 sch 40-seamless pipe
0.113 wall thickness
0.65 max. dia.
3. Plug 159A1176P1
SA182-F304
1/4 thick x 0.812 OD
4. Flange 919D610P1 (719E474)
SA182-F304
3.37 thick x 9 5/8 OD
5. Head 129B3539P3,P5
SA182-F304
3.0 OD x .884 ID
6. Ring Flange 114B5122P2
SA182-F304
1" thick x 5.0 OD x 1.75 ID
7. Cap Screw 117C4516P2
SA193-B6
6 ea. 1/2 dia. on 4 1/8 bolt circle
8. Plug 175A7961P1
SA182-F304
0.38 thick x 1.307 dia.
9. Plug 114B5460P1
SA193-B8A
1.30 thick x 2.62 dia.



FORM N-2 NPT CERTIFICATE HOLDERS' DATA REPORT FOR NUCLEAR PART AND APPURTENANCES
As required by the Provision of the ASME Code Rules, Section III, Div. I

1. Manufactured & Certified by: GE Company, 2117 Castle Hayne Rd., Wilmington, N.C. 2840
(Name and Address of NPT Certificate Holder)
(b) Manufactured for: DUANE ARNOLD PALO, IOWA 52324
(Name and Address of N Certificate Holder for completed nuclear component)
2. Identification-Certificate Holders's S/N of Part: A5075 Nat'l Bd. No. N/
(a) Constructed According to Drawing No: 76LE387G012 Dwg. Prepared by D. L. Pete
(b) Description of Part Inspected: CONTROL ROD DRIVE, MODEL # 7RDBL44EG001
(c) Applicable ASME Code: Section III, Edition 1974, Addenda Date W'75, Case No. 1361-2 CL N207
3. REMARKS: Standard part for use with Reactor. Hydrostatically tested at 1825 psi. min.
(Brief description of service for which component was designed)

Sheet 1 of

We certify that the statements in this report are correct and this vessel part or appurtenance as defined in the code conforms to the rules of construction of the ASME Code Section III. (The applicable Designed Specification and Stress Report are not the responsibility of the Certificate Holder for parts. An NPT Certificate Holder for appurtenances is responsible for furnishing a separate Design Specification and Stress Report if the appurtenance is included in the component Design Specification and Stress Report).

DATE: 3/30, 19 90 Signed GE-NEEG-NF&CM-QA By J. J. Jones
(NPT Certificate Holder) (SCO-QA REPRESENTATIVE)

Certificate of Authorization Expires: 6/16/90 Certification of Authorization No.: NPT N-

CERTIFICATION OF DESIGN FOR APPURTENANCE

Design information on file at GE COMPANY, SAN JOSE, CALIFORNIA
Stress analysis report on file at GE COMPANY, SAN JOSE, CALIFORNIA
DC22 5253 Rev. 0
Design specification certified by BJORH HAABERG Prof. Eng. State CALIF. Reg. No. 151
DC22 5254 Rev. 0.
Stress analysis report certified by EDWARD YOSHIO Prof. Eng. State CALIF. Reg. No. MO1

CERTIFICATION OF SHOP INSPECTION

I, the undersigned, holding a valid commission by the National Board of Boiler and Pressure Vessels Inspectors and/or the State or Province of NORTH CAROLINA and employed by DEPARTMENT OF LABOR of STATE OF NORTH CAROLINA have inspected the part of a pressure vessel described in the Partial Data Report on 3/30 1990, and state that to the best of my knowledge and belief, the NPT Certificate Holder has constructed this part in accordance with the ASME Code Section III.

By signing this certificate, neither the Inspector nor his employer makes any warranty expressed or implied, concerning the part described in the Partial Data Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damages or a loss of any kind arising from or connected with this inspection.

DATE 3/30, 1990 Inspector's Signature James P. Evans National Board, State, Province and NC 1231

Supplemental sheets in form of lists, sketches or drawing may be used provided (1) is 11" X 11", (2) information in 1-2 on this Data Report is included on each sheet, (3) each sheet is numbered and number of sheets is recorded in Item 3. "REMARKS"

FORM H-2 (back)

Items 4-8 incl. to be completed for single wall vessels, jacketed vessels, or shells of heat exchangers.

4. Shell: Material T.S. Thickness in. Allowance in. Dia. ft. in. Length ft. in.
(Kind & Spec. No.) (Min. of Range Specified)

5. Seams: Long H.T. R.T. Efficiency %
Girth H.T. R.T. No. of Courses

6. Heads: (a) Material T.S. (b) Material T.S.
Location (Top Bottom, Ends) Thickness Crown Radius Knuckle Radius Elliptical Ratio Conical Apex Angle Hemispherical Radius Flat Diameter Side to Press. (conv. or conc.)
(a)
(b)
If removable, bolts used Other fastening
(Material, Spec. No., T.S. Size Number) (Describe or attach sketch)

7. Jacket Closure:
(Describe as open and weld, bolt, etc. If bolt give dimensions, if bolts, describe or sketch)

8. Design Pressure ² 1250 psi at 575 °F Drop Weight
Charpy Impact ft.-lb at temp. of °F

Items 9 and 10 to be completed for tube sections.

9. Tube Sheets: Stationary Mat'l. Dia. Thickness in. Attachment
(Kind of Spec. No.) (Subj. to Press.) (Welded, Bolted)
Floating. Material Dia. Thickness in. Attachment
 inches

10. Tubes: Material O.D. in. Thickness or gage. Number Type
(Str. or U)

Items 11-14 incl. to be completed for inner chambers of jacketed vessels, or channels of heat exchangers

11. Shell: Material T.S. Thickness in. Allowance in. Dia. ft. in. Length ft. in.
(Kind & Spec. No.) (Min. of Range Specified)

12. Seams: Long H.T. R.T. Efficiency %
Girth H.T. R.T. No. of Courses

13. Heads: (a) Material T.S. (b) Material T.S.
Location (a) Top, Bottom, Thickness Crown Radius Knuckle Radius Elliptical Ratio Conical Apex Angle Hemispherical Radius Flat Diameter Side to Press. (Conv. or Conc.)
End
(b) Channel
If removable, bolts used (a) (b) (c) Other Fastening
(Describe or attach sketch)

14. Design pressure ² psi at °F Drop Weight
Charpy Impact ft.-lb at temp. of °F

Items below to be completed for all vessels where applicable.

15. Safety Valve Outlets: Number Size Location

16. Nozzles:
Purpose (Inlet Outlet, Drain) Number Dia or Size Type Material Thickness Reinforcement Material Attached

17. Inspection Openings: Manholes, No. Size Location
Handles, No. Size Location
Threaded, No. Size Location

18. Supports: Shirt Legs Legs Other Attached
(Yes or No) (Number) (Number) (Describe) (Where & How)

¹ If Postweld Heat-Treated.

² List other internal or external pressure with coincident temperature when applicable.


FORM N-2 NPT CERTIFICATE HOLDERS' DATA REPORT FOR NUCLEAR PART AND APPURTENANCES*
As required by the Provision of the ASME Code Rules, Section III, Div. I

1. Manufactured & Certified by: GE Company, 2117 Castle Hayne Rd., Wilmington, N.C. 2840
(Name and Address of NPT Certificate Holder)
(b) Manufactured for: DUANE ARNOLD PALO, IOWA 52324
(Name and Address of N Certificate Holder for completed nuclear component)
2. Identification-Certificate Holders's S/N of Part: A5075 Nat'l Bd. N. N/A
- (a) Constructed According to Drawing No: 761E387G012 Dwg. Prepared by D. L. Peter
- (b) Description of Part Inspected: CONTROL ROD DRIVE, MODEL # 7RDB144EG001 N207
- (c) Applicable ASME Code: Section III, Edition 1974, Addenda Date W'75, Case No. 1361-2 Cl.

Sheet 2 of 2

1. Cap 167A2343P1
SA182-F304
1/8 thick x 1 1/16 OD
2. Indicator Tube 104B1336P3
SA312-TP316
1/4 sch 40-seamless pipe
.113 wall thickness
.065 max. dia.
3. Plug 159A1176P1
SA182-F304
1/4 thick x 0.812 OD
4. Flange 919D610P1 (719E474)
SA182-F304
1/37 thick x 9 5/8 OD
5. Head 129B3539P3, P5
SA182-F304
2.0 OD x .884 ID
6. Ring Flange 114B5122P2
SA182-F304
1/2 thick x 5.0 OD x 1.75 ID
7. Cap Screw 117C4516P2
SA193-B6
6 ea. 1/2 dia. on 4 1/8 bolt circle
8. Plug 175A7961P1
SA182-F304
0.38 thick x 1.307 dia.
9. Nut 114B5460P1
SA193-B8A
1.30 thick x 2.62 dia.

CONTROL ROD DRIVE
DWG - 761E387



FORM N-2 NPT CERTIFICATE HOLDERS' DATA REPORT FOR NUCLEAR PART AND APPURTENANCES
As required by the Provision of the ASME Code Rules, Section III, Div. I

Manufactured & Certified by: GE Company, 2117 Castle Hayne Rd., Wilmington, N.C. 28401
(b) Manufactured for: Duane Arnold (Name and Address of NPT Certificate Holder)
Palo, Iowa 52224
(Name and Address of N Certificate Holder for completed nuclear component)
Identification-Certificate Holders's S/N of Part: A4018 Nat'l Bd. No. N/
(a) Constructed According to Drawing No: 761E387G012 Rev 21 Dwg. Prepared by D. L. Peterson
(b) Description of Part Inspected: CONTROL ROD DRIVE, MODEL # 7RDB144EG001
(c) Applicable ASME Code: Section III, Edition 1974, Addenda Date W'75, Case No. 1361-2 Class 1
REMARKS: Standard part for use with Reactor. Hydrostatically tested at 1825 psi. min.
(Brief description of service for which component was designed)

Sheet 1 of 2

I certify that the statements in this report are correct and this vessel part or appurtenance defined in the code conforms to the rules of construction of the ASME Code Section III. The applicable Designed Specification and Stress Report are not the responsibility of the NPT Certificate Holder for parts. An NPT Certification Holder for appurtenances is responsible for furnishing a separate Design Specification and Stress Report if the appurtenance is not included in the component Design Specification and Stress Report).

FE: 5/29, 19 90 Signed GE-NEEG-NF&OM-QA By [Signature]
(NPT Certificate Holder) SCS-QA REPRESENTATIVE
Certificate of Authorization Expires: 6/16/90 Certification of Authorization No.: NPT N-1361

CERTIFICATION OF DESIGN FOR APPURTENANCE

Design information on file at GE COMPANY, SAN JOSE, CALIFORNIA
Stress analysis report on file at GE COMPANY, SAN JOSE, CALIFORNIA
22A6253 Rev. 0
Design specification certified by BJORN HAABERG Prof. Eng. State CALIF. Reg. No. 158
22A6254 Rev. 1
Stress analysis report certified by EDWARD YOSHIO Prof. Eng. CALIF. Reg. No. MO1546

CERTIFICATION OF SHOP INSPECTION

I, the undersigned, holding a valid commission by the National Board of Boiler and Pressure Vessel Inspectors and/or the State or Province of NORTH CAROLINA and employed by DEPARTMENT OF LABOR, STATE OF NORTH CAROLINA have inspected the part of a pressure vessel described in the Partial Data Report on 5-27 1990, and state that to the best of my knowledge and belief, the NPT Certificate Holder has constructed this part in accordance with the ASME Code Section III.
By signing this certificate, neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the part described in the Partial Data Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury, property damages or a loss of any kind arising from or connected with this inspection.

5-29, 1990 Duane P. Evers NC 1231
Inspector's Signature National Board, State, Province and Country

Supplemental sheets in form of lists, sketches or drawing may be used provided (1) size is 8 1/2" x 11", (2) information in 1-2 on this Data Report is included on each sheet and (3) sheet is numbered and number of sheets is recorded in Item 3. "REMARKS"

FORM M-2 (back)

Items 4-8 incl. to be completed for single wall vessels, jacketed vessels, or shells of heat exchangers.

4. Shell: Material T.S. Thickness in. Allowance in. Dia. ft. in. Length ft. in.
(Kind & Spec. No.) (Min. of Range Specified)
5. Seams: Long M.T.¹ R.T. Efficiency %
Girth M.T.¹ R.T. No. of Courses
6. Heads: (a) Material T.S. (b) Material T.S.
Location (Top Bottom, End) Thickness Crown Radius Knuckle Radius Elliptical Ratio Conical Apex Angle Hemispherical Radius Flat Diameter Side to Press. (conv. or conc.)
(e)
(b)
If removable, bolts used Other fastening
(Material, Spec. No., T.S. Size Number) (Describe or attach sketch)
7. Jacket Closure:
(Describe as open end weld, bor, etc. If bor give dimensions, if bolts, describe or sketch)
8. Design Pressure: 2 1250 psi at 575 °F Drop Weight
Charpy Impact ft-lb
at temp. of °F

Items 9 and 10 to be completed for tube sections.

9. Tube Sheets: Stationary Mat'l. Dia. Thickness in. Attachment
(Kind of Spec. No.) (Subj. to Press.) (Welded, Bolted)
Floating. Material Dia. Thickness in. Attachment
Inches
10. Tubes: Material O.D. in. Thickness or gage. Number Type
(Str. or U)

Items 11-16 incl. to be completed for inner chambers of jacketed vessels, or channels of heat exchangers.

11. Shell: Material T.S. Thickness in. Allowance in. Dia. ft. in. Length ft. in.
(Kind & Spec. No.) (Min. of Range Specified)
12. Seams: Long M.T.¹ R.T. Efficiency %
Girth M.T.¹ R.T. No. of Courses
13. Heads (a) Material T.S. (b) Material T.S.
Location (a) Top, Bottom, End (b) Channel
Thickness Crown Radius Knuckle Radius Elliptical Ratio Conical Apex Angle Hemispherical Radius Flat Diameter Side to Press. (Conv. or Conc.)
(a)
(b)
If removable, bolts used (a) (b) (c) Other fastening
(Describe or attach sketch)
14. Design pressure: psi at °F Drop Weight
Charpy Impact ft-lb
at temp. of °F

Items below to be completed for all vessels where applicable.

15. Safety Valve Outlets: Number Size Location
16. Nozzles:
Purpose (Inlet Outlet, Drain) Number Dia or Size Type Material Thickness Reinforcement Material Attached
17. Inspection Openings:
Welded, No. Size Location
Handled, No. Size Location
Threaded, No. Size Location
18. Supports:
(Type or No) (Number) (Number) (Describe) (Where & How)
- ¹ If Postweld Heat-Treated.
- ² List other internal or external pressure with coincident temperature when applicable.

Manufactured & Certified by: GE Company, 2117 Castle Hayne Rd., Wilmington, N.C. 28
(b) Manufactured for: Duane Arnold Palo, Iowa 52324
Name and Address of N Certificate Holder for completed nuclear com

(b) Manufactured for: Duane Arnold Palo, Iowa 52324
(Name and Address of N Certificate Holder for completed nuclear com.)

Name and Address of N Certificate Holder for completed nuclear comp.

Identification-Certificate Holders's S/N of Part: A4018 Nat'l Bd. N. N.


Identification-Certificate Holders's S/N of Part: A4018 Nat'l Bd. N. N/
(a) Constructed According to Drawing No: 761E387G012 Rev 21 Dwg. Prepared by D. L. Pet

a) Constructed According to Drawing No: 761E387G012 Rev 21 Dwg. Prepared by D. L. Pet
b) Description of Part Inspected: CONTROL ROD DRIVE, MODEL # 7RDB144EG001

b) Description of Part Inspected: CONTROL ROD DRIVE, MODEL # 7RDB144EG001

c) Applicable ASME Code: Section III, Edition 1974, Addenda Date W'75, Case No. 1361-2 C

1. Cap 167A2343P1
SA182-F304
3/8 thick x 1 1/16 OD
2. Indicator Tube 104B1336P3
SA312-TP316
3/4 sch 40-seamless pipe
3 wall thickness
5 max. dia.
- Plug 159A1176P1
SA182-F304
1/4 thick x 0.812 OD
- Flange 919D610P1.(719E474)
SA182-F304
3.37 thick x 9 5/8 OD
- Head 129B3539P3,P5
SA182-F304
3.0 OD x .884 ID
- Ring Flange 114B5122P2
SA182-F304
1" thick x 5.0 OD x 1.75 ID
- Cap Screw 117C4516P2
SA193-B6
6 ea. 1/2 dia. on 1 1/8 bolt circle
- Plug 175A7961P1
SA182-F304
0.38 thick x 1.307 dia.
- Plug 14B5460P1
SA193-B8A
1.30 thick x 2.62 dia.



FORM N-2 NPT CERTIFICATE HOLDERS' DATA REPORT FOR NUCLEAR PART AND APPURTENANCE
As required by the Provision of the ASME Code Rules, Section III, Div. 1

1. Manufactured & Certified by: GE Company, 2117 Castle Hayne Rd., Wilmington, N.C. 284
(Name and Address of NPT Certificate Holder)
(1) Manufactured for: DUANE ARNOLD PALO, IOWA 324
(Name and Address of N Certificate Holder for completed nuclear component)
2. Identification-Certificate Holders's S/N of Part: A4549 Part's Bd. No. N
(a) Constructed According to Drawing No: 76LE387G012 Dwg. Prepared by D. L. Peterson
(b) Description of Part Inspected: CONTROL ROD DRIVE, MODEL # 7-8144EG001
(c) Applicable ASME Code: Section III, Edition 1974, Addenda Date W'75, Case No. 1361-2 C
3. REMARKS: Standard part for use with Reactor. Hydrostatically tested at 1825 psi. min.
(Brief description of service for which component was designed)

We certify that the statements in this report are correct and this vessel part or appurtenance as defined in the code conforms to the rules of construction of the ASME Code Section III. (The applicable Designed Specification and Stress Report are not the responsibility of the Certificate Holder for parts. An NPT Certification Holder for appurtenances is responsible for furnishing a separate Design Specification and Stress Report if the appurtenance is included in the component Design Specification and Stress Report).

DATE: 3/30, 19 90 Signed GE-NEEG-NF&CM-QA By J. J. DeLo
(NPT Certificate Holder) (SCO-1A REPRESENTATIVE)

Certificate Of Authorization Expires: 6/16/90 Certification of Authorization No.: NPT N-

CERTIFICATION OF DESIGN FOR APPURTENANCE

Design information on file at GE COMPANY, SAN JOSE, CALIFORNIA

Stress analysis report on file at GE COMPANY, SAN JOSE, CALIFORNIA

DC22A5253 Rev. 0

Design specification certified by BJORN HAABERG Prof. Eng. State CALIF. Reg. No. 15

DC22A5254 Rev. 0.

Stress analysis report certified by EDWARD YOSHIO Prof. Eng. State CALIF. Reg. No. MO

CERTIFICATION OF SHOP INSPECTION

I, the undersigned, holding a valid commission by the National Board of Boiler and Pressure Vessel Inspectors and/or the State or Province of NORTH CAROLINA and employed by DEPARTMENT OF L of STATE OF NORTH CAROLINA have inspected the part of a pressure vessel described in Partial Data Report on 3/30 1990, and state that to the best of my knowledge and belief, the NPT Certificate Holder has constructed this part in accordance with the Code Section III.

By signing this certificate, neither the Inspector nor his employer makes any warranty expressed or implied, concerning the part described in the Partial Data Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damages or a loss of any kind arising from or connected with this inspection.

DATE 3/30, 19 90 Inspector's Signature James P. Evans NC 1231
National Board, State, Province and

Supplemental sheets in form of lists, sketches or drawing may be used provided (1) if the sheet is 11" X 17", (2) information in 1-2 on this Data Report is included on each sheet, and (3) each sheet is numbered and number of sheets is recorded in Item 3. "REMARKS"

FORM N-2 (back)

Items 4-8 incl., to be completed for single well vessels, jacketed vessels, or shells of heat exchangers.

4. Shell: Material _____ T.S. _____ Nominal Thickness _____ in. Allowance _____ in. Dia. _____ ft. _____ in. Length _____ ft. _____ in.
(Kind & Spec. No.) (Min. of Range Specified)

5. Seams: Long _____ H.T.¹ _____ R.T. _____ Efficiency _____ %
Girth _____ H.T.¹ _____ R.T. _____ No. of Courses _____

6. Heads: (a) Material _____ T.S. _____ (b) Material _____ T.S. _____
Location (Top Bottom, Ends) Thickness _____ Crown Radius _____ Knuckle Radius _____ Elliptical Ratio _____ Conical Apex Angle _____ Hemispherical Radius _____ Flat Diameter _____ Side to Press. (conv. or conc.)
(a) _____
(b) _____
If removable, bolts used _____ Other fastening _____
(Material, Spec. No., T.S. Size Number) (Describe or attach sketch)

7. Jacket Closure: _____
(Describe as ogee and weld, bar, etc. If bar give dimensions, if bolts, describe or sketch)

8. Design Pressure ² _____ psi at _____ °F Drop Weight _____
Charpy Impact _____ ft-lb
at temp. of _____ °F

Items 9 and 10 to be completed for tube sections.

9. Tube Sheet: Stationary Mat'l. _____ Dia. _____ Thickness _____ in. Attachment _____
(Kind of Spec. No.) (Subj. to Press.) (Welded, Bolted)
Floating. Material _____ Dia. _____ Thickness _____ in. Attachment _____
Inches

10. Tubes: Material _____ O.D. _____ in. Thickness _____ or gage. Number _____ Type _____
(Str. or U)

Items 11-14 incl., to be completed for inner chambers of jacketed vessels, or channels of heat exchangers

11. Shell: Material _____ T.S. _____ Nominal Thickness _____ in. Allowance _____ in. Dia. _____ ft. _____ in. Length _____ ft. _____ in.
(Kind & Spec. No.) (Min. of Range Specified)

12. Seams: Long _____ H.T.¹ _____ R.T. _____ Efficiency _____ %
Girth _____ H.T.¹ _____ R.T. _____ No. of Courses _____

13. Heads: (a) Material _____ T.S. _____ (b) Material _____ T.S. _____
Location (a) Top, Bottom, Thickness _____ Crown Radius _____ Knuckle Radius _____ Elliptical Ratio _____ Conical Apex Angle _____ Hemispherical Radius _____ Flat Diameter _____ Side to Press. (Conv. or Conc.)
(b) Channel _____
If removable, bolts used (a) _____ (b) _____ (c) _____ Other fastening _____
(Describe or attach sketch)

14. Design pressure ² _____ psi at _____ °F Drop Weight _____
Charpy Impact _____ ft-lb
at temp. of _____ °F

Items below to be completed for all vessels where applicable.

15. Safety Valve Outlets: Number _____ Size _____ Location _____

16. Nozzles:
Purpose (Inlet Outlet, Drain) Number Dia or Size Type Material Thickness Reinforcement Material Attached

17. Inspection Manholes, No. _____ Size _____ Location _____
Openings: Handhole, No. _____ Size _____ Location _____
Threading, No. _____ Size _____ Location _____

18. Supports: Sht _____ Lugs _____ Legs _____ Other _____ Attached _____
(Yes or No) (Number) (Number) (Describe) (Where & How)

¹ If Postweld Heat-Treated.


² List other internal or external pressure with coincident temperature when applicable.

FORM N-2 NPT CERTIFICATE HOLDERS' DATA REPORT FOR NUCLEAR PART AND APPURTENANCES
As required by the Provision of the ASME Code Rules, Section III, Div. I

1. Manufactured & Certified by: GE Company, 2117 Castle Hayne Rd., Wilmington, N.C. 2840
(Name and Address of NPT Certificate Holder)
(b) Manufactured for: DUANE ARNOLD PALO, IOWA 52324
(Name and Address of N Certificate Holder for completed nuclear component)
2. Identification-Certificate Holders's S/N of Part: A4549 Nat'l Bd. N. N/A
(a) Constructed According to Drawing No: 761E387G012 Dwg. Prepared by D. L. Pete
(b) Description of Part Inspected: CONTROL ROD DRIVE, MODEL # 7RDB144EG001 N207
(c) Applicable ASME Code: Section III, Edition 1974, Addenda Date W'75, Case No. 1361-2 CI

Sheet 2 of 2

1. Cap 167A2343P1
SA182-F304
3/8 thick X 1 1/16 OD
2. Indicator Tube 104B1336P3
SA312-TP316
1/4 sch 40-seamless pipe
1.13 wall thickness
1.065 max. dia.
3. Plug 159A1176P1
SA182-F304
1/4 thick x 0.812 OD
4. Flange 919D610P1 (719E474)
SA182-F304
1/37 thick x 9 5/8 OD
5. Head 129B3539P3,P5
SA182-F304
2.0 OD x .884 ID
6. Ring Flange 114B5122P2
SA182-F304
1" thick x 5.0 OD x 1.75 ID
7. Cap Screw 117C4516P2
SA193-B6
6 dia. 1/2 dia. on 4 1/8 bolt circle
8. Plug 175A7961P1
SA182-F304
0.38 thick x 1.307 dia.
9. Nut 114B5460P1
SA193-B8A
1.30 thick x 2.62 dia.



FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Iowa Electric Light and Power Date September 6, 1990
Name

P.O.Box 351, Cedar Rapids, IA 52406 Sheet 1 of 2
Address

2. Plant Duane Arnold Energy Center Unit 1
Name

3277 DAEC Rd., Palo, IA 52324	CMAR #A 02913
Address	Repair Organization P.O.No., Job No.

3. Work Performed by Iowa Electric Type Code Symbol Stamp None
Name

Authorization No. None


3277 DAEC Road Palo, IA 52324 Expiration Date None

4. Identification of System Recirc Riser "F", line 1" DCA-19 (class 2)

5. (a) Applicable Const. Code ANSI B31.7 19 69 Edition, Addenda, N/A Code Case

(b)Applicable Edition of Section XI Utilized for Repairs or Replacements 1980 W81

6. Identification of Components Repaired or Replaced and Replacement Components

 Name of Component	Name of Manufacture	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired Replaced, or Replacement	ASME Code Stamped (Yes or No)
Socket Weld 4F3	Bechtel	n/a	N/A	1" DCA-19	1990	Repair	No

7. Description of Work Weld repair of 1" socket weld

8. Tests Conducted: Hydrostatic ☐ Pneumatic ☐ Nominal Operation Pressure ☒
Other ☐ Pressure 1026 psi Test Temp. 206 °F

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8½ in. x 11 in., (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.



FORM NIS-2 (Back)

sheet 2 of 2

9. Remarks 1/16" groove was found on socket weld it is assumed that the weld was marred by wiring wrapped around
Applicable Manufacturer's Data Reports to be attached
coupling. Weld repair defects, performed PT and VT-2 (see ISI report 89-13 for details)

CERTIFICATE OF COMPLIANCE

We certify that the statements made in the report are correct and this repair conforms to the rules of the ASME Code, Section XI. repair or replacement

Type Code Symbol Stamp NoneCertificate of Authorization No. None Expiration Date _____

Signed Sunder Shauhan Codes & Materials, TGL Date 9-6-, 1990
 Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Iowa and employed by Hartford Steam Boiler I&I Co of Hartford, Connecticut have inspected the components described in this Owner's Report during the period 8-5-90 to 9-11-90, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in the Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Scott Parker Commissions NB 8829(I)(N) 941-IA
 Inspectors Signature National Board, State, Province, and Endorsements

Date 9-11 19 90

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

- Owner Iowa Electric Light and Power Date September 10 1990
 Name
- P.O.Box 351, Cedar Rapids, IA 52406 Sheet 1 of 2
 Address
2. Plant Duane Arnold Energy Center Unit 1
 Name
- 3277 DAEC Rd. Palo, IA 52324 CMAR #91523
 Address Repair Organization P.O.No., Job No.
3. Work Performed by Iowa Electric Type Code Symbol Stamp None
 Name Authorization No. None
- 3277 DAEC Road Palo, IA 52324 Expiration Date None
 Address
4. Identification of System Reactor Vessel Vent Flange N7 Nozzle (class 1)
5. (a)Applicable Const. Code ANSI B 31.7 19 69 Edition, Addenda, N/A Code Case
 (b)Applicable Edition of Section XI Utilized for Repairs or Replacements 1980 W81
6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacture	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired Replaced, or Replacement	ASME Code Stamped (Yes or No)
N7 vent flange	C B & I	39-1	N/A	Vessel 1T201	1969	REPAIRED	YES

7. Description of Work Machined flange for better fit.
8. Tests Conducted: Hydrostatic ☐ Pneumatic ☐ Nominal Operation Pressure ☒
 Other ☐ Pressure 1026 psi Test Temp. 206 °F

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8 1/2 in. x 11 in., (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.



FORM NIS-2 (Back)

sheet 2 of 2

9. Remarks Machined flange for better fit. VT-1 was performed on flange and was accepted. As a note the flange has a
Applicable Manufacturer's Data Reports to be attached
rough mating surface. VT-2 was performed under ISI no. 89-13 and was acceptable.

CERTIFICATE OF COMPLIANCE

We certify that the statements made in the report are correct and this repair conforms
to the rules of the ASME Code, Section XI. repair or replacement

Type Code Symbol Stamp NoneCertificate of Authorization No. Nons Expiration Date _____Signed Sumudu Shaugai Codes & Materials, TGL Date 9-26-, 1990
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel
Inspectors and the State or Province of Iowa and employed by Hartford Steam Boiler I&I Co
of Hartford, Connecticut have inspected the components described in
this Owner's Report during the period 8-8-90 to 12-1-90
, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective
measures described in the Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied,
concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the
Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of
any kind arising from or connected with this inspection.

Scott Busher Commissions NB 8829(I)(N) 941-1A
Inspector's Signature National Board, State, Province, and Endorsements

Date Oct. 1 1990

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1.	Owner <u>Iowa Electric Light and Power</u> Name	Date <u>November 9, 1990</u>
	<u>P.O.Box 351, Cedar Rapids, IA 52406</u> Address	Sheet <u>1 of 2</u>
2.	Plant <u>Duane Arnold Energy Center</u> Name	Unit <u>1</u>
	<u>3277 DAEC Rd. Palo, IA 52324</u> Address	<u>PMAR #1043329, P.O. F16672</u> Repair Organization P.O.No., Job No.
3.	Work Performed by <u>Iowa Electric</u> Name	Type Code Symbol Stamp <u>None</u> Authorization No. <u>None</u>
	<u>3277 DAEC Road Palo, IA 52324</u> Address	Expiration Date <u>None</u>
4.	Identification of System <u>Heed Vent line Flange (lower) line 2" DBA-9 (class 1) "Item 5 on FSK-4042"</u>	
5.	(a) Applicable Const. Code <u>ANSI B 31.7</u> <u>19 69</u> Edition, <u>n/a</u> Addenda, <u>N/A</u> Code Case (b) Applicable Edition of Section XI Utilized for Repairs or Replacements <u>1980 W81</u>	

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacture	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired Replaced, or Replacement	ASME Code Stamped (Yes or No)
8 studs	Daniel Bolt	Ht Code 217	N/A	2" DBA-9	1973	Replacement	No
16 nuts	Daniel Bolt	Ht Code 312	N/A	2" DBA-9	1973	Replacement	No

7. Description of Work Replaced studs and nuts.

8. Tests Conducted: Hydrostatic ☐ Pneumatic ☐ Nominal Operation Pressure ☐
Other ☐ Pressure n/a psi Test Temp. n/a °F

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8½ in. x 11 in., (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

FORM NIS-2 (Back)

sheet 2 of 2

9. Remarks Studs and nuts replaced see NCR 90-124 for further comments. Commitment Control Number A90338 has beenApplicable Manufacturer's Data Reports to be attachedwritten to tract the VT-1 requirements for the next refueling outage.

CERTIFICATE OF COMPLIANCE

We certify that the statements made in the report are correct and this replacement conforms to the rules of the ASME Code, Section XI. repair or replacement

Type Code Symbol Stamp NoneCertificate of Authorization No. None Expiration Date

Signed SShangen Codes & Materials, TGL Date 11-13-
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Iowa and employed by Hartford Steam Boiler I&I Co of Hartford, Connecticut have inspected the components described in this Owner's Report during the period 9-7-90 to 11-13-90, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in the Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Scott Coulton Commissions NB 8829(I)(N) 941-1A
Inspectors Signature National Board, State, Province, and Endorsements

Date Nov 13 19 90

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Iowa Electric Light and Power Date September 10, 1990
 Name
P.O.Box 351, Cedar Rapids, IA 52406 Sheet 1 of 2
 Address
2. Plant Duane Arnold Energy Center Unit 1
 Name
3277 DAEC Rd. Palo, IA 52324 CMAR #93919 (EMA)
 Address Repair Organization P.O.No., Job No.
3. Work Performed by Iowa Electric Type Code Symbol Stamp None
 Name
 Authorization No. None
3277 DAEC Road Palo, IA 52324 Expiration Date None
 Address
4. Identification of System Reactor Vessel vent line 2"DBA-9 (class 1)
5. (a)Applicable Const. Code ASME Section III 19 71 Edition, S71 Addenda, N/A Code
 Case (valve) Const. Code for piping B 31.7, 1967 Edition 1969 Addenda class 1
 (b)Applicable Edition of Section XI Utilized for Repairs or Replacements 1980 W81
6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacture	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired Replaced, or Replacement	ASME Code Stamped (Yes or No)
Valve V-14-006	Rockwell	n/a	n/a	2" CCA-GB	1972	Replaced	Yes
Valve V-14-006	Anchor	EA742-3-1	N/A	2" CCA-GT	1988	Replacement	YES
2" pipe	Tioga Pipe Co.	HT# L61715	N/A	2" DBA-9	1990	Replacement	NO
Welds W32, W33, W34 W35, W36, W37, W38	Iowa Electric	N/A	N/A	2" DBA-9	1990	Replacement	NO

* Nonclass attachment weld to class1 valve V-14-6

7. Description of Work Replaced valve V-14-006 and associated piping.
8. Tests Conducted: Hydrostatic ☒ Pneumatic ☐ Nominal Operation Pressure ☐
 Other ☐ Pressure 1026 psi Test Temp. 206 °F

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8 1/2 in. x 11 in., (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.



AP
 11-14-90

FORM NIS-2 (Back)

sheet 2 of 2

Remarks Replaced valve due to extreme bypass leakage. Performed PT on welds. VT-2 with Hydrostatic test under ISI
Applicable Manufacturer's Data Reports to be attached
report number 90-360 and 89-13 (see NIS2 10-90-40 for further details)

CERTIFICATE OF COMPLIANCE

We certify that the statements made in the report are correct and this replacement conforms
to the rules of the ASME Code, Section XI. repair or replacement

Type Code Symbol Stamp None

Certificate of Authorization No. None Expiration Date

Signed S. Shauji Codes & Materials, TGL Date 11-13-, 19 90
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel
Inspectors and the State or Province of Iowa and employed by Hartford Steam Boiler I&I Co
of Hartford, Connecticut have inspected the components described in
this Owner's Report during the period 5-15-90 to 6-1-90
, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective
measures described in the Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied,
concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the
Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of
any kind arising from or connected with this inspection.

[Signature] Commissions NB 8829(I)(N) 941-1A
Inspectors Signature National Board, State, Province, and Endorsements

Date Nov. 14, 1990

FORM NPV-1 (back)

0011802

Mark No.	Material Spec. No.	Manufacturer	Remarks
(c) Bolting			
N/A			
(d) Other Parts			
Disc HT.#9563	AMS-5387A	Deloro Stellite, Inc.	

8. Hydrostatic test 5400 psi.

CERTIFICATION OF DESIGN

Design information on file at Anchor/Darling Valve Co., Williamsport, PA 17701
Stress analysis report on file at Anchor/Darling Valve Co., Williamsport, PA 17701
Design specifications certified by R. S. Powell (1) Prof. Eng. State CA Reg. No. 14420
Stress analysis report certified by R. S. Farrell (1) Prof. Eng. State PA Reg. No. 35216-E

(1) Signature not required. List name only.

We certify that the statements made in this report are correct.

Date 9/27 19 88 Signed Anchor/Darling Valve Co. By R L Stannett
(Manufacturer)

Certificate of Authorization No. N1712 expires 4/15/89

CERTIFICATE OF SHOP INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and/or the State of ~~Massachusetts~~ of Pennsylvania and employed by Commercial Union Insurance Co. of Boston, Mass.

227 Ch - 9-22 19 88 have inspected the equipment described in this Data Report on 227 Ch - 9-22 19 88, and state that to the best of my knowledge and belief, the Manufacturer has constructed this equipment in accordance with the applicable Subsections of ASME Code, Section III.

By signing this certificate, neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the equipment described in this Data Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date 9-27 19 88

Charles Young (Inspector) Commissions Pennsylvania 2392
(National Board, State, Province and No.)

--	--

1



AP
11-14-90

FORM NIS-2 (Back)

sheet 2 of 2

9. Remarks Replaced valve due to extreme bypass leakage. Performed PT on welds. VT-2 with Hydrostatic test under ISI
Applicable Manufacturer's Data Reports to be attached
89-13 (see nis2 10-90-39 for further details)

CERTIFICATE OF COMPLIANCE

We certify that the statements made in the report are correct and this replacement conforms
to the rules of the ASME Code, Section XI. repair or replacement

Type Code Symbol Stamp NoneCertificate of Authorization No. None Expiration Date _____

Signed S. Shaujan Codes & Materials, TGL Date 11-13-, 19 90
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Iowa and employed by Hartford Steam Boiler I&I Co of Hartford, Connecticut have inspected the components described in this Owner's Report during the period 5-18-90 to 11-15-90, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in the Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

[Signature] Commissions NB 8829(1)(N) 941-1A
Inspectors Signature National Board, State, Province, and Endorsements

Date Nov 14, 19 90

37.

הַיְי

02

—

כ



(Brief description of service for which equipment was designed)

(a) Drawing No. W8822831 R/A Prepared by Anchor/Darling Valve Company

(b) National Board No. N/A

6. Design Conditions 3600 psi 100 °F
(Pressure) (Temperature)

7. The material, design, construction, and workmanship complies with ASME Code Section III. Class _____

Edition 1971, Addenda Date Summer 1971, Case No. -----

[illegible]

Mark No.	Material Spec. No.	Manufacturer	Remarks
(c) Bolting			
N/A			
(d) Other Parts			
Disc H.	S-5387A	De Ioro Stellite, Inc.	

8. Hydrostatic test 5400 psi.

CERTIFICATION OF DESIGN

Design information on file at Anchor/Darling Valve Co., Williamsport, PA 17701
 Stress analysis report on file at Anchor/Darling Valve Co., Williamsport, PA 17701
 Design specifications certified by R. S. Powell (1) Prof. Eng. State CA Reg. No. 14420
 Stress analysis report certified by R. S. Farrell (1) Prof. Eng. State PA Reg. No. 35216-E
 1) Signature not required. List name only.

We certify that the statements made in this report are correct.

Date 9/27 1988 Signed Anchor/Darling Valve Co. By R L Stannett
 (Manufacturer)

Certificate of Authorization No. N1712 expires 4/15/89

CERTIFICATE OF SHOP INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and/or the State of ~~Mass.~~ of Pennsylvania and employed by Commercial Union Insurance Co. of Boston, Mass. have inspected the equipment described in this Data Report on 22264-927 1988, and state that to the best of my knowledge and belief, the Manufacturer has constructed this equipment in accordance with the applicable Subsections of ASME Code, Section III.
 By signing this certificate, neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the equipment described in this Data Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date 9-27 1988

Charles Young
 (Inspector)
 Charles Young

Commissions Pennsylvania 2392
 (National Board, State, Province and No.)

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Iowa Electric Light and Power Date September 11, 1990
Name
P.O.Box 351, Cedar Rapids, IA 52406 Sheet 1 of 2
Address

2. Plant Duane Arnold Energy Center Unit 1
Name
3277 DAEC Rd. Palo, IA 52324 CMAR #A 01133 (EMA)
Address Repair Organization P.O.No., Job No.

3. Work Performed by Iowa Electric Type Code Symbol Stamp None
Name
Authorization No. None
3277 DAEC Road Palo, IA 52324 Expiration Date None
Address

4. Identification of System 1 1/4" Relief valve line for HPCI Barometric Condenser (Class 2)

5. (a) Applicable Const. Code ANSI 831.7 19 67 Edition, Addenda, N/A Code Case
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements 1980 U81
(c) Construction Code of Replacement item Section III 1974 Edition, S75 Addenda with Code Case (pipe)
Sect. III 1977 Edition, S78 Addenda (flange); Section III 1983 Edition S85 Addenda (studs, nuts)

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacture	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired Replaced, or Replacement	ASME Code Stamped (Yes or No)
1 1/4" pipe (sch 80)	Bechtel	n/a	n/a	relief valve line	1972	Replaced	No
1 1/4" pipe (sch 80)	Chicago-Tube & Iron	n/a	n/a	1 1/4" H8B-*	1979	Replacement	No
2- 150# Flanges	Hub Inc.	Ht. Code ARPW-Coffer	n/a	1 1/4" H8B-*	1990	Replacement	No
4 - studs	Cardinal	Ht. No. X5698	n/a	1 1/4" H8B-*	1986	Replacement	No
8 - nuts	Cardinal	Ht. No. KC 8972	n/a	1 1/4" H8B-*	1986	Replacement	No
Welds W1A, W1B	Iowa Electric	n/a	n/a	1 1/4" H8B-*	1990	Replacement	No

7. Description of Work Replaced pipe with pipe and flange connections

8. Tests Conducted: Hydrostatic ☒ Pneumatic ☐ Nominal Operation Pressure ☐
Other ☐ Pressure 18.75 psi Test Temp. 74.5 °F

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8 1/2 in. x 11 in., (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.



AP
10-15-90

FORM NIS-2 (Back)

sheet 2 of 2

9. Remarks Replacement of pipe with pipe, flange connection. Welds were PT examined and the new line was hydrostatic
Applicable Manufacturer's Data Reports to be attached
tested with VT-2 personnel under ISI report # 90-323.

* line designation not identified in Betchel M-190.

CERTIFICATE OF COMPLIANCE

We certify that the statements made in the report are correct and this replacement conforms
 to the rules of the ASME Code, Section XI. repair or replacement

Type Code Symbol Stamp None

Certificate of Authorization No. None Expiration Date

Signed Sumida Shaugha Codes & Materials, TGL Date 10-5-, 19 90
 Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel
 Inspectors and the State or Province of Iowa and employed by Hartford Steam Boiler I&I Co
of Hartford, Connecticut have inspected the components described in
 this Owner's Report during the period 8-14-90 to 10-15-90
 , and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective
 measures described in the Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied,
 concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the
 Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of
 any kind arising from or connected with this inspection.

Scott Presler Commissions NB 8829(1)(N) 941-1A
 Inspectors Signature National Board, State, Province, and Endorsements

Date Oct 15 19 90

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Iowa Electric Light and Power Date Sept. 11, 1990
Name
P.O.Box 351, Cedar Rapids, IA 52406 Sheet 1 of 2
Address

2. Plant Duane Arnold Energy Center Unit 1
Name
3277 DAEC Rd. Palo, IA 52324 PMAR 1043210 & CMAR 093812
Address Repair Organization P.O.No., Job No.

3. Work Performed by Iowa Electric Type Code Symbol Stamp None
Name
Authorization No. None
3277 DAEC Rd. Palo, IA 52324 Expiration Date None
Address

4. Identification of System Main Steam (class 1)

5. * (a) Applicable Const. Code SECT. III 19 68 Edition, W68 Addenda, N A / Code
Case
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements 1980 W81
*GE Spec 21A9206 Rev 6 & 7

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacture	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired Replaced, or Replacement	ASME Code Stamped (Yes or No)
MSRV Pilot Valve	Target Rock	S/M 199	N/A	PSV-4407	1975	Replaced	Yes
MSRV Pilot Valve	Target Rock	S/N 202	N/A	PSV-4407	1975	Replacement	Yes
MSRV Main Body	Target Rock	Unknown	N/A	PSV-4407	1975	Replaced	Yes
MSRV Main Body	Target Rock	S/N 202	N/A	PSV-4407	1975	Replacement	Yes

7. Description of Work MSRV Pilot/Main Body was replaced with new MSRV Pilot/Main Body S/N 202.

8. Tests Conducted: Hydrostatic ☐ Pneumatic ☐ Nominal Operating Pressure ☒
Other ☐ Pressure 1026 psi Test Temp. 206 °F

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8 1/2 in. x 11 in., (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

FORM NIS-2 (Back)

sheet 2 of 2

9. Remarks The MSRV Pilot/Main Body assembly was removed and replaced by a new MSRV Pilot/Main Body assembly S/N 202
Applicable Manufacturer's Data Reports to be attached
purchased from Commonwealth Edison (P.O.E9-18747-N-RG). A VT-1 (Rpt#s 89-18 & 90-200) was performed and accepted.
A VT-3 (Rpt# 90-202) was performed on the Pilot Valve. NCR 90-099 was written because the preservice VT-3 exam on
the Main Body S/M 202 was not performed. The NCR was dispositioned "USE AS IS". A VT-2 exam (89-13) was accepted
after installation.

CERTIFICATE OF COMPLIANCE

We certify that the statements made in the report are correct and this replacement conforms
 to the rules of the ASME Code, Section XI. repair or replacement

Type Code Symbol Stamp NoneCertificate of Authorization No. None Expiration Date None

Signed Sunder Shauja Codes & Materials, TGL Date 10-5-, 19 90
 Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel
 Inspectors and the State or Province of IOWA and employed by Hartford Steam Boiler I&I Co.
of Hartford, Connecticut have inspected the components described in
 this Owner's Report during the period 6-13-92 to 10-9-92
 , and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective
 measures described in the Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied,
 concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the
 Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of
 any kind arising from or connected with this inspection.

Scott J. Fisher Commissions NB 8829(I)(N) 941-1A
 Inspectors Signature National Board, State, Province, and Endorsements

Date Oct 9 19 90



AP
12-15-90

FORM NIS-2 (Back)

sheet 2 of 2

9. Remarks The MSRV Pilot Valve S/N 141 was repaired at Wyle Labs (ref. NIS-2 10-90-04). This pilot valve was
Applicable Manufacturer's Data Reports to be attached
installed in location PSV-4405. A VT-2 examination was performed (89-13) and accepted.

CERTIFICATE OF COMPLIANCE

We certify that the statements made in the report are correct and this replacement conforms
 to the rules of the ASME Code, Section XI. repair or replacement

Type Code Symbol Stamp NoneCertificate of Authorization No. None Expiration Date None

Signed Sunder Shauji Codes & Materials, TGL Date 10-3-, 19 90
 Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel
 Inspectors and the State or Province of IOWA and employed by Hartford Steam Boiler I&I Co.
 of Hartford, Connecticut have inspected the components described in
 this Owner's Report during the period 6-15-90 to 10-15-90
 , and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective
 measures described in the Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied,
 concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the
 Inspector nor his employer shall be liable in any manner for any personnel injury or property damage or a loss of
 any kind arising from or connected with this inspection.

Scott Presler Commissions NB 8829(I)(N) 941-1A
 Inspectors Signature National Board, State, Province, and Endorsements

Date Oct 15 1990

FORM NIS-2 (Back)

sheet 2 of 2

9. Remarks MSRV Pilot Valve S/N 200 was removed for testing. S/N 218 was installed. During installation it was
Applicable Manufacturer's Data Reports to be attached
required to replace the Hex Bolts and Nuts due to damage. A preservice VT-1 (Rpt# 90-195) of the replacement
belting and a VT-2 (Rpt# 89-13) was conducted and accepted. The installed pilot valve S/N 218 was repaired during
testing at Wyle Labs (ref. NIS-2 10-90-05).

CERTIFICATE OF COMPLIANCE

We certify that the statements made in the report are correct and this replacement conforms
 to the rules of the ASME Code, Section XI. repair or replacement

Type Code Symbol Stamp NoneCertificate of Authorization No. NoneExpiration Date None

Signed Sumudu Shanigan Codes & Materials, TGL Date 10-1-, 19 90
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel
 Inspectors and the State or Province of IOWA and employed by Hartford Steam Boiler I&I Co.
 of Hartford, Connecticut have inspected the components described in
 this Owner's Report during the period 5-13-90 to 10-15-90
 , and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective
 measures described in the Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied,
 concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the
 Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of
 any kind arising from or connected with this inspection.

Scott Purser Commissions NB 8829(I)(N) 941-IA
Inspectors Signature National Board, State, Province, and Endorsements

Date Oct 15 19 90

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Iowa Electric Light and Power Date September 11, 1990
 Name
P.O.Box 351, Cedar Rapids, IA 52406 Sheet 1 of 2
 Address
2. Plant Duane Arnold Energy Center Unit 1
 Name
3277 DAEC Rd. Palo, IA 52324 CHAR #095115
 Address Repair Organization P.O.No., Job No.
3. Work Performed by Iowa Electric Type Code Symbol Stamp None
 Name
 Authorization No. None
3277 DAEC Road Palo, IA 52324 Expiration Date None
 Address
4. Identification of System HPCI Steam outboard valve 10"-DLA-3 (class 1)
5. (a)Applicable Const. Code ASME PUMP & VALVE CODE 19 68 Edition, Addenda, N/A Code Case
 (b)Applicable Edition of Section XI Utilized for Repairs or Replacements 1980 W81 class 1
6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacture	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired Replaced, or Replacement	ASME Code Stamped (Yes or No)
MO-2239	ANCHOR Valve Co.	IN-003	N/A	10"-DLA-GT	1972	REPAIRED	YES

7. Description of Work Machining of disc tee slot
8. Tests Conducted: Hydrostatic ☐ Pneumatic ☐ Nominal Operation Pressure ☒
 Other ☐ Pressure 1026 psi Test Temp. 206 °F

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8½ in. x 11 in., (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

AP
10-15-90

FORM NIS-2 (Back)

sheet 2 of 2

9. Remarks After disassembly of MO-2239 it was necessary machine the disc for proper fit. Pressure test was performed
Applicable Manufacturer's Data Reports to be attached
under ISI leakage test No. 89-13. ISI VT-3 was performed under 90-006.

CERTIFICATE OF COMPLIANCE

We certify that the statements made in the report are correct and this repair conforms to the rules of the ASME Code, Section XI. repair or replacement

Type Code Symbol Stamp None

Certificate of Authorization No. None Expiration Date

Signed Sumner Shauhan Codes & Materials, TGL Date 10-5-, 19 90
 Owner or Owner's Designee, Title J

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Iowa and employed by Hartford Steam Boiler I&I Co of Hartford, Connecticut have inspected the components described in this Owner's Report during the period 7-24-90 to 12-15-90, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in the Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Scott Butler Commissions NB 8829(I)(N) 941-1A
 Inspectors Signature National Board, State, Province, and Endorsements

Date Oct 15 19 90

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Iowa Electric Light and Power Date September 12, 1990
Name
P.O.Box 351, Cedar Rapids, IA 52406 Sheet 1 of 2
Address

2. Plant Duane Arnold Energy Center Unit 1
Name
3277 DAEC Rd, Palo, IA 52324 CMAR #098624 (EMA), P.O. S55713, S53552
Address Repair Organization P.O.No., Job No.

3. Work Performed by Iowa Electric Type Code Symbol Stamp None
Name
Authorization No. None
3277 DAEC Road Palo, IA 52324 Expiration Date None
Address

4. Identification of System Recirc 'B" Discharge valve By-pass (class 1)

5. (a) Applicable Const. Code ASME PUMP & VALVE CODE 19 68 Edition, Addenda, N/A Code Case
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements 1980 W81 class 1
(c) Replacement code of construction Section III 1983 Edition N/A Addenda, Class 1

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacture	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired Replaced, or Replacement	ASME Code Stamped (Yes or No)
Disc	ANCHOR Darling	s/n 7	N/A	MO-4630	1983	Replacement	YES
10 - STUDS	Anchor Darling	W-2936	N/A	MO-4630	1990	Replacement	NO
20 - NUTS	Anchor Darling	W-1466	N/A	MO-4630	1990	Replacement	NO

7. Description of Work Replaced disc, studs and nuts. Some areas machined for proper fit.

8. Tests Conducted: Hydrostatic ☐ Pneumatic ☐ Nominal Operation Pressure ☒ X

Other ☐ Pressure 1026 psi Test Temp. 206 °F

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8 1/2 in. x 11 in., (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

AP
9-21-98

FORM NIS-2 (Back)

sheet 2 of 2

9. Remarks After disassembly of MO-4630 it was necessary replace the disc, bonnet studs and bonnet nuts. Some of the
Applicable Manufacturer's Data Reports to be attached
valve internals were also machined for proper fit. Valves were vt-3 and PT inspected. Vt-1 of bolting and nuts were
performed under ISI # 90-238. Valve was VT-2 inspected under ISI # 89-13.

CERTIFICATE OF COMPLIANCE

We certify that the statements made in the report are correct and this replacement conforms
 to the rules of the ASME Code, Section XI. repair or replacement

Type Code Symbol Stamp NoneCertificate of Authorization No. None Expiration Date _____

Signed [Signature] Codes & Materials, TGL Date 10-11-90, 19 90
 Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel
 Inspectors and the State or Province of Iowa and employed by Hartford Steam Boiler I&I Co
 of Hartford, Connecticut have inspected the components described in
 this Owner's Report during the period 6-22-90 to 9-21-90
 , and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective
 measures described in the Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied,
 concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the
 Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of
 any kind arising from or connected with this inspection.

[Signature]
 Inspectors Signature

Commissions NB 8829(I)(N) 941-IA
 National Board, State, Province, and Endorsements

Date Sept 21 19 90

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Iowa Electric Light and Power Date September 12, 1990
Name
P.O.Box 351, Cedar Rapids, IA 52406 Sheet 1 of 2
Address

2. Plant Duane Arnold Energy Center Unit 1
Name
3277 DAEC Rd. Palo, IA 52324 CMAR #098621 (EMA), P.O. S55713, S53552
Address Repair Organization P.O.No., Job No.

3. Work Performed by Iowa Electric Type Code Symbol Stamp None
Name
Authorization No. None
3277 DAEC Road Palo, IA 52324 Expiration Date None
Address

4. Identification of System Recirc 'A' Discharge valve By-pass (class 1)

5. (a) Applicable Const. Code ASME PUMP & VALVE CODE 19 68 Edition, Addenda, N/A Code Case
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements 1980 W81 class 1
(c) Replacement code of construction Section III 1983 Edition N/A Addenda, Class 1

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacture	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired Replaced, or Replacement	ASME Code Stamped (Yes or No)
Disc	Darling Valve	unknown	N/A	MO-4629	1968	Replacac	YES
Disc	ANCHOR Darling	s/n 6	N/A	MO-4629	1983	Replacement	YES
10 - STUDS	Anchor Darling	W-2936	N/A	MO-4629	1990	Replacement	NO
20 - NUTS	Anchor Darling	W-1466	N/A	MO-4629	1990	Replacement	NO
10 - STUDS	Darling Valve Manufacturing	unknown	N/A	MO-4629	1968	Replaced	NO
20 - NUTS	Darling Valve Manufacturing	unknown	N/A	MO-4629	1968	Replaced	NO

7. Description of Work Replaced disc, studs and nuts. Some areas machined for proper fit.

8. Tests Conducted: Hydrostatic ☐ Pneumatic ☐ Nominal Operation Pressure ☒
Other ☐ Pressure 1026 psi Test Temp. 206 °F

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8 1/2 in. x 11 in., (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.



AP
10-15-90

FORM NIS-2 (Back)

sheet 2 of 2

9. Remarks After disassembly of MO-4629 it was necessary replace the disc, bonnet studs and bonnet nuts. Some of the
Applicable Manufacturer's Data Reports to be attached
valve internals were also machined for proper fit. Valve was VT-3 (90-230) and PT inspected VT-1 of bolting & nuts
were performed under ISI # 90-229. Valve was VT-2 inspected under ISI # 89-13.

CERTIFICATE OF COMPLIANCE

We certify that the statements made in the report are correct and this replacement conforms
 to the rules of the ASME Code, Section XI. repair or replacement

Type Code Symbol Stamp None

Certificate of Authorization No. None Expiration Date

Signed Sumner Shangi Codes & Materials, TGL Date 9-29-, 19 90
 Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel
 Inspectors and the State or Province of Iowa and employed by Hartford Steam Boiler I&I Co
of Hartford, Connecticut have inspected the components described in
 this Owner's Report during the period 6-22-90 to 10-15-90
 , and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective
 measures described in the Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied,
 concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the
 Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of
 any kind arising from or connected with this inspection.

Scott Presler Commissions NB 8829 (I) N 941-1A
 Inspectors Signature National Board, State, Province, and Endorsements

Date Oct 15 1990

FORM N-2 NPT CERTIFICATE HOLDERS' DATA REPORT FOR NUCLEAR PART AND APPURTENANCES*

As required by the Provision of the ASME Code Rules, Section III, Div. 1

1. (a) Manufactured by Anchor/Darling Valve Co., 701 First St., Williamsport, PA 17701
(Name and address of NPT Certificate Holder)
- (b) Manufactured for Iowa Electric Light & Power Co., P.O. Box 351, Cedar Rapids, Iowa 52401
(Name and address of N Certificate Holder for completed nuclear component)
2. Identification-Certificate Holder's Serial No. of Part S/N 6 & 7 Nat'l Bd. No. N/A
- (a) Constructed According to Drawing No. B49497 R/A Drawing Prepared by Anchor/Darling Valve Company
- (b) Description of Part Inspected Disc w/Stellite, (2 Pcs.) Heat No. H3520 SA182-F304L
- (c) Applicable ASME Code: Section III, Edition 1983, Addenda date ---, Case No. N/A Class 1
3. Remarks: 4"-S150W-DD
(Brief description of service for which component was designed)
A/DV S.O. P-G586-5
No Disc Hydro Performed

We certify that the statements made in this report are correct and this vessel part or appurtenance as defined in the Code, conforms to the rules of construction of the ASME Code Section III.
(The applicable Design Specification and Stress Report are not the responsibility of the NPT Certificate Holder for parts. An NPT Certificate Holder for appurtenances is responsible for furnishing a separate Design Specification and Stress Report if the appurtenance is included in the component Design Specification and Stress Report.)

Date 6/29 19 90 Signed Anchor/Darling Valve Co. By Debra A. [Signature]
(NPT Certificate Holder)
Certificate of Authorization Expires 4/15/92 Certificate of Authorization No. N1713

CERTIFICATION OF DESIGN FOR APPURTENANCE (when applicable)

Design information on file at _____
Stress analysis report on file at _____
Design specifications certified by _____ Prof. Eng. State _____ Reg. No. _____
Stress analysis report certified by _____ Prof. Eng. State _____ Reg. No. _____

CERTIFICATE OF SHOP INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and/or the State of Pennsylvania and employed by Commercial Union Insurance Company of Boston, Mass. have inspected the part of a pressure vessel described in this Partial Data Report on 6-22-90 6-29-90 19 90, and state that to the best of my knowledge and belief, the NPT Certificate Holder has constructed this part in accordance with the ASME Code Section III.
By signing this certificate, neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the part described in this Partial Data Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date 6-29 19 90
Charles Young [Signature]
Commissions Pennsylvania 2392
National Board, State, Province and No.

*Supplemental sheets in form of lists, sketches or drawings may be used provided (1) size is 8 1/2" x 11", (2) information in items 1-2 on this Data Report is included on each sheet, and (3) each sheet is numbered and number of sheets is recorded in item 3, "Remarks".

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Iowa Electric Light and Power Date September 14, 1990
Name
- P.O.Box 351, Cedar Rapids, IA 52406 Sheet 1 of 2
Address
2. Plant Duane Arnold Energy Center Unit 1
Name
- 3277 DAEC Rd. Palo, IA 52324 CHAR A 03259, P.O. S57418
Address Repair Organization P.O.No., Job No.
3. Work Performed by Iowa Electric Type Code Symbol Stamp None
Name Authorization No. None
- 3277 DAEC Rd. Palo, IA 52324 Expiration Date None
Address
4. Identification of System Control Rod Drives (Class 1)

5. (a) Applicable Const. Code ASME Section III 19 77 Edition, S77 Addenda, N/A Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 1980 W81
 (c) Original Construction Code ASME III 1968 Edition W68 Addenda per GE Construction Quality Requirements 22A2534
6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacture	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired Replaced, or Replacement	ASME Code Stamped (Yes or No)
CRD Housing Bolts (8ea)	General Electric	Ht. Code K05	N/A	1R215(22-19)	1990	Replacement	Yes

7. Description of Work Replacement of CRD Housing Bolting
8. Tests Conducted: Hydrostatic ☐ Pneumatic ☐ Nominal Operating Pressure ☒
 Other ☐ Pressure 1025 psi Test Temp. 202 °F

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8½ in. x 11 in., (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.



FORM NIS-2 (Back)

sheet 2 of 2

9. Remarks Replacement of CRD Housing bolting VT-2 leakage test was performed under 90-362. VT-1 preservice inspection
Applicable Manufacturer's Data Reports to be attached
was performed under ISI # 90-363.

CERTIFICATE OF COMPLIANCE

We certify that the statements made in the report are correct and this replacement conforms
 to the rules of the ASME Code, Section XI. repair or replacement

Type Code Symbol Stamp NoneCertificate of Authorization No. None Expiration Date None

Signed Sumner Shays Codes & Materials, TGL Date 9-18-
 Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel
 Inspectors and the State or Province of IOWA and employed by Hartford Steam Boiler I&I Co.
of Hartford, Connecticut have inspected the components described in
 this Owner's Report during the period 9-5-98 to 9-21-98
 , and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective
 measures described in the Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied,
 concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the
 Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of
 any kind arising from or connected with this inspection.

Scott Barker
 Inspectors Signature

Commissions NB 8829(I)(N) 941-1A
 National Board, State, Province, and Endorsements

Date Sept 21 19 98

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Iowa Electric Light and Power Date Sept. 12 1990
Name
P.O.Box 351, Cedar Rapids, IA 52406 Sheet 1 of 2
Address

2. Plant Duane Arnold Eneg Center Unit 1
Name
3277 DAEC Rd. Palo, IA 52324 PMAR 1043209
Address Repair Organization P.O.No., Job No.

3. Work Performed by Iowa Electric Type Code Symbol Stamp None
Name
Authorization No. None
3277 DAEC Rd. Palo, IA 52324 Expiration Date None
Address

4. Identification of System Main Steam class K)

5. * (a) Applicable Const. Code SECT. III 19 68 Edition, W68 Addenda, N/A Code
Case
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements 1980 W81
*GE Spec 21A9206 Rev 6 & 7

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacture	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired Replaced, or Replacement	ASME Code Stamped (Yes or No)
Hex Bolt (8 ea)	Cardinal	HT#211916	N/A	PSV-4406	1989	Replacement	No
Nut-Flexloc (12 ea)	Target Rock	Part # 00FC1812	N/A	PSV-4406	unknown	Replacement	No

7. Description of Work Replaced 8 Hex Bolts and 12 Nuts on PSV-4406 during installation.

8. Tests Conducted: Hydrostatic ☐ Pneumatic ☐ Nominal Operating Pressure ☒
Other ☐ Pressure 1026 psi Test Temp. 206 °F

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8½ in. x 11 in., (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

FORM NIS-2 (Back)

sheet 2 of 2

9. Remarks MSRV Pilot Valve S/N 227 was removed for testing. S/N 203 was installed. During installation it was
Applicable Manufacturer's Data Reports to be attached
required to replace the Hex Bolts and Nuts due to damage. A preservice VT-1 (Rpt# 90-198) of the replacement
bolting and a VT-2 (Rpt# 89-13) was conducted and accepted. The installed pilot valve S/N 203 was repaired during
testing at Wyle Labs (ref. HIS-2 10-90-06).

CERTIFICATE OF COMPLIANCE

We certify that the statements made in the report are correct and this replacement conforms
 to the rules of the ASME Code, Section XI. repair or replacement

Type Code Symbol Stamp NoneCertificate of Authorization No. None Expiration Date None

Signed Surinder Shargai Codes & Materials, TGL Date 9-26-
 Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel
 Inspectors and the State or Province of IOWA and employed by Hartford Steam Boiler I&I Co.
 of Hartford, Connecticut have inspected the components described in
 this Owner's Report during the period 8-17-98 to 12-1-98
 , and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective
 measures described in the Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied,
 concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the
 Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of
 any kind arising from or connected with this inspection.

Scott Cusler Commissions NB 8829(I)(N) 941-IA
 Inspectors Signature National Board, State, Province, and Endorsements

Date Oct. 1 19 98

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

- Owner Iowa Electric Light and Power Date September 26, 1990
 Name _____
- P.O.Box 351, Cedar Rapids, IA 52406 Sheet 1 of 2
 Address _____
2. Plant Duane Arnold Energy Center Unit 1
 Name _____
- 3277 DAEC Rd. Palo, IA 52324 DCP 1457, P.O. 802368
 Address _____ Repair Organization P.O.No., Job No. _____
3. Work Performed by Iowa Electric Type Code Symbol Stamp None
 Name _____ Authorization No. None
- 3277 DAEC Road Palo, IA 52324 Expiration Date None
 Address _____
4. Identification of System Recirc Pump A (Class 1)

5. (a)Applicable Const. Code ASME Section III 19 68 Edition, W68 Addenda, N/A Code
 Case (class C)
 (b)Applicable Edition of Section XI-Utilized for Repairs or Replacements 1980 W81 class 2
 (c)Fabrication of Item performed under Section III 1983 Edition, S84 Addenda (class 1)
6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacture	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired Replaced, or Replacement	ASME Code Stamped (Yes or No)
Cover/Heat Exchanger Assembly*	BW/IP Intl. INC.	206873	N/A	1P-201A	1990	Replacement	No
Case Stud (16 each)	BW/IP Intl. INC.	HT # 94910	N/A	1P-201A	1990	Replacement	No
Case Nut (16 each)	BW/IP Intl. INC.	HT # B5499	N/A	1P-201A	1990	Replacement	No

*Section XI items of the assembly include the pump cover, Ht. Exch. cover and HT. exch. coil

7. Description of Work Replacod Cover/Heat Exchanger Assembly for Recirc Pump

8. Tests Conducted: Hydrostatic ☐ Pneumatic ☐ Nominal Operation Pressure ☒
 Other ☐ Pressure 1026 psi Test Temp. 206 °F

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8 1/2 in. x 11 in., (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.



FORM NIS-2 (Back)

sheet 2 of 2

9. Remarks Replacement of cover/heat exchanger assembly. VT-2 of recirc pump was performed under ISI report no. 89-13.
Applicable Manufacturer's Data Reports to be attached

Preservice of the pump studs were performed under 89-278. Preservice VT-1 of the flange surface, pump nuts and screws was performed under ISI numbers 89-279, 89-282, and 89-283. For information on recirc pump 1P-2018 see

NIS2 10-90-55.

CERTIFICATE OF COMPLIANCE

We certify that the statements made in the report are correct and this replacement conforms to the rules of the ASME Code, Section XI. repair or replacement

Type Code Symbol Stamp NoneCertificate of Authorization No. None

Expiration Date _____

Signed Sunder Shauger Codes & Materials, TGL Date 11-16-90, 19 90
 Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Iowa and employed by Hartford Steam Boiler I&I Co of Hartford, Connecticut have inspected the components described in this Owner's Report during the period 7-20-90 to 11-19-90, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in the Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Scott Presler Commissions NB 8829(1)(N) 941-1A
 Inspectors Signature National Board, State, Province, and Endorsements

Date Nov. 19 19 90

Owner IOWA ELECTRIC LIGHT & POWER

Date 3/31/90 Sheet 1 of 1

2. Plant DUANE ARNOLD ENERGY CENTER

Unit DAEC UNIT ONE

Name

Palo, Iowa 52324

Address

3. Work Performed By BW/IP INTL., INC.

Repair Organization, PO No. Job No. etc:
Type Code Symbol Stamp NONE

2300 E. VERNON AVE., VERNON, CA 90058

Authorization No. _____

Address

Expiration Date _____

4. Identification of System RECIRCULATION PUMP

5. (a) Applicable Const. Code CL.C 1968 Edition WINTER Addenda 1968 Code Case N/A

(b) Applicable Edition of ASME XI Used for Repairs or Replacement 19 N/A

(c) Original Const Code CL.C 1968 Edition, WINTER Addenda 1968 Code Case N/A

6. Identification of Component Repaired or Replaced and Replaced Components _____

Name of Component	Name of Manuf.	Manuf. S/N	Nat. Board No.	Other Ident.	Year Built	Repaired, Replaced, Replacement	ASME Code Stamped Yes/No
COVER/HEAT EXCHANGER ASSEMBLY	BW/IP INTL. INC.	206873	N/A	891-L-8509	1990	REPLACEMENT	NO

7. Description of Work FABRICATION OF NEW COVER/HEAT EXCHANGER ASSEMBLY

8. Test Conducted (X) Hydrostatic () Pneumatic Nominal Operating Pressure 1030

() Other _____ Pressure 1875 psi Test Temp. 68 of _____

9. Remarks JWEI HAS BEEN FABRICATED IN ACCORDANCE WITH ASME SECTION III, CL. I 1983 ED S'84 ADD.

Applicable Manufacturers Data Report to Be Attached _____

CERTIFICATE OF COMPLIANCE

We certify that the statements made in this report are correct and this ITEM conforms to the statements of P.O. # 205-89E500 Repaired, Replaced (or Modified)

Signed [Signature] Date 31 March 90.

Repair Org. Designer/Title _____

CERTIFICATE OF SHOP INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of CALIFORNIA and employed by ARKWRIGHT MUTUAL INS COOP NORWOOD, MASS have inspected the

components described in this repair organization report during the period 10-25-89 to 3-31-90, and state that to the best of my knowledge and

belief, the Repair Organization has performed examinations and taken corrective measures described in the Repair Organization Report in accordance with the requirements of the Owner's P.O. B02368 REV.1.

By signing this certificate neither the inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Repair Organization Report. Furthermore, neither the Inspector or his employer shall be liable in any manner for any personal injury or property damage or loss of any kind arising from or connected with this inspection.

Commissions 1275 CA.

Date 3-31-90

Inspector's Signature _____

NB, State, Province, Endorse. _____

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Iowa Electric Light and Power Date September 26, 1990
Name
P.O.Box 351, Cedar Rapids, IA 52406 Sheet 1 of 2
Address
2. Plant Duane Arnold Energy Center Unit 1
Name
3277 DAEC Rd. Palo, IA 52324 - DCP 1457, P.O. 802368
Address Repair Organization P.O.No., Job No.
3. Work Performed by Iowa Electric Type Code Symbol Stamp None
Name
Authorization No. None
3277 DAEC Road Palo, IA 52324 Expiration Date None
Address
4. Identification of System Recirc Pump B (Class 1)
5. (a) Applicable Const. Code ASME Section III 1968 Edition, W68 Addenda, N/A Code
Case (class C)
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements 1980 W81 class 2
(c) Fabrication of Item performed under Section III 1983 Edition, S84 Addenda (class 1)
6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacture	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired Replaced, or Replacement	ASME Code Stamped (Yes or No)
Cover/Heat Exchanger Assembly*	BW/IP Intl. INC.	206812	N/A	1P-201B	1990	Replacement	No
Case Stud (16 each)	BW/IP Intl. INC.	HT # 94910	N/A	1P-201B	1990	Replacement	No
Case Nut (16 each)	BW/IP Intl. INC.	HT # B5499	N/A	1P-201B	1990	Replacement	No

*Section XI items of the assembly include the pump cover, Ht. Exch. cover and HT. exch. coil

7. Description of Work Replaced Cover/Heat Exchanger Assembly for Recirc Pump
8. Tests Conducted: Hydrostatic ☐ Pneumatic ☐ Nominal Operation Pressure ☒
Other ☐ Pressure 1026 psi Test Temp. 206 °F

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8 1/2 in. x 11 in., (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.



11-19-90

FORM NIS-2 (Back)

sheet 2 of 2

9. Remarks Replacement of cover/heat exchanger assembly. VT-2 of recirc pump was performed under ISI report no. 89-13.
Applicable Manufacturer's Data Reports to be attached
- Preservice of the pump studs were performed under 89-277. Preservice VT-1 of the flange surface, pump nuts and
screws was performed under ISI numbers 89-280, 89-281, and 89-284. For information on recirc pump 1P-201A see
NIS2 10-90-54.

CERTIFICATE OF COMPLIANCE

We certify that the statements made in the report are correct and this replacement conforms
 to the rules of the ASME Code, Section XI. repair or replacement

Type Code Symbol Stamp NoneCertificate of Authorization No. None Expiration Date _____

Signed Sunder Sharga Codes & Materials, TGL Date 11-16 -, 19 90
 Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel
 Inspectors and the State or Province of Iowa and employed by Hartford Steam Boiler I&I Co
 of Hartford, Connecticut have inspected the components described in
 this Owner's Report during the period 7-28-90 to 11-19-90
 , and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective
 measures described in the Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied,
 concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the
 Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of
 any kind arising from or connected with this inspection.

Scott P. Fisher
 Inspectors Signature

Commissions NB 8829(I)(N) 941-1A
 National Board, State, Province, and Endorsements

Date Nov. 19 19 90

1. Owner IOWA ELECTRIC LIGHT & POWER

Date 30 Mar 90 Sheet 1 of 1

MAR 1990

2. Plant DUANE ARNOLD ENERGY CENTER

Unit DAEC UNIT ONE

Name
Palo, Iowa 52324

Address

3. Work Performed By BW/IP INTL., INC
2300 E. VERNON AVE, VERNON, CA 90058

Address

Repair Organization, PO No. Job No. etc
Type Code Symbol Stamp NONE

Authorization No. _____

Expiration Date _____

4. Identification of System RECIRCULATION PUMP

5. (a) Applicable Const. Code CL.C 1968 Edition WINTER Addenda 1968 Code Case N/A

(b) Applicable Edition of ASME XI Used for Repairs or Replacement 19 N/A

(c) Original Const Code CL.C 1968 Edition WINTER Addenda 1968 Code Case N/A

6. Identification of Component Repaired or Replaced and Replaced Components _____

Name of Component	Name of Manuf.	Manuf. S/N	Nat. Board No.	Other Ident.	Year Built	Repaired, Replaced, Replacement	ASME Cod Stamped Yes/No
COVER/HEAT EXCHANGER ASSEMBLY	BW/IP INTL. INC.	206812	N/A	891-L-8509	1990	REPLACEMENT	NO

7. Description of Work FABRICATION OF NEW COVER/HEAT EXCHANGER ASSEMBLY

8. Test Conducted (X) Hydrostatic () Pneumatic Nominal Operating Pressure 1030
() Other _____ Pressure 1875 psi Test Temp. 68

9. Remarks ITEM HAS BEEN FABRICATED IN ACCORDANCE WITH ASME SECTION III, CL.I, 1983
Applicable Manufacturers Data Report to Be Attached

CERTIFICATE OF COMPLIANCE

We certify that the statements made in this report are correct and this ITEM conforms to the statements of P.O. # 205-89E500 Repaired, Replaced (or Modified)
Signed _____ Date 30 MARCH 90
Repair Org. Designee/Title

CERTIFICATE OF SHOP INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of CALIFORNIA and employed by ARKWRIGHT MUTUAL INS. COOP NORWOOD, MASS have inspected the components described in this repair organization report during the period 10-25-89 to 3-30-90, and state that to the best of my knowledge and belief, the Repair Organization has performed examinations and taken corrective measures described in the Repair Organization Report in accordance with the requirements of the Owner's P.O. B02368 REV.1.

By signing this certificate neither the inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Repair Organization Report. Furthermore, neither the Inspector or his employer shall be liable in any manner for any personal injury or property damage or loss of any kind arising from or connected with this inspection.

Inspector's Signature

Commissions 1275 CA.

NB, State, Province, Endorse.

Date 3-30-90

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Iowa Electric Light and Power Date Oct 1, 1990
Name

P.O.Box 351, Cedar Rapids, IA 52406
Address

Date Oct 1, 1990

Sheet 1 of 2

2. Plant Duane Arnold Energy Center
Name

Unit 1

3277 DAEC Rd. Palo, IA 52324

PMAR 1043204

Address

Repair Organization P.O.No., Job No.

3. Work Performed by Iowa Electric
Name

Type Code Symbol Stamp None

Authorization No. None

3277 DAEC Rd. Palo, IA 52324
Address

Expiration Date None


4. Identification of System Main Steem (class 1)

5. * (a) Applicable Const. Code SECT. III 19 68 Edition, W68 Addenda, N/A Code Case

(b)Applicable Edition of Section XI Utilized for Repairs or Replacements 1980 W81

*GE Spec 21A9206 Rev 6 & 7

6. Identification of Components Repaired or Replaced and Replacement Components

 Name of Component	Name of Manufacture	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired Replaced, or Replacement	ASME Code Stamped (Yes or No)
MSRV Pilot Valve	Target Rock	S/N 226	N/A	PSV-4401	1975	Replaced	Yes
MSRV Pilot Valve	Target Rock	S/N 201	N/A	PSV-4401	1975	Replacement	Yes

7. Description of Work Replaced MSRV Pilot Valve s/n 226 with new Pilot Valve s/n 201.

8. Tests Conducted: Hydrostatic ☐ Pneumatic ☐ Nominal Operating Pressure ☒
 Other ☐ Pressure 1026 psi Test Temp. 206 °F

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8½ in. x 11 in., (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

AP
10-15-98

FORM NIS-2 (Back)

sheet 2 of 2

9. Remarks Replacement MSRV S/N 201 was VT-3 inspected (ISI Rpt# 90-190) and accepted. A VT-1 inspection (ISI Rpt# 90-189 was performed on the Bolting and accepted. After installation a system pressure test (ISI Rpt# 89-13)(VT-2) was performed with no leaks.

CERTIFICATE OF COMPLIANCE

We certify that the statements made in the report are correct and this replacement conforms to the rules of the ASME Code, Section XI. repair or replacement

Type Code Symbol Stamp NoneCertificate of Authorization No. None Expiration Date None

Signed Sunder Shaugi Codes & Materials, TGL Date 10-2
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of IOWA and employed by Hartford Steam Boiler I&I Co. of Hartford, Connecticut have inspected the components described in this Owner's Report during the period 6-15-90 to 10-15-90, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in the Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Scott Butler Commissioners NB 8829(I)(N) 941-IA
Inspectors Signature National Board, State, Province, and Endorsements

Date Oct 15 19 90

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Iowa Electric Light and Power Date Oct. 4, 1990
Name
P.O.Box 351, Cedar Rapids, IA 52406 Sheet 1 of 2
Address
2. Plant Duane Arnold Energy Center Unit 1
Name
3277 DAEC Rd. Palo, IA 52324 PMAR 1043206
Address Repair Organization P.O.No., Job No.
3. Work Performed by Iowa Electric Type Code Symbol Stamp None
Name
Authorization No. None
3277 DAEC Rd. Palo, IA 52324 Expiration Date None
Address
4. Identification of System Main Steam (class 1)
5. (a) Applicable Const. Code SECT. III 19 68 Edition, S69 Addenda, N/A Code
Case
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements 1980 W81
6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacture	Manufacture Serial No.	National Board No.	Other Identification	Year Built	Repaired Replaced, or Replacement	ASME Code Stamped (Yes or No)
Mtuds (6ea)	Tardinal	HT#8869139	N/A	PSV-4403	1989	Replacement	No
Muts (12es)	Tardinal	HT#KB4290	N/A	PSV-4403	1989	Replacement	No

7. Description of Work Replaced 12 Nuts and 6 Studs on PSV-4403 during installation.
8. Tests Conducted: Hydrostatic ☐ Pneumatic ☐ Nominal Operating Pressure ☒
Other ☐ Pressure 1026 psi Test Temp. 206 °F

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8½ in. x 11 in., (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.



FORM NIS-2 (Back)

sheet 2 of 2

9. Remarks PSV-4403 was removed for testing. During installation it was required to replace the studs and nuts due to
Applicable Manufacturer's Data Reports to be attached
damage. A preservice VT-1 (Rpt# 90-008) of the replacement belting and a VT-3 (Rpt# 90-009) of the valve body was
performed and accepted. After installation a VT-2 (Rpt# 89-13) was conducted and accepted.

CERTIFICATE OF COMPLIANCE

We certify that the statements made in the report are correct and this replacement conforms
 to the rules of the ASME Code, Section XI. repair or replacement

Type Code Symbol Stamp NoneCertificate of Authorization No. None Expiration Date None

Signed Sumner Schaefer Codes & Materials, TGL Date 10-5-90
 Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel
 Inspectors and the State or Province of IOWA and employed by Hartford Steam Boiler I&I Co.
of Hartford, Connecticut have inspected the components described in
 this Owner's Report during the period 8-14-90 to 10-15-90
 , and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective
 measures described in the Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied,
 concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the
 Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of
 any kind arising from or connected with this inspection.

Scott Risher Commissions NB 8829(I)(N) 941-1A
 Inspectors Signature National Board, State, Province, and Endorsements

Date Oct 15 1990

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Iowa Electric Light and Power Date November 14, 1990
P.O.Box 351, Cedar Rapids, IA 52406 Sheet 1 of 2
Address
2. Plant Duane Arnold Energy Center Unit 1
3277 DAEC Rd. Palo, IA 52324 DCP-1476
Address Repair Organization P.O.No., Job No.
3. Work Performed by General Electric Co. Type Code Symbol Stamp None
2311 W. 22nd ST., Oak Brook IL. 60521 Authorization No. None
Address Expiration Date None
4. Identification of System Main Steam 'A' (class 1)
5. (a) Applicable Const. Code *ANSI B31.1 19 67 Edition, N/A Addenda, N/A Code
 Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 1980 W81
 *Base Code - GE Spec. 21A9230 Rev. 2.
6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacture	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired Replaced, or Replacement	ASME Code Stamped (Yes or No)
Disc-piston assembly	General Elect.	215585-6	N/A	CV-4412	1990	Replacement	No
Disc	General Elect.	6062065-62	N/A	CV-4412	1985	Replaced	No
Piston	General Elect.	6062065-50	N/A	CV-4412	1985	Replaced	No
Stem Disc	General Elect.	214856-21	N/A	CV-4412	1990	Replacement	No
Bonnet	General Elect.	214856-17	N/A	CV-4412	1990	Replacement	No
Bonnet	General Elect.	N/A	N/A	CV-4412	1971	Replaced	No
Stem\stem disc assemb.	General Elect.	6053657-125	N/A	CV-4412	1988	Replaced	No
Additional Guide Pads	General Elect.	N/A	N/A	CV-4412	1990	Repaired	No
Studs (2ea)		RI-VB23	N/A	CV-4412		Replacement	No
Nuts (4ea)	Castle Metals	Ht#1N85326	N/A	CV-4412		Replacement	No

7. Description of Work The bonnet, disk-piston, and stem disc for CV-4412 were replaced and additional guide ribs were added under DCP-1476
8. Tests Conducted: Hydrostatic ☐ Pneumatic ☐ Nominal Operating Pressure ☒
 Other ☐ Pressure 1026 psi Test Temp. 206 °F

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8 1/2 in. x 11 in., (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

AP
11-19-92

FORM NIS-2 (Back)

sheet 2 of 2

9. Remarks MSIV, CV-4412 was modified per DCP-1476. The bonnet, stem disc, disc-piston assembly were replaced.
Applicable Manufacturer's Data Reports to be attached
- Additionally, four guide pads were welded on the valve body to assist in centering the disc. Bonnet studs
(2ea) and Nuts (4ea) were required to be replaced during re-assembly. A VT-1(90-246) and VT-3(90-247) examination
was performed and accepted. A VT-2(89-13) was completed and accepted after re-assembly.

CERTIFICATE OF COMPLIANCE

We certify that the statements made in the report are correct and this replacement conforms
 to the rules of the ASME Code, Section XI. repair or replacement

Type Code Symbol Stamp None

Certificate of Authorization No. None Expiration Date None

Signed Sunder Shaujai Codes & Materials, TGL Date 11-18-, 1990
 Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of IOWA and employed by Hartford Steam Boiler I&I Co.
of Hartford, Connecticut have inspected the components described in
 this Owner's Report during the period 2-9-88 to 11-17-88
 , and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective
 measures described in the Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Scott Presley Commissions NB 8829(I)(N) 941-IA
 Inspectors Signature National Board, State, Province, and Endorsements

Date Nov. 19 1988

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Iowa Electric Light and Power Date November 14, 1990
Name
P.O.Box 351, Cedar Rapids, IA 52406 Sheet 1 of 2
Address
2. Plant Duane Arnold Energy Center Unit. 1
Name
3277 DAEC Rd. Palo, IA 52324 DCP-1476
Address Repair Organization P.O.No., Job No.
3. Work Performed by General Electric Co. Type Code Symbol Stamp None
Name
Authorization No. None
2311 W. 22nd ST., Oak Brook IL. 60521 Expiration Date None
Address
4. Identification of System Main Steam 'A' (class 1)
5. (a)Applicable Const. Code *ANSI B31.1 19 67 Edition, N/A Addenda, N/A Code Case
(b)Applicable Edition of Section XI Utilized for Repairs or Replacements 1980 W81
*Base Code - GE Spec. 21A9230 Rev. 2.
6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacture	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired Replaced, or Replacement	ASME Code Stamped (Yes or No)
Disc-piston assembly	General Elect.	215585-12	N/A	CV-4413	1990	Replacement	No
Disc	General Elect.	6062065-63	N/A	CV-4413	1985	Replaced	No
Piston	General Elect.	6062065-55	N/A	CV-4413	1985	Replaced	No
Stem Disc	General Elect.	214856-20	N/A	CV-4413	1990	Replacement	No
Bonnet	General Elect.	214856-10	N/A	CV-4413	1990	Replacement	No
Bonnet	General Elect.	N/A	N/A	CV-4413	1971	Replaced	No
Stem\stem disc assemb.	General Elect.	6062065-30	N/A	CV-4413	1988	Replaced	No
Additional Guide Pads	General Elect.	N/A	N/A	CV-4413	1990	Repaired	No
Studs (1ea)		RI-VB23-C195	N/A	CV-4413		Replacement	No

7. Description of Work The bonnet, disc-piston, and stem disc for CV-4413 were replaced and additional guide ribs were added under DCP-1476
8. Tests Conducted: Hydrostatic ☐ Pneumatic ☐ Nominal Operating Pressure ☒
Other ☐ Pressure 1026 psi Test Temp. 206 °F

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8½ in. x 11 in., (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

11-19-78

FORM NIS-2 (Back)

sheet 2 of 2

9. Remarks MSIV, CV-4413 was modified per DCP-1476. The bonnet, stem disc, and disc-piston assembly were replaced.
Applicable Manufacturer's Data Reports to be attached

Additionally, four guide pads were welded on the valve body to assist in centering the disc, 1 bonnet stud
needed to be replaced during re-assembly. A VT-1 (90-248) and VT-3 (90-249) examinations were performed and
accepted. A VT-2 (89-13) was completed and accepted after re-assembly.

CERTIFICATE OF COMPLIANCE

We certify that the statements made in the report are correct and this replacement conforms
to the rules of the ASME Code, Section XI. repair or replacement

Type Code Symbol Stamp None

Certificate of Authorization No. None Expiration Date None

Signed Sumner Shaujan Codes & Materials, TGL Date 11-78
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel
Inspectors and the State or Province of IOWA and employed by Hartford Steam Boiler I&I Co.
of Hartford, Connecticut have inspected the components described in
this Owner's Report during the period 7-2-90 to 11-19-90
, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective
measures described in the Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied,
concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the
Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of
any kind arising from or connected with this inspection.

[Signature] Commissions NB 8829(I)(N) 941-IA
Inspectors Signature National Board, State, Province, and Endorsements

Date Nov 19 1990

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

Owner Iowa Electric Light and Power Date November 14, 1990
Name _____

P.O.Box 351, Cedar Rapids, IA 52406 Sheet 1 of 2
Address

2. Plant Duane Arnold Energy Center Unit 1
Name _____

3277 DAEC Rd. Palo, IA 52324	DCP-1476
Address	Repair Organization P.O.No., Job No.

3. Work Performed by General Electric Co. Type Code Symbol Stamp None
Name

Authorization No. None

2311 W. 22nd ST., Oak Brook IL. 60521 Expiration Date None

4. Identification of System Main Steam 'B' (class 1)

5. (a) Applicable Const. Code *ANSI B31.1 19 67 Edition, N/A Addenda, N/A Code Case

(b)Applicable Edition of Section XI Utilized for Repairs or Replacements 1980 W81

*Base Code - GE Spec. 21A9230 Rev. 2.

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacture	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired Replaced, or Replacement	ASME Code Stamped (Yes or No)
Disc-piston assembly	General Elect.	215585-11	N/A	CV-4415	1990	Replacement	No
Disc	General Elect.	6053657-123	N/A	CV-4415	1988	Replaced	No
Piston	General Elect.	6062065-53	N/A	CV-4415	1985	Replaced	No
Stem Disc	General Elect.	214856-22	N/A	CV-4415	1990	Replacement	No
Bonnet	General Elect.	214856-11	N/A	CV-4415	1990	Replacement	No
Bonnet	General Elect.	N/A	N/A	CV-4415	1971	Replaced	No
Stem\stem disc assemb.	General Elect.	6053657-126	N/A	CV-4415	1988	Replaced	No
Additional Guide Pads	General Elect.	N/A	N/A	CV-4415	1990	Repaired	No

7. Description of Work The bonnet, disc-piston, and stem disc for CV-4415 were replaced and additional guide ribs were added under DCP-1476

8. Tests Conducted: Hydrostatic ☐ Pneumatic ☐ Nominal Operating Pressure ☒
Other ☐ Pressure 1026 psi Test Temp. 206 °F

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8½ in. x 11 in., (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

AD
11-19-92

FORM NIS-2 (Back)

sheet 2 of 2

9. Remarks MSIV, CV-4415 was modified per DCP-1476. The bonnet, stem disc and piston assembly
Applicable Manufacturer's Data Reports to be attached
were replaced. Additionally, four guide pads were welded on the valve body to assist in centering the disc. A valve
body base metal repair was performed (ref. NCR 90-062) and accepted (VT-3 90-326). A VT-1(90-250) and VT-3(90-251)
was performed and accepted. A VT-2(89-13) was also performed and accepted after re-assembly.

CERTIFICATE OF COMPLIANCE

We certify that the statements made in the report are correct and this replacement conforms
 to the rules of the ASME Code, Section XI. repair or replacement

Type Code Symbol Stamp None

Certificate of Authorization No. None Expiration Date None

Signed Swinder Shaugan Codes & Materials, TGL Date 11-16-
 Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel
 Inspectors and the State or Province of IOWA and employed by Hartford Steam Boiler I&I Co.
of Hartford, Connecticut have inspected the components described in
 this Owner's Report during the period 7-7-92 to 11-19-92
 , and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective
 measures described in the Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied,
 concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the
 Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of
 any kind arising from or connected with this inspection.

Scott Butler Commissions NB 8829(I)(N) 941-1A
 Inspectors Signature National Board, State, Province, and Endorsements

Date Nov 19 1992

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Iowa Electric Light and Power Date November 14, 1990
 Name
P.O.Box 351, Cedar Rapids, IA 52406 Sheet 1 of 2
 Address
2. Plant Duane Arnold Energy Center Unit 1
 Name
3277 DAEC Rd. Palo, IA 52324 DCP-1476
 Address Repair Organization P.O.No., Job No.
3. Work Performed by General Electric Co. Type Code Symbol Stamp None
 Name
 Authorization No. None
2311 W. 22nd ST., Oak Brook IL. 60521 Expiration Date None
 Address
4. Identification of System Main Steam 'B' (class 1)
5. (a) Applicable Const. Code *ANSI B31.1 19 67 Edition, N/A Addenda, N/A Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 1980 W81
 *Base Code - GE Spec. 21A9230 Rev. 2.
6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacture	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired Replaced, or Replacement	ASME Code Stamped (Yes or No)
Disc-piston assembly	General Elect.	215585-5	N/A	CV-4416	1990	Replacement	No
Disc	General Elect.	6062065-61	N/A	CV-4416	1985	Replaced	No
Piston	General Elect.	6062065-51	N/A	CV-4416	1985	Replaced	No
Stem Disc	General Elect.	214856-19	N/A	CV-4416	1990	Replacement	No
Bonnet	General Elect.	214856-14	N/A	CV-4416	1990	Replacement	No
Bonnet	General Elect.	N/A	N/A	CV-4416	1971	Replaced	No
Stem\stem disc assemb.	General Elect.	6062065-29	N/A	CV-4416	1985	Replaced	No
Additional Guide Pads	General Elect.	N/A	N/A	CV-4416	1990	Repaired	No
Studs (4ea)		RI-VB23-C195	N/A	CV-4416		Replacement	No
Nuts (1ea)	Castle Metals	HT#IN85326	N/A	CV-4416		Replacement	No

7. Description of Work The bonnet, disc-piston, and stem disc for CV-4416 were replaced and additional guide ribs were added under DCP-1476

8. Tests Conducted: Hydrostatic ☐ Pneumatic ☐ Nominal Operating Pressure ☒
 Other ☐ Pressure 1026 psi Test Temp. 206 °F

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8½ in. x 11 in., (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.



FORM NIS-2 (Back)

sheet 2 of 2

9. Remarks MSIV, CV-4416 was modified per DCP-1476. The bonnet, stem disc, and disc-piston assembly were replaced.
Applicable Manufacturer's Data Reports to be attached
- Additionally, four guide pads were welded on the valve body to assist in centering the disc. Bonnet bolts
(4ea) and Nuts (1ea) were required to be replaced during re-assembly. A VT-1(90-252) and VT-3(90-253) examination
was performed and accepted. A VT-2(89-13) was completed and accepted after re-assembly.

CERTIFICATE OF COMPLIANCE

We certify that the statements made in the report are correct and this replacement conforms
 to the rules of the ASME Code, Section XI. repair or replacement

Type Code Symbol Stamp NoneCertificate of Authorization No. None Expiration Date None

Signed Sumner Shaufer Codes & Materials, TGL Date 11-16-
 Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel
 Inspectors and the State or Province of IOWA and employed by Hartford Steam Boiler I&I Co.
 of Hartford, Connecticut have inspected the components described in
 this Owner's Report during the period 7-2-92 to 11-18-92
 , and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective
 measures described in the Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied,
 concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the
 Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of
 any kind arising from or connected with this inspection.

Scott L. Linder Commissions NB 8829(I)(N) 941-1A
 Inspectors Signature National Board, State, Province, and Endorsements

Date Nov. 19, 1992

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Iowa Electric Light and Power Date November 14, 1990
 Nema
 P.O.Box 351, Cedar Rapids, IA 52406 Sheet 1 of 2
 Address
2. Plant Duane Arnold Energy Center Unit 1
 Nema
 3277 DAEC Rd. Palo, IA 52324 DCP-1476
 Address Repair Organization P.O.No., Job No.
3. Work Performed by General Electric Co. Type Code Symbol Stamp None
 Name Authorization No. None
 2311 W. 22nd ST., Oak Brook IL. 60521 Expiration Date None
 Address
4. Identification of System Main Steam 'C' (class 1)
5. (a)Applicable Const. Code *ANSI B31.1 19 67 Edition, N/A Addenda, N/A Code Case
 (b)Applicable Edition of Section XI Utilized for Repairs or Replacements 1980 W81
 *Base Code - GE Spec. 21A9230 Rev. 2.
6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacture	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired Replaced, or Replacement	ASME Code Stamped (Yes or No)
Disc-piston assembly	General Elect.	215585-9	N/A	CV-4418	1990	Replacement	No
Disc	General Elect.	6062065-57	N/A	CV-4418	1985	Replaced	No
Piston	General Elect.	6062065-52	N/A	CV-4418	1985	Replaced	No
Stem Disc	General Elect.	214856-23	N/A	CV-4418	1990	Replacement	No
Bonnet	General Elect.	214856-16	N/A	CV-4418	1990	Replacement	No
Bonnet	General Elect.	N/A	N/A	CV-4418	1971	Replaced	No
Stem\stem disc assemb.	General Elect.	6062065-34	N/A	CV-4418	1985	Replaced	No
Additional Guide Pads	General Elect.	N/A	N/A	CV-4418	1990	Repaired	No

7. Description of Work The bonnet, disc-piston, and stem disc for CV-4418 were replaced and additional guide ribs were added under DCP-1476
8. Tests Conducted: Hydrostatic ☐ Pneumatic ☐ Nominal Operating Pressure ☒
 Other ☐ Pressure 1026 psi Test Temp. 206 °F

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8 1/2 in. x 11 in., (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

11-19-90

FORM NIS-2 (Back)

sheet 2 of 2

9. Remarks MSIV, CV-4418 was modified per DCP-1476. The bonnet, stem disc, disc-piston assembly
Applicable Manufacturer's Data Reports to be attached
were replaced. Additionally, four guide pads were welded on the valve body to assist in centering the disc. A VT-1
(90-254) and VT-3 (90-255) was performed and accepted. A VT-2 (89-13) examination was performed and accepted after
re-assembly.

CERTIFICATE OF COMPLIANCE

We certify that the statements made in the report are correct and this replacement conforms
 to the rules of the ASME Code, Section XI. repair or replacement

Type Code Symbol Stamp NoneCertificate of Authorization No. None Expiration Date None

Signed Sumner Shapira Codes & Materials, TGL Date 11-16, 1990
 Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel
 Inspectors and the State or Province of IOWA and employed by Hartford Steam Boiler I&I Co.
 of Hartford, Connecticut have inspected the components described in
 this Owner's Report during the period 7-7-90 to 11-14-90
 , and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective
 measures described in the Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied,
 concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the
 Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of
 any kind arising from or connected with this inspection.

Scott Fowler Commissions NB 8829(I)(N) 941-1A
 Inspectors Signature National Board, State, Province, and Endorsements

Date Nov 19 1990

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Iowa Electric Light and Power Date November 14, 1990
Name
P.O.Box 351, Cedar Rapids, IA 52406 Sheet 1 of 2
Address
2. Plant Duane Arnold Energy Center Unit 1
Name
3277 DAEC Rd. Palo, IA 52324 DCP-1476
Address Repair Organization P.O.No., Job No.
3. Work Performed by General Electric Co. Type Code Symbol Stamp None
Name
Authorization No. None
2311 W. 22nd ST., Oak Brook IL. 60521 Expiration Date None
Address
4. Identification of System Main Steam 'C' (class 1)
5. (a) Applicable Const. Code *ANSI B31.1 19 67 Edition, N/A Addenda, N/A Code
Case
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements 1980 W81
*Base Code - GE Spec. 21A9230 Rev. 2.
6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacture	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired Replaced, or Replacement	ASME Code Stamped (Yes or No)
Disc-piston assembly	General Elect.	215585-8	N/A	CV-4419	1990	Replacement	No
Disc	General Elect.	6062065-59	N/A	CV-4419	1985	Replaced	No
Piston	General Elect.	6062065-49	N/A	CV-4419	1985	Replaced	No
Stem Disc	General Elect.	214856-18	N/A	CV-4419	1990	Replacement	No
Bonnet	General Elect.	214856-13	N/A	CV-4419	1990	Replacement	No
Bonnet	General Elect.	N/A	N/A	CV-4419	1971	Replaced	No
Stem\stem disc assemb.	General Elect.	6062065-28	N/A	CV-4419	1985	Replaced	No
Additional Guide Pads	General Elect.	N/A	N/A	CV-4419	1990	Repaired	No

7. Description of Work The bonnet, disc-piston, and stem disc for CV-4419 were replaced and additional guide ribs were added under DCP-1476
8. Tests Conducted: Hydrostatic ☐ Pneumatic ☐ Nominal Operating Pressure ☒
Other ☐ Pressure 1026 psi Test Temp. 206 °F

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8½ in. x 11 in., (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.



FORM NIS-2 (Back)

sheet 2 of 2

9. Remarks MSIV, CV-4419 was modified per DCP-1476. The bonnet, stem disc, and disc-piston assembly
Applicable Manufacturer's Data Reports to be attached
were replaced. Additionally, four guide pads were welded on the valve body to assist in centering the disc. A valve
body repair was performed (ref. NCR 90-045) and accepted (VT-3 90-302). A VT-1(90-256) and VT-3(257) examination
was performed and accepted. A VT-2(89-13) was also conducted and accepted after re-assembly.

CERTIFICATE OF COMPLIANCE

We certify that the statements made in the report are correct and this replacement conforms
to the rules of the ASME Code, Section XI. repair or replacement

Type Code Symbol Stamp None

Certificate of Authorization No. None Expiration Date None

Signed Sumner Shauger Codes & Materials, TGL Date 11-16-90
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel
Inspectors and the State or Province of IOWA and employed by Hartford Steam Boiler I&I Co.
of Hartford, Connecticut have inspected the components described in
this Owner's Report during the period 7-3-90 to 11-18-90
, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective
measures described in the Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied,
concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the
Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of
any kind arising from or connected with this inspection.

Scott Preston Commissions NB 8829(I)(N) 941-1A
Inspectors Signature National Board, State, Province, and Endorsements

Date Nov 19 19 90

FORM NIS-2 (Back)

sheet 2 of 2

9. Remarks MSIV, CV-4420 was modified per DCP-1476. The bonnet, stem disc, and disc-piston assembly
Applicable Manufacturer's Data Reports to be attached
were replaced. Additionally, four guide pads were welded on the valve body to assist in centering the disc. A valve
body repair was performed (ref. NCR 90-063) and accepted (VT-3 90-327). A VT-1(90-258) and VT-3(259) examination
was performed and accepted. A VT-2(89-13) was also conducted and accepted after re-assembly.

CERTIFICATE OF COMPLIANCE

We certify that the statements made in the report are correct and this replacement conforms
 to the rules of the ASME Code, Section XI. repair or replacement

Type Code Symbol Stamp NoneCertificate of Authorization No. None Expiration Date None

Signed Sumner Spang Codes & Materials, TGL Date 11-16-, 1990
 Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel
 Inspectors and the State or Province of IOWA and employed by Hartford Steam Boiler I&I Co.
of Hartford, Connecticut have inspected the components described in
 this Owner's Report during the period 7-2-88 to 11-16-88
 , and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective
 measures described in the Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied,
 concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the
 Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of
 any kind arising from or connected with this inspection.

Inspectors Signature [Signature]Commissions NB 8829(1)(N) 941-1A

National Board, State, Province, and Endorsements

Date Nov. 19, 1990

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Iowa Electric Light and Power Date November 14, 1990
Name
- P.O.Box 351, Cedar Rapids, IA 52406 Sheet 1 of 2
Address
2. Plant Duane Arnold Energy Center Unit 1
Name
- 3277 DAEC Rd. Palo, IA 52324 DCP-1476
Address Repair Organization P.O.No., Job No.
3. Work Performed by General Electric Co. Type Code Symbol Stamp None
Name Authorization No. None
- 2311 W. 22nd ST., Oak Brook IL. 60521 Expiration Date None
Address
4. Identification of System Main Steam 'D' (class 1)
5. (a)Applicable Const. Code *ANSI B31.1 19 67 Edition, N/A Addenda, N/A Code Case
 (b)Applicable Edition of Section XI Utilized for Repairs or Replacements 1980 U81
 *Base Code - GE Spec. 21A9230 Rev. 2.
6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacture	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired Replaced, or Replacement	ASME Code Stamped (Yes or No)
Disc-piston assembly	General Elect.	215585-10	N/A	CV-4421	1990	Replacement	No
Disc	General Elect.	6062065-56	N/A	CV-4421	1985	Replaced	No
Piston	General Elect.	6062065-48	N/A	CV-4421	1985	Replaced	No
Stem Disc	General Elect.	214856-25	N/A	CV-4421	1990	Replacement	No
Bonnet	General Elect.	214856-12	N/A	CV-4421	1990	Replacement	No
Bonnet	General Elect.	N/A	N/A	CV-4421	1971	Replaced	No
Stem\stem disc assemb.	General Elect.	6062065-26	N/A	CV-4421	1985	Replaced	No
Additional Guide Pads	General Elect.	N/A	N/A	CV-4421	1990	Repaired	No

7. Description of Work The bonnet, disc-piston, and stem disc for CV-4421 were replaced and additional guide ribs were added under DCP-1476
8. Tests Conducted: Hydrostatic ☐ Pneumatic ☐ Nominal Operating Pressure ☒
 Other ☐ Pressure 1026 psi Test Temp. 206 °F

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8 1/2 in. x 11 in., (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

AP
11-19-90

FORM NIS-2 (Back)

sheet 2 of 2

9. Remarks MSIV, CV-4421 was modified per DCP-1476. The bonnet, stem disc, and disc-piston assembly
Applicable Manufacturer's Data Reports to be attached
were replaced. Additionally, four guide pads were welded on the valve body to assist in centering the disc. A VT-1
(90-260) and VT-3 (90-261) was performed and accepted. A VT-2 (89-13) was conducted and accepted after re-assembly

CERTIFICATE OF COMPLIANCE

We certify that the statements made in the report are correct and this replacement conforms
 to the rules of the ASME Code, Section XI. repair or replacement

Type Code Symbol Stamp NoneCertificate of Authorization No. None Expiration Date None

Signed Sumner Shantz Codes & Materials, TGL Date 11-16, 1992
 Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel
 Inspectors and the State or Province of IOWA and employed by Hartford Steam Boiler I&I Co.
 of Hartford, Connecticut have inspected the components described in
 this Owner's Report during the period 7-8-92 to 11-19-92
 , and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective
 measures described in the Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied,
 concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the
 Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of
 any kind arising from or connected with this inspection.

Scotti Pearson Commissions NB 8829(I)(N) 941-1A
 Inspectors Signature National Board, State, Province, and Endorsements

Date Nov 19 1992

SERVICE INSPECTION REPORT

December 28, 1988 through September 10, 1990

Part H, Page 1 of 1

- 1) Owners: Iowa Electric Light and Power Company
P.O. Box 351
Cedar Rapids, Iowa 52406

Central Iowa Power Cooperative
Marion, Iowa

Corn Belt Power Cooperative
Humboldt, Iowa

- 2) Plant Duane Arnold Energy Center, Palo, Iowa 52324
- 3) Plant Unit #1
- 4) Owners Certificate of Authorization (if required) N/A
- 5) Commercial Service Date 2-1-75
- 6) National Board Number of Unit N/A

Abstract of Conditions Noted and Corrective Measures Taken:

The corrective measures addressed in this report were performed in accordance with the American Society of Mechanical Engineers Boiler and Pressure Vessel Code, Section XI, 1980 Edition through Winter 1981 Addenda, and the Duane Arnold Energy Center Updated Final Safety Analysis Report. The corrective measures performed as Repairs or Replacements are listed in Part F of this report and are documented, using form NIS-2, in accordance with the American Society of Mechanical Engineers Boiler and Pressure Vessel Code, Section XI, 1980 Edition through Winter 1982 Addenda. Specific details and associated records of additional corrective measures are on file at Iowa Electric Light and Power Company. The corrective measures addressed were performed during the period of December 28, 1988 through September 10, 1990.

INSERVICE INSPECTION REPORT
December 28, 1988 through September 10, 1990

Part I, Pages 45

- 1) Owners: Iowa Electric Light and Power Company
P.O. Box 351
Cedar Rapids, Iowa 52406

Central Iowa Power Cooperative
Marion, Iowa

Corn Belt Power Cooperative
Humboldt, Iowa

- 2) Plant Duane Arnold Energy Center, Palo, Iowa 52324

- 3) Plant Unit #1

- 4) Owners Certificate of Authorization (if required) N/A


- 5) Commercial Service Date 2-1-75

- 6) National Board Number of Unit N/A

GROSS GENERATING CAPACITY: 565 MWE

ISI FIGURES AND ISOMETRICS

PLEASE NOTE: ISI Figures & Isometrics is listed in Part B of this report




CIRCUMFERENTIAL SEAM WELDS

Figure No. 1.1-3

DRAWING RELEASE RECORD

REV	DATE	PREPARED	REVIEWED	APPROVED	PURPOSE
1	4-3-86	SML	SML	RCM	ISO'S FOR 2nd 10 YEAR PLAN
2	9-24-90	<i>(Signature)</i>	<i>(Signature)</i>	<i>RCM</i>	ISO'S TO CAD FORMAT AS PER NG-89-0794



VESSEL STUD AND LIGAMENT LOCATION

Figure No. 1.1-5

PR-Pressure Retaining
 A-Studs
 B-Nuts
 C-Bushings
 D-Washers
 E-Ligaments

DRAWING RELEASE RECORD

REV	DATE	PREPARED	REVIEWED	APPROVED	PURPOSE
1	4-3-86	SML	SML	RCM	ISO'S FOR 2nd 10 YEAR PLAN
2	9-24-90	<i>(Signature)</i>	<i>(Signature)</i>	<i>RCM</i>	ISO'S TO CAD FORMAT AS PER NG-89-0794

REV	DATE	PREPARED	REVIEWED	APPROVED	PURPOSE
1	4-3-86	SM	SM	RCM	ISO'S FOR 2nd 10 YEAR PLAN
2	9-24-90	SM	SM	RCM	ISO'S TO CAD FORMAT AS PER NG-85-0794

DRAWING RELEASE RECORD

ELEVATION

Top Head
56' -4 31/32"

Course 4

44' 2 7/8"

Course 3

32' -0 3/4"


Course 2

19' -10 5/8"

Course 1


7' -8 1/2"

Bottom Head



VESSEL NOZZLE LOCATION

FIGURE NO. 1.1-6




89 CRD' S

CRD FIGURE NO. 1.1-8B

DRAWINGS:
BECH-B11-012

DRAWING RELEASE RECORD					
REV	DATE	PREPARED	REVIEWED	APPROVED	PURPOSE
1	9-24-90	<i>[Signature]</i>	<i>[Signature]</i>	<i>[Signature]</i>	ISO'S TO CAO FORMAT AS PER NG-89-0794



MAIN STEAM "A"

MSA-

CS, 20", 6"


ISO. NO. 1.2-1

P&ID ISI-M114
APEO-B21.7

* - NON INTEGRAL
** - 1" FLOW ELEMENT LINE


DRAWING RELEASE RECORD

REV	DATE	PREPARED	REVIEWED	APPROVED	PURPOSE
1	3-6-86	SML	SML	RCM	ISO'S FOR 2nd 10 YEAR PLAN
2	9-24-90	<i>[Signature]</i>	<i>[Signature]</i>	<i>[Signature]</i>	ISO'S TO CAD FORMAT AS PER NG-69-0794




```
* - NON INTEGRAL
** - 1" FLOW ELEMENT LINE
```

CONT. ON
ISO. NO. 2-2-55-




DRAWING RELEASE RECORD

REV	DATE	PREPARED	REVIEWED	APPROVED	PURPOSE
1	3-10-86	SML	SML	RCM	ISO'S FOR 2nd 10 YEAR PLAN
2	9-24-90	<i>[Signature]</i>	<i>[Signature]</i>	<i>[Signature]</i>	ISO'S TO CAO FORMAT AS PER NG-89-0794



DRAWING RELEASE RECORD

REV	DATE	PREPARED	REVIEWED	APPROVED	PURPOSE
1	3-11-86	SML	SML	RCM	ISO'S FOR 2nd 10 YEAR PLAN
2	9-24-90	<i>[Signature]</i>	<i>[Signature]</i>	<i>[Signature]</i>	ISO'S TO CAD FORMAT AS PER NG-89-0794





* - NON INTEGRAL

REV	DATE	PREPARED	REVIEWED	APPROVED	PURPOSE
1	3-12-86	SAL	9HL	RCM	ISO'S FOR 2nd 10 YEAR PLAN
2	9-24-90	(Signature)	(Signature)	K2m	ISO'S TO CAD FORMAT AS PER NG-83-0794

* - NON INTEGRAL

DRAWING RELEASE RECORD






HIGH PRESSURE COOLANT INJECTION - WATER

PSB-

CS, 12"

ISO. NO. 1.2-10



P&ID ISI-M123
BECH DWG# DLA-1-1-H

P&ID BECH-M123
BECH DWG# DLA-1-1-H

EL. 759'

CONT'D ON
ISO. NO.
2.2-45

* - NON INTEGRAL


DRAWING RELEASE RECORD

REV	DATE	PREPARED	REVIEWED	APPROVED	PURPOSE
1	3-12-86	SML	SML	RCM	ISO'S FOR 2nd 10 YEAR PLAN
2	9-24-90	(SML)	(SML)	(RCM)	ISO'S TO CAO FORMAT AS PER NG-89-0794

REV	DATE	PREPARED	REVIEWED	APPROVED	PURPOSE
1	3-13-86	SQL	SQL	RCH	ISO'S FOR 2nd 10 YEAR PLAN
2	4-24-90	SQL	SQL	RCH	ISO'S TO CAD FORMAT AS PER NG-89-0794
3	9-24-90	SQL	SQL	RCH	DCP 1464, RUCU NONCLASS REPLACEMENT

DRAWING RELEASE RECORD

* - NON INTEGRAL




REACTOR WATER CLEANUP
- DISCHARGE (CLEAN)
CUB-
CS, SS, 4"
ISO. NO. 1.2-11B

P&ID ISI-M127
BECH DWG# DCA-14-1-H

ISO. 1.2-18
RSB
4"x4"x4" T

ORAC INSERVICE INSPECTION ASME SECTION XI ISOMETRIC



CONTROL ROD DRIVE RETURN

CRA-

SS, CS, 2 1/2" → 3"

ISO. NO. 1.2-12A

CONT. ON

ISO. NO. 1.2-12B


P&IS ISI-M117

BECH. DWG# DBA-6-1-H

DRAWING RELEASE RECORD

REV	DATE	PREPARED	REVIEWED	APPROVED	PURPOSE
1	3-13-86	SML	SML	RCM	ISO'S FOR 2nd 10 YEAR PLAN
2	9-24-90	<i>(Signature)</i>	<i>(Signature)</i>	<i>RCM</i>	ISO'S TO CAO FORMAT AS PER NG-89-0794

3/4" CAPPED CONN.



P&ID BECH-M117
BECH DWG# DBA-6-2-H

CONTROL ROD DRIVE RETURN
CRA-
CS, 3"
ISO. NO. 1.2-12B

* - NON INTEGRAL

DRAWING RELEASE RECORD

REV	DATE	PREPARED	REVIEWED	APPROVED	PURPOSE
1	3-13-86	SIL	ML	RCM	ISO'S FOR 2nd 10 YEAR PLAN
2	9-24-90	DB	GA	722	ISO'S TO CAD FORMAT AS PER NG-89-0794

RHR-HEADSPRAY

RHA


C.S. - 6"

ISO. NO. 1.2-13

P&ID-M119


BECH DWG# DBA-5-1-H

6" DIA. 1500# BLIND FLANGE



DRAWING RELEASE RECORD


REV	DATE	PREPARED	REVIEWED	APPROVED	PURPOSE
1	3-14-86	SML	SML	RCM	ISO'S FOR 2nd 10 YEAR PLAN
2	10-26-87	JPM	RCM	REL	PORTION OF SYSTEM REMOVAL PER DCP 1385, 1987 RFO
3	9-24-90	<i>[Signature]</i>	<i>[Signature]</i>	<i>[Signature]</i>	ISO'S TO CAD FORMAT AS PER NG-89-8794



RESIDUAL HEAT REMOVAL-18B
RHB-
SS, CS, 18"
ISO. NO. 1.2-14

P&ID BECH-M119
BECH DWG# DLA-4-1-H

CONT'D ON
ISO. NO.
2.2-34




* - NON INTEGRAL

DRAWING RELEASE RECORD

REV	DATE	PREPARED	REVIEWED	APPROVED	PURPOSE
1	3-17-86	SML	SML	RCM	ISO'S FOR 2nd 10 YEAR PLAN
2	9-24-90	<i>[Signature]</i>	<i>[Signature]</i>	<i>KZM</i>	ISO'S TO CAD FORMAT AS PER NG-89-0794

CONT'D ON
ISO. NO.
2.2-37A ☐

NO 2003



RESIDUAL HEAT REMOVAL-20A
RHC-
SS, CS, 20"
ISO. NO. 1.2-15


* - NON INTEGRAL

P&ID BECH-M120
BECH DWG# DLA-5-1-H

REV	DATE	PREPARED	REVIEWED	APPROVED	PURPOSE
1	3-18-86	SAL	SML	RCH	ISO'S FOR 2nd 10 YEAR PLAN
2	9-24-90	<i>[Signature]</i>	<i>[Signature]</i>	<i>[Signature]</i>	ISO'S TO CAD FORMAT AS PER NG-89-0794


DRAWING RELEASE RECORD

CONT'D ON
ISO. NO.
2.2-40



P&ID BECH-MI19
BECH DWG# DLA-6-1-H


* - NON INTEGRAL



RESIDUAL HEAT REMOVAL-20B
RHD-
SS, CS, 20"
ISO. NO. 1.2-16


REV	DATE	PREPARED	REVIEWED	APPROVED	PURPOSE
1	3-19-86	SRL	SRL	RCM	ISO'S FOR 2nd 10 YEAR PLAN
2	4-24-90	(Signature)	(Signature)	(Signature)	ISO'S TO CAD FORMAT AS PER NC-89-0794

DRAWING RELEASE RECORD



REV	DATE	PREPARED	REVIEWED	APPROVED	PURPOSE
1	3-19-86	SHL	SHL	RCH	ISO'S FOR 2nd 10 YEAR PLAN
2	9-24-90	SHL	SHL	RCH	ISO'S TO CAD FORMAT AS PER NG-89-0794

DRAWING RELEASE RECORD




* - NON INTEGRAL

DRAIN LINE RECIRC. "A"
 2" S.S. RDA
 ISO. NO. 1.2-19B

P&ID BECH-M116
 FSK-04202

REV	DATE	PREPARED	REVIEWED	APPROVED	PURPOSE
1	3-20-86	STL	STL	RCM	ISO'S FOR 2nd 10 YEAR PLAN
2	4-24-90	STL	STL	RCM	ISO'S TO CAD FORMAT AS PER NG-89-0794

DRAWING RELEASE RECORD




RECIRCULATION MANIFOLD "A" & RISERS E, F, G, H
RMA-, RRE-, RRF-, RRG-, RRH-
SS, 16", 10"
ISO. NO. 1.2-20


P&ID BECH-M116
APED-B31-9
** - LUG EXEMPT <5/8"

REV	DATE	PREPARED	REVIEWED	APPROVED	PURPOSE
1	3-21-86	SM	SM	RCM	ISO'S FOR 2nd 10 YEAR PLAN
2	9-2-89	SM	SM	RCM	ADDED HYDROGEN MONITOR, OCP1434
3	9-24-90	SM	SM	RCM	ISO'S TO CAD FORMAT AS PER NG-89-0734

DRAWING RELEASE RECORD

P&ID BECH-M116
 APED-B31-9
 * - NON INTEGRAL






JET PUMP INSTRUMENTATION "A"
 JPA-
 SS, 4"
 ISO. NO. 1.2-25

P&ID BECH-M115
 APED-B11-2655-105-4


DRAWING RELEASE RECORD

REV	DATE	PREPARED	REVIEWED	APPROVED	PURPOSE
1	3-26-86	SML	SML	RCM	ISO'S FOR 2nd 10 YEAR PLAN
2	9-24-90	<i>(Signature)</i>	<i>(Signature)</i>	<i>KRM</i>	ISO'S TO CAD FORMAT AS PER NC-85-0794




DRAWING RELEASE RECORD

REV	DATE	PREPARED	REVIEWED	APPROVED	PURPOSE
1	10-26-87	JPM	RCM	REL	ISO'S FOR 2nd 10 YEAR PLAN
2	9-24-90	<i>[Signature]</i>	<i>[Signature]</i>	<i>KRM</i>	ISO'S TO CAD FORMAT AS PER NG-99-0794



1 LUG


REV	DATE	PREPARED	REVIEWED	APPROVED	PURPOSE
1	10-26-87	JRM	RCM	REL	ISO'S FOR 2nd 10 YEAR PLAN
2	9-24-90				ISO'S TO CAD FORMAT AS PER NG-89-0794



DRAWING RELEASE RECORD

REV	DATE	PREPARED	REVIEWED	APPROVED	PURPOSE
1	10-26-87	JRM	RCM	REL	ISO'S FOR 2nd 10 YEAR PLAN
2	9-24-90	<i>[Signature]</i>	<i>[Signature]</i>	<i>[Signature]</i>	ISO'S TO CAD FORMAT AS PER NG-89-0794

REV	DATE	PREPARED	REVIEWED	APPROVED	PURPOSE
1	4-21-86	SML			ISO'S FOR 2nd 10 YEAR PLAN
2	9-18-90	(SML)			ISO'S TO CNO FORMAT AS PER NG-89-0794



- * - NON INTEGRAL
- ** - EXEMPT < 3/4"
- *** - INST. LINE
- **** - PSV LINE < 1"


RHR PUMP SUCTION (S.E.)
 WELD PREFIX RHA
 CS, 14" & 24"
 ISO. NO. 2.2-32

P&ID ISI-M120
 BECH. DWG# 712-H

REV	DATE	PREPARED	REVIEWED	APPROVED	PURPOSE
1	4-25-86	SM	SM	RCM	ISO'S FOR 2nd 10 YEAR PLAN
2	9-18-90	(Signature)	(Signature)	(Signature)	ISO'S TO CAD FORMAT AS PER NG-85-0794


DRAWING RELEASE RECORD

RHR PUMP SUCTION (N.W.)
WELD PREFIX NO. RHB
CS, 14" & 24"
ISO. NO. 2.2-33




REV	DATE	PREPARED	REVIEWED	APPROVED	PURPOSE
1	4-30-86	SML	SML	RCH	ISO'S FOR 2nd 10 YEAR PLAN
2	9-18-90	<i>[Signature]</i>	<i>[Signature]</i>	<i>[Signature]</i>	ISO'S TO CAD FORMAT AS PER NG-89-0794

DRAWING RELEASE RECORD




CONT. ON ISO.
2.2-37A



RHR HEAT EXCH. DISCHARGE (SE)
WELD PREFIX RHF
CS, 12", 18" & 20"
ISO. NO. 2.2-37B

P&ID ISI-M120
BECH DWG# M-720-H




DRAWING RELEASE RECORD

REV	DATE	PREPARED	REVIEWED	APPROVED	PURPOSE
1	6-17-86	SML	SML	RCM	ISO'S FOR 2nd 10 YEAR PLAN
2	9-18-90	<i>[Signature]</i>	<i>[Signature]</i>	<i>[Signature]</i>	ISO'S TO CAD FORMAT AS PER NG-89-0794

RHR FUEL POOL COOLING & CLEAN-UP WELD PREFIX RHM CS, 8" ISO. NO. 2.2-43

P&ID ISI-M119 & M134
BEEN DWG#
HBB-25-1, 2, 3, 4 & 5




DRAWING RELEASE RECORD

REV	DATE	PREPARED	REVIEWED	APPROVED	PURPOSE
1	6-23-86	SNL	SNL	RCH	ISO'S FOR 2nd 10 YEAR PLAN
2	9-8-90	SNL	SNL	RCH	ISO'S TO CND FORMAT AS PER NG-89-8734


REV	DATE	PREPARED	REVIEWED	APPROVED	PURPOSE
1	7-9-86	SRL			ISO'S FOR 2nd 10 YEAR PLAN
2	9-18-90	SRL			ISO'S TO CAD FORMAT AS PER NG-89-0784

DRAWING RELEASE RECORD



REV	DATE	PREPARED	REVIEWED	APPROVED	PURPOSE
1	7-10-86	SM	SM	RCH	ISO'S FOR 2nd 10 YEAR PLAN
2	9-18-90	(Signature)	(Signature)	(Signature)	ISO'S TO CNO FORMAT AS PER NG-89-0794

DRAWING RELEASE RECORD




* - NON INTEGRAL
 ** - EXEMPT < 3/4"

CORE SPRAY SUCTION (SE)
 WELD PREFIX CSA
 CS, 12"
 ISO. NO. 2.2-48


P&ID ISI-M121
 BECH DWG# M-708-H

REV	DATE	PREPARED	REVIEWED	APPROVED	PURPOSE
1	7-11-86	SRL	SRL	RCM	ISO'S FOR 2nd 10 YEAR PLAN
2	9-18-90	(SRL)	(SRL)	(RCM)	ISO'S TO CAD FORMAT AS PER NG-89-0794

DRAWING RELEASE RECORD



CONT'D ON
ISO. 2.2-40



CONT'D ON
ISO. 2.2-49

CORE SPRAY DISCHARGE (SE CONT.)
WELD PREFIX CSC
CS, 4" & 12"
ISO. NO. 2.2-50

* - NON INTEGRAL
() - 1st TEN YEAR BOUNDARY WELDS

P&ID ISI-M119
BECH DWG# M-710-H


REV	DATE	PREPARED	REVIEWED	APPROVED	PURPOSE
1	7-14-86	SML	SML	RCH	ISO'S FOR 2nd 10 YEAR PLAN
2	9-18-86	<i>[Signature]</i>	<i>[Signature]</i>	<i>[Signature]</i>	ISO'S TO CAD FORMAT AS PER NG-89-0794

DRAWING RELEASE RECORD

MAIN STEAM LOOP "A" WELD PREFIX MSA CS, 20" & 10" ISO. NO. 2.2-53

P&ID ISI-M103
BECH DWG# M-716-H


* - NON INTEGRAL



CONT'D ON
ISO. NO.
1.2-1

REV	DATE	PREPARED	REVIEWED	APPROVED	PURPOSE
1	7-15-86	SNL	SNL	RCM	ISO'S FOR 2nd 10 YEAR PLAN
2	9-18-90	SNL	SNL	RCM	ISO'S TO CAD FORMAT AS PER NG-89-0794

DRAWING RELEASE RECORD





MAIN STEAM LOOP "B"
WELD PREFIX MSB
CS, 20" & 10"
ISO. NO. 2.2-54

P&ID ISI-M103
BECH DWG# M-716-H
* - NON INTEGRAL

CONT'D ON
ISO. NO.
1.2-2

REV	DATE	PREPARED	REVIEWED	APPROVED	PURPOSE
1	7-16-86	SM	SM	RCM	ISO'S FOR 2nd 10 YEAR PLAN
2	4-18-90	SM	SM	RCM	ISO'S TO CND FORMAT AS PER NG-89-0794

DRAWING RELEASE RECORD



MAIN STEAM BYPASS
WELD PREFIX MSE
CS, 12" & 6"
ISO. NO. 2.2-57

P&ID ISI-M103
BECH DWG# EBD-6-1H & 2H

* - NON INTEGRAL

CONT'D ON
ISO. 2.2-58

REV 1 DATE 7-16-86
2 9-18-90



PREPARED BY SNT

REVIEWED BY SNT

APPROVED BY RCH

PURPOSE ISO'S FOR 2nd 10 YEAR PLAN
ISO'S TO CNO FORMAT AS PER NG-89-0794

DRAWING RELEASE RECORD




MAIN STEAM BYPASS
WELD PREFIX MSF
CS, 12" & 10"
ISO. NO. 2.2-58


P&ID ISI-M103
BECH DWG# EBD-6-3-H

* - NDN INTEGRAL

DREC INSERVICE INSPECTION ASME SECTION XI ISOMETRIC




3/4" BOLTS
TYP OF 4




DETAIL 1

TYP.



DETAIL 2



DRAWING RELEASE RECORD

REV	DATE	PREPARED	REVIEWED	APPROVED	PURPOSE
1	7-16-86	SML	SML	RCM	ISO'S FOR 2nd 10 YEAR PLAN
2	10-26-87	JPM	RCM	REL	MODIFICATION OF SUPPORTS, FCN 1323; SEQ 5
3	9-18-90	<i>[Signature]</i>	<i>[Signature]</i>	<i>[Signature]</i>	ISO'S TO CAD FORMAT AS PER NG-89-0794

INSERVICE INSPECTION REPORT
December 28, 1988 through September 10, 1990

Part J, Page 1 6

1) Owners: Iowa Electric Light and Power Company
P.O. Box 351
Cedar Rapids, Iowa 52406

Central Iowa Power Cooperative
Marion, Iowa

Corn Belt Power Cooperative
Humboldt, Iowa

2) Plant Duane Arnold Energy Center, Palo, Iowa 52324

3) Plant Unit #1

4) Owners Certificate of Authorization (if required) N/A

5) Commercial Service Date 2-1-75

6) National Board Number of Unit N/A

GROSS GENERATING CAPACITY: 565 MWE

STATUS OF WORK FOR SECOND INTERVAL

CLASS 1

16% - 34% 16% min
67% max

<u>Item No.</u>	<u>Total #</u>	<u>Period 1</u>	<u>Outage 10</u>	<u>Remarks</u>
B1.11	1	0%	0%	Permissible
B1.12	1	0%	0%	Permissible
B1.21B	1	0%	0%	Permissible
B1.21T	1	33%	66%	1/3 each period
B1.22B	1	0%	0%	Permissible
B1.22T	1	33%	66%	1/3 each period
B1.30	1	33%	66%	1/3 each period
B1.40	1	33%	66%	1/3 each period
B3.90	32	28%	46%	
B3.100	32	28%	46%	
B4.11	2	0%	0%	25% per interval
B4.12	89	0%	0%	25% per interval
B4.13	30	0%	0%	25% per interval
B5.1D	14	73%	73%	See Note 1
B5.20	8	12%	25%	See Note 2
B5.130	8	50%	62%	
B5.140	2	0%	50%	
B6.10	60	0%	66%	Permissible
B6.20	60	0%	66%	Permissible
B6.40	60	0%	66%	Permissible
B6.50	60	0%	66%	Permissible
B6.180	2	0%	100%	16 per pump
B6.190	2	0%	100%	
B6.200	2	0%	100%	16 per pump

INSERVICE INSPECTION REPORT

Part J, Page 2 of 6

September 28, 1988 through September 10, 1990

- 1) Owners: Iowa Electric Light and Power Company
P.O. Box 351
Cedar Rapids, Iowa 52406

Central Iowa Power Cooperative
Marion, Iowa

Corn Belt Power Cooperative
Humboldt, Iowa

- 2) Plant Duane Arnold Energy Center, Palo, Iowa 52324
- 3) Plant Unit #1
- 4) Owners Certificate of Authorization (if required) N/A
- 5) Commercial Service Date 2-1-75
- 6) National Board Number of Unit N/A

GROSS GENERATING CAPACITY: 565 MWE

CLASS 1 (cont.)

16% - 34%

16% min
67% max

IN m No.	Total #	Period 1	Outage 10	Remarks
B7.10	3	66%	66%	
B7.50	2	0%	50%	
B7.60	2	0%	100%	
B7.70	40	N/A	N/A	16 per pump Relief Request NDE-002 when disassembled See Note 3
B7.80	89	N/A	N/A	
B8.10	6	28%	57%	
B9.11	129	38%	53%	
B9.12	51	19%	43%	
B9.21	12	41%	66%	
B9.31	8	37%	87%	
B9.32	1	0%	100%	
B9.40	41	19%	24%	
B10.10	34	35%	55%	
B10.20	8	25%	50%	
B12.20	2	0%	100%	
B12.50	45	N/A	N/A	Relief Request NDE-002
B13.10	*	*	*	
B13.20	*	*	*	*Accessible areas during refueling outage
B13.21	*	*	*	Permissible
B13.22	*	*	*	Permissible
B14.10	28	0%	0%	
B15.10	3	N/A	N/A	100% per refuel outage
B15.11	3	N/A	N/A	Once per interval

INSERVICE INSPECTION REPORT
December 28, 1988 through September 10, 1990

Part J, Page 3 of 6

- 1) Owners: Iowa Electric Light and Power Company
P.O. Box 351
Cedar Rapids, Iowa 52406

Central Iowa Power Cooperative
Marion, Iowa

Corn Belt Power Cooperative
Humboldt, Iowa

- 2) Plant Duane Arnold Energy Center, Palo, Iowa 52324
- 3) Plant Unit #1
- 4) Owners Certificate of Authorization (if required) N/A
- 5) Commercial Service Date 2-1-75
- 6) National Board Number of Unit N/A

GROSS GENERATING CAPACITY: 565 MWE

CLASS 1 (cont.)

16% - 34%

16% min
67% max

<u>Item No.</u>	<u>Total #</u>	<u>Period 1</u>	<u>Outage 10</u>	<u>Remarks</u>
B15.50	1	N/A	N/A	100% per refuel outage
B15.51	1	N/A	N/A	Once per interval
B15.60	2	N/A	N/A	100% per refuel outage
B15.61	2	N/A	N/A	Once per interval
B15.70	1	N/A	N/A	100% per refuel outage
B15.71	1	N/A	N/A	Once per interval

IN SERVICE INSPECTION REPORT

Part J, Page 4 of 6

September 28, 1988 through September 10, 1990

- 1) Owners: Iowa Electric Light and Power Company
P.O. Box 351
Cedar Rapids, Iowa 52406

Central Iowa Power Cooperative
Marion, Iowa

Corn Belt Power Cooperative
Humboldt, Iowa

- 2) Plant Duane Arnold Energy Center, Palo, Iowa 52324
- 3) Plant Unit #1
- 4) Owners Certificate of Authorization (if required) N/A
- 5) Commercial Service Date 2-1-75
- 6) National Board Number of Unit N/A

GROSS GENERATING CAPACITY: 565 MWE

STATUS OF WORK FOR SECOND INTERVAL

CLASS 2

16% - 34%

16% min
67% max

<u>Item No.</u>	<u>Total #</u>	<u>Period 1</u>	<u>Outage 10</u>	<u>Remarks</u>
C1.10	2	50%	50%	
C1.20	1	0%	0%	
C2.21	2	0%	0%	50% Scheduled Outage 11
C3.10	5	20%	20%	
C3.20	44	16%	34%	
C5.11	77	33%	50%	
C5.21	39	33%	53%	
C5.31	4	100%	100%	
C7.10	2	N/A	N/A	Once per period
C7.20	2	50%	50%	Once per period
C7.30	12	N/A	N/A	Once per period
C7.40	14	N/A	N/A	Once per interval
C7.50	3	N/A	N/A	Once per period
C7.60	3	N/A	N/A	Once per interval
C7.70	12	N/A	N/A	Once per period
C7.80	12	N/A	N/A	Once per interval

INSERVICE INSPECTION REPORT
December 28, 1988 through September 10, 1990

Part J, Page 5 of 6

- 1) Owners: Iowa Electric Light and Power Company
P.O. Box 351
Cedar Rapids, Iowa 52406
- Central Iowa Power Cooperative Corn Belt Power Cooperative
Marion, Iowa Humboldt, Iowa
- 2) Plant Duane Arnold Energy Center, Palo, Iowa 52324
- 3) Plant Unit #1
- 4) Owners Certificate of Authorization (if required) N/A
- 5) Commercial Service Date 2-1-75
- 6) National Board Number of Unit N/A
- GROSS GENERATING CAPACITY: 565 MWE

SUPPORTS

CLASS 1		16%-34%	16% min 67% max	
<u>Item No.</u>	<u>Total #</u>	<u>Period 1</u>	<u>Outage 10</u>	<u>Remarks</u>
F2.00	15	20%	26%	
F3.00	166	35%	52%	
CLASS 2				
F1.00	71	38%	52%	
F2.00	34	20%	35%	
F3.00	231	34%	52%	

Note 1 - Item Number B5.1D

11 nozzle to safe-end welds were completed during Outage 08, Period 1. These were submitted in the Summary Report for that period thus credit was taken for those completed. During Outage 10, 3 of the 11 nozzle to safe-end welds were examined again and are submitted in this Summary Report. Because these 3 were already examined the percentages do not change. 7 of the 11, completed during Outage 08, are scheduled for examination during the remainder of this interval.

- 1) Owners: Iowa Electric Light and Power Company
P.O. Box 351
Cedar Rapids, Iowa 52406

Central Iowa Power Cooperative
Marion, Iowa

Corn Belt Power Cooperative
Humboldt, Iowa

- 2) Plant Duane Arnold Energy Center, Palo, Iowa 52324
- 3) Plant Unit #1
- 4) Owners Certificate of Authorization (if required) N/A
- 5) Commercial Service Date 2-1-75
- 6) National Board Number of Unit N/A

GROSS GENERATING CAPACITY: 565 MWE

Note 2 - Item Number B5.20

There was one nozzle to safe-end weld $\leq 4"$ scheduled during Outage 08, Period 1. Because of an oversight, there weren't any scheduled in Outage 09, Period 1. CRA-F002 was completed during Outage 10 which brings the percentage within Code allowable. There are 2 more scheduled for the next refueling outage which will bring the percentage to 50% at the end of period 2.

Note 3 - Item Number B7.80 (CRD Bolting)

There are no percentages calculated for this item number because each CRD that is removed receives a VT-1 examination on the bolting. There are usually 20 scheduled per outage.

<u>System or Component Description</u>	<u>A C C</u>	<u>R E J</u>	<u>Inspection Requirement</u>	<u>Weld or Component Description</u>	<u>UT Report No.</u>	<u>Visual Report No.</u>	<u>PT Report No.</u>	<u>ISI ISO/Fig No.</u>	<u>Comments</u>
RPV Interior	X		E	Jet Pump (MIL)	N/A	*	N/A	None	Visual inspection of PMP MIL 9 thru 16
	X		H	Jet Pump (RB)	N/A	*	N/A	None	Visual inspection of PMP RB 9 thru 16
	X		I	Jet Pump (ASS)	N/A	*	N/A	None	Visual inspection of PMP ASS 9 thru 12
	X		I	Jet Pump (RSS)	N/A	*	N/A	None	Set screw tack welds on Jet Pump 2, 4, 5 & 10 reported indications, acceptable as per NCR #90-076 jet pumps 1 - 16 examined.
	X		C,F	Core Spray Spargers Thermal Sleeve, Nozzle	N/A	*	N/A	None	Spargers A,B,C,D; Thermal Sleeve A,B and Nozzle A,B, T-Box Welds
	X		B	Feedwater Nozzle A	89-46	*	89-441	1.1-9	Inside vessel: right installation bracket accept- able as per NCR-90-70 UT was performed from OD
	X		B	Feedwater Nozzle B	89-47	*	89-442	1.1-9	Inside vessel UT was performed from OD.
	X		B	Feedwater Nozzle C	89-49	*	89-443	1.1-9	Inside vessel UT was performed from OD

<u>System or Component Description</u>	<u>A C C</u>	<u>R E J</u>	<u>Inspection Requirement</u>	<u>Weld or Component Description</u>	<u>UT Report No.</u>	<u>Visual Report No.</u>	<u>PT Report No.</u>	<u>ISI ISO/Fig No.</u>	<u>Comments</u>
	X		B	Feedwater Nozzle D	89-49	*	89-444	1.2-5	Inside vessel UT was performed from OD
	X		B	CRD Return Line Nozzle	N/A	*	89-440	1.1-9	Indications found, repair by grinding, only in cladding
	X		G	Steam Dry DRN CHAN	N/A	*	N/A	None	Acceptable as per NCR 90-069
				Steam Dry EXT SURF	N/A	*	N/A	None	
	X		K	Vessel Head	N/A	*	N/A	None	VT-1 inspection
Feedwater 'A'	X		B	FWA-BD-1	89-42	N/A	N/A	1.1-9	UT-0
	X		B	FWA-BD-1	89-43	N/A	N/A	1.1-9	UT-45
	X		B	FWA-BD-1	89-44	N/A	N/A	1.1-9	UT-60
	X		B	FWA-BD-1 (Bore)	89-46	N/A	N/A	1.1-9	UT-30
	X		B	FWA-BD-1 (T.S.)	89-50	N/A	N/A	1.1-9	UT-45
	X		B	FWA-BD-1 (IR)	89-45	N/A	N/A	1.1-9	UT-70
	X		B	FWA-BD-1 (T.S.)	89-51	N/A	N/A	1.1-9	UT-60
Feedwater 'B'	X		B	FWB-BD-1 (Bore)	89-47	N/A	N/A	1.1-9	UT-30
Feedwater 'C'	X		B	FWC-BD-1 (Bore)	89-49	N/A	N/A	1.1-9	UT-30

<u>System or Component Description</u>	<u>A C C</u>	<u>R E J</u>	<u>Inspection Requirement</u>	<u>Weld or Component Description</u>	<u>UT Report No.</u>	<u>Visual Report No.</u>	<u>PT Report No.</u>	<u>ISI ISO/Fig No.</u>	<u>Comments</u>
Feedwater 'D'	X		B	FWD-BD-1 (Bore)	89-48	N/A	N/A	1.1-9	UT-30
CRD Return	X		B	CRA-F002	89-151	N/A	N/A	1.2-12A	Stainless steel side
	X		B	CRA-F002	89-150	N/A	N/A	1.2-12A	Carbon steel side
	X		B	CRA-J003	89-149	N/A	N/A	1.2-12A	
	X		B	CRA-F004	89-147	N/A	N/A	1.2-12A	Stainless steel side
	X		B	CRA-F004	89-148	N/A	N/A	1.2-12A	Carbon steel side
Core Spray 'A'	X		J,A	CSA-F002	89-127	N/A	N/A	1.2-7	UT-RL
	X		J,A	CSA-F002	89-128	N/A	N/A	1.2-7	UT-45 (safeend side only)
	X		A	CSA-F002A	89-125	N/A	N/A	1.2-7	Pipe side
	X		A	CSA-F002A	89-126	N/A	N/A	1.2-7	Safeend side
	X		A	CSA-J003	89-124	N/A	N/A	1.2-7	
	X		A	CSA-F004	89-122	N/A	N/A	1.2-7	Carbon steel side
	X		A	CSA-F004	89-123	N/A	N/A	1.2-7	Stainless steel side
Reactor Water Cleanup Discharge (Class 1)	X		A	CUB-F004	89-143	N/A	N/A	1.2-11B	

Attachment 2
to NG-90-2858
Page 4 of 17

<u>System or Component Description</u>	<u>A C C</u>	<u>R E J</u>	<u>Inspection Requirement</u>	<u>Weld or Component Description</u>	<u>UT Report No.</u>	<u>Visual Report No.</u>	<u>PT Report No.</u>	<u>ISI ISO/Fig No.</u>	<u>Comments</u>
	X		A	CUB-J005	89-142	N/A	N/A	1.2-11B	
	X		A	CUB-J008	89-141	N/A	N/A	1.2-11B	
	X		A	CUB-J010	89-140	N/A	N/A	1.3-11B	
	X		A	CUB-J011	89-139	N/A	N/A	1.2-11B	
	X		A	CUB-J013	89-138	N/A	N/A	1.2-11B	
	X		A	CUB-J014	89-137	N/A	N/A	1.2-11B	
	X		A	CUB-J016	89-136	N/A	N/A	1.2-11B	
	X		A	CUB-J017	89-135	N/A	N/A	1.2-11B	
Residual Heat Removal - 18B	X		A	RHB-J001-OVL	89-164	N/A	N/A	1.2-14	UT-60 overlay weld
	X		A	RHB-J002	89-165	N/A	N/A	1.2-14	
	X		A	RHB-F003	89-169	N/A	N/A	1.2-14	Stainless steel side
	X		A	RHB-F003	89-170	N/A	N/A	1.2-14	Carbon steel side
Recirc Pump 'A' Suction	X		J,A	RCA-F002	89-192	N/A	N/A	1.2-19	UT-RL
	X		J,A	RCA-F002	89-191	N/A	N/A	1.2-19	UT-45 safeend side only

<u>System or Component Description</u>	<u>A C C</u>	<u>R E J</u>	<u>Inspection Requirement</u>	<u>Weld or Component Description</u>	<u>UT Report No.</u>	<u>Visual Report No.</u>	<u>PT Report No.</u>	<u>ISI ISO/Fig No.</u>	<u>Comments</u>
	X		A	RCA-J004	89-208	N/A	N/A	1.2-19	
	X		A	RCA-J005A	89-196	N/A	N/A	1.2-19	
	X		A	RCA-J018	89-197	N/A	N/A	1.2-19	
	X		A	RCA-J021	89-193	N/A	N/A	1.2-19	
	X		A	RCA-J022	89-194	N/A	N/A	1.2-19	
	X		A	RCA-J024	89-195	N/A	N/A	1.2-19	
	X		A	RCA-J027	89-198	N/A	N/A	1.2-19	
	X		A	RCA-J034	89-199	N/A	N/A	1.2-19	
Recirc Bypass 'A'	X		A	RBA-J001	89-182	N/A	N/A	1.2-19	
	X		A	RBA-J002	89-183	N/A	N/A	1.2-19	
	X		A	RBA-J003	89-184	N/A	N/A	1.2-19	
	X		A	RBA-J006	89-185	N/A	N/A	1.2-19	
	X		A	RBA-J007	89-186	N/A	N/A	1.2-19	
	X		A	RBA-J008	89-187	N/A	N/A	1.2-19	
	X		A	RBA-J009	89-188	N/A	N/A	1.2-19	

<u>System or Component Description</u>	<u>A C C</u>	<u>R E J</u>	<u>Inspection Requirement</u>	<u>Weld or Component Description</u>	<u>UT Report No.</u>	<u>Visual Report No.</u>	<u>PT Report No.</u>	<u>ISI ISO/Fig No.</u>	<u>Comments</u>
	X		A	RBA-J010	89-189	N/A	N/A	1.2-19	
	X		A	RBA-J012	89-190	N/A	N/A	1.2-19	
Recirc Manifold 'A'	X		A	RMA-J005	89-224	N/A	N/A	1.2-20	
	X		A	RMA-J007	89-223	N/A	N/A	1.2-20	
	X		A	RMA-J008	89-225	N/A	N/A	1.2-20	
	X		A	RMA-J010	89-226	N/A	N/A	1.2-20	
Recirc Riser 'E'	X		J, A	RRE-F002	90-62	N/A	N/A	1.2-20	UT-RL
	X		J, A	RRE-F002	90-56	N/A	N/A	1.2-20	UT-45 (safeend side only)
	X		A	RRE-J003	89-230	N/A	N/A	1.2-20	UT-45
	X		A	RRE-J004/ J004A OVL	89-235	N/A	N/A	1.2-20	UT-45 UT-60 weld overlay
	X		A	RRE-J005	89-229	N/A	N/A	1.2-20	
	X		A	RRE-J007	90-298	N/A	N/A	1.2-20	UT-45
Recirc Riser 'F'	X		J, A	RRF-F002	89-244	N/A	N/A	1.2-20	UT-RL
	X		J, A	RRF-F002	89-245	N/A	N/A	1.2-20	UT-48 (safeend side only)

<u>System or Component Description</u>	<u>A C C</u>	<u>R E J</u>	<u>Inspection Requirement</u>	<u>Weld or Component Description</u>	<u>UT Report No.</u>	<u>Visual Report No.</u>	<u>PT Report No.</u>	<u>ISI ISO/Fig No.</u>	<u>Comments</u>
	X		A	RRF-F002A Code Only	89-247	N/A	N/A	1.2-20	
	X		A	RRF-J003	89-228	N/A	N/A	1.2-20	
	X		A	RRF-J004/ J004A OVL	89-237	N/A	N/A	1.2-20	UT-60 weld overlay
	X		A	RRF-J005	89-227	N/A	N/A	1.2-20	
	X		A	RRF-J007	90-297	N/A	N/A	1.2-20	
Recirc Riser 'G'	X		A,J	RRG-F002	90-63	N/A	N/A	1.2-20	UT-RL
	X		J, A	RRG-F002	90-58	N/A	N/A	1.2-20	UT-45: Safeend side only
	X		A	RRG-J003	89-231	N/A	N/A	1.2-20	
	X		A	RRG-J004/ J004A OVL	89-233	N/A	N/A	1.2-20	UT-60 weld overlay
Recirc Riser 'H'	X		J, A	RRH-F002	90-64	N/A	N/A	1.2-20	UT-RL
	X		J, A	RRH-F002	90-60	N/A	N/A	1.2-20	UT-45 safeend side only
	X		A	RRH-J003	89-240	N/A	N/A	1.2-20	
	X		A	RRH-J004/ J004A-OVL	89-239	N/A	N/A	1.2-20	UT-60 weld overlay

<u>System or Component Description</u>	<u>A C C</u>	<u>R E J</u>	<u>Inspection Requirement</u>	<u>Weld or Component Description</u>	<u>UT Report No.</u>	<u>Visual Report No.</u>	<u>PT Report No.</u>	<u>ISI ISO/Fig No.</u>	<u>Comments</u>
Recirc Pump 'B' Suction	X		A	RCB-J006	89-248	N/A	N/A	1.2-21	
	X		A	RCB-J007	89-249	N/A	N/A	1.2-21	
	X		A	RCB-J009	89-250	N/A	N/A	1.2-21	
Recirc Manifold 'B'	X		A	RMB-J009	89-253	N/A	N/A	1.2-22	
	X		A	RMB-J011	89-254	N/A	N/A	1.2-22	
	X		A	RMB-J012	89-252	N/A	N/A	1.2-22	
Recirc Riser 'A'	X		A	RRA-J003	89-262	N/A	N/A	1.2-22	
	X		A	RRA-J004/ J004A-OVL	89-261	N/A	N/A	1.2-22	UT-60 weld overlay
	X		A	RRA-J005	89-259	N/A	N/A	1.2-22	
	X		A	RRA-J007	89-258	N/A	N/A	1.2-22	
Recirc Riser 'B'	X		A	RRB-J003	89-257	N/A	N/A	1.2-22	
	X		A	RRB-J004/ J004A-OVL	89-256	N/A	N/A	1.2-22	UT-60 weld overlay
Recirc Riser 'C'	X		A	RRC-J003	89-263	N/A	N/A	1.2-22	

Attachment 2
to NG-90-2858
Page 9 of 17

<u>System or Component Description</u>	<u>A C C</u>	<u>R E J</u>	<u>Inspection Requirement</u>	<u>Weld or Component Description</u>	<u>UT Report No.</u>	<u>Visual Report No.</u>	<u>PT Report No.</u>	<u>ISI ISO/Fig No.</u>	<u>Comments</u>
Recirc Riser 'D'	X		A	RRD-J003	89-268	N/A	N/A	1.2-22	
	X		A	RRD-J004/ J004A-OVL	89-267	N/A	N/A	1.2-22	UT-60 weld overlay
	X		A	RRD-J007-OVL	89-265	N/A	N/A	1.2-22	UT-60 weld overlay
Jet Pump Inst. 'A'	X		A	JPA-F002	89-269	N/A	N/A	1.2-25	Safeend side
	X		A	JPA-F002	89-270	N/A	N/A	1.2-25	Nozzle side
	X		A	JPA-J003	89-271	N/A	N/A	1.2-25	
Jet Pump Inst. 'A'			A	JPB-F002	89-275	N/A	N/A	1.2-26	Safeend side
			A	JPB-F002	89-274	N/A	N/A	1.2-26	Nozzle side
			A	JPB-F003	89-276	N/A	N/A	1.2-26	
Reactor Water Cleanup (Non- Class) 'CUA'	X		A	CUA-A-01	90-66	N/A	N/A	4.1-01	Preservice replacement
	X		A	CUA-A-03	90-67	N/A	N/A	4.1-01	Preservice replacement
	X		A	CUA-A-04	90-68	N/A	N/A	4.1-01	Preservice replacement

<u>System or Component Description</u>	<u>A C C</u>	<u>R E J</u>	<u>Inspection Requirement</u>	<u>Weld or Component Description</u>	<u>UT Report No.</u>	<u>Visual Report No.</u>	<u>PT Report No.</u>	<u>ISI ISO/Fig No.</u>	<u>Comments</u>
	X		A	CUA-A-05	90-69	N/A	N/A	4.1-01	Preservice replacement
	X		A	CUA-A-06	90-70	N/A	N/A	4.1-01	Preservice replacement
	X		A	CUA-A-07	90-71	N/A	N/A	4.1-01	Preservice replacement
	X		A	CUA-A-08	90-72	N/A	N/A	4.1-01	Preservice replacement
	X		A	CUA-A-09	90-73	N/A	N/A	4.1-01	Preservice replacement
	X		A	CUA-A-11	90-74	N/A	N/A	4.1-01	Preservice replacement
	X		A	CUA-A-12	90-75	N/A	N/A	4.1-01	Preservice replacement
	X		A	CUA-A-15	90-76	N/A	N/A	4.1-01	Preservice replacement
	X		A	CUA-A-16	90-77	N/A	N/A	4.1-01	Preservice replacement
	X		A	CUA-A-17	90-78	N/A	N/A	4.1-01	Preservice replacement
	X		A	CUA-A-18	90-79	N/A	N/A	4.1-01	Preservice replacement
	X		A	CUA-A-19	90-80	N/A	N/A	4.1-01	Preservice replacement
	X		A	CUA-A-20	90-165	N/A	N/A	4.1-01	Preservice replacement
'CUB'	X		A	CUB-A-01	90-81	N/A	N/A	4.1-02	Preservice replacement
	X		A	CUB-A-02	90-82	N/A	N/A	4.1-02	Preservice replacement
	X		A	CUB-A-03	90-83	N/A	N/A	4.1-02	Preservice replacement

<u>System or Component Description</u>	<u>A C C</u>	<u>R E J</u>	<u>Inspection Requirement</u>	<u>Weld or Component Description</u>	<u>UT Report No.</u>	<u>Visual Report No.</u>	<u>PT Report No.</u>	<u>ISI ISO/Fig No.</u>	<u>Comments</u>
	X		A	CUB-A-04	90-84	N/A	N/A	4.1-02	Preservice replacement
	X		A	CUB-A-05	90-85	N/A	N/A	4.1-02	Preservice replacement
	X		A	CUB-A-06	90-86	N/A	N/A	4.1-02	Preservice replacement
	X		A	CUB-A-07	90-85	N/A	N/A	4.1-02	Preservice replacement
	X		A	CUB-A-08	90-86	N/A	N/A	4.1-02	Preservice replacement
	X		A	CUB-A-09	90-87	N/A	N/A	4.1-02	Preservice replacement
	X		A	CUB-A-10	90-88	N/A	N/A	4.1-02	Preservice replacement
	X		A	CUB-A-11	90-89	N/A	N/A	4.1-02	Preservice replacement
	X		A	CUB-A-12	90-90	N/A	N/A	4.1-02	Preservice replacement
	X		A	CUB-A-03A	90-293	N/A	N/A	4.1-02	Preservice replacement
	X		A	CUB-A-04A	90-294	N/A	N/A	4.1-02	Preservice replacement
	X		A	CUB-A-07A	90-295	N/A	N/A	4.1-02	Preservice replacement
'CUC'	X		A	CUC-A-01	90-91	N/A	N/A	4.1-03	Preservice replacement
	X		A	CUC-A-02	90-92	N/A	N/A	4.1-03	Preservice replacement
	X		A	CUC-A-03	90-93	N/A	N/A	4.1-03	Preservice replacement
	X		A	CUC-A-05	90-94	N/A	N/A	4.1-03	Preservice replacement

<u>System or Component Description</u>	<u>A C C</u>	<u>R E J</u>	<u>Inspection Requirement</u>	<u>Weld or Component Description</u>	<u>UT Report No.</u>	<u>Visual Report No.</u>	<u>PT Report No.</u>	<u>ISI ISO/Fig No.</u>	<u>Comments</u>
	X		A	CUC-A-06	90-95	N/A	N/A	4.1-03	Preservice replacement
	X		A	CUC-A-07	90-96	N/A	N/A	4.1-03	Preservice replacement
	X		A	CUC-A-09	90-97	N/A	N/A	4.1-03	Preservice replacement
	X		A	CUC-A-11	90-98	N/A	N/A	4.1-03	Preservice replacement
	X		A	CUC-A-13	90-99	N/A	N/A	4.1-03	Preservice replacement
	X		A	CUC-A-14	90-100	N/A	N/A	4.1-03	Preservice replacement
	X		A	CUC-A-16	90-101	N/A	N/A	4.1-03	Preservice replacement
	X		A	CUC-A-17	90-102	N/A	N/A	4.1-03	Preservice replacement
	X		A	CUC-A-18	90-103	N/A	N/A	4.1-03	Preservice replacement
'DCB'	X		A	DCB-1	90-105	N/A	N/A	RWCU-1	This outage only
	X		A	DCB-2	90-113	N/A	N/A	RWCU-1	This outage only
	X		A	DCB-3	90-114	N/A	N/A	RWCU-1	This outage only
	X		A	DCB-4	90-117	N/A	N/A	RWCU-1	This outage only
	X		A	DCB-5	90-118	N/A	N/A	RWCU-1	This outage only
	X		A	DCB-6	90-121	N/A	N/A	RWCU-1	This outage only
	X		A	DCB-7	90-122	N/A	N/A	RWCU-1	This outage only

<u>System or Component Description</u>	<u>A C C</u>	<u>R E J</u>	<u>Inspection Requirement</u>	<u>Weld or Component Description</u>	<u>UT Report No.</u>	<u>Visual Report No.</u>	<u>PT Report No.</u>	<u>ISI ISO/Fig No.</u>	<u>Comments</u>
'ECB'	X		A	DCB-8	90-125	N/A	N/A	RWCU-1	This outage only
	X		A	DCB-8A	90-285	N/A	N/A	RWCU-1	This outage only
	X		A	DCB-9	90-126	N/A	N/A	RWCU-1	This outage only
	X		A	DCB-10	90-106	N/A	N/A	RWCU-1	This outage only
	X		A	DCB-11	90-109	N/A	N/A	RWCU-1	This outage only
	X		A	ECB-1	90-104	N/A	N/A	RWCU-1	This outage only
	X		A	ECB-1A	90-284	N/A	N/A	RWCU-1	This outage only
	X		A	ECB-2	90-112	N/A	N/A	RWCU-1	This outage only
	X		A	ECB-3	90-115	N/A	N/A	RWCU-1	This outage only
	X		A	ECB-4	90-116	N/A	N/A	RWCU-1	This outage only
	X		A	ECB-5	90-119	N/A	N/A	RWCU-1	This outage only
	X		A	ECB-6	90-120	N/A	N/A	RWCU-1	This outage only
	X		A	ECB-7	90-123	N/A	N/A	RWCU-1	This outage only
	X		A	ECB-8	90-124	N/A	N/A	RWCU-1	This outage only
	X		A	ECB-9	90-127	N/A	N/A	RWCU-1	This outage only
	X		A	ECB-10	90-107	N/A	N/A	RWCU-1	This outage only

<u>System or Component Description</u>	<u>A C C</u>	<u>R E J</u>	<u>Inspection Requirement</u>	<u>Weld or Component Description</u>	<u>UT Report No.</u>	<u>Visual Report No.</u>	<u>PT Report No.</u>	<u>ISI ISO/Fig No.</u>	<u>Comments</u>
'1E-214 Intercon'	X		A	ECB-11	90-108	N/A	N/A	RWCU-1	This outage only
	X		A	ECB-12	90-110	N/A	N/A	RWCU-1	This outage only
	X		A	ECB-13	90-111	N/A	N/A	RWCU-1	This outage only
	X		A	INT-1	90-128	N/A	N/A	RWCU	
	X		A	INT-2	90-139	N/A		RWCU	
	X		A	INT-3	90-149	N/A		RWCU	
	X		A	INT-4	90-150	N/A		RWCU	
	X		A	INT-5	90-151	N/A		RWCU	
	X		A	INT-6	90-152	N/A		RWCU	
	X		A	INT-7	90-153	N/A		RWCU	
	X		A	INT-8	90-154	N/A		RWCU	
	X		A	INT-9	90-155	N/A		RWCU	
	X		A	INT-10	90-129	N/A		RWCU	Replacement of elbow
	X		A	INT-11	90-130	N/A		RWCU	Replacement of elbow
	X		A	INT-12	90-131	N/A		RWCU	Replacement of elbow
	X		A	INT-13	90-132	N/A		RWCU	

<u>System or Component Description</u>	<u>A C C</u>	<u>R E J</u>	<u>Inspection Requirement</u>	<u>Weld or Component Description</u>	<u>UT Report No.</u>	<u>Visual Report No.</u>	<u>PT Report No.</u>	<u>ISI ISO/Fig No.</u>	<u>Comments</u>
	X		A	INT-14	90-133	N/A		RWCU	
	X		A	INT-15	90-134	N/A		RWCU	
	X		A	INT-16	90-135	N/A		RWCU	
	X		A	INT-17	90-136	N/A		RWCU	
	X		A	INT-18	90-137	N/A		RWCU	
	X		A	INT-19	90-138	N/A		RWCU	
	X		A	INT-20	90-140	N/A		RWCU	
	X		A	INT-21	90-141	N/A		RWCU	
	X		A	INT-22	90-142	N/A		RWCU	
	X		A	INT-23	90-143	N/A		RWCU	
	X		A	INT-24	90-144	N/A		RWCU	
	X		A	INT-25	90-145	N/A		RWCU	
	X		A	INT-26	90-146	N/A		RWCU	
	X		A	INT-27	90-147	N/A		RWCU	
	X		A	INT-28	90-148	N/A		RWCU	
Refueling Bellows	X		D	Refueling Bellows	N/A	89-445		N/A	

<u>System or Component Description</u>	<u>A C C</u>	<u>R E J</u>	<u>Inspection Requirement</u>	<u>Weld or Component Description</u>	<u>UT Report No.</u>	<u>Visual Report No.</u>	<u>PT Report No.</u>	<u>ISI ISO/Fig No.</u>	<u>Comments</u>
X-37c/38c Thickness at Penetration	X		D	X-38c/X-37c Plate	P90012	N/A		N/A	All points greater than NWT; 1.5"
Drywell Liner	X		D	A5A42A6AY1	P90013	N/A		N/A	From two feet around penet. X-37/38 (SW bundle) down to Drywell floor 746'-8" upper plate; all points greater than NWT, .75" lower plate; all points greater than NWT, 1.5"
Vent Line	X		D	217-6	P90016	N/A		N/A	All points > NWT = .375"
X-5E	X		D	217-A	P90017	N/A		N/A	All points > NWT = .375"
Drywell Liner	X		D	Azimuth 95	P90021	N/A		N/A	Below drywell floor 746'-8" (1 ft down 2 feet wide). All points > NWT = 1.5"
	X		D	Azimuth 185	P90021	N/A		N/A	Below drywell floor (1 ft. down 2 ft. wide). All points > NWT = 1.5"
Vent Line Air Gaps X-5			D	X-5 vent lines (8)	P90018	N/A		N/A	XS5 - vent line leaking water at about 1/2 gallon per hour. UT thickness of vent performed
Drywell Liner Drains	X		D	Drywell Linear Drains (4)	N/A	P90019		N/A	Drains at 0 , 90 , 180 , and 230 . No leakage found thickness sat.

Attachment 2
to NG-90-2858
Page 17 of 17

System or Component <u>Description</u>	A C C	R E J	Inspection Requirement	Weld or Component <u>Description</u>	UT Report <u>No.</u>	Visual Report <u>No.</u>	PT Report <u>No.</u>	ISI ISO/Fig <u>No.</u>	<u>Comments</u>
Sand Pocket Drains	X		D	Sandpocket Drains	N/A	P90020		N/A	Drains at 5 , 95 , 185 , 275 . Drains at 95 and 185 saturated with water. UT thickness at drywell shell

<u>Key Code</u>	<u>Description</u>
-----------------	--------------------

A	NUREG 0313 (Generic Letter 88-01)
B	NUREG 0619
C	IEB 80-13
D	IE Letter NG-87-4355 (Generic Letter 87-05)
E	GE SIL 465
F	GE SIL 289
G	GE SIL 474
H	GE RICSIL 045
I	NDE Pro. 1111.15
J	GE SIL 455
K	GE RICSIL 051 (VT-1)

* Examination of augmented reactor pressure vessel (RPV) interior is in the document
1990 RFO GE in vessel inspection book.

ACC - Accept
REJ - Reject
RPV - Reactor Pressure Vessel
MIL - Mixer Inlet Lip
RB - Riser Brace
ASS - Assembly
RSS - Restrainer Set Screw
T.S. - Thermal Sleeve
IR - Inside Radius
RL - Refracted L Wave