DISTRIBUTION A	ETER ISSUANCE O	F CRERATING LICEN	NSE	ON COOCKET NUMBER
NRC FORM 195	3 5	U.S. NUC	LEAR REGULATORY COM	JC 50-331
2-76)		PART 50 DOCKET	MATERIAL	FILE NUMBER
		FROM:		DATE OF DOCUMENT
το:		Iowa Elec.	Light & Pwr. Compan	y <u>12/14/17</u>
Mr. Edson G. C	ase	Cedar Rapic	is, Iowa	DATE RECEIVED 12/19/77
X - +++ C	NOTORIZED	PROP	INPUT FORM	NUMBER OF COPIES RECEIVED
CORIGINAL	DUNCLASSIFIED			3 SIGNED
ESCRIPTION			ENCLOSURE	
Notorized 12/1	5/77trans th	ne following:	License No. DPR specs proposed improvements ir DAEC	:-59 Appl for Amend: tech change concerning n operating margin for
:				
		(1-P)	(1/4")	
	Duane Arnold			
FLANI NAME:	RJL 12/19/77		40	DENCL /2005 ADV'D TO PA
SARFTY -	<u> </u>	FOR ACTION	/INFORMATION	
BRANCH CHIEF:	55	LEAR		
·				
	<u>1</u>	INTERNAL	DISTRIBUTION	
PEC FET E				
ALG DILLE				
OFID				
HANAUER				
CHECK				
EISENHUT				
SHAO				
BAFR				
BUTTLER				
GRIMES				
U. COLLINS				
J. MCGOUGH				
	EXT	ERNAL DISTRIBUTIO	N.	CONTROL NUMBER
LPDR . / C AAD	RAPIDSVA			Am 2
TTC	11.11.22 1 1			P
NSTC				773530054
ACRS 16 CYS S	ENT CATEGORY	3		
				B
		الم		, i i i i i i i i i i i i i i i i i i i



135 FOW

IOWA ELECTRIC LIGHT AND POWER COMPANY

General Office CEDAR RAPIDS.IOWA December 14, 1977 IE-77-2255

LEE LIU VICE PRESIDENT - ENGINEERING

> Mr. Edson G. Case, Acting Director Office of Nuclear Reactor Regulation U.S. Nuclear Regulatory Commission Washington, D.C. 20545

Dear Mr. Case:

Transmitted herewith in accordance with the requirements of 10CFR50.59 and 50.90 is an application for amendment of DPR-59, RTS-102 to incorporate proposed changes to the Technical Specifications (Appendix A to License) for the Duane Arnold Energy Center.

The present operating limit MCPR's result in an approximate 10% derate during the last 1000 MWD/t exposure. Evaluation of actual scram insertion times indicates that sufficient margins exist to redefine the limiting scram curve used in the DAEC safety analysis. Use of the enclosed proposed Technical Specifications would essentially delete the end-of-cycle derate. Accordingly, approval of these limits would result in a savings to the public of approximately \$1,000,000 for the remainder of the cycle.

This change would not result in any change to the presently licensed safety limit MCPR of 1.06.

This application has been reviewed and approved by the DAEC Operations Committee and DAEC Safety Committee. This application does not involve a significant hazards consideration.

Three signed and notarized originals and 37 additional copies of this application are transmitted herewith. This application consisting of the foregoing letter and enclosure hereto, is true and accurate to the best of my knowledge and belief.

IOWA	ELECTRIC	LIGHT	AND	POWER	COMPANY
BY:	Ner.	<u></u>			

Lee Liu Vice President, Engineering

Subscribed and Sworn before me on this 15 chiday of December

Notary Public in and for the State of Iowa



773530054

LL/KAM/gan Enclosure .cc: K. Meyer D. Arnold R. Lowenstein R. Clark (NRC) L. Root File J-60a PROPOSED CHANGE RTS-102 TO DAEC TECHNICAL SPECIFICATIONS

I. Affected Technical Specifications

Appendix A of the Technical Specifications for the DAEC (DPR-49) provides as follows:

Specification 3.3.C, Scram Insertion Times, provides average scram insertion times for various rod positions and supporting bases.

Table 3.12-2 provides MCPR limits for 7 x 7 and 8 x 8 fuel.

II. Proposed Changes in Technical Specifications

The licensees of DPR-49 propose the following changes in the Technical Specifications set forth in I above:

Delete pages 3.3-6, 3.3-17 through 3.3-22, and 3.12-9a and replace with the attached pages.

III. Justification for Proposed Change

This change is proposed in order to provide operating margin improvements for DAEC. The safety analysis for these proposed changes is included in NEDO-24075, 77NED354, Class I, November 1977, "Duane Arnold Energy Center Cycle 3 Safety Analysis for Application of Measured Scram Insertion Times".

IV. Review Procedure

This proposed change has been reviewed by the DAEC Operations Committee and Safety Committee which have found that this proposed change does not involve a significant hazards consideration.

LIMITING CONDITIONS FOR OPERATION

C. <u>Scram Insertion Times</u>

- Two specifications for scram insertion time are provided. If the most recent available scram time data set meets Specification 3.3.C.2, the operating MCPR limit shall be as given in Table 3.12-2a. If the most recent available scram time data set does not meet Specification 3.3.C.2 but does meet Specification 3.3.C.3, the operating MCPR limit shall be as given in Table 3.12-2b.
- For application of the operating MCPR limits as specified in Table 3.12-2a, scram insertion time shall be as follows:
- a. The average scram insertion time, based on the de-energization of the scram pilot valve at time zero, of all operable control rods in the reactor power operation condition shall be no greater than:

Rod Position	Average Scram Insertion <u>Times (Sec)</u>
46	0.361
36	0.917
26	1.468
06	2.686

b. The average scram insertion times for the three fastest control rods of all groups of four control rods in a 2 x 2 array shall be no greater than:

Rod <u>Position</u>	Average Scram Insertion Times (Sec)
46	0.383
36	0.972
26	1.556
06	2.847

SURVEILLANCE REQUIREMENTS

C. <u>Scram Insertion Times</u>

- 1. After each refueling outage all operable rods shall be scram time tested from the fully withdrawn position with the nuclear system pressure above 950 psig (with saturation temperature) and the requirements of Specification 3.3.B.3.a met. This testing shall be completed prior to exceeding 40% power. Below 30% power, only rods in those sequences $(A_{12} \text{ and } A_{34} \text{ or } B_{12})$ and B₃₄) which were fully withdrawn in the region from 100% rod density to 50% rod density shall be scram time tested. During all scram time testing below 30% power, the Rod Worth Minimizer shall be operable or a second licensed operator shall verify that the operator at the reactor console is following the control rod program.
- 2. Whenever such scram time measurements are made (such as when a scram occurs and the computer is operable) an evaluation shall be made to provide reasonable assurance that proper control rod drive performance is being maintained.

3.3-6

LIMITING CONDITIONS FOR OPERATION	SURVEILLANCE REQUIREMENTS
3. For application of the operating MCPR limits as specified in Table 3.12-2b scram insertion times shall be as follows:	
a. The average scram insertion time, based on the de-energization of the scram pilot valve solenoids at time zero, of all operable control rods in the reactor power operation condition shall be no greater than:	
Average Scram Rod Insertion <u>Position Times (Sec)</u>	
46 0.37 36 1.10 26 1.87 06 3.41	
b. The average of the scram inser- tion times for the three fastest control rods of all groups of four control rods in a 2 x 2 array shall be no greater than:	
Average ScramRodInsertionPositionTimes (Sec)	
46 0.39 36 1.17 26 1.98 06 3.62	
c. The operating MCPR limits speci- fied in Table 3.12-2a shall not be applied unless the scram in- sertion time specification in 3.3.C.2 is met.	
 Maximum scram insertion time for 90% insertion of any operable control rod should not exceed 7.00 seconds. 	• •

3.3-6a

i

bypassed from the console for maintenance and/or testing. Tripping of one of the channels will block erroneous rod withdrawal soon enough to prevent fuel damage. This system backs up the operator who withdraws control rods according to written sequences. The specified restrictions with one channel out of service conservatively assure that fuel damage will not occur due to rod withdrawal errors when this condition exists.

A limiting control rod pattern is a pattern which results in the core being on a thermal hydraulic limit [MCPR = 1.40 (7 x 7 array) or 1.50 (8 x 8 array) and LHGR = 18.5 KW/ft (7 x 7 array) or 13.4 KW/ft (8 x 8 array)]. During use of such patterns, it is judged that testing of the RBM system prior to withdrawal of such rods to assure its operability will assure that improper withdrawal does not occur. It is the responsibility of the Reactor Engineer to identify these limiting patterns and the designated rods either when the patterns are initially established or as they develop due to the occurrence of inoperable control rods in other than limiting patterns. Other personnel qualified to perform this function may be designated by the DAEC Chief Engineer.

3. Scram Insertion Times

The control rod system is designed to bring the reactor subcritical at a rate fast enough to prevent fuel damage; i.e., to prevent the MCPR from becoming less than the safety limit.

3.3-17

Two sets of scram insertion time specifications are provided:

- a. That specified in Section 3.3.C.2 is based on analysis of data from DAEC and other plants with the same control drives and is the mean of this data plus a conservatism of approximately three standard deviations. When this specification is met, the operating MCPR limits given in Table 2.12-2a may be applied. Analysis of the most limiting transient (Rod Withdrawal Error) under these conditions shows that MCPR remains greater than the safety limit.
- b. That specified in Section 3.3.C.3 is for use if Specification 3.3.C.2 cannot be met and the operating MCPR limits in Table 2.12-2a cannot be applied. If only the specification in Section 3.3.C.3 can be met, only the operating MCPR limits specified in Table 2.12-2b are to be used. Analysis of the most limiting transient (Turbine Trip Without Bypass) under these conditions shows that MCPR remains greater than the safety limit.

After initial fuel loading and subsequent refuelings when operating above 950 psig, all control rods shall be scram tested within the constraints imposed by the Technical Specifications and before the 40% power level is reached.

The requirements for the various scram time measurements ensure that any indication of systematic problems with rod drives will be investigated on a timely basis.

3.3-18

4

3.3 AND 4.3 REFERENCES

 Duane Arnold Energy Center Cycle 3 Safety Analysis for Application of Measured Scram Insertion Times, NEDO-24075, 77NED354, Class I, November 1977.

TABLE 3.12-2

MCPR LIMITS

TABLE 3.12-2a

(For application only if scram time Specification 3.3.C.2 is met)

Fuel Type	
7 x 7	1.27
8 x 8	1.27

TABLE 3.12-2b

(For application if scram time Specification 3.3.C.2 is not met)

Fuel Type	Exposure Remaining t	o End of Cycle
		≤ 1000 MWD/T
	B.O.C to > 1000 MWD/T	to E.O.C.
7 x 7	1.27	1.29
8 x 8	1.27	1.37

NEDO-24075 77NED354 Class I November 1977

DUANE ARNOLD ENERGY CENTER

UNIT 1

CYCLE 3 SAFETY ANALYSIS

APPLICATION OF MEASURED SCRAM INSERTION TIMES

BOILING WATER REACTOR PROJECTS DEPARTMENT • GENERAL ELECTRIC COMPANY SAN JOSE, CALIFORNIA 95125



IMPORTANT NOTICE REGARDING CONTENTS OF THIS REPORT

Please Read Carefully

The only undertakings of General Electric Company respecting information in this document are contained in the contract between Iowa Electric Light and Power Company and General Electric Company, and nothing contained in this document shall be construed as changing the contract. The use of this information by anyone other than Iowa Electric Light and Power Company, for any purpose other than that for which it is intended, is not authorized; and with respect to any unauthorized use, General Electric Company makes no representation or warranty, and assumes no liability as to the completeness, accuracy, or usefulness of the information contained in this document.

TABLE OF CONTENTS

				Page
1.	INTRO	DUCTION	AND SUMMARY	1-1
2.	SCRAM	INSERT	ION TIME ANALYSIS	2-1
	2.1	Data B	ase	2-1
	2.2	Summar	y of Results	2-1
	2.3	Core A	verage Scram Insertion Time Specification	2-2
	2.4	Averag Fastes	e Scram Insertion Time Specification for the Three t Control Rods in a 2x2 Array	2-2
	2.5	Propos Requir	ed Technical Specification Scram Insertion Time ement	2-3
3	THERM	AL-HYDR	AULTC ANALYSES	3-1
J•	3.1	Statis	tical Analysis	3-1
	J.+	3.1.1	Fuel Cladding Integrity Safety Limit	3-1
		3.1.2	Basis for Statistical Analyses	3-1
	3.2	Analys	is of Abnormal Operations Transients	3-1
		3.2.1	Operating Limit MCPR	3-1
	3.3	Transi	ent Analysis Initial Condition Parameters	3-2
4.	ABNOR	MAL OPE	RATING TRANSIENTS	4-1
	4.1	Transi	ents and Core Dynamics	4-1
		4.1.1	Analysis Basis	4-1
		4.1.2	Input Data and Operating Conditions	4-1
		4.1.3	Transient Summary	4-1
	4.2	Transi	ent Descriptions	4-1
		4.2.1	Turbine Trip With Failure of the Bypass Valves	4-1
		4.2.2	Loss of a Feedwater Heater	4-2
		4.2.3	Rod Withdrawal Error	4-2
		4.2.4	Turbine Trip With Operable Bypass	4-2
	•	4.2.5	Feedwater Controller Failure	4-3
5.	TECHN	ICAL SP	ECIFICATION CHANGES	5-1
6.	REFER	ENCES		6-1

.

LIST OF ILLUSTRATIONS

Figure	Title	Page
2-1	Scram Insertion Times, DAEC, Average Scram Insertion Time of All Operable Control Rods	2-4
2-2	Scram Inertion Times, DAEC, Average of Fastest Three out of Four Control Rods in Any 2x2 Array	2-5
2-3	Histogram of DAEC rull Core Individual Drive Scram Insertion Time Data	2-6
2-4	Histogram of DAEC Full Core Individual Drive Scram Insertion Time Data	2-7
2-5	Histogram of DAEC Full Core Individual Drive Scram Insertion Time Data	2-8
2-6	Histogram of DAEC Full Core Scram Insertion Time Data	2-9
2-7	Histogram of DAEC Full Core Scram Insertion Data - Average of Fastest Three Control Rods in a 2x2 Array - Position 06	2-10
2-8	Histogram of DAEC Full Core Scram Insertion Data - Average of Fastest Three Control Rods in a 2x2 Array - Position 26	2-10
2-9	Histogram of DAEC Full Core Scram Insertion Data - Average of Fastest Three Control Rods in a 2x2 Array - Position 36	2-11
2-10	Histogram of DAEC Full Core Scram Insertion Data - Average of Fastest Three Control Rods in a 2x2 Array - Position 46	2-11
4-1	Turbine Trip Without Bypass-Trip Scram	4-5
4-2	Turbine Trip With Bypass-Trip Scram	4-6
4-3	Feedwater Controller Failure Maximum Demand With High Level Turbine Trip	4-7
4-4	Control Rod Drive Specification and Scram Reactivity, DAEC, Cycle 3	4-8

LIST OF TABLES

<u>Table</u>	Title	Page
2-1	Proposed Scram Time Technical Specification	2-3
3-1	Summary of Results Limiting Abnormal Operational ACPR Transients	3-2
3-2	GETAB Transient Analysis Initial Condition Parameters	3- 2
4-1	Transient Input Parameters	4-4
4-2	Transient Data Summary	4 - 4



1. INTRODUCTION AND SUMMARY

Reference 1 contained the safety analysis for the Duane Arnold Energy Center (DAEC) cycle 3 based on scram insertion times as given by the Technical Specifications. Scram data from operating plants had indicated that these scram times are quite conservative; however, a sufficient data base with supporting statistical analysis to justify the use of more realistic scram time in plant safety analyses did not exist.

As part of a continuing program to provide operating margin improvements for DAEC to enable continued full power operation, operating data was collected and the necessary statistical analysis completed. From this analysis a revised scram insertion time specification was derived which would be unlikely to be exceeded during any scram.

This report describes the scram data base and statistical analysis, identifies the proposed scram insertion time limit and presents the results of the safety analysis which defines the MCPR operating limit based on the revised scram insertion time limit.

2. SCRAM INSERTION TIME ANALYSIS

Control rod scram time data from two similar operating BWR/4's were used to derive a more realistic scram insertion time specification to be used in the DAEC safety analysis to define the operating MCPR limit. The collection of the data is described in Section 2.1.

2.1 Data Base

The DAEC data base included four full core (89 control rod drives) individual drive scram tests over a four year operating period (1 full core scram test per year). Scram times were recorded at four insertion positions (≈5%, 20%, 50% and 90% insertion) for each individual control rod drive. DAEC scram times were also available from 8 full core reactor scrams in which the scram times were recorded for approximately 20 drives per reactor scram. This pro-vides a data base of over 500 rod scram times specifically applicable to DAEC.

Scram time data from another BWR operating plant similar to DAEC (BWR/4 plant with the same number of control rods) with an identical control rod drive design were also used in the analysis to obtain a better estimate of the scram time variation between tests. This data base included scram times from 15 scram tests conducted over a two year period. Two of the 15 scram tests were full core (89 control rod drives) individual drive scram tests. The remaining 13 scram tests were from full core reactor scram tests in which the scram times were recorded for approximately 45 drives per reactor scram. Thus, over 1150 rod scram times were to derive a more realistic scram time to be used in the plant safety analysis.

2.2 SUMMARY OF RESULTS

The core average scram insertion time specification assumed in safety analysis to determine the MCPR operating limit for each insertion position is greater than the measured DAEC average scram insertion time plus three standard deviations for the region of greatest importance (less than 50% inserted). The proposed average scram time specification for the three fastest control rods in a 2x2 array is greater than the measured DAEC average scram insertion time

plus 2.6 standard deviations for this same region. The probability of exceeding the proposed specification limits is, therefore, acceptably low (probability <1%) and is unlikely to be exceeded during any scram.

2.3 CORE AVERAGE SCRAM INSERTION TIME SPECIFICATION

- a. The proposed core average scram insertion time specification for each insertion position has been selected so that it is unlikely that the specification would be exceeded. The actual calculated difference between the proposed specification and the measured average (in terms of number of standard deviations) for each insertion position is given in Figure 2-1.
- b. The DAEC average scram insertion time was calculated from the four full core individual drive tests. The data from these tests are the most representative of the population average since each of the four tests included scram times for all drives in the core. The distribution of these data is depicted in Figures 2-3, 2-4, 2-5 and 2-6.
- c. The standard deviation for each insertion position was calculated from the average scram insertion times of the four full core individual drive scram tests and the eight full core scrams at DAEC.
- d. The standard deviations calculated from the DAEC core average data are consistent with the standard deviations experienced at the other BWR.
- 2.4 AVERAGE SCRAM INSERTION TIME SPECIFICATION FOR THE THREE FASTEST CONTROL RODS IN A 2x2 ARRAY
 - a. The proposed specification for the average scram insertion time of the three fastest control rods in a 2x2 array is greater than the DAEC measured average scram insertion times by more than 2.5 standard deviations. The lower bound of the difference between the proposed specification and the measured average (in terms of number of standard deviations) for each insertion position is given in Figure 2-2.

- b. The DAEC average scram insertion time of the fastest 3 rods in a 2x2 array was assumed to be equal to the average calculated for the core average scram insertion time specification. The real average of the fastest 3 rods in a 2x2 array would be less, and therefore, this is a conservative assumption. The data for the 3 fastest rods in all 2x2 arrays is shown in Figures 2-6, 2-7, 2-8, and 2-9.
- c. The standard deviations used for this part of the analysis were calculated from the DAEC measured distribution of individual drive scram times. The standard deviation for the distribution of the averages of the three fastest control rods in a 2x2 array would be less than the calculated standard deviation of scram insertion times for individual drives. A precise calculation of the standard deviation of the average of the three fastest scram insertion times in a 2x2 array is not necessary since the average of the individual drive scram insertion times plus three standard deviations is approximately equal to the proposed specification. Therefore, there is a low probability (<1%) of exceeding the proposed technical specification for the average scram time of the three fastest control rods in a 2x2 array.
- d. The standard deviations calculated from the DAEC individual drive measurements are consistent with the standard deviations experienced at the other BWR.

2.5 PROPOSED TECHNICAL SPECIFICATION SCRAM INSERTION TIME REQUIREMENT

The proposed new scram insertion time specification is given in Table 2-1.

Table 2-1

PROPOSED SCRAM TIME TECHNICAL SPECIFICATION

Average of Fastest

		2
	Core Mean	3 out of 4 Insertion
Control Rod	Insertion Time	Times in any 2x2
Position	(sec)	Array (sec)
46	<u><</u> 0.361	<u><</u> 0.383
36	<u><</u> 0.917	<u><</u> 0.972
26	<u><</u> 1.468	<u><</u> 1.556
06	<u><</u> 2.686	<u><</u> 2.847
	· · · ·	



NED0-24075





Figure 2-2. Scram Insertion Times, DAEC, Average of Fastest Three out of Four Control Rods in Any 2x2 Array





Figure 2-3. Histogram of DAEC Full Core Individual Drive Scram Insertion Time Data





Figure 2-4. Histogram of DAEC Full Core Individual Drive Scram Insertion Time Data



Figure 2-5. Histogram of DAEC Full Core Individual Drive Scram Insertion Time Data



Figure 2-6. Histogram of DAEC Full Core Scram Insertion Time Data



Figure 2-7. Histogram of DAEC Full Core Scram Insertion Data - Average of Fastest Three Control Rods in a 2x2 Array - Position 06



PROPOSED SPECIFICATION = 1.556 sec





PROPOSED SPECIFICATION = 0.972 sec

PROPOSED SPECIFICATION = 0.383 sec







2-11/2-12

3. THERMAL-HYDRAULIC ANALYSES

Discussions of thermal-hydraulic design requirements, hydraulic models, statistical analysis and uncertainties, and thermal hydraulics of mixed core loading are given in Section 4 of Reference 2. The analysis applicable to Duane Arnold Cycle 3, is given below and in References 1, 3 and 4.

3.1 STATISTICAL ANALYSIS

The statistical analysis is described in Reference 3.

3.1.1 Fuel Cladding Integrity Safety Limit

The fuel cladding integrity safety limit is a MCPR of 1.06.

3.1.2 Basis for Statistical Analyses

The basis for the statistical analysis is described in Reference 3.

3.2 ANALYSIS OF ABNORMAL OPERATIONS TRANSIENTS

The results of the most limiting pressure and power increase transients were evaluated to determine the largest decrease in MCPR. Other types of transients have an insignificant effect upon critical power and are, therefore, not reviewed in depth. The results of the transients analyzed are summarized in Table 3-1.

Addition of the \triangle CPR to the Safety Limit MCPR gives the minimum operating MCPR required to avoid violating the Safety Limit should this limiting transient occur.

3.2.1 Operating Limit MCPR

Based on the fuel cladding integrity safety limit and the results of the abnormal operational transient analyses, the operating limit MCPR is 1.21 for 7x7 and 1.22 for 8x8 fuels.

3.3 TRANSIENT ANALYSIS INITIAL CONDITION PARAMETERS

The magnitude of values used as initial input conditions for the transient analysis is shown in Table 3-2.

Table 3-1

SUMMARY OF RESULTS LIMITING ABNORMAL OPERATIONAL \triangle CPR TRANSIENTS

		EOC3	
Event		<u>7x7</u>	<u>8x8</u>
Rod Withdrawal Error	•	0.15	0.16
Loss of Feedwater Heater*		0.14	0.15
Turbine Trip w/o Bypass		0.08	0.12
Feedwater Controller Failure		0.04	0.07
Turbine Trip with Bypass		<0.01	0.02

Table 3-2

GETAB TRANSIENT ANALYSIS INITIAL CONDITION PARAMETERS

	<u>7x7</u>	<u>8x8</u>
Peaking factors (local, radial and axial)	(1.24, 1.285, 1.40)	(1.22, 1.44, 1.40)
R-Factor	1,100	1.098
Bundle Power, MWt	5.524	6.115
Non-fuel Power Fraction	0.04	0.04
Core Flow, Mlb/hr	49.0	49.0
Bundle Flow, 10 ³ 1b/hr	122.7	110.9
Reactor Pressure, psia	1035.0	1035.0
Inlet Enthalpy, Btu/1b	526.3	526.3
Initial MCPR	1.20	1.20

*Results of bounding analysis from Reference 1.

4. ABNORMAL OPERATING TRANSIENTS

4.1 TRANSIENTS AND CORE DYNAMICS

4.1.1 Analysis Basis

This subsection contains the analyses of the most limiting abnormal operational transients for Duane Arnold Energy Center Cycle 3 using the proposed new scram insertion time specification. The control rod drive specifications are given in Figure 4-4.

4.1.2 Input Data and Operating Conditions

The input data and operating conditions are shown in Table 4-1 and represent the nominal basis for these analyses. Each transient is considered at these conditions unless otherwise specified.

4.1.3 Transient Summary

A summary of the transients analyzed and their consequences is provided in Table 4-2.

4.2 TRANSIENT DESCRIPTIONS

The abnormal operating transients which are limiting according to safety criteria and which also are sensitive to nuclear core parameter changes have been analyzed and are evaluated in the following narrative.

4.2.1 <u>Turbine Trip With Failure of the Bypass Valves</u>

The primary characteristic of the turbine trip without bypass is a pressure increase due to the obstruction of steam flow by the turbine stop valves. The pressure increase causes a significant void reduction which yields a pronounced positive void reactivity effect. Core net reactivity is sharply positive and causes a rapid increase in neutron flux until the net reactivity is forced negative by the scram initiated from the position switches on the turbine stop valves.

This unlikely event would produce a transient as shown in Figure 4-1. The initial reactor power is at a level corresponding to 105% of rated steam flow, the neutron flux peaks at 249% initial, the average surface heat flux peaks at 104% of initial.

The peak streamline pressure is limited to 1171 psig as a result of the highpressure actuation of the six safety/relief valves which provides a 69-psi margin to the 1240-psig set point of the first spring safety valve.

4.2.2 Loss of a Feedwater Heater

The loss of a feedwater heater was analyzed in Reference 1. This analysis is consevative for the new scram insertion time. Since the loss of feedwater heater does not affect the MCPR limit this transient was not reanalyzed.

4.2.3 Rod Withdrawal Error

The rod withdrawal error was analyzed for the fully drilled core (most conservative case). The results were not measurably different from those presented in Reference 3; therefore the analysis presented in Reference 3 is applicable to the half-drilled core. The rod withdrawal error analysis is unchanged by the control rod scram insertion time.

4.2.4 Turbine Trip With Operable Bypass

A variety of turbine or nuclear system malfunctions will initiate a turbine trip. Some examples are: moisture separator and heater drain tank high levels, large vibration, loss of control fluid pressure, loss of condenser vacuum and reactor high water level.

The following sequence of events occurs for a turbine trip:

a. The turbine stop valves close over a period of approximately 0.1 second.

- b. A reactor scram is initiated from position switches on the turbine stop values at 10% closure.
- c. The turbine bypass valves are opened by the turbine control system. Delay after start of stop valve closure is 0.1 second.
- d. The pressure continues to rise until the pressure relief set points are reached, some or all of the safety/relief valves briefly discharge steam to the suppression pool.

This event would produce a transient as shown in Figure 4-2. The initial reactor power is at a level corresponding to 105% of NBR steam flow, the neutron flux peaks at 140% of initial, the average surface heat peaks at 100% initial.

The peak streamline pressure is limited to 1137 psig as a result of the highpressure actuation of the six safety/relief valves, which provides a 103-psi margin to the 1240-psig set point of the first spring safety valve.

4.2.5 Feedwater Controller Failure

An event that can directly cause excess coolant inventory is one in which feedwater flow is increased. The most severe applicable event in a feedwater controller failure in the maximum demand direction. The transient was initiated from a level corresponding to 105% of NBR steam flow. The feedwater controller was assumed to fail such as to demand maximum feedwater valve opening resulting in a maximum runout flow of 135% of NBR rated feedwater flow at a system pressure of 1060 psig. With excess feedwater flow, the water level rises to the high level trip setpoint, at which time the main turbine and feedwater pumps are tripped and a reactor scram is initiated. Figure 4-3 shows the results of this transient. The neutron flux peaks at 153% of initial and the average surface heat flux peaks at 104% initial.

The peak streamline pressure is limited to 1138 psig as a result of the highpressure actuation of the six safety/relief valves, which provides a 102-psi margin to the 1240-psig set point of the first spring safety valve.

Table 4-1 TRANSIENT INPUT PARAMETERS

Thermal Power	(MWt)	1657	104%	Rated
Steam Flow	(1b/hr)	7.16 x 10 ⁶	105%	NBR
NBR Core Flow	(1b/hr)	49.0 x 10 ⁶	100%	NBR
Dome Pressure	psig	1020		
Turbine Pressure	psig	960		
RV Set Point (nominal/analysis)	psig	1090/1101		
RV/Capacity (at Set Point)	No./%NBR	6/72.0		
RV Time Delay	(msec)	400		
RV Stroke Time	(msec)	100		
SV Set Point (nominal/analysis)	psig	1240/1253		
SV/Capacity (at Set Point)	No./%NBR	2/18.9		

		Analysis	Nominal
Dynamic Void Coefficient	(-c/%Rg)	11.67	9.34
Doppler Coefficient	(-c/°F)	0.2186	0.2301
Average Fuel Temperature	(°F)	1435	1435
Scram Reactivity Curve		Fig. 4-4	Fig. 4-4
Scram Worth	(-\$)	31.51	39.39

Table 4-2

TRANSIENT DATA SUMMARY

Transient	Power (%)	Core Flow (%)	¢ (% reference)	0/A (% reference)	Ps1 (psig)
Turbine Trip without Bypass	104	100	249	104	1171
Loss of Feedwater Heater*	104	100	121	119	1023
Feedwater Controller Failure	104	100	153	104	1138
Turbine Trip with Bypass	104	100	140	100	1137

*Results of bounding analysis from Reference 1.





4-5



ł





Figure 4-3. Feedwater Controller Failure Maximum Demand With High Level Turbine Trip

4-7





REACTIVITY (-\$)

5. TECHNICAL SPECIFICATION CHANGES

The following technical specification changes will be required.

a. MCPR Operating Limit

b. Scram Insertion Times

6. REFERENCES

- "General Electric Boiling Water Reactor, Reload Number 2 Licensing Submittal Supplement 1, Partially Drilled Core, Duane Arnold Energy Center," Supplement 1, June 1977, (NEDO-21082-02-1).
- GE/BWR Generic Reload Licensing Application for 8x8 fuel, Rev. 1, Supplement 4, April 1976 (NEDO-20360).
- 3. General Electric Boiling Water Reactor Reload 2 Licensing Submittal Duane Arnold Energy Center, January 1977 (NEDO-21082-02).
- 4. Safety Evaluation, Safety/Relief Valve Replacement, Duane Arnold Energy Center, May 1977.

NUCLEAR ENERGY DIVISIONS • GENERAL ELECTRIC COMPANY SAN JOSE, CALIFORNIA 95125



TECHNICAL INFORMATION EXCHANGE

AUTHOR	SUBJECT	TIE NUMBER	
		77NED354	
Jim Rash	DUANE ARNOLD	DATE November 1977	
TITLE DUANE ARN	OLD ENERGY CENTER	GE CLASS	
UNIT 1 CYCLE 3	SAFETY ANALYSIS	I	
APPLICATION OF	MEASURED SCRAM	GOVERNMENT CLASS	
REPRODUCIBLE COP	PY FILED AT TECHNICAL	NUMBER OF PAGES	
SUPPORT SERVICES,	, R&UO, SAN JOSE,		
CALIFORNIA 95125	(Mail Code 211)	24	
SUMMARY			
This report de the statistica	escribes the creation I analysis, specifies	of the data base and the proposed scram	
insertion time	e limit and presents a	nalyses to support	
MCPR limits ba	ased on the new scram	insertion time	
limits.			
L	······································		
av outting out this m	stands and folding in half the	have information can be fitted	

By cutting out this rectangle and folding in half, the above information can be fitted into a standard card file.

DOCUMENT NUMBER NEDO-24075 INFORMATION PREPARED FOR Nuclear Energy Division SECTION BWR PD BUILDING AND ROOM NUMBER K-2606 MAIL CODE 682