

NOTES TO TABLE 3.7-2

<sup>1</sup>Test volume is filled with demineralized water then pressurized to 54 psig with air or nitrogen for test. For all other penetrations (except 7A-D), test volumes are pressurized to 54 psig with air or nitrogen for test.

<sup>2</sup>MO-4441, MO-4442 will be remote manually closed.

<sup>3</sup>In accordance with 10 CFR 50, Appendix A, General Design Criterion 57, the redundant barriers are a single isolation valve outside containment and a closed system inside. Testing of the single isolation valve only is required. Manual valves V-57-75, V-57-76, V-57-77 and V-57-78 will be normally closed. |

<sup>4</sup>Tested in reverse direction.

8501310424 850124  
PDR ADOCK 05000331  
P PDR