

**SUPPLEMENTAL RELOAD LICENSING SUBMITTAL
FOR DUANE ARNOLD ATOMIC ENERGY CENTER
RELOAD 6**

8305060076 830504
PDR ADOCK 05000331
PDR

GENERAL  ELECTRIC

Y1003J01A46
Revision 1
Class I
March 1983

SUPPLEMENTAL RELOAD LICENSING SUBMITTAL
FOR
DUANE ARNOLD ATOMIC ENERGY CENTER
RELOAD 6

Prepared: R. L. Wagner
R. L. Wagner

Verified: W. A. Zarbis
W. A. Zarbis

Approved: J. S. Charnley
J. S. Charnley
Fuel Licensing Manager

NUCLEAR POWER SYSTEMS DIVISION • GENERAL ELECTRIC COMPANY
SAN JOSE, CALIFORNIA 95125

GENERAL  ELECTRIC

IMPORTANT NOTICE REGARDING
CONTENTS OF THIS REPORT
PLEASE READ CAREFULLY

This report was prepared by General Electric solely for Iowa Electric Light and Power Company (IELP) for IELP's use with the U.S. Nuclear Regulatory Commission (USNRC) for amending IELP's operating license of the Duane Arnold Energy Center Unit 1. The information contained in this report is believed by General Electric to be an accurate and true representation of the facts known, obtained or provided to General Electric at the time this report was prepared.

The only undertakings of the General Electric Company respecting information in this document are contained in the contract between Iowa Electric Light and Power Company and General Electric Company for nuclear fuel and related services for the nuclear system for Duane Arnold Energy Center Unit 1, dated February 8, 1968, and nothing contained in this document shall be construed as changing said contract. The use of this information except as defined by said contract, or for any purpose other than that for which it is intended, is not authorized; and with respect to any such unauthorized use, neither General Electric Company nor any of the contributors to this document makes any representation or warranty (express or implied) as to the completeness, accuracy or usefulness of the information contained in this document or that such use of such information may not infringe privately owned rights; nor do they assume any responsibility for liability or damage of any kind which may result from such use of such information.

1. PLANT-UNIQUE ITEMS (1.0)*

Appendix A: Operating Flexibility Options

2. RELOAD FUEL BUNDLES (1.0, 2.0, 3.3.1 AND 4.0)

		<u>CYCLE LOADED</u>	<u>NUMBER</u>	<u>NUMBER DRILLED</u>
Irradiated	8DB274H	4	68	68
Irradiated	P8DPB289	5	88	88
Irradiated	P8DPB289	6	84	84
New	P8DRB284H	7	88	88
New	P8DRB299	7	40	40
TOTAL			<u>368</u>	<u>368</u>

3. REFERENCE CORE LOADING PATTERN (3.3.1)

Nominal previous cycle core average exposure at end of cycle: 17,045 MWd/t

Minimum previous cycle core average exposure at end of cycle from cold shutdown considerations: 16,845 MWd/t

Assumed reload cycle core average exposure at end of cycle: 17,443 MWd/t

Core loading pattern: Figure 1

4. CALCULATED CORE EFFECTIVE MULTIPLICATION AND CONTROL SYSTEM WORTH - NO VOIDS, 20°C (3.3.2.1.1 AND 3.3.2.1.2)

BOC k_{eff}

Uncontrolled	1.112
Fully Controlled	0.954
Strongest Control Rod Out	0.988
R, Maximum Increase in Cold Core Reactivity with Exposure Into Cycle, Δk	0.001

* () refers to areas of discussion in "General Electric Standard Application for Reactor Fuel," NEDE-24011-P-A-4, January 1982.

5. STANDBY LIQUID CONTROL SYSTEM SHUTDOWN CAPABILITY (3.3.2.1.3)

<u>ppm</u>	<u>Shutdown Margin (Δk) (20°C, Xenon Free)</u>
600	0.029

6. RELOAD-UNIQUE TRANSIENT ANALYSIS INPUTS (3.3.2.1.5 AND S.2)

(REDY Events Only)	<u>EOC7</u>
Void fraction (%)	41.8
Average Fuel Temperature (°F)	1289
Void Coefficient N/A* (¢/% Rg)	-8.82/-11.02
Doppler Coefficient N/A (¢/°F)	-0.232/-0.220
Scram Worth N/A (\$)	-46.31/-37.05

7. RELOAD-UNIQUE GETAB TRANSIENT ANALYSIS INITIAL CONDITION PARAMETERS (S.2)

<u>Fuel Design</u>	<u>Peaking Factors</u>			<u>R- Factor</u>	<u>Bundle Power (MWt)</u>	<u>Bundle Flow (1000 lb/hr)</u>	<u>Initial MCPR</u>
	<u>Local</u>	<u>Radial</u>	<u>Axial</u>				
BOC 7 to EOC 7							
P8x8R	1.20	1.56	1.40	1.051	6.598	110.3	1.22
8x8	1.22	1.43	1.40	1.098	6.062	109.3	1.20

8. SELECTED MARGIN IMPROVEMENT OPTIONS (S.2.2.2)

Transient Recategorization: No
 Recirculation Pump Trip: Yes
 Rod Withdrawal Limiter: No
 Thermal Power Monitor: No
 Measured Scram Time: Yes
 Number of Exposure Points: 1

*N = Nuclear Input Data

A = Used in Transient Analysis

9. CORE-WIDE TRANSIENT ANALYSIS RESULTS (S.2.2.1)

<u>Transient</u>	<u>Flux (%NBR)</u>	<u>Q/A (%NBR)</u>	<u>ΔCPR</u>		<u>Figure</u>
			<u>P8x8R</u>	<u>8x8</u>	
Exposure: BOC 7 to EOC 7 Load Rejection w/o Bypass	434	117	0.17	0.15	2
Exposure: BOC to EOC Loss of Feedwater Heater	125	124	0.15	0.15	3
Exposure: BOC 7 to EOC 7 Feedwater Controller Failure	326	114	0.11	0.10	4

10. LOCAL ROD WITHDRAWAL ERROR (WITH LIMITING INSTRUMENT FAILURE) TRANSIENT SUMMARY (S.2.2.1)

(Generic Bounding Analysis Results)

<u>Rod Block Reading</u>	<u>ΔCPR (All Fuel Types)</u>
104	0.13
105	0.16
106	0.19
107	0.22
108	0.28
109	0.32
110	0.36

Set Point Selected: 105

11. OPERATING MCPR LIMIT (S.2.2)

ODYN (Option A)

<u>8x8</u>	<u>P8x8R</u>
1.27	1.29

] Rev. 1

] Rev. 1

12. OVERPRESSURIZATION ANALYSIS SUMMARY (S.2.3)

<u>Transient</u>	P_{sl} (psig)	P_v (psig)	<u>Plant Response</u>
MSIV Closure (Flux Scram)	1232	1257	Figure 5

13. STABILITY ANALYSIS RESULTS (S.2.4)

Rod Line Analyzed: Extrapolated Rod Block Line

Decay Ratio:

Figure 6

Reactor Core Stability Decay Ratio, x_2/x_0

0.85

Channel Hydrodynamic Performance Decay Ratio, x_2/x_0

Channel Type

P8x8R

0.31

8x8

0.39

14. LOADING ERROR RESULTS (S.2.5.4)

Variable Water Gap Misoriented Bundle Analysis: Yes

Includes 2.2% Power Spiking Penalty: Yes

<u>Event</u>	<u>Initial MCPR</u>	<u>Resulting MCPR</u>
Misoriented	1.20	1.07

15. CONTROL ROD DROP ANALYSIS RESULTS (S.2.5.1)

Bounding Analysis Results:

Doppler Reactivity Coefficients: Figure 7

Accident Reactivity Shape Functions: Figures 8 and 9

Scram Reactivity Functions: Figures 10 and 11

Plant Specific Analysis Results:

Parameters not Bounded, Cold: Accident Reactivity
Scram Reactivity

Resultant Peak Enthalpy, Cold (cal/gm): 236.6

Parameters not Bounded, HSB: None

16. LOSS-OF-COOLANT ACCIDENT RESULTS (S.2.5.2)

See "Loss-of-Coolant Accident Analysis Report for Duane Arnold Energy Center (Lead Plant)", July 1977 (NEDO-21082-02-1A).

Fuel Type: P8DRB299


<u>Exposure</u>		<u>MAPLHGR</u> (kW/ft)	<u>PCT</u> (°F)	<u>Local Oxidation</u> (Fraction)
<u>(GWd/t)</u>	<u>(GWd/MT)</u>			
0.20	0.22	10.90	2080.0	0.023
1.0	1.1	11.00	2082.0	0.023
5.0	5.5	11.50	2114.0	0.025
10.0	11.0	12.20	2191.0	0.031
15.0	17.0	12.20	2198.0	0.032
20.0	22.0	12.10	2199.0	0.032
25.0	28.0	11.80	2153.0	0.027
30.0	33.0	11.30	2118.0	0.059
35.0	39.0	10.90	2048.0	0.047
40.0	44.0	10.50	1978.0	0.037
45.0	50.0	10.00	1911.0	0.028

Fuel Type: P8DRB284H

<u>Exposure</u>		<u>MAPLHGR</u> (kW/ft)	<u>PCT</u> (°F)	<u>Local Oxidation</u> (Fraction)
<u>(GWd/t)</u>	<u>(GWd/MT)</u>			
0.20	0.22	11.20	2119.0	0.026
1.0	1.1	11.20	2115.0	0.026
5.0	5.5	11.70	2148.0	0.028
10.0	11.0	12.00	2177.0	0.030
15.0	17.0	12.00	2182.0	0.030
20.0	22.0	11.90	2176.0	0.030
25.0	28.0	11.30	2098.0	0.023
30.0	33.0	10.80	2034.0	0.044
35.0	39.0	10.40	1963.0	0.034
40.0	44.0	10.00	1894.0	0.026
45.0	50.0	9.50	1827.0	0.018

LIST OF FIGURES

1. Reference Core Loading Pattern
2. Plant Response to Load Rejection, Without Bypass (104% Power/100% Flow)
3. Plant Response to Loss of Feedwater Heating (104% Power/100% Flow)
4. Plant Response to Feedwater Controller Failure (104% Power/100% Flow)
5. Plant Response to MSIV Closure, Flux Scram (104% Power/100% Flow)
6. Reactor Core Decay Ratio
7. Doppler Reactivity Coefficient Comparison for RDA
8. RDA Reactivity Shape Function at 20°C
9. RDA Reactivity Shape Function at 286°C
10. RDA Scram Reactivity Function at 20°C
11. RDA Scram Reactivity Function at 286°C



FUEL TYPE	
A = P8DRB299	D = P8DPB289
B = P8DRB284H	E = P8DPB289
C = 8DB274H	

Figure 1. Reference Core Loading Pattern







Figure 2. Plant Response to Load Rejection, Without Bypass (104% Power/100% Flow)







Figure 3. Plant Response to Loss of Feedwater Heating (104% Power/100% Flow)







Figure 4. Plant Response to Feedwater Controller Failure (104% Power/100% Flow)







Figure 5. Plant Response to MSIV Closure, Flux Scram (104% Power/100% Flow)




Figure 6. Reactor Core Decay Ratio




Figure 7. Doppler Reactivity Coefficient Comparison for RDA




Figure 8. RDA Reactivity Shape Function at 20°C




Figure 9. RDA Reactivity Shape Function at 286°C




Figure 10. RDA Scram Reactivity Function at 20°C




Figure 11. RDA Scram Reactivity Function at 286°C

APPENDIX A

OPERATING FLEXIBILITY OPTIONS

The following operating flexibility options have been developed for BWRs. A "Yes" indicates that the option has been verified as being applicable to Cycle 7.

- a. Single Loop Operation: Yes
- b. Load Line Limit: Yes
- c. Extended Load Line Limit: No
- d. Increased Core Flow: No
- e. Feedwater Temperature Reduction: No