

LIMITING CONDITION FOR OPERATION

2.
 - a. From and after the date that the safety valve function of one relief valve is made or found to be inoperable, continued reactor operation is permissible only during the succeeding thirty days unless such valve function is sooner made operable.
 - b. From and after the date that the safety valve function of two relief valves is made or found to be inoperable, continued reactor operation is permissible only during the succeeding seven days unless such valve function is sooner made operable.
3. If Specification 3.6.D.1 is not met, an orderly shutdown shall be initiated and the reactor coolant pressure shall be reduced to atmospheric within 24 hours.

Note: See Section 6.11.2.a for prompt notification requirement.

E. Jet Pumps

1. Whenever the reactor is in the startup or run modes, all jet pumps shall be operable. If it is determined that a jet pump is inoperable, an orderly shutdown shall be initiated and the reactor shall be in a Cold Shutdown Condition within 24 hours.

SURVEILLANCE REQUIREMENT

2. At least one of the relief valves shall be disassembled and inspected each refueling outage.
 3. With the reactor pressure \geq 100 psig and turbine bypass flow to the main condenser, each relief valve shall be manually opened and verified open by turbine bypass valve position decrease and pressure switches and thermocouple readings downstream of the relief valve to indicate steam flow from the valve once per operating cycle.
- E. Jet Pumps
1. Whenever there is recirculation flow with the reactor in the startup or run modes, jet pump operability shall be checked daily by verifying that the following conditions do not occur simultaneously:
 - a. The two recirculation loops have a flow imbalance of 15% or more when the pumps are operated at the same speed.

8307250227 830720
PDR ADDCK 05000331
P PDR

- c. Monthly Operating Report Routine reports of operating statistics and shutdown experience shall be submitted on a monthly basis to the Director, Office of Management Information and Program Control, U.S. Nuclear Regulatory Commission, Washington, D.C. 20555, with a copy to the appropriate Regional Office, to arrive no later than the 15th of each month following the calendar month covered by the report.

- d. Table 6.11-1 lists some of the routine reports required by 10 CFR Parts 20, 40, 50 and 70, including those listed in Specification 6.11.1.

- e. Annual Safety/Relief Valve Challenge A report documenting safety/relief valve challenges shall be submitted within 60 days of January 1 each year.

- (7) Conditions arising from natural or man-made events that, as a direct result of the event require plant shutdown, operation of safety systems, or other protective measures required by technical specifications.
- (8) Errors discovered in the transient or accident analyses or in the methods used for such analyses as described in the safety analysis report or in the bases for the technical specifications that have or could have permitted reactor operation in a manner less conservative than assumed in the analyses.
- (9) Performance of structures, systems, or components that requires remedial action or corrective measures to prevent operation in a manner less conservative than assumed in the accident analyses in the safety analysis report or technical specifications bases; or discovery during plant life of conditions not specifically considered in the safety analysis report or technical specifications that require remedial action or corrective measures to prevent the existence or development of an unsafe condition.

Note: This item is intended to provide for reporting of potentially generic problems.

- (10) Failure or malfunction of the primary reactor coolant system (safety valves or) safety/relief valves.

b. Thirty Day Written Reports. The reportable occurrences discussed below shall be the subject of written reports to the Director

TABLE 6-11-1

REPORTING SUMMARY - ROUTINE REPORTS

<u>Requirement</u>	<u>Report</u>	<u>Timing of Submittal</u>
TS	Annual Safety/ Relief Valve Challenge	Within 60 days after January 1.
TS	Annual Exposure	Within 60 days after January 1.
§20.407	Personnel Exposure and Monitoring	Within first quarter of each calendar year.
§20.408	Personnel Exposure on Termination of Employment or Work	Within 30 days after the exposure of the individual has been determined or 90 days after date of termination of employment or work assignment, whichever is earlier.
§40.64(a)	Transfer of Source Material	Promptly upon transfer.
§40.64(a)	Receipt of Source Material	Within 10 days after material is received.
§40.64(b)	Source Material Inventory	Within 30 days after September 30 of each year.