

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR:8007140366 DOC.DATE: 80/07/07 NOTARIZED: YES DOCKET #
 FACIL:50-331 Duane Arnold Energy Center, Iowa Electric Light & Pow 05000331
 AUTH.NAME AUTHOR AFFILIATION
 ROOT,L.D. Natural Resources Defense Council
 RECIP.NAME RECIPIENT AFFILIATION
 Commission

SUBJECT: Application to reinstate Amend 60 to App A (Tech Specs) to
 License DPR-49 re reactor startup & operation for greater
 than 24-h w/one recirculation loop out of svc.

DISTRIBUTION CODE: A001S COPIES RECEIVED:LTR 1 ENCL 0 SIZE: 1
 TITLE: General Distribution for after Issuance of Operating Lic

NOTES: _____

	RECIPIENT		COPIES			RECIPIENT		COPIES	
	ID CODE/NAME		LTR	ENCL		ID CODE/NAME		LTR	ENCL
ACTION:	BC/APOLITO, T	05	1	1		PM KEVERN, T	12	2	1
INTERNAL:	DIR, HUM FAC SFY		1	1		I&E	12	2	1
	MOORE, V.	22	1	1		NRC PDR	02	1	1
	OELD	14	1	1		OR ASSESS BR	19	1	1
	REG FILE	01	1	1					
EXTERNAL:	ACRS	20	16	16		LPDR	03	1	1
	NSIC	04	1	1					

JUL 15 1990

TOTAL NUMBER OF COPIES REQUIRED: LTR 39 ENCL 2

App 2
 60

Iowa Electric Light and Power Company

July 7, 1980
LDR-80-181

LARRY D. ROOT
ASSISTANT VICE PRESIDENT
NUCLEAR GENERATION

Mr. Harold R. Denton, Direction
Office of Nuclear Reactor Regulation
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

Dear Mr. Denton:

Transmitted herewith in accordance with the requirements of 10CFR50.59 and 50.90 is an application to reinstate Amendment No. 60 to Appendix A (Technical Specification) to Operating License DPR-49 for the Duane Arnold Energy Center. The proposed application is for reactor startup and operation for greater than 24 hours with one recirculation loop out of service. Justification for this application is the same as that provided with the application for Amendment No. 60. The supporting data from the Amendment No. 60 safety evaluation is still valid and applies equally to this application which is intended for an identical situation. This application for reinstatement is for a time period which will end on July 14, 1980. This application is intended to minimize the shutdown period which will be required to replace a recirculation pump mechanical seal.

It has been determined that this is a Category III amendment and a payment of \$4,000.00 is herewith enclosed.

Three signed and 37 additional copies of this application are transmitted herewith. This application consisting of the foregoing letter is true and accurate to the best of my knowledge and belief.

IOWA ELECTRIC LIGHT AND POWER COMPANY

Larry D. Root

Larry D. Root
Assistant Vice President
Nuclear Generation

A001
S
1/6
w/check:
\$4000.00

LDR/RFS/mz

cc: R. Salmon
D. Arnold
L. Liu
S. Tuthill
K. Meyer
D. Mineck
J. Van Sickle
T. Kevern (NRC)
File: A-117

Subscribed To And Sworn To Before Me
On This 7th day of July,
19 80.

Marjorie E. McDonald
Notary Public In and For The
State of Iowa