.ê	A	03/07/1	
⊫ REGÚ DISTRIBUTI	LATORY INFORMATION DISTRI ON FOR INCOMING MATERIAL	BUTION SYSTEM (RIDS) 50-	-331
REC: CASE E G	ORG: LIU L IA ELEC LIG	DC HT & PWR D4	OCDATE: 03/01/78 ATE RCVD: 03/06/78
DOCTYPE: LETTER SUBJECT: LICENSE NO DPR-49 CONCERNING REVISI EVENTS.	NOTARIZED: YES APPL FOR AMEND: TECH SPE ONS TO CYCLE 3 SAFETY ANA	CS PROPOSED CHANGE LYSIS FOR RECATERGORIZ	COPIES RECEIVED LTR 3 ENCL 40 ED
PLANT NAME: DUANE (	ARNOLD	REVIEWER I DISTRIBUTO	NITIAL: XJM DR INITIAL:
***********	DISTRIBUTION OF THIS MAT	ERIAL IS AS FOLLOWS **	*****
GENERAL DISTRI	BUTION FOR AFTER ISSUANCE CODE A001)	OF OPERATING LICENSE.	
FOR ACTION:	BR CHIEFTERRANN ENCL		
INTERNAL:	REG_FILE**W/ENCL I & E**W/2 ENCL HANAUER**W/ENCL EISENHUT**W/ENCL BAER**W/ENCL GRIMES**W/ENCL J. MCGOUGH**W/ENCL	NRC PDR**W/EN OELD**LTR ONL CHECK**W/ENCL SHAO**W/ENCL BUTLER**W/ENC J COLLINS**W/	ICL Y - ENCL
EXTERNAL:	LPDR'S CEDAR RAPIDS, IA**W/N TIC**W/ENCL	ENCL	

DISTRIBUTION: SIZE: 2P+22P

LTR 40 ENCL 39

NSIC\*\*W/ENCL

. .

ACRS CAT B\*\*W/16 ENCL

CONTROL NBR:

780660029

\*\*\*\*\*\*\*\*\*\*\*

THE END

\*

# REGULATORY DOCKET FILE COPY

# IOWA ELECTRIC LIGHT AND POWER COMPANY

### General Office Cedar Rapids. Iowa

March 1, 1978 IE-78-315 26-331

LEE LIU VICE PRESIDENT - ENGINEERING

> Mr. Edson Case, Acting Director Office of Nuclear Reactor Regulation U.S. Nuclear Regulatory Commission Washington, D.C. 20555

Dear Mr. Case:

ì

Transmitted herewith in accordance with the requirements of 10CFR50.59 and 50.90 is an application for amendment of DPR-49 and the Technical Specifications (Appendix A to License) for the Duane Arnold Energy Center.

This application consists of:

- Proposed Technical Specifications (RTS-107) reflecting the results of the safety and transient analyses discussed in (2) below.
- (2) Duane Arnold Energy Center Unit 1 Cycle 3 Safety Analysis for Recategorized Events.

The enclosed analyses sets forth the bases to recategorize Turbine Trip without Bypass from an incident of moderate frequency to an infrequent incident. Although the anlayses have been conducted for DAEC Cycle 3 which will end shortly, it is applicable to subsequent cycles and we therefore request your review of this submittal. As stated in our December 13, 1977 letter we understand that the review of this item depends on NRC approval of new models based on the Peach Bottom tests.

This application has been reviewed and approved by the DAEC Operations Committee and the DAEC Safety Committee. This application does not involve a significant hazards consideration.

780660**02.9** 

Mr. Edson Case

#### March 1, 1978

Three signed and notarized originals and 37 additional copies of this application are transmitted herewith. This application, consisting of the foregoing letter and enclosures hereto, is true and accurate to the best of my knowledge and belief.

-2-

Iowa Electric Light and Power Company

By Lee Liŭ

Vice President-Engineering

LL/OCS/D cc:Mr. D. Arnold Mr. K. Meyer Mr. R. Lowenstein Mr. J. Keppler Mr. R. Clark Mr. L. Root File A-117

Subscribed and Sworn to before me on this  $\underline{| st}$  day of March, 1978.

Public in and for the State Notary

Iowa.

1. 1. 1. Marinta I. Kalwaald stra entra Salara Kapirea Laphanber 10, 1879

NEDO-24062 Class I October 1977

#### DUANE ARNOLD ENERGY CENTER

UNIT 1

CYCLE 3 SAFETY ANALYSIS

FOR RECATEGORIZED EVENTS

BOILING WATER REACTOR PROJECTS DEPARTMENT 

GENERAL ELECTRIC COMPANY
SAN JOSE, CALIFORNIA 95125



### DISCLAIMER OF RESPONSIBILITY

This document was prepared by or for the General Electric Company. Neither the General Electric Company nor any of the contributors to this document:

A. Makes any warranty or representation, express or implied, with respect to the accuracy, completeness, or usefulness of the information contained in this document, or that the use of any information disclosed in this document may not infringe privately owned rights; or

B. Assumes any responsibility for liability or damage of any kind which may result from the use of any information disclosed in this document.

PROPOSED CHANGE RTS-107 TO DAEC TECHNICAL SPECIFICATIONS

#### I. Affected Technical Specifications

Appendix A of the Technical Specifications for the DAEC (DPR-49) provides as follows:

Table 3.12-2 provides MCPR limits applicable for Cycle 3 operation.

#### II. Proposed Changes in Technical Specifications

The licensees of DPR-49 propose the following changes in the Technical Specifications set forth in I above:

Change the MCPR limits for  $7 \ge 7$  and  $8 \ge 8$  fuel as shown on the attached sheet.

#### III. Justification for Proposed Change

This change is proposed in order to incorporate the results of analyses obtained from the turbine trip combined with bypass system failure study. The results of this study are contained in the attached document entitled, "Duane Arnold Energy Center Unit 1 Cycle 3 Safety Analysis for Recategorized Events," NEDO-24062, Class 1, October 1977.

#### IV. Review Procedure

This proposed change has been reviewed by the DAEC Operations Committee and Safety Committee which have found that this.proposed change does not involve a significant hazards consideration.

### TABLE 3.12-2

### MCPR LIMITS

Fuel Type	MCPR Limits
7 x 7	1.21
8 x 8	1.22

### TABLE OF CONTENTS

1.	INTRODUCTION	<u>Page</u> 1-1
2.	CATEGORY A - MODERATE FREQUENCY EVENTS	2-1
	2.1 Turbine Trip with Operable Bypass	2-1
	2.2 Feedwater Controller Failure	2-2
	2.3 Loss of 100°F Feedwater Heating	2-3
	2.4 Local Rod Withdrawal Error	2-3
3.	CATEGORY B - INFREQUENT INCIDENTS	•
	3.1 Turbine Trip with Failure of the Bypass Valve	3-1

4-1

4. REFERENCES

### LIST OF ILLUSTRATIONS

Figure	Title	Page
2-1	Turbine Trip with Bypass (DAEC, EOC3, 104% Power, 100% Flow, Half Drill, Trip Scram)	2-6
2-2	Feedwater Controller Failure (DAEC, EOC3, 104% Power, 100% Flow, Half Drill)	2-7
2-3	Loss of 100% Feedwater Heater, Manual Flow Control, FSCRAM (DAEC, EOC3, 104% Power, 100% Flow, Half Drill)	2-8
3-1	Turbine Trip without Bypass - Trip Scram (DAEC, EOC3, 104% Power, 100% Flow, Half Drill)	3-3

v/vi

### LIST OF TABLES

<u>Table</u>	Title	Page
1-1	Category A - Incidents of Moderate Frequency	1-3
1-2	Category B - Infrequent Incidents	1-4
2-1	GETAB Transient Analysis Initial Condition Parameters	2-4
2-2	Category A - Event Results	· 2 <b>-</b> 5
3-1	Category B - Event Results	3-2

#### 1. INTRODUCTION

On 28 May 1976, the General Electric Company transmitted a letter<sup>1</sup> to the Nuclear Regulatory Commission (NRC) which provided the results of a study to determine the frequency of occurrence of presently analyzed abnormal operating transients based on actual operating data. The impetus for this study was the issuance of Reference 2 by the NRC.

Reference 2 establishes three categories of events based upon frequency of occurrence and qualifies them by acceptable event consequences. These categories are as follows:

Category A - Incidents of moderate frequency (once per year to once in 20 years),

Category B - Infrequent incidents (once in 20 years to once in 100 years),

Category C - Limiting faults (not expected to occur but postulated because occurrence of these events could result in the release of significant amounts of radioactive material).

These three categories were to replace the present "Transient" and "Design Basis Accident" categories.

Plant safety limits for Category A events caused by a single operator error or equipment malfunction are derived from the approved GETAB criteria<sup>3</sup> in which 99.9% of the rods in the core are expected to avoid boiling transition during the event. In addition, a commercial limit is established for plants with unpiped spring safety valves such that actuation of these safety valves is avoided. For Category B events, the GETAB Fuel Cladding Safety (Transient) Limit established for Category A events may be exceeded on a limited number of fuel rods and unpiped safety valves are allowed to open. The philosophy used to evaluate the Category C faults has not changed from that used to analyze the previously categorized "Design Basis Accidents." The results of the study transmitted in the Reference 1 letter indicated that several abnormal operating events were considered to be infrequent incidents.

A list of events considered to be moderate frequency, Category A incidents is given in Table 1-1; events considered to be infrequent incidents are listed in Table 1-2. Of the events in Category B, Turbine Trip without Bypass has been analyzed in detail to determine the consequence of occurrence upon fuel integrity if this event was not used to establish the Category A operating MCPR limit. The results of this analysis, documented in Reference 4, showed that no fuel failures were calculated to occur because of these events. Until similar documentation is provided for the other Category B events, these events will be limited by and will be used to determine the Category A operating limit.

This report documents the results of the safety analysis performed for the Duane Arnold Energy Center Nuclear Plant (DAEC) using the above recategorized basis. The analysis was performed for the half drilled core configuration documented in Reference 5 at the end-of-cycle 3 (EOC3) conditions. Recategorization does not affect the statistical Fuel Cladding Safety Limit or the results of the accident (Category C) analyses given in Reference 6. Therefore, only the results of the Category A and Category B analyses are given in this document.

### Table 1-1 CATEGORY A INCIDENTS OF MODERATE FREQUENCY

Transient

Frequency (Events/Plant Yr)

Generator Load Rejection	0.75
Turbine Trip	1.33
MSIV Closure	1.0
Pressure Regulator Failure-Closed	N/A
Inadvertent Start of HPCI Pump	0.20
Loss of Feedwater Flow	0.75
Pressure Regulator Failure-Open	0.67
One Recirculation Pump Trip	1.33
Two Recirculation Pump Trip	0.25
Recirculation Flow Controller Failure-Decreasing	0.25
Recirculation Flow Controller Failure-Increasing	0,25
Abnormal Start of Idle Recirculation Pump	0.10
Loss of RHR Shutdown Cooling	N/A •
Feedwater Controller Failure (Maximum Demand)	0.5
Inadvertent Opening of Safety/Relief Valve	0.1
Loss of Condenser Vacuum	0.67
Loss of Auxiliary Power	0,25

### Table 1-2 CATEGORY B INFREQUENT INCIDENTS

#### Frequency

(Events/Plant Yr)

0.0036

0.0064

#### Incident

Generator Load Rejection with Bypass Failure

Turbine Trip with Bypass Failure

Loss of Feedwater Heating

Rod Withdrawal Error at Power

Rod Withdrawal Error during Startup

\*The data base required to establish the frequency of these events is not yet available. For the present these events are conservatively considered to be members of Category A.

1-4

#### 2. CATEGORY A - MODERATE FREQUENCY EVENTS

The results of the most limiting moderate frequency pressure and power increase transients were evaluated to determine the largest decrease in MCPR. In addition, the results of the infrequent loss of  $100^{\circ}$  feedwater heating and local rod withdrawal error events were conservatively evaluated as moderate frequency events as described above.

The initial conditions used in the DAEC GETAB analysis are given in Table 2-1. Input parameters to the transient analyses are the same as those documented in Table 6-1 of Reference 5. The digital computer model described in Reference 6 was used in these analyses. Results of the analyses are summarized in Table 2-2. A review of these results shows that the limiting Category A events for DAEC at the end of Cycle 3 are the feedwater controller failure event with a  $\Delta$ MCPR of 0.21 for the reload 8x8 fuel, and feedwater controller failure and rod withdrawal error, each with a  $\Delta$ MCPR of 0.15, for the remaining 7x7 initial core fuel. The limiting event for exposures up to 1000 MWd/t before the end of Cycle 3 is the rod withdrawal error with a AMCPR of 0,16 for the 8x8 fuel and 0.15 for the 7x7 fuel, as shown in Reference 5. The turbine trip with bypass and feedwater controller failure event are less severe than the turbine trip without bypass event; therefore, the mid-cycle AMCPR reported in Reference 5 is conservatively applied to the less severe events in this report. Adding the results of these limiting events to the Fuel Cladding Safety Limit of 1.06 results in new DAEC Cycle 3 MCPR operating limits of 1.22 for 8x8 fuel and 1.21 for 7x7 fuel for exposures up to 1000 MWd/t before the end of Cycle 3, and 1.27 for 8x8 fuel and 1.21 for 7x7 fuel for exposures from 1000 MWd/t before the end of Cycle 3 to the end of Cycle 3. Details of the event descriptions and results are given below.

#### 2.1 TURBINE TRIP WITH OPERABLE BYPASS

A variety of turbine or nuclear system malfunctions will initiate a turbine trip. Some examples are: moisture separator and heater drain tank high levels, large vibration, loss of control fluid pressure, loss of condenser vacuum and reactor high water level. The following sequence of events occurs for a turbine trip:

- a. The turbine stop valves close over a period of approximately 0.1 second.
- A reactor scram is initiated from position switches on the turbine stop valves at 10% closure.
- c. The turbine bypass valves are opened by the turbine control system. Delay after start of stop valve closure is 0.1 second.
- d. The pressure continues to rise until the pressure relief set points are reached, some or all of the safety/relief valves briefly discharge steam to the suppression pool.

This event would produce a transient as shown in Figure 2-1. The initial reactor power is at a level corresponding to 105% of NBR steam flow, the neutron flux peaks at 198.7% rated, the average surface heat flux peaks at 105.9% rated.

The peak streamline pressure is limited to 1142 psig as a result of the highpressure actuation of the six safety/relief valves, which provides a 98-psi margin to the 1240-psig set point of the first spring safety valve.

#### 2.2 FEEDWATER CONTROLLER FAILURE

An event that can directly cause excess coolant inventory is one in which feedwater flow is increased. The most severe applicable event is a feedwater controller failure in the maximum demand direction. The transient was initiated from a level corresponding to 105% of NBR steam flow. The feedwater controller was assumed to fail such as to demand maximum feedwater valve opening resulting in a maximum runout flow of 135% of NBR rated feedwater flow at a system pressure of 1060 psig. With excess feedwater flow, the water level rises to the high level trip setpoint, at which time the main turbine and feedwater pumps are tripped and a reactor scram is initiated. Figure 2-2 shows the results of this transient. 2.3 LOSS OF 100°F FEEDWATER HEATING

The transient analysis documented in Reference 5 is not affected by recategorization and is therefore still valid (Figure 2-3). The resultant MCPR is given in Table 2-2.

2.4 LOCAL ROD WITHDRAWAL ERROR

The analysis documented in Reference 5 is not affected by recategorization.

NEDO-24062

# Table 2-1

### GETAB TRANSIENT ANALYSIS

### INITIAL CONDITION PARAMETERS

EOC3	Eva	lua	tion	
	the second second second	_		

<u>7x7</u>

Peaking Factors (local, radial and axial)	(1.24, 1.282, 1.40)(	1.22, 1.364, 1.40)
R-Factor	1,100	1.098
Bundle Power, MWt	5,447	5.791
Nonfuel Power Fraction	0.04	0.04
Core Flow, Mlb/hr	49.0	49.0
Bundle Flow, 10 <sup>3</sup> lb/hr	128.1	114.3
Reactor Pressure, psia	1035.0	1035.0
Inlet Enthalpy, Btu/lb	526.3	526.3
Initial MCPR	1.22	1.28

# GETAB TRANSIENT ANALYSIS INITIAL CONDITION PARAMETERS

1 GWd/t Before EOC3 Evaluation	<u>7x7</u>	<u>8x8</u>
Peaking Factors (local, radial		
and axial)	(1.24, 1.286, 1.40)	(1.22, 1.423, 1.40)
R-Factor	1.100	1,098
Bundle Power, MWt	5.464	6.042
Nonfuel Power Fraction	0.04	0,04
Core Flow, Mlb/hr	49.0	49.0
Bundle Flow, 10 <sup>3</sup> lb/hr	128.0	112.7
Reactor Pressure, psia	1035.0	1035.0
Inlet Enthalpy, Btu/lb	526.3	526.3
Initial MCPR 🔨	1.21	1.22

2-4

### Table 2-2 CATEGORY A EVENT RESULTS

έ.

NEDO-24062

EVENT	INITIAL POWER	$\hat{\theta}$ $\hat{Q}/A$ $\hat{P}_{LINE}$		CPR for Exposures Up to 1000 MWd/t Before EOC3		CPR for Exposures 1000 MWd/t Before EOC3 to EOC3		
	(%) NBR	(%) NBR	(%) NBR	(PSIG)	7×7	8x8	7x7	8x8
Turbine Trip with Bypass	104	198.7	105.9	1142		•	0.10	0.14
FW Controller Failure	104	225.0	113.0	1146	0.05	0.06	0.15	0.21
Loss of 100°F Feedwater Heating	104	121.0	119.0	1023	0.14	0.15	0.14	0.15
Rod Withdrawal Error (RBM Set to 105%)		<b></b>	<b></b> ,	, <del></del>	0.15	0.16	0.15	0.16

2-5



Figure 2-1. Turbine Trip with Bypass (DAEC, EDC3, 104% Power, 100% Flow, Half Drill, Trip Scram)

.

NED0-24062

![](_page_20_Figure_0.jpeg)

Figure 2-2 Feedwater Controller Failure (DAEC, EOC3, 104% Power, 100% Flow, Half Drill)

NED0-24062

![](_page_21_Figure_0.jpeg)

![](_page_21_Figure_1.jpeg)

2-8

### 3. CATEGORY B - INFREQUENT INCIDENTS

The only event analyzed herein as part of this category is the turbine trip combined with bypass system failure. This section is included to cover the transient response of infrequent incidents when MCPR limits have been applied to Category A (moderate frequency) incidents. The initial conditions and input parameters used in the analyses are given in Section 2. The most severe Category B event is Turbine Trip without Bypass. The results of the analyses are given in Table 3-1. Subtracting the  $\Delta$ CPR for this event from the Category A MCPR operating limit yields a MCPR of 0.98 (1.27 - 0.29) for 8x8 fuel and 1.00 (1.21 - 0.21) for 7x7 fuel. However, as shown in Reference 4, continued fuel integrity is assured for this event. Details of the analysis are given below.

### 3.1 TURBINE TRIP WITH FAILURE OF THE BYPASS VALVES

The primary characteristic of the turbine trip without bypass is a pressure increase due to the obstruction of steam flow by the turbine stop valves. The pressure increase causes a significant void reduction which yields a pronounced positive void reactivity effect. Core net reactivity is sharply positive and causes a rapid increase in neutron flux until the net reactivity is forced negative by the scram initiated from the position switches on the turbine stop valves.

This unlikely event would produce a transient as shown in Figure 3-1. The initial reactor power is at a level corresponding to 105% of rated steam flow, the neutron flux peaks at 351% rated, the average surface heat flux peaks at 115% of initial. This transient is slightly more severe than that which results from full load rejection with bypass failure.

3-1

# Table 3-1 CATEGORY B EVENT RESULTS

						Rods
	•					Subject
	INITIAL				•	to Boiling
EVENT	POWER	Ø	QA	<b>∆CP</b> R ·	ACPR	Transition
	(%)	( <i>¶</i> )	(%)	7x7	8x8	(%)
		NBR	Initial	•		
Nurbine Trip			•			
						0.00

ţ

w/o Bypass	104.1	351	1 15	0.21	0,29	0.88
------------	-------	-----	------	------	------	------

![](_page_24_Figure_0.jpeg)

Figure 3-1. Turbine Trip without Bypass - Trip Scram (DAEC, EOC3, 104% Power, 100% Flow, Half Drill)

3-3/3-4

1

NEDO-24062

### 4. REFERENCES

- Letter, E. A. Hughes to R. C. DeYoung, "Transient Recategorization per Regulatory Guide 1.70, Revision 2," 28 May 1976.
- Nuclear Regulatory Commission, Regulatory Guide 1.70, Revision 2, "Standard Format and Content of Safety Analysis Reports for Nuclear Power Plants," September 1975.
- 3. "General Electric Thermal Analysis (GETAB): Data, Correlation, and Design Application," January 1977, (NEDO-10958-A).
- 4. Letter, E. A. Hughes to R. C. DeYoung, "Turbine Trip without Bypass Analyzed as an Infrequent Incident," 5 October 1976.
- 5. "General Electric Boiling Water Reactor, Reload Number 2 Licensing Submittal, Supplement 1, Partially Drilled Core, Duane Arnold Energy Center," June 1977, (NEDO-21082-02-1).

4-1/4-2

 R. B. Linford, "Analytical Methods of Plant Transient Evaluations for the General Electric Boiling Water Reactor," February 1973, (NEDO-10802).