REGULATORY FORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR:	8610280502 DDC. DATE: 86/10/13 NOTARIZED: YES	DOCKET #
FACIL: 50-331	Duane Arnold Energy Center, Iowa Electric Light & Pou	05000331
AUTH. NAME	AUTHOR AFFILIATION	
MCGAUGHY, R. W.	Iowa Electric Light & Power Co.	
RECIP. NAME	RECIPIENT AFFILIATION	
DENTON, H.	Office of Nuclear Reactor Regulation, Director (p	ost 851125

SUBJECT: Application for amend to License DPR-49, revising Tech Specs. Changes bring program into compliance w/ASME Boiler & Pressure Vessel Code Section XI.Fee paid.

NOTES:

22 1 2

	RECIPIENT COP		COPIE	IES RECIPIENT		COPIES		IES	
	ID CODE/NA	AME	LTTR	ENCL	II) CODE/NA	ME	LTTR	ENCL
	BWR ADTS		1	1	BWR	EB		1	1
	BWR PD2 LA		1	0	BWR	PD2 PD	01	5	5
	GILBERT, R		1	1					
INTERNAL:	ADM/LFMB		1	0	AEOI)/PTB		1	1
	ELD/HDS2		1	0	NRR/	DSRO/EIB		1	1
	NRR/TAMB		1	1	REG	FILE	04	1	1
	RGNB		1	1					
EXTERNAL:	LPDR	03	1	1	NRC	PDR	02	1	1
	NSIC	05	1	1					

w/check \$ 150 \$ 098837

TOTAL NUMBER OF COPIES REQUIRED: LTTR 19 ENCL 16

DISTRIBUTION CODE: A047D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 4+12TITLE: OR Submittal: Inservice Inspection/Testing

Iowa Electric Light and Power Company

October 13, 1986 NG-85-4698

Mr. Harold Denton, Director Office of Nuclear Reactor Regulation U.S. Nuclear Regulatory Commission Washington, DC 20555

> Subject: Duane Arnold Energy Center Docket No: 50-331 Op. License No: DPR-49 ASME Section XI Technical Specification Changes (RTS-195) File: A-286

Dear Mr. Denton:

In accordance with the Code of Federal Regulations, Title 10, Parts 50.59 and 50.90, Iowa Electric Light and Power Company hereby requests revision of the Technical Specifications (TS) for the Duane Arnold Energy Center (DAEC) to conform to the Inservice Testing (IST) Program for Pumps and Valves.

Pursuant to 10 CFR 50.55a(g)(4)(ii), (5)(i) and (5)(ii), we are required to revise our TS so that the DAEC IST Program complies with Section XI of the edition and addendum of the ASME Boiler and Pressure Vessel Code incorporated by reference into NRC regulations 12 months prior to the start of the 120-month inspection interval.

The proposed change requests are consistent with Paragraphs IWP-3400, "Frequency of Inservice Tests," and IWV-3400, "Inservice Tests, Category A and B Valves," which establish test frequencies embodied in the 1980 Edition (Winter 1981 Addenda) of the Code. Changing the frequency of the pump and valve testing program is permissible as noted in the NRC Standard Review Plan 3.9.6, Sections II.1 and II.2, "Inservice Testing of Pumps and Valves." In addition, the proposed changes will provide consistency throughout the TS for the frequency of pump and valve testing.

This proposed change request, RTS-195, has been reviewed by both the DAEC Operations Committee and Safety Committee.

 B6102B0502 PDR ADOCK	861013 05000331
	PDR

General Office • P.O. Box 351 • Cedar Rapids, Iowa 52406 • 319/398-4411

Mr. Harold Denton October 13, 1986 NG-85-4698 Page Two

In accordance with the requirements of 10 CFR Part 170, we are enclosing the required application fee of \$150.00.

Pursuant to the requirements of 10 CFR 50.91, a copy of this submittal and analysis of no significant hazards considerations is being forwarded to our appointed state official.

This application, which consists of three signed originals and 37 copies with their enclosures, is true and accurate to the best of my knowledge and belief.

IOWA ELECTRIC LIGHT AND POWER COMPANY

Ankard W modowig ΒY Richard W. McGaughy Manager, Nuclear Division

Subscribed and sworn to Before Me on this <u>22nd</u> day of <u>Octobuk</u> 1986.



Notary Public in and for the State of Iowa

RWM/MSG/dmb*

Attachments:	1)	Proposed RTS-195
	2)	10 CFR 50.92 Evaluation
	3)	Check No. 098837

cc: M. Grim L. Liu L. Root M. Thadani NRC Resident Office T. Houvenagle (ICC)

PROPOSED CHANGE RTS-195 TO THE DUANE ARNOLD ENERGY CENTER TECHNICAL SPECIFICATIONS

The holders of license DPR-49 for the Duane Arnold Energy Center propose to amend Appendix A (Technical Specifications) to said license by deleting current pages and replacing them with the attached, new pages. A List of Affected Pages is given below.

List of Affected Pages

3.4-1	3.5-6	Bases
3.5-1	3.5-7	3.4-7
3.5-2	3.5-12	3.5-16
3.5-3	3.7-19a	3.5-25
	3.8-6	3.5-27
		3.7-49a
		3.8-14

Page Summary of Changes

....

- 3.4-1 Revised testing of Standby Liquid Control System pumps from "once per month" to "once per three months."
- 3.5-1 Revised testing of the core spray system pumps and associated valves from "once per month" to "once per three months."
- 3.5-2 Revised testing of LPCI subsystem pumps from "once per month" to "once per three months." Corrected "innoperable" to "inoperable."
- 3.5-3 Revised testing of LPCI subsystem valves from "once per month" to "once per three months."
- 3.5-6 Revised testing of the HPCI subsystem pumps and associated valves from "once per month" to "once per three months."
- 3.5-7 Revised testing of the RCIC subsystem pump and associated valve from "once per month" to "once per three months."
- 3.5-12 Revised flow rate test of River Water Supply System pumps from "monthly" to "once per three months."
- 3.7-19a Revised testing of Main Steam Isolation Valve Leakage Control System valve from "once per month" to "once per 3 months."
- 3.8-6 Revised flow rate test of Emergency Service Water System pumps from "every month" to "once per 3 months."

Bases Summary of Changes

- 3.4-7 Revised testing of Standby Liquid Control pumps from "monthly test" to "test conducted once every three months."
- 3.5-16 Revised testing of core spray subsystem and LPCI subsystem from "1 month" to "once every three months."

3.5-25 Corrected the typographical error "continuous" to "continuous."

...

- 3.5-27 Revised core and containment cooling system surveillance frequencies from "each month" to "every three months."
- 3.7-49a Revised bases to note that the test interval for the MSIV-LCS motor-operated valve is based on Section XI of the ASME Code.
- 3.8-14 Revised bases to note that surveillance frequencies for the Emergency Service Water Pumps are based on Section XI of the ASME Code.