

# REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 7901150134 DOC. DATE: 79/01/08 NOTARIZED: NO  
 FACIL: 50-331 DUANE ARNOLD, IOWA ELECTRIC & POWER CO.  
 AUTH. NAME AUTHOR AFFILIATION  
 LIU, L. IA ELEC LIGHT & PWR  
 RECIP. NAME RECIPIENT AFFILIATION  
 DENTON, H. R. OFFICE OF NUCLEAR REACTOR REGULATION

DOCKET #  
 05000331

SUBJECT: Documents 781218 conversation re stresses at welds 2 & 4 of replacement recirculation safe ends. Forwards breakdown of sustained stress values in the calculation of welds 2 & 4 stress index values.

DISTRIBUTION CODE: A001S COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 3  
 TITLE: GENERAL DISTRIBUTION FOR AFTER ISSUANCE OF OPERATING LIC

## NOTES:

	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL
ACTION:	05 BC <u>ORB #3</u>	7 7		
INTERNAL:	01 REG FILE	1 1	02 NRC PDR	1 1
	12 I&E	2 2	14 HANAUER	1 1
	15 CORE PERF BR	1 1	16 AD SYS/PROJ	1 1
	17 ENGR BR	1 1	18 REAC SFTY BR	1 1
	19 PLANT SYS BR	1 1	20 EEB	1 1
	21 EFLT TRT SYS	1 1	22 BRINKMAN	1 1
EXTERNAL:	03 LPDR	1 1	04 NSIC	1 1
	23 ACRS	16 16		

JAN 16 1979

MA 4  
 60

TOTAL NUMBER OF COPIES REQUIRED: LTTR 38 ENCL 38

# IOWA ELECTRIC LIGHT AND POWER COMPANY

*General Office*  
CEDAR RAPIDS, IOWA

January 8, 1979  
IE-79-32

LEE LIU  
SENIOR VICE PRESIDENT - ENGINEERING

Mr. Harold Denton  
Office of Nuclear Reactor Regulation  
U.S. Nuclear Regulatory Commission  
Washington, D.C. 20555

Dear Mr. Denton:

The purpose of this letter is to document a phone conversation of December 18, 1978 between members of Iowa Electric, General Electric and the Nuclear Regulatory Commission staff.

The discussion centered mainly around the stresses at welds #2 and #4 (nozzle to safe end and safe end to pipe welds) of replacement recirculation inlet safe ends.

1. It was verified that the safe end stress reports included the thermal differential expansion stresses caused by the dissimilar materials. This stress was calculated by the finite element computer program. The zero stress temperature input into the program was 70 °F.
2. At weld #4, the finite element program reports compressive stresses in both the longitudinal and hoop directions on the stainless steel side of the weld and tensile stresses on the alloy 600 side. These results were also confirmed by a shell type computer model.
3. The highest stress index value at weld #4 occurred on the stainless steel side. The secondary portion of the stress index value was reported as zero since thermal stresses were compressive. The stainless steel side of the weld joint had the greater stress index value because the primary stress contribution to the stress index value was larger for stainless steel than for alloy 600.

7901150134


P  
Aoor  
15/11

Mr. Harold Denton  
IE-79-32  
Page 2

4. The stress index value at weld #4 was calculated using a finite element stress analysis since the safe ends are considered as part of the reactor vessel. This is consistent with the analysis methods used to calculate stress index values on previous safe ends evaluations. For weld #5 (pipe to pipe), the stress index value was calculated using the ASME Section III NB3600 piping equations and factors which is consistent with the stress index calculations on previous piping weld joints.

For further clarification, we are also enclosing a breakdown of the sustained stress values in the calculation of the stress index values for welds #2 and #4.

Very truly yours,



Lee Liu  
Senior Vice President-Engineering

LL/KAM/sb

cc: K. Meyer  
D. Arnold  
R. Lowenstein  
R. Clark (NRC)  
H. Rehrauer  
B-3lc

# STRESS INDEX SUMMARY

## WELD #2 (ALLOY 600 SIDE)

### PRIMARY STRESSES

LOAD	STRESS COMPONENTS			
	$\sigma_z$	$\sigma_\theta$	$\sigma_r$	$\tau_{z\theta}$
PRESSURE	0.68	5.66	-1.05	0
DEAD WEIGHT	1.29	0	0	0.20
TOTAL	1.97	5.66	-1.05	0.20

PRINCIPLE STRESSES = 1.96, 5.67, -1.05

### SECONDARY STRESSES

LOAD	$\sigma_z$	$\sigma_\theta$	$\sigma_r$	$\tau_{z\theta}$
THERMAL RFE NOZZLE REACTION	3.37	0	0	1.36
STEADY STATE THERMAL	-13.2	-6.3	-3.5	0.6
TOTAL	-9.83	-6.3	-3.5	1.96

PRINCIPLE STRESSES = -10.7, -5.43, -3.5

PEAK STRESSES = 0 (STRESS CONCENTRATION  
FACTOR = 1.0)

RESIDUAL STRESSES = 40.0

$$S.I. = \frac{P_m + P_B}{S_y} + \frac{Q + F + (RESID)}{S_y + (0.002)E}$$

$$S.I. = \frac{5.67}{28.5} + \frac{0 + 0 + 40}{28.5 + (0.002)(29.5 \times 10^3)} = .66$$

## WELD #4 (STN STL SIDE)

### PRIMARY STRESSES

LOAD	STRESS COMPONENTS			
	$\sigma_z$	$\sigma_\theta$	$\sigma_r$	$\tau_{z\theta}$
PRESSURE	3.06	9.76	-1.37	0
DEAD WEIGHT	2.28	0	0	0.36
TOTAL	5.34	9.76	-1.37	0.36

PRINCIPLE STRESSES = 5.31, 9.79, -1.37

### SECONDARY STRESSES

LOAD	$\sigma_z$	$\sigma_\theta$	$\sigma_r$	$\tau_{z\theta}$
THERMAL RFE NOZZLE REACTION	6.5	0	0	2.65
STEADY STATE THERMAL	-8.8	-11.1	-4.8	-0.6
TOTAL	-2.3	-11.1	-4.8	2.05

PRINCIPLE STRESSES = -1.84, -11.55, -4.8

PEAK STRESSES = 0 (STRESS CONCENTRATION  
FACTOR = 1.0)

RESIDUAL STRESSES = 37.0

$$S.I. = \frac{P_m + P_B}{S_y} + \frac{Q + F + (RESID)}{S_y + (0.002)E}$$

$$S.I. = \frac{9.79}{19.1} + \frac{0 + 0 + 37}{19.1 + (0.002)(25.9 \times 10^3)} = 1.03$$