REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR:		
FACIL:50-331	Duane Arnold Energy Center, Iowa Electric Light & Pow 05000331	,
AUTH NAME	AUTHOR AFFILIATION	
ROOT, L.D.	Iowa: Electric: Light & Power Co.	
RECIP, NAME	RECIPIENT AFFILIATION	
IPPOLITO, T.A.	Operating Reactors Branch 3	

SUBJECT: Responds to NRC 791213 Itr re loss of offsite power events. Review of records indicate facility experienced no partial or complete loss of offsite power since completion of constwhich were not planned or part of surveillance testing.

DISTRIBUTION CODE: A0155 COPIES RECEIVED:LTR _/ ENCL _ SIZE:

NOTEST

	RECIPIENT	COPIES	RECIPIENT	COPIES
	ID CODE/NAME	LITTR ENCL	ID CODE/NAME	LTTR ENCL
ACTION:	05 BC ORB # 3	7	LA ORB#3	1. 1.
INTERNAL	OI REG FILE	1	02 NRC PDR	1 1
	13 186	2 2	15 OELD	-1-1
	16 MPA	1. 1.	17 AUXIL SYS BR	-1 1
	18 ISC SYS BR	1	20 ENGR BR	1 1
	21 REAC SETY BR	1	22 PLANT SYS BR	-1. 1
	23 ADV REAC BR	1 1	24 PWR SYS BR	1
	25 CHIRAMAL M	1. 1 .	26 TONDI,D	· 1 /
	27 MCDONALD, D	1.	30 EEB	1. 1.
	AEOD	1. 1.	HANAUER, S.	1 / 1
	STS GROUP LEADR	1		
EXTERNAL	03 LPDR	1.	04 NSIC	1
	31 ACRS	16 1 4		•

MAR 2 0 1980

Real of the

Iowa Electric Light and Power Company

March 14, 1980 LDR-80-84

LARRY D. ROOT ASSISTANT VICE PRESIDENT NUCLEAR GENERATION

. 5

Mr. Thomas A. Ippolito, Chief Operating Reactors Branch #3 Division of Operating Reactors U.S. Nuclear Regulatory Commission Washington, D.C. 20555

> Subject: Adequacy of Offsite Power Systems File: A-107a

Dear Mr. Ippolito:

This letter is in response to your letter of December 13, 1979 requesting information regarding loss of offsite power events at the Duane Arnold Energy Center. We have reviewed our records and have found that this facility has experienced no partial or complete loss of offsite power since completion of plant construction which were not either planned or part of surveillance testing requirements.

Very truly yours, ry a. C

Larry D. Root Assistant Vice President Nuclear Generation

LDR/JVS/ms

- cc: J. VanSickel
 - D. Arnold
 - S. Tuthill
 - L. Liu
 - K. Meyer
 - D. Mineck

8003190527