

REGULATORY INFORMATION DISTRIBUTION SYSTEM (GRIDS)

ACCESSION NBR: 8204200375 DOC. DATE: 82/04/14 NOTARIZED: NO DOCKET #
 FACIL: 50-331 Duane Arnold Energy Center, Iowa Electric Light & Pow 05000331
 AUTH. NAME: AUTHOR AFFILIATION
 ROOT, L.D.: Iowa Electric Light & Power Co.
 RECIP. NAME: RECIPIENT AFFILIATION
 DENTON, H.R.: Office of Nuclear Reactor Regulation, Director

SUBJECT: Responds to Generic Ltr 82-05, Schedule of NUREG-0737 items status encl.

DISTRIBUTION CODE: A0355 COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 3
 TITLE: SEP Topics

NOTES:

	RECIPIENT ID CODE/NAME		COPIES		RECIPIENT ID CODE/NAME		COPIES	
			LTR	ENCL			LTR	ENCL
	ORB #2 BC	01	7	7				
INTERNAL:	IE	06	1	1	NRR/DE/ADMGE	13	1	1
	NRR/DE/HGEB	10	2	2	NRR/DL/ORAB	11	1	1
	NRR/DL/SEP8	12	3	3	NRR/DSI/AEB		1	1
	NRR/DSI/CSB	07	1	1	<u>REG FILE</u>	04	1	1
	RGN3		1	1				
EXTERNAL:	ACRS	14	10	10	LPDR	03	1	1
	NRC PDR	02	1	1	NTIS	5	1	1

TOTAL NUMBER OF COPIES REQUIRED: LTR 32 ENCL 32

Iowa Electric Light and Power Company

April 14, 1982

LDR-82-0101

LARRY D. ROOT
ASSISTANT VICE PRESIDENT
OF NUCLEAR DIVISION



Mr. Harold Denton, Director
Office of Nuclear Reactor Regulation
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Dear Mr. Denton:

Pursuant to Generic Letter 82-05 of March 17, 1982, from Mr. Darrel Eisenhut, the attachment to this letter provides information requested for the items listed in enclosure 1 to Mr. Eisenhut's letter.

We believe this is responsive to the request. However, should you have any questions, please contact this office.

Very truly yours,

B. W. McLaughlin
for Larry D. Root
Assistant Vice President
Nuclear Generation

LDR/YB/kmh*
Attachment

cc: Y. Balas
D. Arnold
L. Liu
S. Tuthill
K. Eccleston (NRC)
NRC Resident Office

8204200375 820414
PDR ADOCK 05000331
P PDR

*A095
5/11*

* 1882 - A CENTURY OF SERVICE - 1982 *

RESPONSES TO ENCLOSURE 1

I.A.3.1 Simulator Exams

Iowa Electric Light and Power Company has included simulator exams in licensing examinations. The schedules of the exams have been provided in our submittal LDR-81-288 of September 25, 1981.

II.B.2 Plant Shielding

Iowa Electric Light and Power Company has provided a shielding report for NRC review. Vital areas at the DAEC are either accessible or their functions will be moved to alternate locations.

II.B.3 Post-Accident Sampling

A Post Accident Sampling System has been installed at the DAEC, however, the system is not yet operable due to a component malfunction. Every effort is being made to make the system operable. Interim procedures and practices which have been utilized will remain in effect until the system is operable.

II.B.4 Training for Mitigation of Core Damage

Iowa Electric Light and Power Company completed the required training for the item on October 10, 1981.

II.E.4.2 Containment Isolation

- 5) Iowa Electric Light and Power Company's compliance with this item is provided in LDR-80-393 of December 30, 1980.
- 7) The BWR Owners' Group is re-evaluating this item and plans to make a submittal to the NRC at the end of April of 1982.
 - a) Schedule slipped by NRC staff at NRC/BWROG meeting on November 19, 1981.
 - b) The need for the new schedule was based on the clarification and new understanding of the problem.
 - c) No interim measures have been required or planned.

II.F.1 Accident Monitoring

The implementation schedule for this item has been provided in our submittal LDR-81-348 of December 31, 1981 which was approved by the NRC by letter from T.A. Ippolito to D. Arnold dated January 8, 1982. Further clarification and status were given in our letter LDR-82-077 of March of 1982.

Justification, need and interim measures were also provided in our submittal of December 31, 1981.

II.K.3.15 Isolation of HPCI & RCIC

Implementation of this item has been documented in our submittal LDR-80-393 of December 30, 1980.

II.K.3.22 RCIC Suction

Implementation of the item has been completed and documented in our January 1, 1982, submittal transmitted by LDR-81-348, dated December 23, 1981.

II.K.3.24 Space Cooling for HPCI/RCIC

Compliance with this item is demonstrated in our January 1, 1982, submittal transmitted by LDR-81-348, dated December 23, 1981.

II.K.3.27 Common Reference Level

Implementation schedule for this item has been provided in our letter LDR-82-0019, of February 3, 1982.

- a) Original position on this item was not accepted by the NRC. The justification for the new schedule is based on required time for re-evaluation, design and procurement of new scales.
- b) Need for proposed schedule is based on lead time requirements and training time of operators on new scales.
- c) No compensatory measures are needed for this item.