REGULATE Y INFORMATION DISTRIBUTIO BYSTEM (RIDS)

	** *** é* **	
		8211040001 DOC.DATE: 82/10/28 NOTARIZED; NO DOCKET #
÷	FACIL:50-331	Duane Arnold Energy Center, Iowa Electric Light & Pow 05000331
	AUTH NAME	AUTHOR AFFILIATION
٠.	ROOT, L.D.	Iowa Electric Light & Power Co.
	RECIP.NAME	RECIPIENT AFFILIATION
	DENTON, H.R.	Office of Nuclear Reactor Regulation, Director
	SUBJECT: For	ards suppl to util 820622 response to fine protection
	rula	10CFR50,48(c)(5) & Section III.G.3 of App R.confirming
		s discussed at 821014 meeting w/NRC.Addl justification

for exemption requests will be submitted within 2 wks.

DISTRIBUTION CODE: A001S COPIES RECEIVED:LTR _/ ENCL _/ SIZE: 2 TITLE: OR Submittal: General Distribution

NOTES:

f^ar 1

	RECIPIE ID CODE/ NRR ORB2	NAME	ÇOPI LTTR 7	ES ENCL 7	RECIPI ID CODE		COP LTTR	IES Encl
INTERNAL:	ELD/HDS2 NRR/DL DI NRR/DSI/R RGN3		1 1 1	0 1 1 1	NRR/DHFS NRR/DL/OI REG FILE	RAB	1 1 1	1 0 1
EXTERNAL:	ACRS NRC PDR NTIS	09 02	6 1 1	6 1 1	LPDR NSIC	03 05	1 1	1 1

TOTAL NUMBER OF COPIES REQUIRED: LTTR 24 ENCL 22

Iowa Electric Light and Power Company October 28, 1982 NG-82-2233

LARRY D. ROOT ASSISTANT VICE PRESIDENT NUCLEAR GENERATION

Mr. Harold Denton, Director Office of Nuclear Reactor Regulation U.S. Nuclear Regulatory Commission Washington, DC 20555

> Subject: Duane Arnold Energy Center Docket No: 50-331 Op. License No: DPR-49 10CFR50.48 and 10CFR50, Appendix R

Dear Mr. Denton:

On October 14, 1982 Iowa Electric representatives met with NRC and Brookhaven National Laboratory personnel in Ann Arbor, Michigan to discuss questions concerning our June 22, 1982 response to the fire protection rule. At that meeting, we agreed to furnish confirmation of the items discussed by October 28, 1982. This letter transmits the confirmation requested by members of your staff.

Also, we intend to submit additional justification for exemptions to the fire zone boundary requirements of 10CFR50 Appendix R, Section III.G.2. We will submit this within two weeks of the date of this letter. We believe that this information will allow you to complete your review of our requests for exemptions.

Very truly yours

Larry D. Root Assistant Vice President Nuclear Generation

LDR/SLS/dmh*

8211040001 821028 PDR ADDCK 05000331

cc: S. Swails D. Arnold L. Liu S. Tuthill F. Apicella

PDR

F. Apicella NRC Resident Office Ref: Commitment Control No. 82-0366

601

1082 - A CENTURY OF SERVICE - 1982 *

SUPPLEMENT TO IOWA ELECTRIC'S RESPONSE TO FIRE PROTECTION RULE 10CFR50.48(C)(5) AND SECTION III.G.3 OF APPENDIX R TO 10CFR50 DATED JUNE 22, 1982

Item 1.e (page 10)

1. mile - 1. 🖡 💡

Revised procedures will require operators to monitor reactor temperature (through relation to reactor pressure) and verify alignment and operation of safe shutdown systems during reactor shutdown and cooldown from outside the control room. The DAEC will be able to achieve cold shutdown within 72 hours of a fire using these revised procedures.

Item 1.f (page 10)

Adequate manpower will be available to perform the shutdown functions using the procedures of Item 1.e. above prior implementing the Alternate Shutdown System.

Table 5 (page 51)

	System	Component	Schematic		
Add	Core Spray	M0-2132	2B4414		
Add	AC Power	1B-42	2B401		
Add	AC Power	1B-44	2B403		
Delete	Assoc. Circuit	M0-2290B	2B4232		
Add	Assoc. Circuit	and water level	Suppression pool water temperature and water level indication (part of SPOTMOS to be implemented)		