

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8212170308 DOC. DATE: 82/12/14 NOTARIZED: NO DOCKET #
 FACIL: 50-331 Duane Arnold Energy Center, Iowa Electric Light & Pow 05000331
 AUTH. NAME AUTHORITY AFFILIATION
 ROOT, L.D. Iowa Electric Light & Power Co.
 RECIPIENT NAME RECIPIENT AFFILIATION
 DENTON, H.R. Office of Nuclear Reactor Regulation, Director

SUBJECT: Forwards response to 820728 request for addl info re
 NUREG-0737, Item II.D.1, "Relief & Safety Valve Test." No
 functional deficiencies or anomalies of valves experienced
 during Wyle Lab testing.

DISTRIBUTION CODE: A046S COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 11x3
 TITLE: OR Submittal: TMI Action Plan Rgmt NUREG-0737 & NUREG-0660

NOTES:

	RECIPIENT ID CODE/NAME	COPIES		RECIPIENT ID CODE/NAME	COPIES	
		LTR	ENCL		LTR	ENCL
	NRR ORB2 BC 01	7	7			
INTERNAL:	ELD/HDS2	1	0	IE/DEP DIR 33	1	1
	IE/DEP EPDS	1	1	IE/DEP/EPLB	3	3
	NRR/DHFS/DEPY29	1	1	NRR/DL DIR 14	1	1
	NRR/DL/ADL 16	1	1	NRR/DL/ADOR 15	1	1
	NRR/DL/ADSA 17	1	1	NRR/DL/ORAB 18	3	3
	NRR/DSI/ADRP 26	1	1	NRR/DSI/ADRS 27	1	1
	NRR/DSI/AEB	1	1	NRR/DSI/RAB	1	1
	NRR/DST DIR 30	1	1	REG FILE 04	1	1
	RGN3	1	1			
EXTERNAL:	ACRS 34	10	10	FEMA-REP DIV	1	1
	INPO, J. STARNES	1	1	LPDR 03	1	1
	NRC PDR 02	1	1	NSIC 05	1	1
	NTIS	1	1			

TOTAL NUMBER OF COPIES REQUIRED: LTR 44 ENCL 43

Iowa Electric Light and Power Company

December 14, 1982

NG-82-2759

LARRY D. ROOT
ASSISTANT VICE PRESIDENT
NUCLEAR GENERATION

Mr. Harold Denton, Director
Office of Nuclear Reactor Regulation
U.S. Nuclear Regulatory Commission
Washington, DC 20555

Subject: Duane Arnold Energy Center
Docket No.: 50-331
Op. License No: DPR-49
NUREG-0737, Item II.D.1, "Relief and Safety Valve Test,"
Request for Additional Information

Dear Mr. Denton:

This letter transmits our response to your letter of July 28, 1982 requesting additional information on Relief and Safety Valve Testing. We feel this response answers the six questions attached to your letter.

Very truly yours,

Larry D. Root

Larry D. Root
Assistant Vice President

LDR/SS/rh*

Attachments

cc: S. Swails
D. Arnold
L. Liu
S. Tuthill
F. Apicella
NRC Resident Office
Commitment Control 82-0254

8212170308 821214
PDR ADOCK 05000331
P PDR

* 1882 - A CENTURY OF SERVICE - 1982 *

General Office • P.O. Box 351 • Cedar Rapids, Iowa 52406 • 319/398-4411

A046

NRC QUESTION 1

The test program utilized a "rams head" discharge pipe configuration. Duane Arnold utilizes a "tee" quencher configuration at the end of the discharge line. Describe the discharge pipe configuration used at Duane Arnold and compare the anticipated loads on valve internals in the plant configuration to the measured loads in the test program. Discuss the impact of any differences in loads on valve operability.

RESPONSE TO QUESTION 1

The safety/relief valve discharge piping configuration at the Duane Arnold Energy Center (DAEC) utilizes a "tee" quencher at the discharge pipe exit. The average length of the six SRV discharge lines (SRVDL) is 97 feet and the submergence length in the suppression pool is approximately 11.9 feet. The SRV test program utilized a ramshead at the discharge pipe exit, a pipe length of 112 feet and a submergence length of approximately 13 feet. Loads on valve internals during the test program envelope loads on valve internals in the DAEC configuration for the following reasons:

1. No dynamic mechanical load originating at the "tee" quencher is transmitted to the valve in the DAEC configuration because there is at least one anchor point between the valve and the tee quencher.
2. The first length of the segment of piping downstream of the SRV in the test facility was longer than the DAEC piping, thereby resulting in a bounding dynamic mechanical load on the valve in the test program due to the larger moment arm between the SRV and the first elbow. The first segment length in the test facility is 12 feet whereas this length is a maximum of 5.3 feet in the DAEC configuration.
3. Dynamic hydraulic loads (backpressure) are experienced by the valve internals in the DAEC configuration. The backpressure loads may be either (i) transient backpressures occurring during valve actuation, or (ii) steady-state backpressures occurring during steady-state flow following valve actuation.
 - a) The key parameters affecting the transient backpressures are the fluid pressure upstream of the valve, the valve opening time, the fluid inertia in the submerged SRVDL and the SRVDL air volume. Transient backpressures increase with higher upstream pressure, shorter valve opening times, greater line submergence, and smaller SRVDL air volume. The test program submergence length of 13 feet is greater than the DAEC submergence length of 11.9 feet, however, the test program SRVD pipe length of 112 feet is greater than the average DAEC SRVD pipe length of 97 feet. A plant specific sensitivity analysis has been performed to confirm that the decrease in transient backpressure due to the shorter submergence length exceeds the increase in transient backpressure due to the shorter discharge line length. This has been confirmed for the

average discharge line length, however, for the shortest discharge line (88 feet), the analysis shows that transient backpressure exceeds the test configuration by 1.2%. This difference is within the limits of error of the analysis and considered negligible; therefore, the transient backpressures in the DAEC design are enveloped by the test conditions.

The maximum transient backpressure occurs with high pressure steam flow conditions. The transient backpressure for the alternate shutdown cooling mode of operation is always much less than the design for steam flow conditions because of the lower upstream pressure and the longer valve opening time.

- b) The steady-state backpressure in the test program was maximized by utilizing an orifice plate in the SRVDL above the water level and before the ramshead. Use of the orifice resulted in a steady state backpressure greater than that calculated for any of the DAEC SRVDLs.

The differences in the line configuration between the DAEC plant and the test program as discussed above result in the loads on the valve internals for the test facility which bound the actual DAEC loads. An additional consideration in the selection of the ramshead for the test facility was to allow more direct measurement of the thrust load in the final pipe segment. Utilization of a "tee" quencher in the test program would have required quencher supports that would unnecessarily obscure accurate measurement of the pipe thrust loads. For the reasons stated above, differences between the SRVDL configurations in DAEC and the test facility will have no adverse effect on SRV operability at DAEC relative to the test facility.

NRC QUESTION 2

The test configuration utilized no spring hangers as pipe supports. Plant specific configurations do use spring hangers in conjunction with snubber and rigid supports. Describe the safety relief valve pipe supports used at Duane Arnold and compare the anticipated loads on valve internals for the plant pipe supports to the measured loads in the test program. Describe the impact of any differences in loads on valve operability.

RESPONSE TO QUESTION 2

The DAEC SRVDLs are supported by a combination of snubbers, rigid supports, and spring hangers. The locations of snubbers and rigid supports at DAEC are such that the location of such supports in the BWR generic test facility is prototypical, i.e., in each case (DAEC and the test facility) there are supports near each change of direction in the pipe routing. The spring hangers, snubbers, and rigid supports were designed to accommodate combinations of loads resulting from piping dead weight, thermal conditions, seismic and suppression pool hydrodynamic events, and a high pressure steam discharge transient.

The DAEC is currently proposing modifications to the SRVDLs which will install additional supports as part of the Mark I containment loads program. These additional supports will enhance the ability of the SRVDLs to withstand the loads resulting from the events evaluated.

The dynamic load effects on the piping and supports of the test facility due to the water discharge event (the alternate shutdown cooling mode) were found to be significantly lower than corresponding loads resulting from the high pressure steam discharge event. As stated in NEDE-24988-P, this finding is considered generic to all BWRs since the test facility was designed to be prototypical of the features pertinent to this issue.

During the water discharge transient, there will be significantly lower dynamic loads acting on the snubbers and rigid supports than during the steam discharge transient. This will more than offset the small increase in the dead load on these supports due to the weight of the water during the alternate shutdown cooling mode of operation. Therefore, design adequacy of the snubbers and rigid supports is assured as they are designed for the larger steam discharge transient loads.

This question addresses the design adequacy of the spring hangers with respect to the increased dead load due to the weight of the water during the liquid discharge transient. As was discussed with respect to snubbers and rigid supports, the dynamic loads resulting from liquid discharge during the alternate shutdown cooling mode of operation are significantly lower than those from the high pressure steam discharge. Therefore, sufficient margin exists in the DAEC piping system design to adequately offset the increased dead load on the spring hangers in an unpinned condition due to a water filled condition. Furthermore, the effect of the water dead weight load does not affect the ability of SRVs to open to establish the alternate shutdown cooling path since the loads occur in the SRVDL only after valve opening.

NRC QUESTION 3

Report NEDE-24988-P did not identify any valve functional deficiencies or anomalies encountered during the test program. Describe the impact on valve safety function of any valve functional deficiencies or anomalies encountered during the program.

RESPONSE TO QUESTION 3

No functional deficiencies or anomalies of the safety relief or relief valves were experienced during the testing at Wyle Laboratories for compliance with the alternate shutdown cooling mode requirement. All of the valves subjected to test runs, valid and invalid, opened and closed without loss of pressure integrity or damage. Anomalies encountered during the test program were all due to failures of test facility instrumentation, equipment, data acquisition equipment, or deviation from the approved test procedure.

The test specification for each valve required six runs. Under the test procedure, any anomaly caused the test run to be judged invalid. All anomalies were reported in the test report. The Wyle Laboratories test log sheet and notice of anomaly for the Target Rock Model 67F valve tests are included in Enclosure 1. This valve model is used in the DAEC.

Each Wyle test report for the respective valves identifies each test run performed and documents whether or not the test run is valid or invalid and states the reason for considering the run invalid. No anomaly encountered during the required test program affects any valve safety or operability function.

All valid test runs are identified in Table 2.2-1 of NEDE-24988-P. The data presented in Table 4.2-1 for each valve were obtained from the Table 2.2-1 test runs and were based upon the selection criteria of:

- a) Presenting the maximum representative loading information obtained from the steam run data
- b) Presenting the maximum representative water loading information obtained from the 15F subcooled water test data
- c) Presenting the data on the only test run performed for the 50F subcooled water test condition

NRC QUESTION 4

The purpose of the test program was to determine valve performance under conditions anticipated to be encountered in the plants. Describe the events and anticipated conditions at Duane Arnold for which the valves are required to operate and compare these plant conditions to the conditions in the test program. Describe the plant features assumed in the event evaluation used to scope the test program and compare them to plant features at Duane Arnold. For example, describe high level trips to prevent water from entering the steam lines under high pressure operating conditions as assumed in the test event and compare them to trips used at Duane Arnold.

RESPONSE TO NRC QUESTION 4

The purpose of the SRV test program was to demonstrate that the SRV will open and reclose under all expected flow conditions. The expected valve operating conditions were determined through the use of analyses of accidents and anticipated operational occurrences referenced in Regulatory Guide 1.70, Revision 2. Single failures were applied to these analyses so that the dynamic forces on the safety and relief valves would be maximized. Test pressures were the highest predicted by conventional safety analysis procedures. The BWR Owners Group, in their enclosure to the September 17, 1980, letter from D.B. Waters to R.H. Vollmer, identified thirteen events which may result in liquid or two-phase SRV inlet flow that would maximize the dynamic forces on the safety and relief valve. These events were identified by evaluating the initial events described in Regulatory Guide 1.70, Revision 2, with and without the additional conservatism of a

single active component failure or operator error postulated in the event sequence. It was concluded from this evaluation that the alternate shutdown cooling mode is the only expected event which will result in liquid at the valve inlet. Consequently, this was the event simulated in the SRV test program. This conclusion and the test results applicable to DAEC are discussed below. The alternate shutdown cooling mode of operation has been described in the response to NRC Question 5.

The SRV inlet fluid conditions tested in the BWR Owners Group SRV test program, as documented in NEDE-24988-P are 15 to 50 degrees subcooled liquid at 20 psig to 250 psig. These fluid conditions envelope the conditions expected to occur at DAEC in the alternate cooling mode of operation.

The BWR Owners Group identified thirteen events by evaluating the initiating events described in Regulatory Guide 1.70, Revision 2, with the additional conservatism of a single active component failure or operator error postulated in the events sequence. These events and the plant-specific features that mitigate these events are summarized in Table 1. Of these thirteen events, only ten are applicable to the DAEC plant because of its design and specific plant configuration. Three events, namely 5, 6, and 10 are not applicable to the DAEC plant for the reasons listed below:

- a) Events 5 and 10 are not applicable because DAEC does not have a HPCS system.
- b). Event 6 is not applicable because DAEC does not have RCIC head sprays.

For the ten remaining events, the DAEC specific features, such as trip logic, power supplies, instrument line configuration, alarms and operator actions, have been compared to the base case analysis presented in the BWR Owners Group submittal of September 17, 1980. The comparison has demonstrated that, in each case, the base case analysis is applicable to DAEC because the base case analysis does not include any plant features which are not already present in the DAEC design. For these events, Table 1 demonstrates that the DAEC specific features are included in the base case analyses presented in the BWR Owners Group submittal of September 17, 1980. It is seen from Table 1 that all plant features assumed in the event evaluation are also existing features in the DAEC plant. All features included in this base case analysis are similar to plant features in the DAEC design. Furthermore, the time available for operator action is expected to be longer in the DAEC plant than in the base case analysis for each case where operator action is required.

As discussed above, the BWR Owners Group evaluated transients including single active failures that would maximize the dynamic forces on the safety relief valves. As a result of this evaluation, the alternate shutdown cooling mode (Event 7) is the only expected event involving liquid or two-phase flow. Consequently, this event was tested in the BWR SRV test program. The fluid conditions and flow conditions tested in the BWR Owners Group test program are expected to envelope the DAEC plant-specific fluid conditions for the alternate shutdown cooling mode of operation. As discussed in the response to NRC Question 5, analyses are being developed which are expected to confirm this.

NRC QUESTION 5

The valves are likely to be extensively cycled in a controlled depressurization mode in a plant specific application. Was the mode simulated in the test program? What is the effect of this valve cycling on valve performance and probability of the valve to fail open or to fail close?

RESPONSE TO QUESTION 5

The BWR SRV operability test program was designed to simulate the alternate shutdown cooling mode, which is the only expected liquid discharge event for DAEC. The sequence of events leading to the alternate shutdown cooling mode is given below. Although not currently utilized at DAEC, the necessary procedures and analyses are being developed to incorporate this mode into the DAEC operating capability. The analyses will incorporate the final Mark I containment modifications and are expected to confirm the conclusions reached during the test program and stated in this report.

Following normal reactor shutdown, the reactor operator depressurizes the reactor vessel by opening the turbine bypass valves and removing heat through the main condenser. If the main condenser is unavailable, the operator could depressurize the reactor vessel by using the SRVs to discharge steam to the suppression pool. If SRV operation is required, the operator cycles the valves in order to assure that the cooldown rate is maintained within the technical specification limit of 100F per hour. When the vessel is depressurized, the operator initiates normal shutdown cooling by use of the RHR system. If that system is unavailable because the valve on the RHR shutdown cooling suction line fails to open, the operator initiates the alternate shutdown cooling mode.

For alternate shutdown cooling, the operator opens one SRV and initiates either an RHR or core spray pump utilizing the suppression pool as the suction source. The reactor vessel is filled such that water is allowed to flow into the main steam lines and out of the SRV and back to the suppression pool. Cooling of the system is provided by use of an RHR heat exchanger. As a result, an alternate cooling mode is maintained.

In order to assure continuous long term heat removal, the SRV is kept open and no cycling of the valve is performed. In order to control the reactor vessel cooldown rate, the operator is instructed to control the flow rate into the vessel. Consequently, no cycling of the SRV is required for the alternate shutdown cooling mode, and no cycling of the SRV was performed for the generic BWR SRV operability test program.

The ability of the DAEC SRV to be extensively cycled for steam discharge conditions has been confirmed during steam discharge qualification testing of the valve by the valve vendor. Based on the qualification testing of the SRVs, the cycling of the valves in a controlled depressurization mode for steam discharge conditions will not adversely affect valve performance and the probability of the valve to fail open or closed is extremely low.

NRC QUESTION 6

Describe how the values of valve C_v s in report NEDE-24988-P will be used at Duane Arnold. Show that the methodology used in the test program to determine the valve C_v will be consistent with the application at Duane Arnold.

RESPONSE TO NRC QUESTION 6

The flow coefficient, C_v , for the Target Rock SRV utilized in DAEC was determined in the generic SRV test program (NEDE-24988-P). The average flow coefficient calculated from the test results for the Target Rock is reported in Table 5.2-1 of NEDE-24988-P. This test value is being used by Iowa Electric to confirm that the liquid discharge flow capacity of the DAEC SRVs will be sufficient to remove core decay heat when injecting into the reactor pressure vessel (RPV) in the alternate shutdown cooling mode. The C_v values determined in the SRV test is expected to demonstrate that the DAEC SRVs are capable of returning the flow injected by the RHR or CS pump to the suppression pool.

If it were necessary for the operator to place the DAEC plant in the alternate shutdown cooling mode, he would assure that adequate core cooling was being provided by monitoring the following parameters: RHR or CS flow rate, reactor vessel pressure and reactor vessel temperature.

The flow coefficient for the Target Rock valve reported in NEDE-24988-P was determined from the SRV flow rate when the valve inlet was pressurized to approximately 250 psig. The valve flow rate was measured with the supply line flow venturi upstream of the steam chest. The C_v for the valve was calculated using the nominal measured pressure differential between the valve inlet (steam chest) and 3 feet downstream of the valve and the corresponding measured flowrate. Furthermore, the test conditions and test configuration were representative of the expected DAEC plant conditions for the alternate shutdown cooling mode, e.g., pressure upstream of the valve, fluid temperature, friction losses and liquid flowrate. Therefore, the reported C_v values are appropriate for application to the DAEC plant.

TABLE 1 - EVENTS EVALUATED

PLANT FEATURES	#1 FW Cont. Fail., FW L8 Trip Failure	#2 Press. Reg. Fail.	#3 Transient HPCI, HPCI L8 Trip Failure	#4 Transient PCIC, PCIC L8 Trip Failure	#5 Transient HPCS, HPCS L8 Trip Failure	#6 Transient RCIC Hd. Spr.	#7 Alt. Shutdown Cooling, Suction Unavailable	#8 MSL Brk OSC	#9 SBA, RCIC, RCIC L8 Trip Failure	#10 SBA, HPCS, HPCS L8 Trip Failure	#11 SBA, HPCI, HPCI L8 Trip Failure	#12 SPA, Depress. & ECCS Over., Operator Error	#13 LBA, FCCS Overf Brk Isol
Low Pressure ECCS Initiation on High Drywell Pressure												X S	X S
Low Pressure Initiation on Low Water Level													X S
FW Pumps Trip on Low Suction Pressure	X S												
HPCS Trip on High Backpressure			X NA								X NA		
RCIC Trip on High Backpressure				X S					X S				
Turbine Trip on Vessel High Level	X S	X S											
MSIVs Closure on Low Turbine Inlet Pressure	X S	X S						X S					
MSIVs Closure on High Steam Flow		X S						X S					
MSIVs Closure on High Steam Tunnel Temperature								X S					

TABLE 1 - EVENTS EVALUATED

PLANT FEATURES	#1 FW Cont. Fail., FW L8 Trip Failure	#2 Press. Reg. Fail.	#3 Transient HPCI, HPCI L8 Trip Failure	#4 Transient PCIC, RCIC L8 Trip Failure	#5 Transient HPCS, HPCS L8 Trip Failure	#6 Transient PCIC Hd. Spr.	#7 Alt. Shutdown Cooling, Suction Unavailable	#8 MSL Brk OSC	#9 SBA, PCIC, PCIC L8 Trip Failure	#10 SBA, HPCS, HPCS L8 Trip Failure	#11 SBA, HPCI, HPCI L8 Trip Failure	#12 SBA, Depress. & ECCS Over., Operator Pror	#13 LRA, ECCS Overf Brk Isol
MSIV Closure on High Radiation								X S					
Reactor Scram on Turbine Trip	X S	X S											
Reactor Scram on Neutron Flux Monitor		X S											
Reactor Scram on MSIVs Closure		X S											
Reactor Scram on High Radiation							X S						
Reactor Scram on High Drywell Pressure								X S	X NA	X S	X S	X S	X S
Reactor Scram on Low Water Level													X S
Reactor Isolation on Low Water Level													X S

KEY: X - Feature considered in Base Case Analysis
 S - Feature in Plant Specific Design
 NA - Not Applicable