

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8308030417 DOC. DATE: 83/07/29 NOTARIZED: NO DOCKET #
 FACIL: 50-331 Duane Arnold Energy Center, Iowa Electric Light & Power 05000331
 AUTH. NAME AUTHOR AFFILIATION
 MCGAUGHY, R.W. Iowa Electric Light & Power Co.
 RECIP. NAME RECIPIENT AFFILIATION
 DENTON, H. Office of Nuclear Reactor Regulation, Director

SUBJECT: Summaries results of wetwell/drywell (W/D) vacuum breaker calculations per Generic Ltr 83-08. Calculations indicate certain components of W/D vacuum breaker could exceed allowables when subjected to design impact velocities.

DISTRIBUTION CODE: A0255 COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 4
 TITLE: OR Submittal: USI A-7 Mark I Containment

NOTES:

RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL
NRR ORB2 BC 01	4 0		
INTERNAL: EDO	1 0	ELD/HDS2 13	1 0
NRR DIR	1 0	NRR SIEGEL, B	5 5
NRR/DE/MEB	4 4	NRR/DE/MTEB	1 1
NRR/DL/ORAB 10	1 1	NRR/DSI/CSB 11	1 1
REG FILE 04	1 1	RGN3	1 1
EXTERNAL: ACRS 12	10 3	LPDR 03	1 1
NRC PDR 02	1 1	NSIC 05	1 1
NTIS	1 1		

Iowa Electric Light and Power Company

July 29, 1983

NG-83-2619

Mr. Harold Denton, Director
Office of Nuclear Reactor Regulation
U.S. Nuclear Regulatory Commission
Washington, DC 20555

Re: Duane Arnold Energy Center
Subject: Modification of Wetwell/Drywell Vacuum Breakers
Reference: 1) NRC Generic Letter 83-08
2) IE Letter NG-83-1771

Dear Mr. Denton:

This letter will summarize the results of the Wetwell/Drywell (W/D) vacuum breaker plant unique calculations made for the Duane Arnold Energy Center (DAEC) and provide a response to Reference #1.

The results of the aforementioned calculations indicate that certain components of the W/D vacuum breaker could exceed code allowables when subjected to design "impact velocities" which presently calculated to be 6.75 Radians/sec. (refer to Attachment #1). The expected impact velocity for the valves, however, has been calculated to be 5.72 Radians/sec.

This potential overstressed condition has proven, however, to be acceptable under the guidelines of the Mark I Short Term program guidelines because the "strength ratio" of these components does not exceed 0.50. (The "Strength Ratio" is defined as the most probable applied load divided by the most probable load that will cause failure.)

In order to increase the integrity of these assemblies and to restore the original design margin, Iowa Electric (IE) will replace the affected components with components fabricated from materials having higher code allowable stresses (refer to Attachment #2).

The following is a summary of the modifications which are anticipated to be made to the W/D vacuum breaker at the DAEC:

- a) Replacement of the W/D vacuum breaker pallets (SA-516 Gr 70) with SA-705 Gr 630 (age hardened @ 1100°F)
- b) Replacement of the W/D vacuum breaker hinge shafts (SA-320 B8) with SA-564 Gr 630 (age hardened @ 1100°F)

8308030417 830729
PDR ADOCK 05000331
P PDR

A025
11

Page Two
Mr. Harold Denton
July 29, 1983
NG-83-2619


- c) Replacement of the W/D vacuum breaker hinge arms (SA-516 Gr 70) with SA-564 Gr 630 (age hardened @ 1100°F)
- d) Replacement of the W/D vacuum breaker hinge arm studs (SA-320 B8) with SA-564 Gr 630 (age hardened @ 1100°F)

Additionally, because of the sealing gasket "fold-over", which was evidenced at the Full-Scale Test Facility after completion of test No. M1, the original gasket will be replaced by an improved design. The new gasket will be a steel-ring-stiffened design which has proven to seal properly and eliminate the "fold-over" condition.

The above modifications will be completed during the next refueling outage which currently is scheduled for the fall of 1984, as stated in reference #2.

If you should have any additional questions in regard to this matter, please contact this office.

Very truly yours,



Richard W. McGaughy
Manager, Nuclear Division

RWM/BWR/rh*

Attachments: Attachment 1, Stress Levels by Component for 18-Inch GPE Vacuum Breaker
Attachment 2, Higher Strength Replacement Materials for 18-Inch GPE Vacuum Breaker

cc: B. Reid
L. Liu
S. Tuthill
L. Root
H. Rehrauer
T. Shugart
F. Apicella
NRC Resident Office
Commitment Control No. 83-0139

ATTACHMENT 1

STRESS LEVELS BY COMPONENT FOR 18-INCH GPE VACUUM BREAKER

<u>Component</u>	<u>Existing Material</u>	<u>ASME Allowable Stress (ksi)</u>	Stress (ksi) for Various Pallet Impact Velocities		
			3.0 (rad/sec)	4.5	9.3
Pallet,	SA-516 Gr 70	35.0	21.6	32.4	67.0
Hinge Arm	SA-516 Gr 70	35.0	11.8	17.7	36.6
Hinge Shaft	SA-320 B8	30.0	19.1	28.6	59.2
Hinge Arm Stud	SA-320 B8	30.0	12.5	18.8	38.8

ATTACHMENT 2

HIGHER STRENGTH REPLACEMENT MATERIALS
FOR 18-INCH GPE VACUUM BREAKER

<u>Component</u>	<u>Material</u>	<u>Allowable Stress</u>
Pallet	SA-705 Gr 630 (age hardened at 1100°F)	70 ksi
Hinge Shaft	SA-564 Gr 630 (age hardened at 1100°F)	70 ksi
Hinge Arm		
Hinge Arm Stud		