

Job Performance Measure "A"

Facility: **Vogtle**

Task No: V-LO-TA-09029

Task Title: Emergency Borate from the RWST

JPM No: V-RQ-JP-13009-005

K/A Reference: 004A2.14

Examinee: _____

NRC Examiner: _____

Facility Evaluator: _____

Date: _____

Method of testing:

Simulated Performance _____

Actual Performance _____

Classroom _____

Simulator _____

Plant _____

Read to the examinee:

I will explain the initial conditions, which steps to simulate or discuss, and provide initiating cues. When you complete the task successfully, the objective for this job performance measure will be satisfied.

Initial Conditions: **A rapid down power per AOP 18013-C, "Rapid Power Reduction" has just been performed by the operating crew. Boric Acid Transfer Pump 1 is Danger Tagged.**

Task Standard: Student initiates emergency boration from the RWST using SOP 13009-1.

Required Materials: 1. SOP 13009-1 Ver. 46.1
 2. Control Room Simulator

General References: None

Initiating Cue: **The SS has directed you to emergency borate the RCS using SOP 13009-1 to clear the rod bank Lo-Lo Limit alarm.**

Time Critical Task: No

Validation Time: 6 minutes

SIMULATOR SETUP:

Simulator Setup:

1. Reset to IC # 237 for HL-15 NRC Exam
2. Place a Red Danger Tag on HS-0276A (Boric Acid Transfer # 1)

Simulator Setup from Scratch:

1. Reset to IC # 14 (100% MOL)
2. Insert the following overrides:

LV-112D	closed
HS-276A	stop
HS-276A	green light – off
HS-276A	Red Danger Tag on hand switch
HS-277A	stop – on Trigger 1 (T1)
HS-277A	amber light on – on Trigger 1 (T1)
ALB37 window D01 (BBD Trouble)	on - on Trigger 1 (T1)
3. Select the following hand switch positions:

HS-277A	auto
---------	------
4. Place 75 gpm letdown in service and adjust charging flow as appropriate to maintain PRZR level stable.
5. Reduce reactor power to ~ 70% power and stabilize the plant, ensure that CBD rods are below the RIL to ensure ALB-10, D04 for ROD BANK LO-LO LIMIT is illuminated. (Recommend 5 to 10 steps below the RIL to ensure the alarm does not inadvertently clear, some patience is required to accomplish this (~ 106 steps on CBD should be pretty close).
6. Acknowledge / Reset alarms
7. Freeze

Setup time: 10 minutes

Performance Information

Critical steps denoted with an asterisk

***Student selects section 4.9 of SOP 13009-1**

Standard: Section 4.9 referenced

Comment:

Reviews note at beginning of section 4.9 and may refer to table 1 for available flow paths

**TABLE 1
EMERGENCY BORATION FLOW PATH ALTERNATIVES**

Flow path	BATP	Valve Alignments	Other Pump Required	Flows	Flow	Note
HV8104	At least one	OPEN 1HV-8104	Any charging pump	>42 GPM 1FI-0121C	>30 GPM 1FI-0183A	Operate heaters
Charging Flow path	At least one	OPEN 1FV-0110A 1FV-0110B	Any charging pump	>42 GPM 1FI-0121C	>30 GPM 1FI-0110A	Operate heaters
RWST to Regen Hx	NA	OPEN 1LV-0112D 1LV-0112E CLOSE 1LV-0112B 1LV-0112C 1LV-0112A	Any charging pump	>100 GPM 1FI-0121C	8 to 13 GPM seal injection flow 1HV-0182	Operate heaters
RWST to BIT	NA	OPEN 1HV-8801A 1HV-8801B	Any charging pump	BIT flow (1FI-0917A) + total seal flow - seal return flow >87.5 GPM	Adjust 1FIC-0121C to <13 GPM per RCP	Operate heaters
RHR (Mode 6)	NA	OPEN HV-8812A/B HV-8809A/B	RHR other than S/D Cooling	>100 gpm	See Proc.	Establish water removal path to prevent vessel overflow
SI (Mode 6)	NA	OPEN HV-8923A/B HV-8821A/B HV-8835	SI	>100 gpm	See Proc.	Establish water removal path to prevent vessel or cavity overflow

Student may use any of the first four methods. Most likely method will be using HV-8104 or the charging flow path

Standard: N/A

Comment:

4.9.1 Emergency Boration Through 1-HV-8104

OR

4.9.2 Emergency Boration Through The Normal Charging Flow Path

***4.9.1.1 OR 4.9.2.1 Start one (1) Boric Acid Transfer Pump.**

Standard: Boric acid transfer pump hand switch placed in START
 Red light – ON
 Green light - OFF

Comment:

CUE: Simulator operator actuates trigger 1

*** Determines that boric acid transfer pump has tripped**

Standard: Boric acid transfer pump:
 Red light – OFF
 Green light – ON
 Amber light – ON
 1BBD Trouble Alarm

Comment:

*** Determines that sections 4.9.1 and 4.9.2 are N/A due to both boric acid transfer pumps being unavailable.**

Standard: Refers to section 4.9.3 “Emergency Boration From The RWST Through The Normal Charging Flow Path”

Comment:

4.9.3 Emergency Boration From The RWST Through The Normal Charging Flow Path

4.9.3.1 **Verify** one (1) Charging Pump is running and supplied with cooling water.

CUE: IF asked, Auxiliary Building Operator reports NCP is supplied with cooling water.

Standard: NCP: Red light – ON
Green light – OFF
Amber light - OFF

Comment:

***4.9.3.2 Open the following Charging Pump Suctions from the RWST:**

- 1-LV-0112D
- 1-LV-0112E

Standard: Places 1-LV-112D in open position: Green light – stays ON
Red light - stays OFF

Places 1-LV-112E in open position: Green light – OFF
Red light - ON

Comment:

***4.9.3.3 Close the following VCT Outlet Isolations:**

- 1-LV-0112B
- 1-LV-0112C

Standard: Places 1-LV-112B to close position: Green light - ON
Red light - OFF

Places 1-LV-112C to close position: Green light - ON
Red light - OFF

Comment:

***4.9.3.4 Place 1-LV-0112A to the HUT position.**

Standard: Places 1-LV-0112A to the HUT position: Red light - OFF
Amber light - ON

Comment:

4.9.3.5 Place 1-FIC-0121 in MANUAL,

Standard: Checks 1-FIC-0121 in MANUAL
Auto light – OFF
Manual light - ON

Comment:

***4.9.3.6 Adjust Charging Line Flow Controller 1-FIC-0121 to obtain Charging Flow 1-FI-0121C greater than 100 gpm,**

Standard: Charging Flow 1-FI-0121C greater than 100 gpm

Comment:

4.9.3.7 **Adjust** Charging Seal Flow Control 1-HV-0182 as necessary to maintain RCP seal injection flow at approximately 40 gpm (between 8 and 13 gpm per pump).

Standard: RCP seal injection flows between 8 and 13 GPM per pump

Comment:

4.9.3.8 IF required for RCS inventory control, **place** an additional letdown orifice in service per 13006-1.

CUE: The extra operator will place an additional letdown orifice in service.

Standard: N/A

Comment:

4.9.3.9 **Operate** the Pressurizer Backup Heaters as necessary to equalize boron concentrations between the RCS and the Pressurizer.

Standard: Turns on Pressure back up heaters as needed:

1HS-10469A
1HS-10470A
1HS-10472

Comment:

4.9.3.10 **Check** for indications consistent with RCS boration:

RCS Tavg may be dropping.

NIS may be dropping.

CUE: The extra operator will monitor boron concentration and terminate emergency boration flow when the rod bank Lo-Lo Limit Alarm is clear.

Standard: N/A

Comment:

Reports to the SS that emergency boration from the RWST has been initiated per 13009-1.

Standard: N/A

Comment:

Terminating cue: Student returns initiating cue sheet

Verification of Completion

Job Performance Measure No. V-RQ-JP-13009-005

Examinee's Name:

Examiner's Name:

Date Performed:

Number of Attempts:

Time to Complete:

Question Documentation:

Question: _____

Response: _____

Result: Satisfactory/Unsatisfactory

Examiner's signature and date: _____

Initial Conditions: A rapid down power per AOP 18013-C, "Rapid Power Reduction" has just been performed by the operating crew. Boric Acid Transfer Pump 1 is Danger Tagged.

Initiating Cue: The SS has directed you to emergency borate the RCS using SOP 13009-1 to clear the rod bank Lo-Lo Limit alarm.

Job Performance Measure "B"

Facility: **Vogtle**

Task No: V-LO-TA-37002

Task Title: **Establish Safety Grade Letdown**

JPM No: V-NRC-JP-19001-001

K/A Reference: 004A2.11

Examinee: _____

NRC Examiner: _____

Facility Evaluator: _____

Date: _____

Method of testing:

Simulated Performance _____

Actual Performance _____

Classroom _____

Simulator _____

Plant _____

Read to the examinee:

I will explain the initial conditions, which steps to simulate or discuss, and provide initiating cues. When you complete the task successfully, the objective for this job performance measure will be satisfied.

Initial Conditions: **The plant was manually tripped due to an unisolable instrument air break. Unable to prevent instrument air header depressurization, the compressors have been stopped. The crew has transitioned from EOP 19000-C to EOP 19001-C.**

Task Standard: Safety grade letdown flow established.

Required Materials: EOP 19001-C, Reactor Trip Response

Initiating Cue: **The SS has directed you to "Establish a safety grade letdown flow at 40 gpm using EOP 19001-C step 10 a RNO."**

Time Critical Task: No

Validation Time: 5 minutes

SIMULATOR SETUP:

Simulator Setup:

1. Reset to IC # 14 (MOL 100%)
2. Initiate manual reactor trip.
3. Close MSIVs.
4. Throttle total AFW flow to stabilize RCS temperature.
5. Verify PRZR level and pressure stable or rising.
6. Insert malfunction IA01 (instrument air leak) at 100%.
7. Place all air compressor handswitches in STOP.
8. Ack/Reset alarms.
9. Verify instrument air pressure ~ 0 psig.
10. Place Train B Safety grade charging in service per 13006-C
11. Freeze simulator.

Setup time: 10 minutes

Performance Information

Critical steps denoted with an asterisk

Step 10 RNO a 1): Establish Safety Grade Charging by initiating 13006, CHEMICAL AND VOLUME CONTROL SYSTEM

CUE: IF ASKED, “Train B Safety Grade Charging is in service.”

Standard: N/A

Comment:

***Step 10 RNO a 2) a): Open Rx Head Vent to LETDOWN ISOLATION VLVs:**

**-HV-8095A
-HV-8096A
-HV-8095B
-HV-8096B**

Standard: All valves opened.

Comment:

***Step 10 RNO a 2) b): Open REACTOR HEAD VENT TO PRT flow control valves as necessary:**

**-HV-0442A
-HV-0442B**

NOTE to examiner: FI-406A and FI-407A are in series and each will read the total flow.

Standard: Head vent flow controller valves HV-0442A and/or HV-442B adjusted to attain a 35 to 45 gpm letdown flow rate.

Comment:

Report completion to SS.

Standard: Report letdown flow established at rate to the SS.

Comment:

Terminating cue: Student returns initiating cue sheet

Verification of Completion

Job Performance Measure No. V-NRC-JP-19001-001

Examinee's Name:

Examiner's Name:

Date Performed:

Number of Attempts:

Time to Complete:

Question Documentation:

Question: _____

Response: _____

Result: Satisfactory/Unsatisfactory

Examiner's signature and date: _____

Initial Conditions: The plant was manually tripped due to an unisolable instrument air break. Unable to prevent instrument air header depressurization, the compressors have been stopped. The crew has transitioned from EOP 19000-C to EOP 19001-C.

Initiating Cue: The SS has directed you to “Establish a safety grade letdown flow at 40 gpm using EOP 19001-C step 10 a RNO.”

Job Performance Measure “C”

Facility: **Vogtle**

Task No: V-LO-TA-37011

Task Title: Depressurize RCS to Reduce Break Flow to Ruptured Steam Generator—Normal Pressurizer Spray Not Available and 1st PORV block valve fails shut. (Alternate Path)

JPM No: V-NRC-JP-19030-004

K/A Reference: 038EA1.04

Examinee: _____

NRC Examiner: _____

Facility Evaluator: _____

Date: _____

Method of testing:

Simulated Performance _____

Actual Performance _____

Classroom _____

Simulator _____

Plant _____

Read to the examinee:

I will explain the initial conditions, which steps to simulate or discuss, and provide initiating cues. When you complete the task successfully, the objective for this job performance measure will be satisfied.

Initial Conditions: A tube rupture has occurred on SG-A. The crew has transitioned from EOP 19000-C to 19030-C. Steps 1 through 33 of EOP 19030-C have been performed. Normal pressurizer spray was not available.

Task Standard: RCS depressurized using a PORV to at or slightly below ruptured SG pressure per EOP 19030-C.

- Required Materials:**
1. EOP 19030-C Ver 37.1, “Steam Generator Tube Rupture”.
 2. Replacement copies of EOP 19030-C need to be printed and in simbooth for quick replacement.

General References: None

Initiating Cue: The SS has directed you to “Depressurize the RCS beginning with EOP 19030-C step 34.”

Time Critical Task: No

Validation Time: 11 minutes

SIMULATOR SETUP:

Simulator Setup:

1. **Reset to IC # 83 for HL-15R NRC Exam.**

Simulator Setup from Scratch:

1. Reset to IC # 14 (100% MOL).
2. Override: PIC 455B to "CNT DN."
3. Override: PIC-455C to "CNT DN."
4. Insert malfunction SG01A at 50%.
5. Initiate manual Rx Trip and SI.
6. Throttle AFW flow to ~ 200gpm per SG.
7. Verify ruptured SG level > 10% NR.
8. Perform 19030 steps 1 through 33.
9. Insert Override HS-8000G to Block
10. Insert Override HS-8000H to Block
11. Ack/Reset alarms.
12. Freeze simulator

Setup time from scratch: 20 minutes

Performance Information

Critical steps denoted with an asterisk and bolded.

***Step 34:** Depressurize RCS using a PRZR PORV to refill PRZR:

a) Arm one available train of COPS and check PRZR PORV Block Valve – OPEN.

NOTE to examiner: After candidate arms COPS, simulator operator will remove the override from the other train of COPS.

Standard: The candidate recognizes that the PRZR PORV Block Valve did not OPEN.

Comment:

***Step 34.a** RNO Open PRZR PORV Block Valve.

Standard: The candidate recognizes that the PRZR PORV Block Valve did not remain open when Handswitch released.

Comment:

***Step 34.a** Arm one available train of COPS and check PRZR PORV Block Valve – OPEN.

Standard: The candidate now arms the opposite train of COPS and checks the Block Valve OPEN.

NOTE to examiner: The candidate may block the first train of COPS before arming the opposite train.

Comment:

***Step 34.b** Open one PRZR PORV.

Standard: The candidate opens one PRZR PORV.

Comment:

Step 34.c Go To Step 37.

Standard: The candidate goes to Step 37.

Comment:

***Step 37: Check if ANY of the following conditions are satisfied:**

BOTH of the following:

**-RCS pressure – LESS THAN RUPTURED SG(s) PRESSURE.
-PRZR level – GREATER THAN 9% [37% ADVERSE.]**

OR

-RCS Subcooling – LESS THAN 24°F [38 °F ADVERSE.]

OR

-PRZR level – GREATER THAN 75% [52% ADVERSE.]

Standard: The candidate monitors these parameters to until one of the criteria is satisfied.

Comment:

***Step 38: Terminate RCS depressurization:**

- a) Verify Normal PRZR Spray valve(s) – CLOSED.**
- b) Verify PRZR PORV(s) – CLOSED.**
- c) Block COPS.**
- d) Check Auxiliary Spray – IN SERVICE.**

**Standard: The candidate checks Normal PRZR Spray valves CLOSED.
The candidate shuts the open PORV.
The candidate blocks both trains of COPS.**

NOTE to examiner: One train of COPS may have been previously blocked prior to arming the opposite train.

The candidate checks auxiliary spray NOT IN SERVICE.

Comment:

***Step 39: Check RCS pressure – RISING.**

Standard: Candidate notes that RCS pressure is RISING.

Comments:

Terminating Cue: “Another operator will continue this procedure.”

Verification of Completion

Job Performance Measure No. V-RQ-JP-19030-004

Examinee's Name:

Examiner's Name:

Date Performed:

Number of Attempts:

Time to Complete:

Question Documentation:

Question: _____

Response: _____

Result: Satisfactory/Unsatisfactory

Examiner's signature and date: _____

Initial Conditions: A tube rupture has occurred on SG-A. The crew has transitioned from EOP 19000-C to 19030-C. Steps 1 through 33 of EOP 19030-C have been performed. Normal pressurizer spray was not available.

Initiating Cue: The SS has directed you to “Depressurize the RCS beginning with EOP 19030-C step 34.”

Job Performance Measure “D”

Facility: **Vogtle**

Task No: V-LO-TA-37010

Task Title: Isolate a Faulted Steam Generator—Alternate Path.

JPM No: V-NRC-JP-19020-002

K/A Reference: WE12EA2.2

Examinee: _____

NRC Examiner: _____

Facility Evaluator: _____

Date: _____

Method of testing:

Simulated Performance _____

Actual Performance _____

Classroom _____

Simulator _____

Plant _____

Read to the examinee:

I will explain the initial conditions, which steps to simulate or discuss, and provide initiating cues. When you complete the task successfully, the objective for this job performance measure will be satisfied.

Initial Conditions: **A low steamline pressure SI has occurred. The crew has transitioned from EOP 19000-C to EOP 19020-C.**

Task Standard: Faulted generator isolation attempted then 19121-C implemented to minimize cooldown.

Required Materials: EOP 19020-C Ver 18
 EOP 19121-C Ver 26

General References: None

Initiating Cue: **The SS has directed you to “Isolate the ruptured SG using EOP 19020-C.”**

Time Critical Task: No

Validation Time: 15 minutes

SIMULATOR SETUP:

- 1) Reset to IC14 (MOL 100%).
- 2) Insert malfunctions ES10 and ES11.
- 3) Insert malfunction MS02A at 5%
- 4) Insert malfunction MS02B at 5%
- 5) Insert malfunction MS02C at 5%
- 6) Insert malfunction MS02D at 5%
- 7) Trip reactor and actuate SI.
- 8) Throttle total AFW flow to ~ 200gpm per SG (Do not isolate AFW flow to faulted SGs.)
- 9) Ack/Reset alarms.

Setup time: 7 minutes

Performance Information

Critical steps denoted with an asterisk

19020-C
Step 3 Verify MSIVs and BSIVs Valves CLOSED.

Standard: Train A and B MSIVs and BSIVs are open.
 Student manually actuates SLI and/or attempts manually closing all valves.
 Student verifies all MSIVs and BSIVs are closed.

Comment:

***Step 4 RNO: IF all SG pressures are lowering in an uncontrolled manner, THEN go to
19121- C ECA-2.1 UNCONTROLLED DEPRESSURIZATION OF ALL STEAM
GENERATORS.**

Standard: Checks all S/G pressure indications.
 Determines all S/G pressures are lowering uncontrollably.
 Transitions to 19121-C.

Comment:

19121-C
Step 2a: Check SGs secondary pressure boundaries: Verify the following valves
 CLOSED:

- MSIVs
- MFIVs
- BFIVs
- MFRVs
- BFRVs

Standard: Verifies all valves are shut.

Comment:

Step 2b: Verify BSIVs CLOSED.

Standard: Verifies valves CLOSED.

Comment:

Step 2c Verify SG Blowdown and Sample Valves CLOSED.

Standard: Verifies valves CLOSED.

Comment:

Step 2d Verify SG ARVs CLOSED.

Standard: Verifies valves CLOSED.

Comment:

***Step 3: Isolate steam supply to TDAFW Pump.**

Check one MDAFW running AND capable of feeding SG(s) needed for RCS Cooldown.

Close TDAFW Pump Steam Supply Valves:

-HV-3009.

-HV-3019.

**Standard: Checks that one MDAFW is running AND capable of feeding SG(s).
Closes TDAFW Pump Steam Supply Valves.**

Comment:

***Step # 4 Control feed flow to SG to minimize RCS cooldown.**

Standard: Monitors Shutdown Margin.

CUE: When mentioned, “An Extra RO will perform a shutdown margin.”

Checks cooldown in RCS cold legs LESS THAN 100F/hr.

Checks NR level in all SGs LESS THAN 65%.

Lowers AFW to 30gpm in all SGs with level GREATER THAN 10%.

Checks NR level in all SGs GREATER THAN 10% [32% ADVERSE].

Checks RCS WR Hot Leg temperatures STABLE or LOWERING.

Comment:

Terminating cue: “The SS will have another operator complete the procedure”.

Verification of Completion

Job Performance Measure No. V-LO-JP-19030-006

Examinee's Name:

Examiner's Name:

Date Performed:

Number of Attempts:

Time to Complete:

Question Documentation:

Question: _____

Response: _____

Result: Satisfactory/Unsatisfactory

Examiner's signature and date: _____

Initial Conditions: A low steamline pressure SI has occurred. The crew has transitioned from EOP 19000-C to EOP 19020-C.

Initiating Cue: The SS has directed you to “Isolate the ruptured SG using EOP 19020-C.”

Job Performance Measure "E"

Facility: **Vogtle**

Task No: V-LO-TA-29008

Task Title: Place Containment Hydrogen Monitors in service.

JPM No: V-NRC-JP-13130-002

K/A Reference: 028A1.01

Examinee: _____

NRC Examiner: _____

Facility Evaluator: _____

Date: _____

Method of testing:

Simulated Performance _____

Actual Performance _____

Classroom _____

Simulator _____

Plant _____

Read to the examinee:

I will explain the initial conditions, which steps to simulate or discuss, and provide initiating cues. When you complete the task successfully, the objective for this job performance measure will be satisfied.

Initial Conditions: **A LOCA has occurred on Unit 1. The crew is performing EOP 19010-C.**

Task Standard: Containment hydrogen monitor in service.

Required Materials: 1. SOP 13130-1 Ver 19 "Post Accident Hydrogen Control".

General References: None

Initiating Cue: **The SS has directed you to "Place Containment Hydrogen Monitors in service using SOP 13130-1."**

Time Critical Task: No

Validation Time: 8 minutes

SIMULATOR SETUP:

Simulator Setup from Scratch:

1. Reset to IC # 14 (MOL 100%)
2. Insert malfunction RC05C at 100% (Hot Leg Break).
3. Stop RCPs and Throttle AFW flow ~ 200gpm/SG.
4. Reset SI, Reset CIA, and Stop RHR pumps.
5. Energize Stub busses and establish Instr. Air to Cnmt.
6. Use Remote Function ED08 for target H₂ at 8.4%.
7. Use Remote Function ED07 for H₂ override.
13. Ack/Reset alarms.
14. Freeze simulator

Setup time from scratch: 10 minutes

Performance Information

Critical steps denoted with an asterisk and bolded.

Student determines that 13130-1, "Post-Accident Hydrogen Control" is applicable.

Standard: Student selects 13130-1, section 4.2.1 or 4.2.2 for "Containment Hydrogen Monitor A/B 1-1513-P5-HMA Operation (Hydrogen Measurement.)"

NOTE to examiner: Student could choose place either monitor in service first.

**Cue: If student elects to go to 4.2.2 first:
Align Train A Hydrogen Monitor First."**

Comment:

NOTE: The Hydrogen Monitors require a 6 hour warm-up period in STANDBY before accurate readings may be obtained.

**CUE: IF ASKED, "The Hydrogen Monitors
have been in STANDBY for 3 days."**

CAUTION: The Hydrogen Monitor Isolation Valves must remain closed except during Hydrogen Monitor operation while in Modes 5 or 6 or during post accident conditions to ensure containment integrity is maintained.

Standard: Student reviews NOTE and CAUTION prior to step 4.2.1.1 and determines that the standby requirement is met and that this is post-accident so that he may open the isolation valves.

Comment:

4.2.1.1.1 **IF** the following conditions exist, **THEN** **notify** maintenance to implement 28834-1, to provide power to Containment Isolation Valves 1-HV-2791B and 1-HV-2793B:

- A post accident condition (LOCA) exist AND
- 125VDC Bus 1BD11 is not available AND
- Containment Hydrogen Concentration is required.

Standard: Student recognizes that 125VDC Bus 1BD11 is available.

Comment:

***4.2.1.2 Verify the Hydrogen Monitor A sample line heat tracing temperature is greater than 260°F:**

- a. At Heat Tracing Panel 1-1817-U3-007B,(
1AB-B07) read the temperature for circuit
C1-7 and C1-8.

CUE: If asked, “The UO reports no alarms on the Heat Tracing Alarm Panel.”

- b. **IF** less than 260°F, notify the Control Room immediately.

Standard: Student verifies that the sample line heat tracing temperature is greater than 260°F.

Comment:

***4.2.1.3 Open the H₂ MONITOR A SPLY ISO IRC**

- a) 1-HV-2792A
- b) 1-HV-2792B

Standard: Student opens valves

Comment:

***4.2.1.4 Open H₂ MONITOR A SPLY ISO ORC 1-HV-2791B**

NOTE to examiner: ORC isolation valves are powered from the opposite train and are located as such on the QPCP.

Standard: Student opens valve 1-HV-2791B.

Comment:

***4.2.1.5 Open H₂ MONITOR A RTN ISO ORC 1-HV-2793B**

NOTE to examiner: ORC isolation valves are powered from the opposite train and are located as such on the QPCP.

Standard: Student opens valve 1-HV-2793B.

Comment:

***4.2.1.6 Place Mode Switch 1-HS-22900 in ANALYZE.**

Standard: Student places Switch 1-HS-22900 in ANALYZE.

Comment:

***4.2.1.7 Verify Function Selector Switch 1-HS-22904 in Sample position.**

Standard: Student verifies function selector switch 1-HS-22904 in SAMPLE.

Comment:

***4.2.1.8 Momentarily depress Remote Control Selector Pushbutton 1-HS-22944 and verify Sample Light LIT.**

Standard: Student momentarily depresses pushbutton.
Student verifies sample light is LIT.

Comment:

4.2.1.9 Note containment hydrogen concentration as indicated by CONTAIN H₂ MONITOR TRN A 1-AI-12979 on QMCB WHEN indications stabilize.

Standard: Student observes Hydrogen concentration on AI-12979.

Comment:

Terminating Cue: “Another operator will place the Train B Hydrogen Monitor in Service.”

Verification of Completion

Job Performance Measure No. V-NRC-JP-13130-002

Examinee's Name:

Examiner's Name:

Date Performed:

Number of Attempts:

Time to Complete:

Question Documentation:

Question: _____

Response: _____

Result: Satisfactory/Unsatisfactory

Examiner's signature and date: _____

Initial Conditions: A LOCA has occurred on Unit 1. The crew is performing EOP 19010-C.

Initiating Cue: The SS has directed you to “Place Containment Hydrogen Monitors in service using SOP 13130-1.”

Job Performance Measure "F"

Facility: **Vogtle**

Task No: V-LO-TA-11014

Task Title: **Parallel DG with Voltage Regulator Failure**

JPM No: V-NRC-JP-13427-002

K/A Reference: 062A1.01

Examinee: _____

NRC Examiner: _____

Facility Evaluator: _____

Date: _____

Method of testing:

Simulated Performance _____

Actual Performance _____

Classroom _____

Simulator _____

Plant _____

Read to the examinee:

I will explain the initial conditions, which steps to simulate or discuss, and provide initiating cues. When you complete the task successfully, the objective for this job performance measure will be satisfied.

Initial Conditions: Following a 7 day D/G 1A outage, Maintenance and Engineering Support are standing by for a D/G 1A test run. D/G 1A was just started, and is now operating unloaded with the D/G output breaker open. You are relieving the UO, and will be performing the remainder of this test run. The outside area SO is stationed at the D/G to support the evolution.

Task Standard: DG-1A paralleled to bus 1AA02 using 13427A-1, and DG-1A output breaker opened when KVAR load goes negative.

Required Materials: SOP 13427A-1 Ver. 6.2, 4160V AC BUS 1AA02 1E ELECTRICAL DISTRIBUTION SYSTEM

Instructions: **Students should be pre-briefed to save simulator time for this JPM.**

Initiating Cue: The applicable portions of SOP 13145-1 have been completed for starting DG-1A. In accordance with procedure SOP 13427A-1, parallel D/G 1A to 1AA01 and raise DG-1A load to 7000 kw per Section 4.2.1, starting with step 4.2.1.3.

Time Critical Task: No

Validation Time: 10 minutes

SIMULATOR SETUP:

1. **Reset to IC # 238 for HL-15 NRC Exam**

Simulator Setup from Scratch:

1. Reset to IC 14 (100% MOL)
2. Start D/G 1A allow it to run unloaded until all annunciators are clear
3. Set **Trigger 1** with the following overrides:
Override Lamps (voltage raise/lower PB lights)
EAB-LO_DG1A_V_LWR VC-DG1A LOWER A533P28-C11 set to **OFF**
EAB-LO_DG1A_V_R VC-DG1A RAISE A533P28-B6 set to **OFF**
Override DI(voltage raise control won't work)
EAB-DG1A_VC_INC VC_DI VC-DG1A RAISE A521P29-A3 set to **FALSE**
4. Set **Trigger 2** with the following overrides:
Override DI (voltage lower control lower VARS)
EAB-DG1A_VC_VC_DEC_DI VC-DG1A LOWER A521P29-B10 set to **TRUE**
5. Acknowledge alarms and freeze simulation

Setup time: 5 minutes

Performance Information

Critical steps denoted with an asterisk

Student review precautions and limitations section of 13427A-1.

4.2.1.3 **Verify** DG1A SYNC MODE SELECTOR Switch 1TS-DG1A in AUTO.

Standard: 1TS-DG1A in AUTO

Comment:

Reviews CAUTION about synchronizing switches

4.2.1.4 **Verify** Breaker 1AA0205 and 1AA0201 Synchronizing Switches are OFF:

- 1AA0205 SYNCHRONIZING SWITCH OFF
- 1AA0201 SYNCHRONIZING SWITCH OFF

Standard: 1AA0205 SYNCHRONIZING SWITCH OFF
 1AA0201 SYNCHRONIZING SWITCH OFF

Comment:

***4.2.1.5 Place the BRKR 1AA0219 SYNCHRONIZING SWITCH to ON.**

Standard: 1AA0219 SYNCHRONIZING SWITCH - ON.
Synchroscope starts rotating.

Comment:

***4.2.1.6** **Momentarily place DSL GEN 1A UNIT/PARALLEL switch 1HS-4414B to PARALLEL/SLOW START and check blue DSL GEN 1A UNIT MODE/FAST START light NOT lit.**

Standard: **Blue light - OFF**

Comment:

4.2.1.7 **Set DSL GEN 1A LOADING SET PT CONTROL 1SE-4915 to 1.00.**

NOTE to examiner: The Control range is 1.0 to 11.0 and is normally left at 1.00.

Standard: Verify 1SE-4915 set at 1.00.

Comment:

4.2.1.8 **Select the highest 1AA02 4160V Bus phase voltage on the QEAB Voltmeter by moving the BUS 1AA02 Normal Incoming Voltmeter Switch through all positions.**

Standard: Highest reading 1AA02 bus voltage selected.

Comment:

Reviews CAUTION on bus voltage limits.

4.2.1.9 **Check 1AA02 4160V Bus voltage between 4025V and 4250V.**

a. **IF NOT, coordinate** with PCC to establish 1AA02 4160V Bus voltage between 4025V and 4250V.

NOTE to examiner: Adjustment should not have to be made.

Standard: 1AA02 4160V Bus voltage between 4025V and 4250V.

Comment:

4.2.1.10 **Select** the DG 1A voltage on the QEAB Voltmeter by moving the DG 1A Voltmeter Switch through all positions.

Standard: Lowest DG-1A voltage selected on voltmeter.

Comment:

NOTES

- It may be necessary to adjust DG speed slightly in order to verify the next step.
- Synchronizing lights are bright at the 6 o'clock position. Synchronizing lights are dark at the 12 o'clock position. The red AUTO SYNC PERMISSIVE light is lit near the 12 o'clock position.

4.2.1.11 **Check** Sync Scope Meter is rotating.

Standard: Sync Scope Meter - rotating

Comment:

NOTE

The following step adjusts DG voltage to slightly higher than bus voltage to ensure the DG kVAR loading will be positive.

4.2.1.12 **Adjust** DG voltage to approximately 50V above the highest phase of the bus voltage, as necessary.

Standard: DG-1A voltage ~ 50 V > 1AA02 bus voltage.

Comment:

NOTE

The following step adjusts DG frequency slightly higher than bus frequency to ensure the DG will start loading when the breaker is closed.

4.2.1.13 **WHILE** observing the Sync Scope, **adjust** the DG speed until the Sync Scope needle is rotating slowly in the clockwise (Fast) direction. (Greater than 10 seconds per revolution.)

Standard: Sync Scope needle is rotating in the clockwise (Fast) direction with at least a 10 second period.

Comment:

CAUTION

As soon as the DG Output breaker closes, kVAR must be controlled in the acceptable range specified in Figure 1, "Emergency Diesel Generator Operating Limits."


***4.2.1.14 WHEN Sync Scope needle reaches the 11 o'clock position, depress and hold the DG 1A AUTO SYNC PERMISSIVE pushbutton PB-DG1A.**

NOTE: Concurrent Verification should be requested for this step.

Standard: PB-DG1A depressed when synch scope needle is at 11 o'clock.

Comment:

GENERATOR 8750 KVA, 4160V
 1214.4A 60 HZ 0.8 PF
 FREQUENCY 60HZ
 MODEL NO. 72 12500 100



EMERGENCY DIESEL GENERATOR
 OPERATING LIMITS

4.2.1.15 **Check** DG1A OUTPUT BRKR 1AA02-19 closes WHEN Sync Scope needle reaches 12 o'clock position.

AND

a. IF Sync Scope needle passes the 12 o'clock position, **release** Auto Sync Permissive pushbutton.

Standard: 1AA02-19: Red light – ON
 Green light – OFF
 Amber light - OFF

Comment:

4.2.1.16 **Check** that DG loads to at least 700kW.

Standard: DG-1A load @ 700 KW

Comment:

4.2.1.17 **Adjust** DG voltage to obtain kVAR loading between 200 and 300 kVAR positive (Out).

- a. IF kVAR loading goes negative (In) and NO adjustment can be made With the voltage control to restore kVAR load positive (Out), trip DG Breaker 1AA0219.

Standard: Candidate adjusts kVAR loading to between 200 and 300kVAR positive.

Comment:

4.2.1.18 **Place** BRKR 1AA0219 SYNCHRONIZING SWITCH to OFF.

Standard: 1AA0219 SYNCHRONIZING SWITCH - OFF.

Comment:

Step 4.2.1.19 Record DG data required in 11885A-1 "DG 1A Operating Log."

Cue: "An extra operator will record the data in the DG 1A Operating Log."

Standard: N/A

Comment:

Notes and Caution prior to Step 4.2.1.20

NOTES

As DG load is adjusted in the following step, DG voltage should be adjusted concurrently to maintain kVAR loading positive (Out) and no more than half the kW load. Figure 1, "Emergency DG Operating Limits," identifies the Vogtle administrative limits.

The DG should be loaded in increments of approximately 1000kW and 500kVAR in time increments of approximately 5 minutes between load changes.

DSL GEN 1A LOADING SET PT CONTROL 1SE 4915 has a range of 10% [1.00] to 110% [11.00] D/G LOAD which corresponds to 700kW 7700kW.

It is highly desirable to initially load the DG to 3000kW and maintain this load until cylinder exhaust temperatures stabilize or 15 minutes, whichever comes first, prior to further load increases.

With the DG paralleled to the SAT, DG voltage will tend to run high. The maximum voltage is 4326V AC. kVAR loading is expected to be at the lower end of the operating limits to maintain voltage below maximum.

Standard: Candidate reads notes and cautions.

Comment:

***4.2.1.20 Load the DG as follows:**

- a. Adjust DG load to 2100 to 7000kW by gradually increasing the pot setting on DSL GEN 1A LOADING SET PT CONTROL 1SE-4916.
- b. Concurrently adjust DG voltage to maintain kVAR loading between 1000 and 3000kVAR (out), NOT to exceed half of the kW load.

Standard: Candidate adjust DG load and voltage to approx 1700kw and approx 850 kVARs (OUT).

CUE: After the candidate has adjusted load and voltage the first time, “5 minutes has elapsed.”

Comment:

4.2.1.20 second load step Load the DG to approx 2700 Kw

NOTE to Sim operator:

The following sequence must be done promptly or DG will trip:

When student raises DG load the second time,

Insert Trigger 1 to disable lights and raise voltage

Then Insert Trigger 2 to lower VARS to -500 to -1000 kVARs

Unset Trigger 2 and set value to FALSE to hold kVARs at value

-
- 4.2.1.17.a IF kVAR loading goes negative (In) AND NO adjustment can be made with the voltage control control to restore restore kVAR load positive (Out), trip DG Breaker 1AA0219.

Standard: Student recognizes that kVAR will or has gone negative and cannot be controlled and trips breaker 1AA0219.

Comment:

Terminating cue: Student returns initiating cue sheet

Verification of Completion

Job Performance Measure No. V-NRC-JP-13427-002

Examinee's Name:

Examiner's Name:

Date Performed:

Number of Attempts:

Time to Complete:

Question Documentation:

Question: _____

Response: _____

Result: Satisfactory/Unsatisfactory

Examiner's signature and date: _____

Initial Conditions: Following a 7 day D/G 1A outage, Maintenance and Engineering Support are standing by for a D/G 1A test run. D/G 1A was just started, and is now operating unloaded with the D/G output breaker open. You are relieving the UO, and will be performing the remainder of this test run. The outside area SO is stationed at the D/G to support the evolution.

Initiating Cue: The applicable portions of SOP 13145-1 have been completed for starting DG-1A. In accordance with procedure SOP 13427A-1, parallel D/G 1A to 1AA01 and raise DG-1A load to 7000 kw per Section 4.2.1, starting with step 4.2.1.3.

Job Performance Measure "G"

Facility: **Vogtle**

Task No: V-LO-TA-17007

Task Title: Perform NIS Power Range COT

JPM No: V-NRC-JP-14425-001

K/A Reference: 015A3.03 (3.9 / 3.9)

Examinee: _____

NRC Examiner: _____

Facility Evaluator: _____

Date: _____

Method of testing:

Simulated Performance _____

Actual Performance _____

Classroom _____

Simulator _____

Plant _____

Read to the examinee:

I will explain the initial conditions, which steps to simulate or discuss, and provide initiating cues. When you complete the task successfully, the objective for this job performance measure will be satisfied.

Initial Conditions: Unit 1 is currently at 100% power.

Task Standard: NIS Power Range COT completed for N43.

Required Materials: 1. Procedure 14425C-1 Power Range Quarterly Analog Channel NI 43 Operational Test

General References: None

Initiating Cue: The SS has directed you to "Perform the Power Range Quarterly Analog Channel Operability Test for N43, using procedure 14425C-1.

Time Critical Task: No

Validation Time: 15 minutes

SIMULATOR SETUP:

Simulator Setup:

1. **Reset to IC # 235 for HL-16 NRC Exam.**

Simulator Setup from Scratch:

1. Reset to IC # 14 (100% MOL).
2. open Monitor and insert **yremfadd2(62)**
(Type in and enter -should appear on line 1)
3. Type in 1=4.00 and enter. Line 1 should show **yremfadd2(62) =4.0000**
(this sets N43 Hi flux trip setpoint to 113%)
4. Insert following remote functions on Trigger 1.

BT04C NC43P PR High Flux Rx Trip Low Stpt Bypass to **BYPASS**

BT05C NC43R PR High Flux +ve Rate Rx Trip Bypass to **BYPASS**

BT06C NC43U PR High Flux Rx Trip Low Stpt Bypass to **BYPASS**

BT10C NC43M PR P-10 Permissive Bypass to **BYPASS**

BT08C NC43P PR P-8 Permissive Bypass to **BYPASS**

BT09C NC43P PR P-9 Permissive Bypass to **BYPASS**

BT12C TB431C Loop 3 Over Temp Delta T Rx Trip Bypass- to **BYPASS**

BT14C TB431D Loop 3 Over Temp Delta T Turb Runback Bypass- to **BYPASS**
5. Ack/Reset alarms.
6. Freeze simulator

Setup time from scratch: 10 minutes

Performance Information

Critical steps denoted with an asterisk

Section 5.0 NOTE: If any reactor trip bistable or Alert annunciator energizes during this procedure, performance should be stopped and the Shift Supervisor notified immediately.

Standard: Note read.

Comments:

Step 5.1.1 Obtain SS approval to perform test.

NOTE to examiner: This will be filled in prior to handing the procedure to the Candidate.

Standard: SS Initials noted by candidate.

Comments:

Step 5.1.2 Student verifies no testing in progress in 7300 Process cabinets.

CUE: "There is no testing currently in progress in the 7300 Process cabinets."

Standard: Step initialed.

Comment:

Step 5.1.3 Student verifies NI 43 has been energized for at least one hour.

CUE: "NI 43 has been energized for greater than one hour."

Standard: Step initialed.

Comment:

Step 5.1.4 Obtain BTI enable keys from SS for NIS and NSSS BTI panels.

CUE: "The extra RO will obtain the BTI keys and perform the required actions."

Standard: Step initialed after CUE.

Comment:

***Step 5.1.5 Place Control Rods in MANUAL.**

Standard: Student places Rod Bank Selector Switch to Manual:

NOTE to examiner: This step requires Concurrent Verification.

Comment:

Step 5.1.6 Record Test Start Date

Standard: Student records current Date current Time 1 or one.
 DATE TIME MODE

Comment:

***Step 5.1.7 Defeat Channel N-43 by performing the following:**

NOTE to examiner: All parts of the following step require Concurrent Verification.

- a. At the COMPARATOR RATE Drawer, position the COMPARATOR CHANNEL DEFEAT Switch to N43.
- b. At the DETECTOR CURRENT COMPARTOR/MISCELLANEOUS CONTROL AND INDICATION PANEL, position the following switches as follows:

UPPER SECTION Switch to PRN43.

LOWER SECTION Switch to PRN43.

ROD STOP BYPASS to BYPASS PRN43.

POWER MISMATCH BYPASS Switch to BYPASS PRN43.

Standard: Switches positioned as listed above.

Comments:

Step 5.1.8 Verify PR OVERPWR ROD STOP MAN BYPASS I/N49A CH.III Status Light (BPLB 3.4) is lit.

Standard: PR OVERPWR ROD STOP MAN BYPASS I/N49A CH.III Light – LIT.

Comments:

Before step 5.1.9 CAUTION: Bypassing more than one NIS Channel will require entry into the Action Statement of Technical Specification 3.0.3.

Standard: Candidate reads caution.

Comments:

Step 5.1.9a Bypass NIS Channel 43 by performing the following at CHANNEL #3 NIS BTI TEST PANEL in Cabinet 13CQNIR:

CUE: “The extra RO and SS will perform steps 5.1.9 through 5.1.12”

Sim operator - Insert Trigger 1 and acknowledge alarms.

CUE: “Steps 5.1.9 through 5.1.12 complete consider those steps initialed in your procedure”

***Step 5.1.13** At N-43 POWER RANGE B Drawer, place the OPERATION SELECTOR Switch in the DET A&B position and verify 1-N-43 CHANNEL ON TEST Drawer Light is lit.

Standard: 1N-43 POWER RANGE B Drawer OPERATION SELECTOR Switch placed in DET A&B position.

Verify 1-N-43 CHANNEL ON TEST Drawer Light – LIT.

Comments:

Step 5.1.14 Verify ALB10-C06 NIS CHANNEL ON TEST is illuminated.

Standard: Verify ALB10-C06 CHANNEL ON TEST – LIT.

Comments:

NOTE: Rotating the potentiometers will generate a mismatch between the Power Range channels, which may cause a Radial Tilt alarm.

Standard: NOTE read.

CUE: "The OATC is notified to expect Radial Tilt alarm"

Comments:

Step 5.1.15 On N-43, rotate DETECTOR A and DETECTOR B TEST SIGNAL potentiometers fully counter-clockwise.

NOTE to examiner: Pots are normally left in this position.

Standard: DETECTOR A TEST SIGNAL potentiometer – Verified FULLY counter-clockwise.

DETECTOR B TEST SIGNAL potentiometer – Verified FULLY counter-clockwise.

Comments:

Step 5.1.16 At N-43 POWER RANGE A Drawer, record PERCENT FULL POWER Meter reading.

Standard: Record 100% (99 to 101% acceptable).

Comments:

NOTES: If the DETECTOR A TEST SIGNAL Potentiometer is rotated fully clockwise before reaching the OVERPOWER ROD STOP (Step 5.1.17) or OVERPOWER TRIP HIGH RANGE (Step 5.1.19) setpoint, it will be necessary to rotate the DETECTOR B TEST SIGNAL Potentiometer.

If NI 43 OVERPOWER TRIP HIGH RANGE setpoint has been previously reduced to either 90% or 50% Power (i.e., after a plant shutdown or start-up,) then Steps 5.1.19 and 5.1.20 should be performed prior to Steps 5.1.17 and 5.1.18.

Following are the anticipated values for the OVERPOWER ROD STOP bistable trip:

EXPECTED VALUE:	105%
UPPER LIMIT:	106%
LOWER LIMIT:	104%

Standard: Notes read.

Comments:

***Step 5.1.17 Trip the OVERPOWER ROD STOP bistable as follows:**

- a. **Slowly rotate DETECTOR A UNTIL the OVERPOWER ROD STOP Drawer Light just illuminates OR UNTIL fully clockwise.**
- b. IF DETECTOR A is fully clockwise AND OVERPOWER ROD STOP light is NOT lit, slowly rotate DETECTOR B clockwise UNTIL the OVERPOWER ROD STOP Drawer light just illuminates.
- c. **Record “As Found” trip setpoint on 1-N-43 PERCENT FULL POWER Meter.**

NOTE to examiner: The applicable parts of the step are in **BOLD**.

Standard: Pot rotated until OVERPOWER ROD STOP Drawer light just illuminates at 105%.

Record 105% (104-106% acceptable).

Comments:

***Step 5.1.18** Verify that trip-point value recorded in Step 5.1.17c is between 104% and 106%.

Standard: Candidate initials step.

Comments:

***Step 5.1.19** Trip the OVERPOWER TRIP HIGH RANGE bistable as follows:

- a. IF DETECTOR A was NOT fully clockwise in Step 5.1.17, slowly rotate DETECTOR A clockwise UNTIL the OVERPOWER TRIP HIGH RANGE Drawer Light just illuminates OR fully clockwise.
- b. IF DETECTOR A is fully clockwise AND OVERPOWER TRIP light is NOT lit, slowly rotate DETECTOR B clockwise UNTIL the OVERPOWER TRIP HIGH RANGE Drawer Light just illuminates.
- c. Record the “As Found” trip setpoint on 1-N-43 PERCENT FULL POWER Meter.

NOTE to examiner: The applicable parts of the step are in **BOLD**.

Standard: Pot rotated until OVERPOWER ROD STOP Drawer light just illuminates at 113%.

Record 113% (112-114% acceptable).

Comments:

***Step 5.1.20** Verify that the value recorded in Step 5.1.19.c is within applicable limits by performing the following: (ACCEPTANCE CRITERIA)

- a. **IF the last calorimetric was performed when power was greater than 50%, verify trip-point value recorded in Step 5.1.19.c is between 108% and 109%.**
- b. IF the last calorimetric was performed between 20% and 50% power, verify trip-point value recorded in Step 5.1.19.c is between 89% and 91.9%.
- c. IF the last calorimetric was performed at less than 20% power, verify trip-point value recorded in Step 5.1.19.c is between 49% and 51.1%.

Standard: Candidate compares to a. and **DOES NOT** initial step as criteria is not met.

NOTE to examiner: The applicable parts of the step are in **BOLD**. The candidate may attempt to inform SS of unacceptable result.

CUE: If candidate attempts to inform SS of result, “SS acknowledges your report, continue the ACOT to check all setpoints.”

Comments:

NOTE: If NI 43 OVERPOWER TRIP HIGH RANGE Trip setpoint has been previously reduced to either 90% or 50% Power, Steps 5.1.23 and 5.1.24 should be performed prior to Steps 5.1.21 and 5.1.22.

Standard: Note read but not applicable.

Comments:

***Step 5.1.21 Reset OVERPOWER TRIP HIGH RANGE bistable as follows:**

- a. IF DETECTOR B was rotated in Step 5.1.19, slowly rotate DETECTOR B counter-clockwise UNTIL the OVERPOWER TRIP HIGH RANGE light just resets OR fully counter-clockwise.
- b. **IF DETECTOR B is fully counter-clockwise AND OVERPOWER TRIP light is NOT reset, slowly rotate DETECTOR A counter-clockwise UNTIL the OVERPOWER TRIP HIGH RANGE Drawer Light just resets.**
- c. Record “As Found” reset setpoint on 1-N-43 PERCENT FULL POWER Meter.

Standard: Pot rotated until OVERPOWER ROD STOP Drawer resets at 108%.

Record 108% (112-114% acceptable).

Comments:

NOTE: The following are the anticipated values for the OVERPOWER TRIP HIGH RANGE bistable reset:

<u>POWER LEVEL</u>	<u>NOMINAL VALUE</u>	<u>UPPER LIMIT</u>	<u>LOWER LIMIT</u>
50% or greater	107%	108%	106%
Less than 50%	88%	89%	87%
Less than 20%	48%	49%	47%

NOTE to examiner: The applicable parts of the step are in BOLD.

Standard: Note read.

Comments:

Step 5.1.22 Verify that the value recorded in Step 5.1.21.c is within the anticipated values by performing the following:

- a. **IF the last calorimetric was performed when power was greater than 50%, verify reset-point recorded in Step 5.1.21.c is between 106% and 108%**
- b. IF the last calorimetric was performed between 20% and 50% power, **verify** trip-point value recorded in Step 5.1.21.c is between 87% and 89%.
- c. IF the last calorimetric was performed below 20% power, **verify** trip-point value recorded in Step 5.1.21.c is between 47% and 49%.

NOTE to examiner: The applicable parts of the step are in **BOLD**.

Standard: Step a. initialed.

Comments:

Step 5.1.23 **Reset** the OVERPOWER ROD STOP bistable as follows:

- a. IF DETECTOR B is NOT fully counter-clockwise, slowly **rotate** DETECTOR B UNTIL the OVERPOWER ROD STOP Drawer Light just resets OR UNTIL fully counter-clockwise.
- b. IF DETECTOR B is fully counter-clockwise AND ROD STOP light is NOT reset, slowly rotate DETECTOR A counter-clockwise UNTIL the OVERPOWER ROD STOP Drawer Light just resets.
- c. Record the "As Found" reset setpoint on 1N-43 PERCENT FULL POWER Meter.

Standard: Pot rotated until OVERPOWER ROD STOP Drawer light just resets at 103%
Record 103% (102-104% acceptable)

Comments:

Step 5.1.24 **Verify** that reset-point value recorded in Step 5.1.23.c is between 102% and 104%.

Standard: Step 5.1.23.c initialed.

Comments:

Step 5.1.25 **Verify** DETECTOR A and DETECTOR B TEST SIGNAL potentiometers are fully counter-clockwise and 1-N-43 PERCENT FULL POWER Meter indicates actual reactor power level recorded in Step 5.1.16.

Standard: DETECTOR A potentiometer – FULLY counter-clockwise
DETECTOR B potentiometer – FULLY counter-clockwise

Comments:

Step 5.1.26 **Adjust** DETECTOR A TEST SIGNAL Potentiometer such that the PERCENT FULL POWER Meter indicates 5% to 5-1/2% greater than actual reactor power level.

Standard: Potentiometer adjusted N-43 POWER RANGE A Drawer PERCENT FULL POWER Meter reading indicate 105-105.5 %.

Comments:

Step 5.1.27 **Turn** the RATE MODE Switch momentarily to RESET and **verify** POSITIVE RATE TRIP Drawer Light is NOT lit.

Standard: Rate Mode Switch momentarily reset.

POSITIVE RATE TRIP Drawer Light – NOT LIT.

Comments:

Step 5.1.28 **Wait** at least 30 seconds, THEN **rotate** OPERATION SELECTOR Switch to the DET B position.

Standard: Wait ≥ 30 secs, THEN, OPERATION SELECTOR Switch placed to the DET B position.

Comments:

Step 5.1.29 **Wait** at least 30 seconds, THEN **rotate** OPERATION SELECTOR Switch to the DET A&B position and **verify** the POSITIVE RATE TRIP Drawer Light lights. (ACCEPTANCE CRITERIA)

Standard: Wait ≥ 30 secs, THEN OPERATION SELECTOR SWITCH – DET A&B POSITIVE RATE TRIP DRAWER Light – LIT.

Comments:

Step 5.1.30 **Turn** the RATE MODE Switch momentarily to RESET and **verify** POSITIVE RATE TRIP Drawer Light is NOT lit.

Standard: RATE MODE SWITCH momentarily RESET.
POSITIVE RATE TRIP Drawer Light – NOT LIT.

Comments:

NOTE: IVs for steps 5.1.31, 5.1.34, 5.1.35, 5.1.38, 5.1.40, and 5.1.44 may be completed after these steps have been performed.

Standard: NOTE read.

Comments:

Step 5.1.31 Notify SS that Channel Restoration is about to begin and perform the following:

Standard: SS is notified that restoration is about to begin.

CUE: If candidate did not report the out of specification reading, “Were all acceptance criteria met?”

NOTE to examiner: High Flux setpoint is the only parameter that does not meet acceptance criteria.

CUE: “The SS directs you not to restore the channel to service to allow I&C to investigate”

Terminating cue: Student returns initiating cue sheet

Verification of Completion

Job Performance Measure No. V-RQ-JP-18038-014

Examinee's Name:

Examiner's Name:

Date Performed:

Number of Attempts:

Time to Complete:

Question Documentation:

Question: _____

Response: _____

Result: Satisfactory/Unsatisfactory

Examiner's signature and date: _____

Initial Conditions: Unit 1 is at 100% power

Initiating Cue: The USS has directed you to "Perform the Power Range Quarterly Analog Channel Operability Test for N43, using procedure 14425C-1.

Job Performance Measure "H"

Facility: **Vogtle**

Task No: V-LO-TA-29006

Task Title: Place Containment Main Purge in Service

JPM No: V-NRC-JP-13125-002

K/A Reference: 029A2.03

Examinee: _____

NRC Examiner: _____

Facility Evaluator: _____

Date: _____

Method of testing:

Simulated Performance _____

Actual Performance _____

Classroom _____

Simulator _____

Plant _____

Read to the examinee:

I will explain the initial conditions, which steps to simulate or discuss, and provide initiating cues. When you complete the task successfully, the objective for this job performance measure will be satisfied.

Initial Conditions: **The Plant is in Mode 5 with the Containment Equipment Hatch Open.**

Task Standard: Student shuts down the mini-purge exhaust system and then starts the main purge exhaust system per 13125-1.

Required Materials: 13125-1, Containment Main Purge System

General References: None

Initiating Cue: **The SS has authorized Gaseous Release Permits and has directed you to "Place Containment Main (Preaccess) Purge in service" using procedure 13125-1.**

"Checklist 1 for Main Purge isolation dampers and valves has been performed".

NOTE: **For time considerations, the students may be allowed to "pre-brief" this JPM and allowed to review 13125-1 prior to starting the JPM.**

Time Critical Task: No

Validation Time: 20 minutes

SIMULATOR SETUP:

Snapped IC is QQ??. If new setup is required, then perform the following:

1. Reset to mode 5 mid loop IC
2. Place Mini-Purge supply fan in service per 13125 and ensure Containment Pressure is atmospheric.
3. Verify Power to the Containment Main Purge dampers is on
4. Acknowledge / Reset alarms
5. Freeze simulator

Setup time: 10 minutes

Performance Information

Critical steps denoted with an asterisk

Student refers to SOP 13125-1 and determines section 4.1.2 should be performed.

Standard: Section 4.1.2 used

Comment:

Student reviews precautions and limitations of 13125-1

Student reviews notes and cautions at the beginning of section 4.1.2

CUE: IF asked, the conditions stated in the note or caution have been met.

Standard: N/A

Comment:

4.1.2.1 IF the unit is in MODE 5, 6 OR defueled, AND the Containment Equipment Hatch is open, operate the Containment Main Purge System with the Exhaust Fan on, and Supply Fan off to verify airflow is maintained into the building.

Standard: Student determines this step IS applicable from initial conditions.

Comment:

4.1.2.2 **Perform** Checklist 1 as required, to restore power to the Main Purge Isolation dampers and fans.

Standard: Determines checklist 1 has been completed from initial conditions.

Comment:

Reviews NOTE concerning interlocks between main and mini-purge fans.

4.1.2.3 IF the Mini-Purge System is operating, **perform** the following:

- a. **Notify** Chemistry that containment purge will be shifted from the Mini-Purge to the Main Purge System, ~~and the Current Gaseous Release Permit will be terminated,~~

CUE: Chemistry has been notified that containment purge will be shifted from mini to main purge.

~~b. **Request** a new Release Permit to operate on the main purge System,~~

~~c. **Record** the name of the person contacted in the Unit Control Log,~~

~~db.~~ **Go To** Section 4.3.2 and **shut down** the Mini-Purge System.

Standard: Determines that section 4.3.2 needs to be performed

Comment:

SECTION 4.3.2

Reviews note at beginning of section 4.3.2

4.3.2.1 **Terminate** Mini-Purge Supply flow as follows:

- a. **Stop** the CTB MINI-PURGE SPLY FAN using 1-HS-2630B. (B32)
- b. **Close** CTB NORM PURGE SPLY ORC ISO VLV-MINI 1-HV-2627B using 1-HS -2627B (D32).
- c. **Close** CTB NORM PURGE SPLY IRC ISO VLV-MINI 1-HV-2626B using 1-HS -2626B (C32).

Standard: Determines that these steps are N/A from initial conditions given and control board indications.

Comment:

***4.3.2.2 Terminate Mini-Purge Exhaust flow as follows:**

a. Stop the CTB MINI-PURGE EXH FAN using 1-HS-2631B. (D34)

**Standard: 1HS-2631B hand switch rotated counter clockwise.
Red light –OFF
Green light -ON**

Comment:

***4.3.2.2b. Close CTB MINI PURGE EXH ORC ISO VLV-MINI 1-HV-2629B using 1-HS
-2629B (B34).**

**Standard: 1HS-2629B hand switch rotated counter clockwise.
Red light –OFF
Green light -ON**

Comment:

***4.3.2.2c. Close CTB NORM PURGE EXH IRC ISO VLV-MINI 1-HV-2628B using 1-HS
-2628B (A34).**

**Standard: 1HS-2628B hand switch rotated counter clockwise.
Red light –OFF
Green light -ON**

Comment:

***4.3.2.2d. Place CTB MINI-PURGE EXH DMPR 1-HV-12592 in CLOSE using 1-HS
-12592 (C34).**

**Standard: 1HS-12592 hand switch rotated counter clockwise.
Red light –OFF
Green light -ON**

Comment:

4.3.2.2e. **Log** the Containment Mini-Purge Termination TIME and DATE on the Release Permit on the same line where flow is recorded.

CUE: **Containment Mini-Purge Termination TIME and DATE have been entered on the Release Permit**

Standard: N/A

Comment:

***4.3.2.3 Close CTB PREACCESS PURGE SPLY UNIT INLET DMPR, 1-HV-2593 using 1-HS -2593 (A31).**

Standard: **Hand switch 1-HS-2593 rotated counter clockwise.
Green light – ON
Red light – OFF**

Comment:

4.3.2.4 **Notify** Chemistry that Containment Mini-Purge has been terminated, and the Containment Gaseous Release Permit has been closed.

CUE: **Chemistry has been notified that containment mini-purge has been terminated and the containment gaseous release permit has been closed.**

Standard: N/A

Comment:

4.3.2.5 **Record** the name of the person contacted in the Unit Control Log.

CUE: **Name of person contacted has been recorded in the unit control log.**

Standard: N/A

Comment:

4.3.2.6 **Restore** the Mini-Purge System per Checklist 3:

<u>COMPONENT</u>	<u>DESCRIPTION</u>	<u>POSITION</u>
1-HS-2593 (A31)	CTB PREACCESS PURGE SPLY UNIT INLET DMPR	CLOSED
1-HS-2628B (A34)	CTB NORM PURGE EXH IRC ISO VLV-MINI	CLOSED/AUTO
1-HS-2629B (B34)	CTB NORM PURGE EXH ORC ISO VLV-MINI	CLOSED/AUTO
1-HS-2626B (C32)	CTB NORM PURGE SPLY IRC ISO VLV-MINI	CLOSED/AUTO
1-HS-2627B (D32)	CTB NORM PURGE SPLY ORC ISO VLV-MINI	CLOSED/AUTO
CUE:	If asked, “the extra operator will perform the independent verification of checklist 3”.	

Standard: Each damper verified closed by Green light – ON and Red light OFF.
Student requests an independent verification for these steps.

Comment:

4.3.2.7 IF the Main Purge System is being placed in service, **Return To** Step 4.1.2.4.

Standard: Determines that this step is applicable and returns to step 4.1.2.4

Comment:

Reviews note prior to next step

4.1.2.4 IF the Mini-Purge System is NOT operating, **perform** the following:

a. **Notify** Chemistry of the upcoming Main Purge operation:

Obtain the current approved Containment Gaseous Release Permit.

IF an updated permit is unavailable, **request** that Chemistry sample the containment atmosphere and prepare for the gaseous release.

b. WHEN a current approved Containment Gaseous Release Permit is obtained, **continue** with this section.

Standard: Determines release permit obtained from initial conditions given and proceeds.

Comment:

4.1.2.5 **Verify** all conditions that must be satisfied prior to the release are met.

Standard: Determines all conditions satisfied:

 Release permit obtained

Comment:

4.1.2.6 Place CTB PREACCESS PURGE EXH DMPR 1-HS-2632A (C33) in AUTO.

Standard: 1-HS-2632A verified in the AUTO position

Comment:

Reviews CAUTION prior to step 4.1.2.7 for Rad Monitor Operability and Release Permit

4.1.2.7 To ensure accurate sampling by 1RE-2565, PRIOR to placing CTB Main Purge in service, **verify** the following sampling flow valves are in the required positions:

- a. 1-1609-u4-052 CLOSED
- b. 1-1609-U4-054 OPEN

CUE: Chemistry has verified 1-1609-U4-052 is closed and 1-1609-U4-054 is open.

Standard: N/A

Comment:

Reviews cautions prior to next step

| **4.1.2.88** Initiate Main Purge Exhaust flow as follows:

- *a. Open CTB PREACCESS PURGE SPLY UNIT INLET DMPR 1-HV-2593 using 1-HS -2593 (A31).

Standard: 1-HS-2593 rotated clockwise
Red light – ON
Green light - OFF

Comment:

| ***4.1.2.88b** Open CTB NORM PURGE EXH ORC ISO VLV-MAIN 1-HV-2629A using 1-HS -2629A (B33),

Standard: 1-HS-2629A rotated clockwise
Red light – ON
Green light - OFF

Comment:

| *4.1.2.88c. **Open CTB NORM PURGE EXH IRC ISO VLV-MAIN 1-HV-2628A using 1-HS-2628A (A33),**

Standard: 1-HS-2628A rotated clockwise
 Red light – ON
 Green light - OFF

Comment:

| *4.1.2.88d. **Start the CTB PREACCESS PURGE EXH FAN using 1-HS-2631A (D33),**

Standard: 1-HS-2631A rotated clockwise
 Red light – ON
 Green light - OFF

Comment:

| 4.1.2.88e. **Log** the Release Start Time and Date on the Chemistry data sheet provided.

CUE: **Release start time and date has been logged on the Chemistry data sheet.**

Standard: N/A

Comment:

Reviews note prior to next step

4.1.2.8 f. **Note** the Main Purge Exhaust Flow rate, and **verify** it is within allowable value as stated on Release Permit,

CUE: **Main Purge Exhaust flow rate is within its allowable value on the release permit.**

Standard: N/A

Comment:

4.1.2.8 g. IF both Radiation Monitors 1-RE-12442C and 1-RE-12444C, become inoperable, immediately **shut down** the Main Purge System per section 4.3.1 and **notify** the SS.

Standard: N/A

Comment:

Reviews caution prior to next step

4.1.2.9 Initiate Main Purge Supply flow if desired as follows:

- a. Open CTB NORM PURGE SPLY ORC ISO VLV-MAIN 1-HV-2627A using 1-HS -2627A (D31).
- b. Open CTB NORM PURGE SPLY IRC ISO VLV-MAIN 1-HV-2626A using 1-HS -2626A (C31).
- c. Start the CTB PREACCESS PURGE SPLY FAN using 1-HS-2630A (B31).

4.1.2.10 Note the Main Purge Exhaust Flow rate with Supply and Exhaust Fans in service, and verify it is within allowable value as stated on Release Permit.

4.1.2.11 Log flow rate on Chemistry data sheet provided.

CUE: If asked, “Flow rate is logged on the Chemistry data sheet”.

Standard: These steps are determined to be N/A from initial conditions given. **If step 4.1.2.9 is performed, then it becomes critical and is unsatisfactory.**

Comment:

4.1.2.12 Notify Chemistry that the Main Containment Purge System is operating, and record the name of the person contacted in the Unit Control Log.

CUE: **Chemistry has been notified that the Main Containment Purge System is operating, and the name of the person contacted has been recorded in the Unit Control Log.**

Standard: N/A

Comment:

Student notifies SS that the main purge system has been placed in service per 13125-1.

Standard: N/A

Comment:

Terminating cue: Student returns initiating cue sheet

Verification of Completion

Job Performance Measure No. V-LO-JP-13125-002

Examinee's Name:

Examiner's Name:

Date Performed:

Number of Attempts:

Time to Complete:

Question Documentation:

Question: _____

Response: _____

Result: Satisfactory/Unsatisfactory

Examiner's signature and date: _____

Initial Conditions: **The Plant is in Mode 5 with the Containment Equipment Hatch Open.**

Initiating Cue: **The SS has authorized Gaseous Release Permits and has directed you to "Place Containment Main (Preaccess) Purge in service" using procedure 13125-1.**

"Checklist 1 for Main Purge isolation dampers and valves has been performed".

Job Performance Measure "I"

Facility: **Vogtle**

Task No: V-LO-TA-60025

Task Title: **Establish RWST Gravity Drain Through RHR Pumps to RCS Hot Legs**

JPM No: V-NRC-JP-18019-003

K/A Reference: 025G2.1.20

Examinee: _____

NRC Examiner: _____

Facility Evaluator: _____

Date: _____

Method of testing:

Simulated Performance _____

Actual Performance _____

Classroom _____

Simulator _____

Plant _____

Read to the examinee:

I will explain the initial conditions, which steps to simulate or discuss, and provide initiating cues. When you complete the task successfully, the objective for this job performance measure will be satisfied.

Initial Conditions: During mid-loop operations, Unit 2 experienced a loss of all AC power to the 1E buses. The crew is attempting to align the RWST for gravity drain to the RCS.

Task Standard: RWST Gravity Drain aligned through RHR.

Required Materials: 1) AOP 18019-C Ver. 26.2
2) RWP and required dosimetry.

General References: None

Initiating Cue: The SS has directed you to "perform AOP 18019-C Attachment A, 'Loss of RHR –RWST Gravity Drain to RCS; to align Train A for gravity drain.'"

Time Critical Task: No

Validation Time: 12 minutes

Performance Information

Critical steps denoted with an asterisk

ATTACHMENT A: RWST GRAVITY DRAIN TO RCS

NOTE: This attachment should not be used if an ECCS pump is available.

Standard: Determines ECCS pump not available due to loss of all AC power to 1E busses.

Comment:

ATTACHMENT A: RWST GRAVITY DRAIN TO RCS

CAUTION: An RCS pressure of 35 psig allows no RWST to RCS gravity drain.

Step 1: Check RCS pressure – LESS THAN 35 psig.

CUE: If asked: The SS reports “RCS pressure is 0 psig.”

Standard: Determines RCS pressure < 35psig.

Comment:

Step 2: Verify at least one of the following RCS Vent Paths:

- a. RV head removed
- b..... other conditions that are NOT applicable

Standard: Determines RV head off from initial conditions

Comment:

NOTE:

- It is desirable to gravity drain to a closed cold leg using Section A or B.
- If a closed cold leg is unavailable, then go to Section C or D for gravity drain to a hot leg.
- Gravity drain paths through the RHR loops are preferable since these can achieve the greatest flow rate.

Standard: Student reads note.

Comment:

3. If desired to gravity drain from RWST through RHR pumps to cold legs, then go to Section A of this attachment.

CUE: “Flow paths using the cold leg are UNAVAILABLE.”

Standard: Student determines Section A should not be used due to flow path to cold leg not available.

Comment:

4. If desired to gravity drain from RWST through SI pumps to cold legs, then go to Section B of this attachment.

Standard: Determines Section B should not be used due to a closed cold leg being unavailable from cue in previous step.

Comment:

5. IF desired to gravity drain from RWST through RHR pumps to hot legs, THEN Go to Section C of this attachment.

Standard: Determines Section C should be used.

Comment:

ATTACHMENT A SECTION C: RWST GRAVITY DRAIN THROUGH
RHR PUMPS TO HOT LEGS

***C1.** Locally throttle open the following RWST TO RHR PMP-A(B) SUCTION VALVES.

2-HV-8812A (AB-D22)

Locates valves and determines current position is closed based on valve position indicator

CUE: IF ASKED:

If valve is closed: “Valve is positioned as you see it”

If valve is open: provide visual cue that valve position pointer is aligned with closed indicator

As valve is throttled: provide visual cue that valve position is changing.

NOTE to examiner: If this valve is inaccessible, the path of ingress should be to the closest point allowed by radiological conditions.

Standard: Throttles open 2-HV-8812A (AB-D22).

Comment:

***C2** Locally close the following RHR PMP-A(B) TO COLD LEG ISO VLV valves:

- 2-HV-8809A (AB-A103)

Locates valves and determines current position is open based on valve position indicator

CUE: IF ASKED:

If valve is open: “Valve is positioned as you see it”

If valve is closed: provide visual cue that valve position pointer is aligned with closed indicator

As valve is throttled: provide visual cue that valve position is changing.

NOTE to examiner: If this valve is inaccessible, the path of ingress should be to the closest point allowed by radiological conditions.

Standard: Determines valve position then closes valve 2-HV-8809A (AB-A103).

Comment:

C3. Verify RHR PMP-A SUCTION FROM HOT LEG LOOP isolation valves open:

CUE: “The RHR Suction from hot leg loop isolation valves have been verified open.”

Standard: None.

Comment:

Reports to the SS that the SI system has been aligned gravity drain the RWST through the RHR pumps to the hot legs per ATTACHMENT A section C of AOP 18019-C.

Standard: N/A

Comment:

Terminating cue: Student returns initiating cue sheet

Verification of Completion

Job Performance Measure No. V-RNC-JP-18019-003

Examinee's Name:

Examiner's Name:

Date Performed:

Number of Attempts:

Time to Complete:

Question Documentation:

Question: _____

Response: _____

Result: Satisfactory/Unsatisfactory

Examiner's signature and date: _____

Initial Conditions: During mid-loop operations, Unit 2 experienced a loss of all AC power to the 1E buses. The crew is attempting to align the RWST for gravity drain to the RCS.

Initiating Cue: The SS has directed you to “perform AOP 18019-C Attachment A, ‘Loss of RHR –RWST Gravity Drain to RCS; to align Train A for gravity drain.’”

Job Performance Measure "J"

Facility: **Vogtle**

Task No: V-LO-TA-37005

Task Title: Response To Inability To Reset Or Block SI

JPM No: V-NRC-JP-19011-003

K/A Reference: 013A4.02

Examinee: _____

NRC Examiner: _____

Facility Evaluator: _____

Date: _____

Method of testing:

Simulated Performance _____

Actual Performance _____

Classroom _____

Simulator _____

Plant _____

Read to the examinee:

I will explain the initial conditions, which steps to simulate or discuss, and provide initiating cues. When you complete the task successfully, the objective for this job performance measure will be satisfied.

Initial Conditions: **An inadvertent SI has occurred on Train A and will not reset using the Handswitches in the Main Control Board.**

Task Standard: SI Train A is reset using 19011-C Attachment D

Required Materials: 1. EOP 19011-C Ver. 28.1

General References: None

Initiating Cue: **The SS directs you to reset SI using EOP 19011-C Attachment D .**

Time Critical Task: No

Validation Time: 10 minutes

Performance Information

Critical steps denoted with an asterisk

Step 1: Identify the affected train.

Standard: Train A is identified in the initial conditions.

Comment:

NOTE: De-energizing the two 48 VDC power supplies to a train of SSPS will result in the following:

- General Warning
- ALB05-E06 or ALB05-F06 will illuminate.
- Undervoltage Driver output de-energizes.
- Reactor Trip condition (Reactor Trip Breaker OPEN) on the affected train (already initiated from Turbine Trip.)
- 48VDC removed from all master relays.

Standard: Student should read note before continuing.

Comment:

***Step 2** **At the affected train SSPS Logic Cabinet, de-energize both 48 VDC power supplies (located in the upper 2 sections) by placing the ON/OFF switch to the OFF position.**

Cue: Provide indication that the switch was placed in the OFF position.

Standard: Student placed ON/OFF switch to OFF position.

Comment:

***Step 3** **At the affected train Safeguards Test Cabinet (STC) #1, reset SSPS Slave Relays by momentarily turning TEST RESET SWITCH S-821 to the RESET position.**

CUE: **ANY INDICATION CHANGE????**

Standard: Student momentarily places the switch in RESET position.

Comment:

***Step 4** **At the affected train Safeguards Test Cabinet (STC) #2, reset SSPS Slave Relays by momentarily turning TEST RESET SWITCH S-921 to the RESET position.**

CUE: **ANY INDICATION CHANGE????**

Standard: Student momentarily places the switch in RESET position.

Comment:

***Step 5** **At the affected train, locate and open the Output Cabinet and place the MODE SELECTOR Switch in the TEST position and check the OPERATE lamp NOT lit.**

CUE: ***Provide indication that the lamp is OUT.***

Standard: Student places the switch in TEST and verifies OPERATE lamp goes out.

Comment:

Step 6: Notify I&C to investigate the affected train SSPS to determine the source of the SI signal.

Terminating Cue: “The SS will notify I&C.”

Verification of Completion

Job Performance Measure No. V-RQ-JP-19011-003

Examinee's Name:

Examiner's Name:

Date Performed:

Number of Attempts:

Time to Complete:

Question Documentation:

Question: _____

Response: _____

Result: Satisfactory/Unsatisfactory

Examiner's signature and date: _____

Initial Conditions: An inadvertent SI has occurred on Train A and will not rest using the Handswitches in the Main Control Board.

Initiating Cue: The SS directs you to reset SI using EOP 19011-C Attachment D.

Job Performance Measure "K"

Facility: **Vogtle**

Task No: LO-TA-60040

Task Title: **Locally Remove Diesel Generator From Service**

JPM No: V-NRC-JP-18034-001

K/A Reference: 058G2.1.20

Examinee: _____

NRC Examiner: _____

Facility Evaluator: _____

Date: _____

Method of testing:

Simulated Performance _____

Actual Performance _____

Classroom _____

Simulator _____

Plant _____

Read to the examinee:

I will explain the initial conditions, which steps to simulate or discuss, and provide initiating cues. When you complete the task successfully, the objective for this job performance measure will be satisfied.

Initial Conditions: **A loss of 125VDC Bus 2BD1 has occurred. The plant has been stabilized in Mode 3, and the crew is responding per AOP 18034-2. Diesel Generator 2B was paralleled to the grid for the monthly surveillance prior to the transient and continues to run.**

Task Standard: Diesel Generator stopped with the DG output breaker open per 18034-2.

Required Materials: 1. AOP 18034-2 Ver 11.0 , Loss of Class 1E 125V DC Power
 2. Hearing Protection

General References: None

Initiating Cue: **The SS has directed you to "Locally remove Diesel Generator 2B from service by performing step A6 of AOP 18034-2."**

Time Critical Task: No

Validation Time: 15 minutes

Performance Information

Critical steps denoted with an asterisk

***STEP A6a/B6a: Verify 2BA03-19 breaker-OPEN.**

Standard: Student locates breaker 2BA03-19.

CUE: When student checks the mechanical flag, provide indication that the mechanical flag is RED.

Determines 2BA03-19 breaker is Closed.
Student pushes mechanical trip.

CUE: Use attached photograph for student to simulate pressing mechanical trip.

Student verifies mechanical flag to determine that the breaker has opened.

CUE: When the trip pushed by the student, provide indication that the mechanical flag is GREEN.

NOTE to examiner: Breaker can only be tripped by the mechanical trip button and the only breaker position indication will be the mechanical flag. Discussion of location of trip button and mechanical flag is satisfactory performance for this step and the following step. **Breaker cubicle door should not be opened.**

Comment:

***Step A6b/B6b:** Stop the Diesel Generator by placing the “Pull-To-Run/Push-to-Stop Handswitch” at the south end of the engine in STOP.

Standard: Student places handswitch in STOP and verifies that DG is slowing.

CUE: If the student asks for indications of or states he is listening to diesel speed to verify that it is stopping, “DG speed is decreasing of if referenced DG RPM is lowering.”

Comment:

Report Diesel Generator stopped to SS.

Standard: Report Made to SS.

Comment:

Terminating cue: Student returns initiating cue sheet

Verification of Completion

Job Performance Measure No. V-NRC-JP-18034-001

Examinee's Name:

Examiner's Name:

Date Performed:

Number of Attempts:

Time to Complete:

Question Documentation:

Question: _____

Response: _____

Result: Satisfactory/Unsatisfactory

Examiner's signature and date: _____

Initial Conditions: A loss of 125VDC Bus 2BD1 has occurred. The plant has been stabilized in Mode 3, and the crew is responding per AOP 18034-2. Diesel Generator 2B was paralleled to the grid for the monthly surveillance prior to the transient and continues to run.

Initiating Cue: The SS has directed you to “Locally remove Diesel Generator 2B from service by performing step A6 of AOP 18034-2.”