

NOTES:

1. ALL MOTOR OPERATED VALVES SHALL HAVE MANUAL OPERATION HANDWHEELS.

WLS SUP 9.2-5

WILLIAM STATES LEE III NUCLEAR STATION UNITS 1 & 2

Raw Water System, Refill Subsystem

FIGURE 9.2-206 Rev 2