

NRC DISTRIBUTION FOR PART 50 DOCKET MATERIAL
(TEMPORARY FORM)

CONTROL NO: 8591

FILE: MONTHLY REPORT FILE

FROM: Iowa Electric And Power Co. Cedar Rapids, Iowa G.G. Hunt			DATE OF DOC 8-8-75	DATE REC'D 8-13-75	LTR xxxxx	TWX	RPT	OTHER
TO: Office of Plans and Schedules			ORIG not signed	CC 1	OTHER	SENT AEC PDR <u>xxxx</u> SENT LOCAL PDR <u>xxx</u>		
CLASS	UNCLASS xxxx	PROP INFO	INPUT	NO CYS REC'D		DOCKET NO: 50-331		

DESCRIPTION:
Ltr trans the following:

ACKNOWLEDGED

DO NOT REMOVE

PLANT NAME: Duane Arnold

ENCLOSURES:
Monthly Report for July, 1975
Plant & Component Operability & Availability
This Report to be used in preparing Gray Book by Plans & Operations.

NUMBER OF COPIES REC'D: 1

FOR ACTION/INFORMATION 8-13-75 JGB

BUTLER (L) W/ Copies	SCHWENCER (L) W/ Copies	ZIEMANN (L) W/ Copies	REGAN (E) W/ Copies
CLARK (L) W/ Copies	STOLZ (L) W/ Copies	DICKER (E) W/ Copies	✓ EAR (L) W/ Copies
PARR (L) W/ Copies	VASSALLO (L) W/ Copies	KNIGHTON (E) W/ Copies	SPELS W/ Copies
KNIEL (L) W/ Copies	PURPLE (L) W/ Copies	YOUNGBLOOD (E) W/ Copies	✓ MIPC/PE W/4 Copies

INTERNAL DISTRIBUTION

REG FILE NRC PDR OGC, ROOM P-506A. GOSSICK/STAFF CASE GIAMBUSSO BOYD MOORE (L) DEYOUNG (L) SKOVHOLT (L) GOLLER (L) (Ltr) P. COLLINS DENISE REG OPR FILE & REGION (2) T.R. WILSON STEELE	<u>TECH REVIEW</u> SCHROEDER MACCARY KNIGHT PAWLICKI SHAO STELLO HOUSTON NOVAK ROSS IPPOLITO TEDESCO J. COLLINS LAINAS BENAROYA VOLLMER	DENTON GRIMES GAMMILL KASTNER BALLARD SPANGLER <u>ENVIRO</u> MULLER DICKER KNIGHTON YOUNGBLOOD REGAN PROJECT LDR <u>HARLESS</u>	<u>LIC ASST</u> R. DIGGS (L) H. GEARIN (L) E. GOULBOURNE (L) P. KREUTZER (E) J. LEE (L) M. MAIGRET (L) S. REED (E) M. SERVICE (L) S. SHEPPARD (L) M. SLATER (E) H. SMITH (L) S. TEETS (L) G. WILLIAMS (E) V. WILSON (L) R. INGRAM (L)	<u>A/T IND.</u> BRAITMAN SALTZMAN MELTZ <u>PLANS</u> MCDONALD CHAPMAN DUBE (Ltr) E. COUPE PETERSON HARTFIELD (2) KLECKER EISENHUT WIGGINTON
--	--	--	--	--

EXTERNAL DISTRIBUTION


- | | | |
|----------------------------------|--------------------------------|---|
| 1 - LOCAL PDR Cedar Rapids, Iowa | 1 - NATIONAL LABS | 1 - PDR-SAN/LA/NY |
| 1 - TIC (ABERNATHY) (1)(2)(10) | 1 - W. PENNINGTON, Rm E-201 GT | 1 - BROOKHAVEN NAT LAB |
| 1 - NSIC (BUCHANAN) | 1 - CONSULTANTS | 1 - G. ULRIKSON, ORNL |
| 1 - ASLB | NEWMARK/BLUME/AGBABIAN | 1 - AGMED (RUTH GUSSMAN)
Rm B-127 GT |
| 1 - Newton Anderson | | 1 - J. D. RUNKLES, Rm E-201
GT |
| - ACRS HOLDING/SENT | | |

to Declaring
Attn: Eric Humphreys

IOWA ELECTRIC LIGHT AND POWER COMPANY

General Office

CEDAR RAPIDS, IOWA
DUANE ARNOLD ENERGY CENTER
PALO, IOWA
AUGUST 8, 1975
DAEC - 75 -315



Regulatory File Cy.


Office of Plans and Schedules
Office of Nuclear Reactor Regulation
U. S. Nuclear Regulatory Commission
Washington, D.C. 20545

SUBJECT: Monthly Plant and Component
Operability and Availability
Report

FILE: A-118d

Gentlemen:

In accordance with Regulatory Guide 1.16, please find enclosed the Monthly Plant and Component Operability and Availability Report for July 1975.



Very truly yours,

G. G. Hunt
Chief Engineer

Duane Arnold Energy Center

DLW/GGH/mg

Enclosure

- cc: C. W. Sandford
- J. A. Wallace
- L. D. Root
- D. L. Wilson
- W. D. Bryant
- (E. L. Hammond)
- B. R. York
- D. A. Moen
- K. M. Haas
- Dennis Murdock
- George Toyne

8591

DATE August 7, 1975

COMPLETED BY D. Wilson 319/851-5611

DOCKET NO. 50-331

OPERATING STATUS

1. REPORTING PERIOD: 0001, 750701 THROUGH 2400, 750730
HOURS IN REPORTING PERIOD: 744
2. CURRENTLY AUTHORIZED POWER LEVEL (Mwth) 1593 MAX. DEPENDABLE CAPACITY (MWe-NET) 515
3. LOWEST POWER LEVEL TO WHICH SPECIFICALLY RESTRICTED (IF ANY) (MWe-NET): 430 (approximately)
4. REASONS FOR RESTRICTION (IF ANY): NRC directive as a result of potential in-core instrument tube vibration.

	THIS REPORTING PERIOD	YR TO DATE	CUMULATIVE TO DATE
5. HOURS REACTOR WAS CRITICAL.....	297.8	3694.7	8449.50
6. REACTOR RESERVE SHUTDOWN HOURS..	0	0	0
7. HOURS GENERATOR ON LINE.....	271	3464.7	7376.7
8. UNIT RESERVE SHUTDOWN HOURS.....	0	0	0
9. GROSS THERMAL ENERGY GENERATED (MMH).....	309326	3579936	8122656
10. GROSS ELECTRICAL ENERGY GENERATED (MWH).....	101,103	1180047	2684797
11. NET ELECTRICAL ENERGY GENERATED (MWH).....	* 93,590.1	1094493.2	2496550.1
12. REACTOR AVAILABILITY FACTOR (1).....	40%	68%	68%
13. UNIT AVAILABILITY FACTOR (2).....	36%	64%	64%
14. UNIT CAPACITY FACTOR (3).....	24%	40%	40%
15. UNIT FORCED OUTAGE RATE (4).....	0	15%	15%
16. SHUTDOWNS SCHEDULED TO BEGIN IN NEXT 6 MONTHS (STATE TYPE, DATE, AND DURATION OF EACH):			

17. IF SHUT DOWN AT END OF REPORT PERIOD, ESTIMATED DATE OF STARTUP: _____
18. UNITS IN TEST STATUS (PRIOR TO COMMERCIAL OPERATION) REPORT THE FOLLOWING:

	DATE LAST FORECAST	DATE ACHIEVED
INITIAL CRITICALITY	_____	_____
INITIAL ELECTRICAL POWER GENERATION	_____	_____
COMMERCIAL OPERATION	_____	February, 1975

- (1) REACTOR AVAILABILITY FACTOR = $\frac{\text{HOURS REACTOR WAS CRITICAL}}{\text{HOURS IN REPORTING PERIOD}} \times 100$
- (2) UNIT AVAILABILITY FACTOR = $\frac{\text{HOURS GENERATOR ON LINE}}{\text{HOURS IN REPORTING PERIOD}} \times 100$
- (3) UNIT CAPACITY FACTOR = $\frac{\text{NET ELECTRICAL POWER GENERATED}}{\text{MAX. DEPENDABLE CAPACITY (MWe-NET)} \times \text{HOURS IN REPORTING PERIOD}}$
- (4) UNIT FORCED OUTAGE RATE = $\frac{\text{FORCED OUTAGE HOURS}}{\text{HOURS GENERATOR ON LINE} + \text{FORCED OUTAGE HOURS}} \times 100$

*Does not include station

- (1) REASON
 A-Equipment Failure (Explain)
 B-Maint. or Test
 C-Refueling
 D-Regulatory Restriction
 E-Operator Training and License Examination
 F-Administrative
 G-Operational Error (Explain)
 H-Other (Explain)

- (2) METHOD
 1-Manual
 2-Manual Scram
 3-Automatic Scram

UNIT SHUTDOWNS

DOCKET NO. 50-331

UNIT NAME Duane Arnold Energy Center

DATE August 7, 1975

COMPLETED BY D. Wilson 319/851/5611

REPORT MONTH July

NO.	DATE	TYPE F-FORCED S-SCHEDULED	DURATION (HOURS)	REASON (1)	METHOD OF SHUTTING DOWN THE REACTOR (2)	CORRECTIVE ACTIONS/COMMENTS
13	750606	S	449	B	1	Continuation of outage from previous month for inspection of in-core monitors and associated fuel channels. Also, repair of relief valve ramshead restraints in pressure suppression chamber.

SUMMARY: Power operations in the load following mode were resumed on July 19, 1975.

DOCKET NO. 50-331

UNIT Duane Arnold Energy Center

DATE August 7, 1975

COMPLETED BY D. Wilson 319/851-5611

AVERAGE DAILY UNIT POWER LEVEL

MONTH July, 1975

AVERAGE DAILY POWER LEVEL		AVERAGE DAILY POWER LEVEL	
DAY	(MWe-net)	DAY	(MWe-net)
1	0	17	0
2	0	18	0
3	0	19	2.6
4	0	20	28.8
5	0	21	126.2
6	0	22	257.1
7	0	23	318.4
8	0	24	350.8
9	0	25	391.2
10	0	26	404.1
11	0	27	417.7
12	0	28	381.1
13	0	29	399.7
14	0	30	407.5
15	0	31	407.1
16	0		