

50-331

NRC DISTRIBUTION FOR PART 50 DOCKET MATERIAL

FILE NUMBER

ENVIRO

TO: Mr B C Rusche

FROM: Iowa Elec Light & Power Co
Cedar Rapids, Ia
E L Hammond

DATE OF DOCUMENT 1-26-77

DATE RECEIVED 1-31-77

☒ LETTER
☒ ORIGINAL
☐ COPY☐ NOTORIZED
☒ UNCLASSIFIED

PROP

INPUT FORM

NUMBER OF COPIES RECEIVED

one signed

DESCRIPTION

Ltr reporting Enviromental Deviation (77-1) which occurred on 1-17-77 & concerned receipt of a low flow alarm from the offgas stack radiation monitor due to a plugged line.....

2p

PLANT NAME: Duane Arnold

ENCLOSURE

ACKNOWLEDGED
Do Not Remove

SAFETY

FOR ACTION/INFORMATION

ENVIRO

2-1-77

ehf

ASSIGNED AD:		ASSIGNED AD:
BRANCH CHIEF:	Lear (S)	BRANCH CHIEF:
PROJECT MANAGER:	Shea	PROJECT MANAGER:
LIC. ASST. :	Parrish	LIC. ASST. :

INTERNAL DISTRIBUTION

REG-FILE	SYSTEMS SAFETY	PLANT SYSTEMS	SITE SAFETY &
NRC PDR	HEINEMAN	TEDESCO	ENVIRO ANALYSIS
I & E (2)	SCHROEDER	BENAROYA	DENTON & MULLER
OELD		LAINAS	
GOSSICK & STAFF	ENGINEERING	IPPOLITO	ENVIRO TECH.
MIPC	MACARRY	KIRKWOOD	ERNST
CASE	KNIGHT		BALLARD
HANAUER	SIHWEIL	OPERATING REACTORS	SPANGLER
HARLESS	PAWLICKI	STELLO	
			SITE TECH.
PROJECT MANAGEMENT	REACTOR SAFETY	OPERATING TECH.	GAMMILL
BOYD	ROSS	EISENHUT	STEPP
P. COLLINS	NOVAK	SHAO	HULMAN
HOUSTON	ROSZTOCZY	BAER	
PETERSON	CHECK	BUTLER	SITE ANALYSIS
MELTZ		GRIMES	VOLLMER
HELTEMES	AT & I		BUNCH
SKOVHOLT	SALTZMAN		J. COLLINS
	RUTBERG		KREGER

EXTERNAL DISTRIBUTION

CONTROL NUMBER

LPDR:	NAT. LAB: ANL	BROOKHAVEN NAT. LAB.
TIC:	REG V. IE	ULRIKSON (ORNL)
NSIC:	LA PDR	
ASLB:	CONSULTANTS:	
ACRS / CYS HOLDING/SENT	As CAT D 2/1/77	

1021

ans.
GD1

IOWA ELECTRIC LIGHT AND POWER COMPANY

DUANE ARNOLD ENERGY CENTER
P. O. Box 351
Cedar Rapids, Iowa 52406
January 26, 1977
DAEC - 77 - 61

Mr. Benard C. Rusche, Director
Office of Nuclear Reactor Regulation
U. S. Nuclear Regulatory Commission
1717 H Street N.W.
Washington, D.C. 20545

50-331



Subject: Environmental Technical Specification
Violation 77-1

File: A-117

Dear Mr. Rusche:

This report is submitted in accordance with the requirements of Appendix B to Operating License DPR-49, Specifications 3.3.1.C.1 and 5.4.2.1.

Problem


On January 17, 1977, a low flow alarm was received from the Offgas Stack radiation monitor. A subsequent investigation determined that the discharge of the flow indicator in the monitor was frozen.

Investigation

The sample line became plugged as the result of sub-freezing temperatures at the Offgas Stack. Moisture in the sample flow turned to ice in a section of the sample line that was not heat traced.

Corrective Action

The section of pipe in which the icing occurred was thawed out. Heat tracing was added in order to prevent further icing problems. The offgas stack radiation monitor was returned to operation in approximately four hours. The Offgas System pretreatment and posttreatment monitors were operable during the period when the stack monitor was inoperable.



1021

January 26, 1977

This report was reviewed and approved by the DAEC Operations Committee and Safety Committee.

Very truly yours,

Ellery L. Hammond

Ellery L. Hammond
Chief Engineer
DUANE ARNOLD ENERGY CENTER

ELH/DLW/mg

cc: D. Arnold
J. Wallace
D. Mineck
L. Liu
D. Wilson
H. Rehrauer
J. Newman
J. Keppler