

3.4 REACTOR COOLANT SYSTEM (RCS)

3.4.1 RCS Pressure, Temperature, and Flow Departure from Nucleate Boiling (DNB) Limits

LCO 3.4.1 DNB parameters for RCS pressurizer pressure, RCS average coolant temperature, and RCS total flow rate shall be within the limits specified in the COLR.

APPLICABILITY: MODE 1.
-----NOTE-----
RCS pressurizer pressure limit does not apply during:
a. THERMAL POWER ramp > 5% RTP per minute; or
b. THERMAL POWER step > 10% RTP.

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. One or more DNB parameters not within limits.	A.1 Restore the DNB parameter(s) to within limits.	2 hours
B. Required Action and associated Completion Time not met.	B.1 Be in MODE 2.	6 hours

SURVEILLANCE REQUIREMENTS

SURVEILLANCE		FREQUENCY
SR 3.4.1.1	Verify RCS pressurizer pressure is within the limits specified in the COLR.	12 hours
SR 3.4.1.2	Verify RCS average coolant temperature is within the limits specified in the COLR.	12 hours
SR 3.4.1.3	Verify RCS total flow rate is within the limits specified in the COLR.	12 hours
SR 3.4.1.4	<p>-----NOTE----- Not required to be performed until 24 hours after ≥ 90% RTP. -----</p> <p>Verify by precision heat balance that RCS total flow rate is within the limits specified in the COLR.</p>	24 months

3.4 REACTOR COOLANT SYSTEM (RCS)

3.4.2 RCS Minimum Temperature for Criticality

LCO 3.4.2 Each RCS loop average coolant temperature (T_{avg}) shall be $\geq 568^{\circ}\text{F}$.

APPLICABILITY: MODE 1,
MODE 2 with $k_{eff} \geq 1.0$.

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. T_{avg} in one or more RCS loops not within limit.	A.1 Be in MODE 2 with $k_{eff} < 1.0$.	30 minutes

SURVEILLANCE REQUIREMENTS

SURVEILLANCE	FREQUENCY
SR 3.4.2.1 Verify RCS T_{avg} in each loop $\geq 568^{\circ}\text{F}$.	12 hours

3.4 REACTOR COOLANT SYSTEM (RCS)

3.4.3 RCS Pressure and Temperature (P/T) Limits

LCO 3.4.3 RCS pressure, RCS temperature, and RCS heatup and cooldown rates shall be maintained within the limits specified in the PTLR.

APPLICABILITY: At all times.

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
<p>A. -----NOTE----- Required Action A.2 shall be completed whenever this Condition is entered. ----- Requirements of LCO not met in MODE 1, 2, 3, or 4.</p>	<p>A.1 Restore parameter(s) to within limits. <u>AND</u> A.2 Determine RCS is acceptable for continued operation.</p>	<p>30 minutes 72 hours</p>
<p>B. Required Action and associated Completion Time of Condition A not met.</p>	<p>B.1 Be in MODE 3. <u>AND</u> B.2 Be in MODE 5 with RCS pressure < 355 psig.</p>	<p>6 hours 36 hours</p>

ACTIONS (continued)

CONDITION	REQUIRED ACTION	COMPLETION TIME
<p>C. -----NOTE----- Required Action C.2 shall be completed whenever this Condition is entered. ----- Requirements of LCO not met any time in other than MODE 1, 2, 3, or 4.</p>	<p>C.1 Initiate action to restore parameter(s) to within limits. <u>AND</u> C.2 Determine RCS is acceptable for continued operation.</p>	<p>Immediately Prior to entering MODE 4</p>

SURVEILLANCE REQUIREMENTS

SURVEILLANCE	FREQUENCY
<p>SR 3.4.3.1 -----NOTE----- Only required to be performed during RCS heatup and cooldown operations and RCS inservice leak and hydrostatic testing. ----- Verify RCS pressure, RCS temperature, and RCS heatup and cooldown rates are within the limits specified in the PTLR.</p>	<p>30 minutes</p>

3.4 REACTOR COOLANT SYSTEM (RCS)

3.4.4 RCS Loops - MODES 1 and 2

LCO 3.4.4 Four RCS loops shall be OPERABLE and in operation.

APPLICABILITY: MODES 1 and 2.

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. One RCS loop not in operation.	A.1 Reduce THERMAL POWER to $\leq 60\%$ RTP.	15 minutes
	<u>AND</u> A.2 Restore RCS loop to operation.	2 hours
B. Required Action and associated Completion Time of Condition A not met. <u>OR</u> Requirements of LCO not met for reasons other than Condition A.	B.1 Be in MODE 3.	6 hours

SURVEILLANCE REQUIREMENTS

SURVEILLANCE	FREQUENCY
SR 3.4.4.1 Verify each RCS loop is in operation.	12 hours

3.4 REACTOR COOLANT SYSTEM (RCS)

3.4.5 RCS Loops - MODE 3

LCO 3.4.5 RCS loops shall be OPERABLE and in operation as follows:

- a. Four RCS loops shall be OPERABLE and in operation when the Control Rod Drive Control System (CRDCS) is capable of rod withdrawal; or
- b. Two RCS loops shall be OPERABLE and one in operation when the CRDCS is not capable of rod withdrawal.

-----NOTE-----

All reactor coolant pumps may be removed from operation for ≤ 1 hour per 8 hour period provided:

- a. No operations are permitted that would cause introduction of coolant into the RCS with boron concentration less than required to meet the SDM of LCO 3.1.1, "SHUTDOWN MARGIN (SDM)";
 - b. Core outlet temperature is maintained at least 10°F below saturation temperature; and
 - c. The CRDCS is not capable of rod withdrawal.
-

APPLICABILITY: MODE 3.

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
<p>A. One RCS loop inoperable with CRDCS capable of rod withdrawal.</p> <p><u>OR</u></p> <p>One RCS loop not in operation with CRDCS capable of rod withdrawal.</p>	<p>A.1 Place the CRDCS in a condition incapable of rod withdrawal.</p>	<p>2 hours</p>

ACTIONS (continued)

CONDITION	REQUIRED ACTION	COMPLETION TIME
B. One or more required RCS loops inoperable with CRDCS not capable of rod withdrawal.	B.1 Restore required RCS loops to OPERABLE status.	72 hours
C. With no required RCS loop in operation with CRDS not capable of rod withdrawal.	C.1 Initiate action to place one RCS loop in operation.	Immediately
D. Required Action and associated Completion Time of Conditions A, B, or C not met.	D.1 Be in MODE 4.	12 hours

SURVEILLANCE REQUIREMENTS

SURVEILLANCE	FREQUENCY
SR 3.4.5.1 Verify required RCS loops are in operation.	12 hours
SR 3.4.5.2 Verify steam generator secondary side water levels are $\geq 20\%$ for required RCS loops.	12 hours
SR 3.4.5.3 -----NOTE----- Not required to be performed until 24 hours after a required pump is not in operation. ----- Verify correct breaker alignment and indicated power are available to each required pump.	7 days

3.4 REACTOR COOLANT SYSTEM (RCS)

3.4.6 RCS Loops - MODE 4

LCO 3.4.6 Two RCS loops shall be OPERABLE and one RCS loop shall be in operation.

OR

Three Residual Heat Removal (RHR) loops shall be OPERABLE and two RHR loops shall be in operation.

-----NOTES-----

1. All reactor coolant pumps and LHSI pumps may be removed from operation for ≤ 1 hour per 8 hour period provided:
 - a. No operations are permitted that would cause introduction of coolant into the RCS with boron concentration less than required to meet the SDM of LCO 3.1.1, "SHUTDOWN MARGIN (SDM)"; and
 - b. Core outlet temperature is maintained at least 10°F below saturation temperature.
2. No RCP shall be started with any RCS cold leg temperature \leq Low Temperature Overpressure Protection (LTOP) arming temperature specified in the PTLR unless the secondary side water temperature of each steam generator (SG) is $\leq 50^\circ\text{F}$ above each of the RCS cold leg temperatures.

APPLICABILITY: MODE 4.

SURVEILLANCE REQUIREMENTS (continued)

SURVEILLANCE		FREQUENCY
SR 3.4.6.2	Verify SG secondary side water levels are \geq 20% for required RCS loops.	12 hours
SR 3.4.6.3	<p>-----NOTE-----</p> <p>Not required to be performed until 24 hours after a required system is not in operation.</p> <p>-----</p> <p>Verify correct breaker alignment and indicated power are available to each required pump.</p>	7 days

3.4 REACTOR COOLANT SYSTEM (RCS)

3.4.7 RCS Loops - MODE 5, Loops Filled

LCO 3.4.7 One residual heat removal (RHR) loop shall be OPERABLE and in operation, and either:

- a. One additional RHR loop shall be OPERABLE; or
- b. The secondary side water level of at least two steam generators (SGs) shall be $\geq 20\%$.

-----NOTES-----

- 1. The LHSI pump may be removed from operation for ≤ 1 hour per 8 hour period provided:
 - a. No operations are permitted that would cause introduction of coolant into the RCS with boron concentration less than required to meet the SDM of LCO 3.1.1, "SHUTDOWN MARGIN (SDM)"; and
 - b. Core outlet temperature is maintained at least 10°F below saturation temperature.
- 2. All RHR loops may be removed from operation during planned heatup to MODE 4 when at least one RCS loop is in operation.

APPLICABILITY: MODE 5 with RCS Loops Filled.

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
<p>A. One required RHR loop inoperable.</p> <p><u>AND</u></p> <p>One RHR loop OPERABLE.</p>	<p>A.1 Initiate action to restore required RHR loop to OPERABLE status.</p> <p><u>OR</u></p> <p>A.2 Initiate action to restore required SGs secondary side water level to within limit.</p>	<p>Immediately</p> <p>Immediately</p>
<p>B. One or more required SGs with secondary side water level not within limit.</p> <p><u>AND</u></p> <p>One RHR loop OPERABLE.</p>	<p>B.1 Initiate action to restore a second RHR loop to OPERABLE status.</p> <p><u>OR</u></p> <p>B.2 Initiate action to restore required SGs secondary side water level to within limit.</p>	<p>Immediately</p> <p>Immediately</p>
<p>C. No required RHR loops OPERABLE.</p> <p><u>OR</u></p> <p>Required RHR loop not in operation.</p>	<p>C.1 Initiate action to restore one RHR loop to OPERABLE status and operation.</p>	<p>Immediately</p>

SURVEILLANCE REQUIREMENTS

SURVEILLANCE		FREQUENCY
SR 3.4.7.1	Verify required RHR loop is in operation and circulating reactor coolant at a flow rate of ≥ 2200 gpm.	12 hours
SR 3.4.7.2	Verify SG secondary side water level is $\geq 20\%$ in required SGs.	12 hours
SR 3.4.7.3	<p>-----NOTE----- Not required to be performed until 24 hours after a required RHR loop is not in operation. -----</p> <p>Verify correct breaker alignment and indicated power are available to each required LHSI pump.</p>	7 days

3.4 REACTOR COOLANT SYSTEM (RCS)

3.4.8 RCS Loops - MODE 5, Loops Not Filled

LCO 3.4.8 Two Residual Heat Removal (RHR) loops shall be OPERABLE and one RHR loop shall be in operation.

APPLICABILITY: MODE 5 with RCS loops not filled.

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. One required RHR loop inoperable.	A.1 Initiate action to restore RHR loop to OPERABLE status.	Immediately
B. No required RHR loops OPERABLE. <u>OR</u> Required RHR loop not in operation.	B.1 Initiate action to restore one RHR loop to OPERABLE status and operation.	Immediately

SURVEILLANCE REQUIREMENTS

SURVEILLANCE		FREQUENCY
SR 3.4.8.1	Verify required RHR loop is in operation and circulating reactor coolant at a flow rate of ≥ 2200 gpm.	12 hours
SR 3.4.8.2	<p>-----NOTE-----</p> <p>Not required to be performed until 24 hours after required RHR loop is not in operation.</p> <p>-----</p> <p>Verify correct breaker alignment and indicated power are available to each required LHSI pump.</p>	7 days

3.4 REACTOR COOLANT SYSTEM (RCS)

3.4.9 Pressurizer

LCO 3.4.9 The Pressurizer shall be OPERABLE with:

- a. Pressurizer water level \leq 59%;
- b. Three groups of emergency supply pressurizer heaters OPERABLE with the capacity of each group \geq 144 kW; and
- c. The Chemical Volume and Control System (CVCS) charging and auxiliary spray isolation valves shall be OPERABLE.

APPLICABILITY: MODES 1, 2, and 3,
MODE 4 > P17.

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. Pressurizer water level not within limit.	A.1 Be in MODE 3. <u>AND</u>	6 hours
	A.2 Fully insert all rods. <u>AND</u>	6 hours
	A.3 Place the Control Rod Drive Control System in a condition incapable of rod withdrawal. <u>AND</u>	6 hours
	A.4 Be in MODE 4 at \leq P17.	24 hours

ACTIONS (continued)

CONDITION	REQUIRED ACTION	COMPLETION TIME
B. One required group of pressurizer heaters inoperable.	B.1 Restore required group of pressurizer heaters to OPERABLE status.	72 hours
-----NOTE----- Separate Condition entry is allowed for each valve. -----	C.1 Isolate the associated flow path.	6 hours
C. CVCS charging isolation valve or auxiliary spray isolation valve inoperable.		
D. Required Action and associated Completion Time of Condition B or C not met.	D.1 Be in MODE 3. <u>AND</u> D.2 Be in MODE 4 at \leq P17.	6 hours 24 hours

SURVEILLANCE REQUIREMENTS

SURVEILLANCE		FREQUENCY
SR 3.4.9.1	Verify pressurizer water level is \leq 59%.	12 hours
SR 3.4.9.2	Verify capacity of each required group of emergency supply pressurizer heaters is \geq 144 kW.	92 days
SR 3.4.9.3	Verify the CVCS charging and auxiliary spray isolation valves actuate to the correct position on an actual or simulated actuation signal.	24 months

3.4 REACTOR COOLANT SYSTEM (RCS)

3.4.10 Pressurizer Safety Relief Valves

LCO 3.4.10 Three Pressurizer Safety Relief Valves (PSRVs) shall be OPERABLE with a lift setting of ≥ 2484.3 psig and ≤ 2585.7 psig.

APPLICABILITY: MODES 1, 2, and 3, MODE 4 with all RCS cold leg temperatures greater than the low temperature overpressure protection (LTOP) arming temperature specified in the PTLR.

-----NOTE-----
The lift settings are not required to be within the LCO limits during MODES 3 and 4 for the purpose of setting the PSRVs under ambient (hot) conditions. This exception is allowed for 54 hours following entry into MODE 3 provided a preliminary cold setting was made prior to heatup.

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. One PSRV inoperable.	A.1 Restore PSRV to OPERABLE status.	15 minutes
B. Required Action and associated Completion Time of Condition A not met. <u>OR</u> Two or more PSRVs inoperable.	B.1 Be in MODE 3. <u>AND</u> B.2 Be in MODE 4 with any RCS cold leg temperature less than or equal to the LTOP arming temperature specified in the PTLR.	6 hours 24 hours

SURVEILLANCE REQUIREMENTS

SURVEILLANCE		FREQUENCY
SR 3.4.10.1	Verify each PSRV is OPERABLE in accordance with the Inservice Testing Program. Following testing, lift settings shall be within $\pm 1\%$.	In accordance with the Inservice Testing Program

3.4 REACTOR COOLANT SYSTEM (RCS)

3.4.11 Low Temperature Overpressure Protection (LTOP)

LCO 3.4.11 LTOP shall be OPERABLE, consisting of the following:

- a. All accumulators isolated from injecting into the RCS;
- b. Miniflow lines open for any medium head safety injection (MHSI) pump capable of injecting into the RCS;
- c. Reactor coolant pumps (RCPs) shall not be started unless the secondary side water temperature of each steam generator (SG) is $\leq 50^{\circ}\text{F}$ above each of the RCS cold leg temperatures; and
- d. One of the following pressure relief capabilities:
 1. The two Pressurizer Safety Relief Valves (PSRVs) which are LTOP capable with lift settings within the limits specified in the PTLR; or
 2. The RCS depressurized and an RCS vent of ≥ 10.1 square inches.

-----NOTE-----

An accumulator may be unisolated when accumulator pressure is less than the maximum RCS pressure for the existing RCS cold leg temperature allowed by the P/T limit curves provided in the PTLR.

APPLICABILITY: MODE 4 when any RCS cold leg temperature is less than or equal to the LTOP arming temperature specified in the PTLR,
MODE 5,
MODE 6 when the reactor vessel head is on.

ACTIONS

-----NOTE-----

LCO 3.0.4.b is not applicable when entering MODE 4.

CONDITION	REQUIRED ACTION	COMPLETION TIME
<p>A. Miniflow line of any MHSI pump capable of injecting into the RCS not open.</p>	<p>A.1 Initiate action to open miniflow line of the MHSI pump(s) capable of injecting into the RCS.</p>	<p>Immediately</p>
	<p><u>OR</u></p> <p>A.2 Initiate action to verify affected MHSI pump(s) with miniflow line not open is incapable of injecting into the RCS.</p>	<p>Immediately</p>
<p>B. One or more accumulators not isolated when the accumulator pressure is greater than or equal to the maximum RCS pressure for existing cold leg temperature allowed in the PTLR.</p>	<p>B.1 Isolate affected accumulator(s).</p>	<p>1 hour</p>
<p>C. Required Action and associated Completion Time of Condition A or B not met.</p>	<p>C.1 Increase RCS cold leg temperature greater than the LTOP arming temperature specified in the PTLR.</p>	<p>12 hours</p>
	<p><u>OR</u></p> <p>C.2 Depressurize affected accumulator to less than the maximum RCS pressure for existing cold leg temperature allowed in the PTLR.</p>	<p>12 hours</p>

ACTIONS (continued)

CONDITION	REQUIRED ACTION	COMPLETION TIME
D. One required PSRV inoperable in MODE 4.	D.1 Restore required PSRV to OPERABLE status.	72 hours
E. One required PSRV inoperable in MODE 5 or 6.	E.1 Restore required PSRV to OPERABLE status.	12 hours
F. Required Action and associated Completion Time of Condition A, C, D, or E not met. <u>OR</u> Two required PSRVs inoperable. <u>OR</u> LTOP inoperable for any reasons other than Condition A, B, C, D, or E.	F.1 Depressurize RCS and establish RCS vent of ≥ 10.1 square inches.	6 hours

SURVEILLANCE REQUIREMENTS

SURVEILLANCE	FREQUENCY
SR 3.4.11.1 Verify each accumulator is isolated.	12 hours
SR 3.4.11.2 Verify each MHSI pump capable of injecting into the RCS has its associated miniflow line open.	12 hours

SURVEILLANCE REQUIREMENTS (continued)

SURVEILLANCE		FREQUENCY
SR 3.4.11.3	Verify required RCS vent \geq 10.1 square inches open.	12 hours for unlocked open vent valve(s) <u>AND</u> 31 days for other vent path(s)
SR 3.4.11.4	Verify RCP start limitations are met.	Once within 15 minutes prior to each start of an RCP

3.4 REACTOR COOLANT SYSTEM (RCS)

3.4.12 RCS Operational LEAKAGE

LCO 3.4.12 RCS operational LEAKAGE shall be limited to:

- a. No pressure boundary LEAKAGE;
- b. 1 gpm unidentified LEAKAGE;
- c. 10 gpm identified LEAKAGE; and
- d. 150 gallons per day primary to secondary LEAKAGE through any one steam generator (SG).

APPLICABILITY: MODES 1, 2, 3, and 4.

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. RCS operational LEAKAGE not within limits for reasons other than pressure boundary LEAKAGE or primary to secondary LEAKAGE.	A.1 Reduce LEAKAGE to within limits.	4 hours
B. Required Action and associated Completion Time of Condition A not met. <u>OR</u> Pressure boundary LEAKAGE exists. <u>OR</u> Primary to secondary LEAKAGE not within limit.	B.1 Be in MODE 3. <u>AND</u> B.2 Be in MODE 5.	6 hours 36 hours

SURVEILLANCE REQUIREMENTS

SURVEILLANCE	FREQUENCY
<p>SR 3.4.12.1 -----NOTES-----</p> <ol style="list-style-type: none"> 1. Not required to be performed until 12 hours after establishment of steady state operation. 2. Not applicable to primary to secondary LEAKAGE. <p>-----</p> <p>Verify RCS operational LEAKAGE is within limits by performance of RCS water inventory balance.</p>	<p>72 hours</p>
<p>SR 3.4.12.2 -----NOTE-----</p> <p>Not required to be performed until 12 hours after establishment of steady state operation.</p> <p>-----</p> <p>Verify primary to secondary LEAKAGE is \leq 150 gallons per day through any one SG.</p>	<p>72 hours</p>

3.4 REACTOR COOLANT SYSTEM (RCS)

3.4.13 RCS Pressure Isolation Valve (PIV) Leakage

LCO 3.4.13 Leakage from each RCS PIV shall be within limit.

APPLICABILITY: MODES 1, 2, and 3,
MODE 4, except valves in the residual heat removal (RHR) flow path
when in, or during the transition to or from, the RHR mode of
operation.

ACTIONS

NOTES

1. Separate Condition entry is allowed for each flow path.
2. Enter applicable Conditions and Required Actions for systems made inoperable by an inoperable PIV.

CONDITION	REQUIRED ACTION	COMPLETION TIME
<p>A. One or more flow paths with leakage from one or more RCS PIVs not within limit.</p>	<p>-----NOTE----- Each valve used to satisfy Required Action A.1 must have been verified to meet SR 3.4.13.1 and be in the reactor coolant pressure boundary or the high pressure portion of the system.</p> <hr/> <p>A.1 Isolate the high pressure portion of the affected system from the low pressure portion by use of one closed manual, deactivated automatic, or check valve.</p> <p><u>AND</u></p>	<p>4 hours</p>

ACTIONS (continued)

CONDITION	REQUIRED ACTION	COMPLETION TIME
	<p>A.2.1 Isolate the high pressure portion of the affected system from the low pressure portion by use of a second closed manual, deactivated automatic, or check valve.</p> <p><u>OR</u></p> <p>A.2.2 Restore RCS PIV to within limits.</p>	<p>72 hours</p> <p>72 hours</p>
<p>B. Required Action and associated Completion Time not met.</p>	<p>B.1 Be in MODE 3.</p> <p><u>AND</u></p> <p>B.2 Be in MODE 5.</p>	<p>6 hours</p> <p>36 hours</p>

SURVEILLANCE REQUIREMENTS

SURVEILLANCE	FREQUENCY
<p>SR 3.4.13.1 -----NOTES-----</p> <ol style="list-style-type: none"> 1. Not required to be performed in MODES 3 and 4. 2. Not required to be performed on the RCS PIVs located in the RHR flow path when operating in the RHR mode. 3. RCS PIVs actuated during the performance of this Surveillance are not required to be tested more than once if a repetitive testing loop cannot be avoided. <p>-----</p> <p>Verify leakage from each RCS PIV is equivalent to ≤ 0.5 gpm per nominal inch of valve size up to a maximum of 5.0 gpm at an RCS pressure of ≥ 2215 psig and ≤ 2255 psig.</p>	<p>In accordance with the Inservice Testing Program, and 24 months</p> <p><u>AND</u></p> <p>Prior to entering MODE 2 whenever the unit has been in MODE 5 for 7 days or more, if leakage testing has not been performed in the previous 9 months</p> <p><u>AND</u></p> <p>Within 24 hours following valve actuation due to automatic or manual action or flow through the valve</p>

3.4 REACTOR COOLANT SYSTEM (RCS)

3.4.14 RCS Leakage Detection Instrumentation

LCO 3.4.14 The following RCS leakage detection instrumentation shall be OPERABLE:

- a. One containment sump (level or discharge flow) monitor;
- b. One containment atmosphere radioactivity (particulate) monitor; and
- c. One containment air cooler condensate flow rate monitor.

APPLICABILITY: MODES 1, 2, 3, and 4.

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. Required containment sump monitor inoperable.	<p>A.1 -----NOTE----- Not required until 12 hours after establishment of steady state operation. -----</p> <p>Perform SR 3.4.12.1.</p> <p><u>AND</u></p> <p>A.2 Restore required containment sump monitor to OPERABLE status.</p>	<p>Once per 24 hours</p> <p>30 days</p>

ACTIONS (continued)

CONDITION	REQUIRED ACTION	COMPLETION TIME
<p>B. Required containment atmosphere radioactivity monitor inoperable.</p>	<p>B.1.1 Analyze grab samples of the containment atmosphere.</p>	<p>Once per 24 hours</p>
	<p><u>OR</u></p>	
	<p>B.1.2 -----NOTE----- Not required until 12 hours after establishment of steady state operation. -----</p>	
	<p>Perform SR 3.4.12.1.</p>	<p>Once per 24 hours</p>
	<p><u>AND</u></p>	
	<p>B.2.1 Restore required containment atmosphere radioactivity monitor to OPERABLE status.</p>	<p>30 days</p>
	<p><u>OR</u></p>	
	<p>B.2.2 Verify containment air cooler condensate flow rate monitor is OPERABLE.</p>	<p>30 days</p>
<p>C. Required containment air cooler condensate flow rate monitor inoperable.</p>	<p>C.1 Analyze grab samples of the containment atmosphere.</p>	<p>Once per 24 hours</p>
	<p><u>OR</u></p>	
	<p>C.2 -----NOTE----- Not required until 12 hours after establishment of steady state operation. -----</p>	
	<p>Perform SR 3.4.12.1.</p>	<p>Once per 24 hours</p>

ACTIONS (continued)

CONDITION	REQUIRED ACTION	COMPLETION TIME
D. Required containment atmosphere radioactivity monitor inoperable. <u>AND</u> Required containment air cooler condensate flow rate monitor inoperable.	D.1 Restore required containment atmosphere radioactivity monitor to OPERABLE status.	30 days
	<u>OR</u> D.2 Restore required containment air cooler condensate flow rate monitor to OPERABLE status.	30 days
E. Required Action and associated Completion Time not met.	E.1 Be in MODE 3.	6 hours
	<u>AND</u> E.2 Be in MODE 5.	36 hours
F. All required monitors inoperable.	F.1 Enter LCO 3.0.3.	Immediately

SURVEILLANCE REQUIREMENTS

SURVEILLANCE		FREQUENCY
SR 3.4.14.1	Perform a CHANNEL CHECK of the required containment atmosphere radioactivity monitor.	12 hours
SR 3.4.14.2	Perform a CALIBRATION of the required containment sump monitor.	24 months

SURVEILLANCE REQUIREMENTS (Continued)

SURVEILLANCE		FREQUENCY
SR 3.4.14.3	Perform a CALIBRATION of the required containment atmosphere radioactivity monitor.	24 months
SR 3.4.14.4	Perform a CALIBRATION of the required containment air cooler condensate flow rate monitor.	24 months
SR 3.4.14.5	Perform SENSOR OPERATIONAL TEST of the required containment atmosphere radioactivity monitor.	24 months

3.4 REACTOR COOLANT SYSTEM (RCS)

3.4.15 RCS Specific Activity

LCO 3.4.15 RCS DOSE EQUIVALENT I-131 and DOSE EQUIVALENT XE-133 specific activity shall be within limits.

APPLICABILITY: MODES 1, 2, 3, and 4.

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
<p>A. DOSE EQUIVALENT I-131 not within limit.</p>	<p>-----NOTE----- LCO 3.0.4.c is applicable. -----</p> <p>A.1 Verify DOSE EQUIVALENT I-131 $\leq 1.0 \mu\text{Ci/gm}$.</p> <p><u>AND</u></p> <p>A.2 Restore DOSE EQUIVALENT I-131 to within limit.</p>	<p>Once per 4 hours</p> <p>48 hours</p>
<p>B. DOSE EQUIVALENT XE-133 not within limit.</p>	<p>-----NOTE----- LCO 3.0.4.c is applicable. -----</p> <p>B.1 Restore DOSE EQUIVALENT XE-133 to within limit.</p>	<p>48 hours</p>

ACTIONS (continued)

CONDITION	REQUIRED ACTION	COMPLETION TIME
C. Required Action and associated Completion Time of Condition A or B not met. <u>OR</u> DOSE EQUIVALENT I-131 > 1.0 µCi/gm.	C.1 Be in MODE 3. <u>AND</u>	6 hours
	C.2 Be in MODE 5.	36 hours

SURVEILLANCE REQUIREMENTS

SURVEILLANCE	FREQUENCY
SR 3.4.15.1 -----NOTE----- Only required to be performed in MODE 1. ----- Verify reactor coolant DOSE EQUIVALENT XE-133 specific activity ≤ 210 µCi/gm.	7 days
SR 3.4.15.2 -----NOTE----- Only required to be performed in MODE 1. ----- Verify reactor coolant DOSE EQUIVALENT I-131 specific activity ≤ 0.45 µCi/gm.	14 days <u>AND</u> Once between 2 and 6 hours after a THERMAL POWER change of ≥ 15% RTP within a 1 hour period

3.4 REACTOR COOLANT SYSTEM (RCS)

3.4.16 Steam Generator (SG) Tube Integrity

LCO 3.4.16 SG tube integrity shall be maintained.

AND

All SG tubes satisfying the tube repair criteria shall be plugged in accordance with the Steam Generator Program.

APPLICABILITY: MODES 1, 2, 3, and 4.

ACTIONS

-----NOTE-----
Separate Condition entry is allowed for each SG tube.

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. One or more SG tubes satisfying the tube repair criteria and not plugged in accordance with the Steam Generator Program.	A.1 Verify tube integrity of the affected tube(s) is maintained until the next refueling outage or SG tube inspection. <u>AND</u> A.2 Plug the affected tube(s) in accordance with the Steam Generator Program.	7 days Prior to entering MODE 4 following the next refueling outage or SG tube inspection
B. Required Action and associated Completion Time of Condition A not met. <u>OR</u> SG tube integrity not maintained.	B.1 Be in MODE 3. <u>AND</u> B.2 Be in MODE 5.	6 hours 36 hours

SURVEILLANCE REQUIREMENTS

SURVEILLANCE		FREQUENCY
SR 3.4.16.1	Verify SG tube integrity in accordance with the Steam Generator Program.	In accordance with the Steam Generator Program
SR 3.4.16.2	Verify that each inspected SG tube that satisfies the tube repair criteria is plugged in accordance with the Steam Generator Program.	Prior to entering MODE 4 following an SG tube inspection

3.4 REACTOR COOLANT SYSTEM (RCS)

3.4.17 RCS Loops - Test Exceptions

LCO 3.4.17 The requirements of LCO 3.4.4, "RCS Loops – MODES 1 and 2," may be suspended provided THERMAL POWER is < 5% RTP.

APPLICABILITY: MODES 1 and 2 during startup and PHYSICS TESTS.

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. THERMAL POWER not within limit.	A.1 Open reactor trip breakers.	Immediately

SURVEILLANCE REQUIREMENTS

SURVEILLANCE	FREQUENCY
SR 3.4.17.1 Verify THERMAL POWER is \leq 5% RTP.	1 hour