



Nuclear Regulatory Commission  
 Exhibit # - NRC000036-00-BD01  
 Docket # - 05200012 | 05200013  
 Identified: 08/18/2011

Admitted: 08/18/2011      Withdrawn:  
 Rejected:                      Stricken:

NRC000036  
 05/09/2011

Rev. 04

**STP 3 & 4**

**Environmental Report**

**1.0. Introduction**

This chapter presents an overview of the proposed STP 3 & 4 project that is the subject of this Environmental Report (ER). A brief description is given regarding the applicants, purpose and need, general plant description, status of permits and required consultations, and the underlying methodology of the report presentation. These items are presented in the following three subsections:

- The Proposed Project (Section 1.1)
- Status of Reviews, Approvals, and Consultations (Section 1.2)
- Methodology (Section 1.3S)

**1.1 The Proposed Project**

Pursuant to the Atomic Energy Act of 1954, as amended, and Title 10 of the Code of Federal Regulations, the Nuclear Regulatory Commission (NRC) is responsible for issuing a license for construction and operation of domestic nuclear power plants. In accordance with the provisions of 10 CFR Part 52, Subpart C (Combined Licenses), and supporting guidance (e.g., NRC Regulatory Guides), STP Nuclear Operating Company (STPNOC) on behalf of itself and the owners of STP 3 & 4: NINA-South Texas 3 LLC, NINA-South Texas 4 LLC, and the City of San Antonio, Texas acting by and through the City Public Service Board (CPS Energy) is applying an application for a Combined Operating Licenses (COLs) to authorize for construction and operation of two new nuclear power facilities-STP 3 & 4-on the site of South Texas Project Electric Generating Station, Units 1 & 2 (STP 1 & 2) in Matagorda County, Texas (STP site). STPNOC is including with the COL application this ER, which has been prepared in accordance with the provisions of 10 CFR Part 51. The ER provides an analysis of the impacts to the environment from site preparation, construction, operation, and decommissioning of two additional nuclear reactors-STP 3 & 4-at the STP site. The combined impacts of all four units at the STP site are also considered. NRC will use the ER as input to meet the National Environmental Policy Act of 1969 (42 United States Code [U.S.C.] 4321-4347, January 1, 1970, as amended) requirement that federal agencies consider the impacts that their actions, such as license issuance, might have on the environment.

**1.1.1 Purpose and Need**

The proposed action is NRC issuance of COLs to the applicants authorizing the construction and operation of two U.S. Advanced Boiling Water Reactors (ABWRs) at the STP site. The purpose of STP 3 & 4 is to provide baseload generation for use by the owners and/or for eventual sale on the wholesale market. STP 3 will be owned by NINA-South Texas 3 LLC and CPS Energy, and STP 4 will be owned by NINA-South Texas 4 LLC and CPS Energy.

As explained in Chapter 8 of this report, there is a need for the power to be produced from STP 3 & 4. NRC approval gives the owners a generation option that the owners may or may not exercise, at their discretion.

## 1.1.2 Project Description

This subsection provides a brief summary of project information that subsequent sections, particularly Chapter 3, Plant Description, describe in greater detail.

### 1.1.2.1 The Applicant and Owners

NRG South Texas LP (NRG) (44% ownership), City Public Service Board of San Antonio, Texas (CPS Energy) (40% ownership), and the City of Austin, Texas (16% ownership) are the owners of the STP 1 & 2 site and facilities. STPNOC is the licensed operator of STP 1 & 2, with control of STP 1 & 2 and the authority to act as the agent applying for a COL for the STP site. STP 3 will be owned by NINA-South Texas 3 LLC and CPS Energy, and STP 4 will be owned by NINA-South Texas 4 LLC and CPS Energy. Pursuant to existing agreements, the ~~NRG entities and CPS Energy would each own 50% of each unit.~~ NINA entities would own 92.375% of each unit while CPS Energy would own 7.625% of each unit. If plans regarding the ownership percentages change, this application will be updated accordingly. The proposed units would be baseload merchant generator plants. NINA-South Texas 3 LLC and NINA-South Texas 4 LLC intends to sell its share of the power from STP 3 & 4 on the wholesale market. CPS Energy may either use its share of STP 3 & 4 to supply the needs of its service area and/or sell the power on the wholesale market.

STPNOC will be the operator for STP 3 & 4. The COL application, COLA Part 1, Administrative Information, provides additional information about the co-owners of STP 3 & 4.

### 1.1.2.2 Site Location

The STP site is located on approximately 12,220 acres in a rural area of Matagorda County, Texas, approximately 12 miles south-southwest of the city limits of Bay City, Texas, and 10 miles north of Matagorda Bay, along the west bank of the Colorado River. The plant footprint for STP 3 & 4 is approximately 2000 feet northwest of existing STP 1 & 2 and is generally the area that had been designated for two additional units when the facility was first planned. The location of STP 3 & 4 on the STP site is shown on Figure 1.1-1. Section 2.1, Site Location, provides additional information regarding the site and the location of the two new ABWR reactors.

### 1.1.2.3 Reactor Information

STPNOC and the owners have selected the General Electric (GE) ABWR as the technology for two new reactors at the STP site, STP 3 & 4. The NRC approved the reference ABWR DCD in March 1997. The final design certification rule was published in the Federal Register on May 12, 1997 (62 FR 25827). This allows the ABWR design to be referenced in a COL application under 10 CFR 52. The total gross thermal megawatt output is 3926 MWt and the net electrical output is approximately 1300 MWe per unit. Further details on the ABWR reactor design is provided in Section 3.2.

### 1.1.2.4 Cooling System Information

STP 3 & 4 will use a closed-loop cooling water system that would withdraw and discharge water from and to the Main Cooling Reservoir (MCR), similar to the existing

cooling system for STP 1 & 2. Makeup water for the MCR will be withdrawn from the Colorado River using the preexisting intake structure. STP 3 & 4 will use mechanical draft cooling towers to dissipate waste heat and a water storage basin for the safety-related cooling system. This differs from STP 1 & 2, which uses the essential cooling pond. The STP 3 & 4 cooling tower basin makeup water is normally provided by the plant well water system. Blowdown will discharge from the MCR to the Colorado River. Additional details regarding the STP 3 & 4 cooling system are provided in Section 3.4.

#### **1.1.2.5 Transmission System Information**

The STP 3 & 4 connections to the regional grid will use existing rights-of-way to minimize, to the extent feasible, new disturbance and potential adverse impacts. The onsite power transmission system for STP 3 & 4 consists of the STP 3 & 4 345kV switchyard, five 345kV power transmission lines, and a 345kV tie-line from the STP 3 & 4 345kV switchyard to the existing STP 1 & 2 345kV switchyard. Two of these 345kV transmission lines will be upgraded from the STP site to their connection to the Hillje substation some 20 miles northwest of the STP site. The modifications to upgrade these two transmission lines will be on an existing right-of-way. No new rights-of-way outside the STP site are required for STP 3 & 4.

The three interconnect transmission line rights-of-way commence from the STP 3 & 4 345kV switchyard and head northward less than a quarter mile to intersect the existing transmission line corridor. From the point of intersection, the additional power provided by STP 3 & 4 would be transmitted over upgraded circuits in an existing right-of-way. Subsection 2.2.2 and Section 3.7 provide additional details regarding both the onsite and offsite transmission systems.

#### **1.1.2.6 Preapplication Public Involvement**

STPNOC has an active community affairs and public outreach program. Examples of public outreach include community board meetings, student presentations, and emergency preparedness community activities. STPNOC offers educational and emergency preparedness information to the public by providing tours of the Control Room simulator and the Emergency Operations Facility, presentations during Career Day, distributing flyers and newsletters, and by advertising on local radio stations and in local newspapers.

STPNOC also plays an active role in supporting local philanthropy efforts including the United Way Foundation, the American Cancer Society, the American Red Cross, the March of Dimes, and the Palacios Boys & Girls Club.

STPNOC plans to continue conducting public outreach and communications efforts in conjunction with preparing the COL application. Examples of STP 3 & 4 communications include: fact sheets; presentations; interaction with civic, state, and local officials; and industry updates and interfaces. Several meetings with local officials, the community, and the NRC are anticipated through the start of commercial operations. The first public outreach meeting held by the NRC in Bay City occurred on June 27, 2007. This meeting was announced via local media outlets (e.g. newspapers).

**1.1.2.7 Proposed Dates for Major Activities**

NRC regulations provide for COL applicants to perform both preconstruction site preparation activities and limited work authorization (LWA) activities before issuance of the COL. STPNOC plans to start preconstruction activities in January 2009 and conclude these activities in January 2010. If LWA activities are to be performed, they may begin in January 2010 and conclude in January 2011.

Construction activities for STP 3 will begin following the site preparation for both STP 3 & 4. STPNOC expects to initiate construction of STP 3 in January 2011 and STP 4 in May 2011. STPNOC estimates that construction would occur over a 63-month period for both units, beginning with NRC approval of the COL application in January 2011. Commercial operation for STP 3 is projected in March 2015 and March 2016 for STP 4.




Figure 1.1-1 Site Layout



## 8.0 Need for Power

The electric utility industry in the State of Texas was deregulated in 2002. One of the principal owners of STP 3 & 4 is a merchant generator that does not have a specific service area and the other owner sells excess capacity in the Electric Reliability Council of Texas (ERCOT) wholesale market. Therefore, STP Nuclear Operating Company (STPNOC) has defined the region of interest for evaluating the need for power and alternative sites (Section 9.3) as the entire area served by ERCOT, which is the independent system operator for the electric grid for most of Texas. STPNOC is relying upon several studies performed for or by ERCOT for its need for power evaluation.

This chapter provides an evaluation of the need for power. According to NUREG-1555, an NRC independent evaluation may not be needed if the NRC determines that the State/region-prepared evaluation is (1) systematic, (2) comprehensive, (3) subject to confirmation, and (4) responsive to forecasting uncertainty. As discussed in more detail below, the ERCOT studies related to need for power satisfy these four criteria and provide an appropriate basis for the need for power evaluation for STP 3 & 4.

The following ERCOT studies were used for this evaluation:

- The Report on Existing and Potential Electric System Constraints and Needs (Reference 8.0-1) identifies and analyzes existing and potential constraints in the ERCOT transmission system that could either pose reliability concerns or increase costs to the electric power market and Texas consumers. This report is used in Section 8.1.
- The Long-Term Forecast Model (LTFM) is used in the Long-Term Hourly Peak Demand and Energy Forecast (Reference 8.0-2) to predict the peak hourly power demand and energy consumption for each of the next ten years. Some of the calculations are extrapolated to 2025. The forecast is based on the latest hourly peak demands for the region and adjusted for economic and weather variables. This report is described more completely in Section 8.2.
- The Report on the Capacity, Demand, and Reserves (Reference 8.0-3) is developed from data provided by the market participants as part of the annual load data request, the generation asset registrations, and from data collected for the annual U.S. Department of Energy Coordinated Bulk Power Supply Program Report. The working paper is a series of spreadsheets that compares demand load forecasts from other ERCOT analyses with the generation resources reported to be available by market participants, and calculates reserve margins. This report is the basis for Sections 8.3 and 8.4.
- The last report is the ERCOT Long Term System Assessment (Reference 8.0-4), which uses available data to predict the type and general location of new generation that the market may find economic to construct. ERCOT recognizes in the report that it cannot control these decisions, but the ERCOT estimation of



market behavior provides a reasonable basis on which to assess longer-term transmission needs under a range of scenarios.

Subsection 8.4.2 demonstrates that these reports satisfy the criteria in NUREG-1555 for a reliable independent evaluation of the need for power.

As described in Section 8.1, the owners of STP 3 & 4 are NINA and CPS Energy, who are both market participants in the ERCOT system. As such, they recognize ERCOT's legal responsibilities under Public Utility Commission of Texas (PUCT) oversight, and support ERCOT in achieving its vision and mission through the open and collaborative process involving electric industry members, customers, and regulators. NINA and CPS Energy endorse the ERCOT studies that were prepared to inform the PUCT, the Texas Legislature, the public, and the market participants. They accept the assumptions made in the studies and believe that ERCOT is providing valuable and accurate assessments of the ERCOT system for the benefit of all ERCOT members. One of the benefits of deregulation was to consolidate regional planning under a single entity with the expertise and resources necessary to accurately and efficiently ensure that the entire region was proceeding on a course that benefits everyone.

The remainder of this chapter provides the following information:

- A description of the project owners (Section 8.1)
- A description of the PUCT and ERCOT (Section 8.1)
- A discussion of the deregulation of electric generation in the State of Texas and associated market forces (Section 8.1)
- A description of the ERCOT studies and a discussion of the forecast for demand for power provided in those studies (including reserve margins specified by ERCOT) (Section 8.2)
- A discussion of the generation capacity in the ERCOT region (Section 8.3)
- Conclusions related to the need for power from STP 3&4 (Section 8.4)

### **8.0.1 References**

- 8.0-1 ERCOT Report on Existing and Potential Electric System Constraints and Needs, December 2006, available at [http://www.ercot.com/news/presentations/2006/2006\\_ERCOT\\_Reports\\_Transmission\\_Constraints\\_and\\_Needs.pdf](http://www.ercot.com/news/presentations/2006/2006_ERCOT_Reports_Transmission_Constraints_and_Needs.pdf).
- 8.0-2 2007 ERCOT Planning Long-Term Hourly Peak Demand and Energy Forecast – May 8, 2007, available at [http://www.ercot.com/news/presentations/2007/2007\\_ERCOT\\_Planning\\_Long\\_Term\\_Hourly\\_Demand\\_Energy\\_Forecast\\_.pdf](http://www.ercot.com/news/presentations/2007/2007_ERCOT_Planning_Long_Term_Hourly_Demand_Energy_Forecast_.pdf).



- 8.0-3 Report on the Capacity, Demand, and Reserves in the ERCOT Region, May 2007, available at <http://www.ercot.com/news/presentations/2007/07CDR05172007-final.xls>.
- 8.0-4 Long Term System Assessment for the ERCOT Region, December 2006, available at [http://www.ercot.com/news/presentations/2006/Attch\\_A\\_-\\_Long\\_Term\\_System\\_Assessment\\_ERCOT\\_Region\\_December\\_.pdf](http://www.ercot.com/news/presentations/2006/Attch_A_-_Long_Term_System_Assessment_ERCOT_Region_December_.pdf).



## 8.1 Description of Power System

### 8.1.1 Project Description and Owners

South Texas Project Unit 3 will be owned by NINA ~~South~~-Texas 3 LLC and the City of San Antonio, Texas, acting by and through the City Public Service Board (CPS or CPS Energy). South Texas Project Unit 4 will be owned by NINA ~~South~~-Texas 4 LLC and CPS Energy. Once licensed and built, STP 3 & 4 will be operated by STP Nuclear Operating Company. STP 3 & 4 each utilizes the GE Advanced Boiling Water Reactor (ABWR) light water reactor design rated at approximately 1370 MWe (gross). Initial commercial operation for STP 3 & 4 is expected to be June 2015 and July 2016, respectively.

NINA ~~South~~-Texas 3 LLC and NINA ~~South~~-Texas 4 LLC are indirectly majority-owned and controlled by NRG Energy, Inc. (NRG Energy). In this discussion, "NRG" is used when referring to NRG Energy, the parent, or to one of the NINA ~~South~~-Texas LLCs. Further detail regarding the ownership of the NRG LLCs is provided in Part 1 of the COLA. NRG is a wholesale power generation company, primarily engaged in the ownership and operation of power generation facilities and the sale of energy, capacity and related products in the United States and internationally. NRG has a diverse portfolio of electric generation facilities in terms of geography, fuel type, and dispatch levels. NRG does not meet the definition of an electric utility in 10 CFR 50.2. NRG is a merchant generator that will sell its share of the electricity generated at STP 3 & 4 to the wholesale market in bilateral transactions with wholesale purchasers of electric power and at market prices. As such, NRG does not have a specific service area in the traditional sense of pre-deregulation utilities. The area of Texas that is served by the Electric Reliability Council of Texas (ERCOT) is the area in which NRG intends to sell its power.

As a municipal utility, CPS Energy meets the definition of an electric utility in 10 CFR 50.2, that provides retail power to its service area around San Antonio, which is within the ERCOT region, and sells excess capacity to wholesale buyers anywhere within the ERCOT system. The CPS Energy electric system serves a territory consisting of substantially all of Bexar County and small portions of the adjacent counties. Certification of this service area has been approved by the Public Utility Commission of Texas (PUCT). CPS Energy is currently the exclusive provider of electric service within this service area. Until and unless the San Antonio City Council and the CPS Energy Board exercise the option to opt-in to retail electric competition, CPS Energy has the sole right to provide retail electric services in its service area (Reference 8.1-1). The ERCOT studies being relied upon for the need for power evaluation include the CPS Energy electric system.

In addition to the area served at retail rates, CPS Energy currently has wholesale supply agreements to sell wholesale electricity to the Floresville Electric Light & Power System, the City of Hondo, and the City of Castroville. These three wholesale supply agreements have remaining terms ranging from less than one to ten years, although all of the agreements provide for extensions. Discussions are ongoing with all three entities to renew their respective long-term wholesale power agreements. Additionally,

CPS Energy has recently entered into several one-year wholesale supply agreements with various other municipalities and cooperatives. CPS Energy will seek additional opportunities to enter into long-term wholesale electric power agreements in the future. The requirements under the existing and any new wholesale agreements would be firm energy obligations of CPS Energy (Reference 8.1-1). In any event, because the need for power evaluation for STP 3 & 4 is based on the need for power in the entire ERCOT region, these supply agreements are not material to the need for power from STP 3 & 4 or the need for CPS Energy to develop additional generation to meet the needs of the growing customer base within its certificated service area.

### 8.1.2 Public Utility Commission and Electric Reliability Council of Texas

In 1975, Texas became the last state in the country to provide for state-wide comprehensive regulation of electric utilities by creating the Public Utility Commission of Texas (PUCT). For approximately the first 20 years of the PUCT's existence, its primary role was traditional regulation of electric and telecommunications utilities. Significant legislation enacted by the Texas Legislature in 1995 dramatically changed this role by creating a competitive electric wholesale market. In 1999, the Legislature provided for restructuring of the electric utility industry, further changing the PUCT's mission and focus (Reference 8.1-2).

Although the PUCT's traditional regulatory functions have decreased since 1999, many of those functions have been replaced by other, more challenging responsibilities. Restructuring of the utility industry is not simply elimination of regulation. Effective oversight of competitive wholesale and retail markets is necessary to ensure that customers receive the benefits of competition. The PUCT's responsibilities under the Public Utilities Regulatory Act (PURA) include the following (Reference 8.1-2):

- Issuance of certificates of convenience and necessity for proposed transmission lines
- Licensing of retail electric providers
- Registration of power generation companies and aggregators
- Oversight of competitive wholesale and retail markets
- Resolution of customer complaints, using informal processes whenever possible
- Implementation of a customer education program for retail electric choice
- Regulation of vertically integrated investor owned utilities outside ERCOT
- Jurisdiction over ratemaking and quality of service of transmission and distribution utilities within ERCOT
- Establishing wholesale transmission rates for investor owned utilities, cooperatives, and municipally-owned utilities within ERCOT

ERCOT is a membership-based 501(c)(6) nonprofit corporation governed by a board of directors and subject to oversight by the PUCT and the Texas Legislature. ERCOT's members include retail consumers, investor- and municipally-owned utilities, rural electric cooperatives, river authorities, independent generators, power marketers, and retail electric providers (Reference 8.1-3). The ERCOT board of directors is made up of independent members, consumers, and representatives from each of ERCOT's electric market segments. The board of directors appoints ERCOT's officers to direct and manage ERCOT's day-to-day operations, accompanied by a team of executives and managers responsible for critical components of ERCOT's operations areas (Reference 8.1-4).

ERCOT manages the flow of electric power to approximately 20 million Texas customers, representing 85% of the state's electric load and 75% of the state's land area (approximately 200,000 square miles). Figure 8.1-1 depicts the ERCOT region. As the independent system operator (ISO) for the region, ERCOT schedules power on an electric grid that connects 38,000 miles of high-voltage transmission lines and more than 500 generation units. ERCOT also manages financial settlements for the competitive wholesale bulk-power market and administers customer switching for 5.9 million Texans in competitive choice areas (Reference 8.1-3).

ERCOT performs three main roles in managing the electric power grid and marketplace (Reference 8.1-5):

- Monitor schedules submitted by wholesale buyers and sellers for the next day's electricity supply. ERCOT ensures the system can accommodate those schedules and, if necessary, creates a new market to fill the gap.
- Ensure electricity transmission reliability by managing the incoming and outgoing supply of electricity over the grid. ERCOT monitors the flow of power and issues instructions to generation and transmission companies to maintain balance.
- Serve as the central hub for retail transactions. When a consumer chooses a retail electric provider, ERCOT ensures the information related to that transaction is conveyed to the appropriate companies in a timely manner.

The ERCOT region is almost entirely isolated from other areas. At the beginning of World War II, several electric utilities in Texas banded together as the Texas Interconnected System (TIS) to support the war effort. They sent their excess power generation to industrial manufacturing companies on the Gulf Coast to provide reliable supplies of electricity for energy-intensive aluminum smelting. Recognizing the reliability advantages of remaining interconnected, the TIS members continued to use and develop the interconnected grid. TIS members adopted official operating guides for their interconnected power system and established two monitoring centers within the control centers of two utilities, one in North Texas and one in South Texas. TIS formed ERCOT in 1970 to comply with North American Reliability Council (NERC) requirements (Reference 8.1-6). The goal of TIS, and later ERCOT, was not to create ties with the rest of the country, but to assure that the Texas grid was reliable through interconnection. Even today, there are only a few asynchronous ties that go outside

of the ERCOT region with a total capacity of approximately 1100 MW. There are also approximately 2,850 MW of “switchable” generation resources that can be connected to either the ERCOT transmission grid or a grid outside the ERCOT region. There is currently no indication of plans to increase either the asynchronous MW or the switchable resources (Reference 8.1-7). While this means that ERCOT can only export a very small amount of power, it also means that ERCOT cannot import significant amounts of power. This becomes an important fact when considering the need for power in the ERCOT region. Essentially, all power required to supply the ERCOT region loads must be generated within the ERCOT region.

Representatives of all segments of ERCOT’s market participants collaboratively created the ERCOT Protocols, which is the governing document adopted by ERCOT that contains the scheduling, operating, planning, reliability, and settlement policies, rules, guidelines, procedures, standards, and criteria of ERCOT. These Protocols were approved by the PUCT and amendments are subject to PUCT review and modification. The Protocols are intended to implement ERCOT’s functions as the Independent Organization for the ERCOT Region as certified by the PUCT. The ERCOT Board, Technical Advisory Committee (TAC), and other ERCOT subcommittees authorized by the Board or the TAC, may develop procedures, forms and applications for the implementation of and operation under the Protocols. ERCOT and its market participants must abide by the Protocols (Reference 8.1-8).

Since deregulation of the electric supply market in the ERCOT region, utilities no longer perform the comprehensive analysis and planning functions they once did. The central planning organization under the new Texas market is the ERCOT ISO. State law assigns these obligations to ERCOT, under the oversight of the PUCT. The analyses, reports, system planning processes, and criteria development from ERCOT are the key measures for determining resource needs in the state [See *e. g.*, Tex. Util. Code Ann. §§ 39.155(b) and 39.904(k)].

### 8.1.3 Deregulation of the Texas Electric Utility Industry

The traditional discussion of the need for power, including a description of the power system, service areas, regional relationships, power pool agreements, electrical transfer capabilities, diversity interchange agreements, wheeling contracts, types of customers, and major electrical load centers, generally does not apply in the case of STP 3 & 4 because the electrical utility industry in Texas has been deregulated.

In 1995, the Texas Legislature passed Senate Bill 373 (SB 373) introducing wholesale competition into Texas’ intrastate markets. Under what is now Chapter 35 of the PURA, prior bilateral transactions addressing use of the interconnected transmission systems of vertically integrated utilities within ERCOT were replaced by PUCT-regulated open access requirements and a methodology for placement of new merchant generation. SB 373 directed the PUCT to adopt rules requiring all transmission system owners to make their transmission systems available for use by others at prices and on terms comparable to each respective owner’s use of its system for its own wholesale transactions. The PUCT implemented its initial transmission open access rules in January 1997.

During the 1999 legislative session, the Texas Legislature enacted Senate Bill 7 (SB 7), providing for retail electric open competition that began in 2002. SB 7 continued electric transmission wholesale open access and fundamentally redefined and restructured the Texas electric industry. SB 7 allowed retail customers of investor-owned utilities (IOUs) to choose their electric energy supplier (Reference 8.1-1). SB 7 allowed municipally-owned utilities and electric cooperatives to remain non-opt-in entities (NOIEs) until they choose to enter competition. Most have elected to remain NOIEs. Therefore, the customers within the service areas of most electric cooperatives and municipally-owned utilities are not able to choose their electric energy supplier.

Under the terms of SB 7, NOIEs may remain vertically integrated electric utilities offering generation, transmission, and distribution services. However, SB 7 required IOUs to separate their retail energy service activities from regulated utility activities and to unbundle their generation, transmission/distribution, and retail electric sales functions into separate units. An IOU could choose to sell one or more of its lines of business to independent entities, or it could create separate but affiliated companies, and possibly operating divisions, that could be owned by a common holding company, but which must operate largely independent of each other subject to code of conduct restrictions under PUCT rules. The services offered by transmission entities had to be available to other parties on a non-discriminatory basis (Reference 8.1-1).

IOUs and independent power producers owning generation assets must be registered as Power Generation Companies (PGCs) with the PUCT and must comply with certain rules that are intended to protect consumers, but they are otherwise unregulated and may sell electricity in private bilateral transactions and at market prices (Reference 8.1-1).

IOU owners of transmission and/or distribution facilities, or Transmission Service Providers (TSPs), are fully regulated by the PUCT. IOU TSPs, Municipal Utilities, Electric Co-ops, and other entities providing transmission and distribution service are obligated to deliver the electricity to retail customers. These utilities are also required to transport power to wholesale buyers. TSPs are required to provide access to both their transmission and distribution systems on a non-discriminatory basis to all eligible customers (Reference 8.1-1).

Retail sales activities in the IOU service areas are performed by Retail Electric Providers (REPs) on a “customer choice” basis. These are the only entities authorized to sell electricity to retail customers. REPs must register with the PUCT, demonstrate financial capabilities, and comply with certain customer protection requirements. REPs buy electricity from PGCs, power marketers, or other parties and may resell that electricity to retail customers at any location in Texas other than within the service areas of Municipal Utilities and Electric Co-ops (Reference 8.1-1).

#### **8.1.4 Market Economic Forces**

Beyond compliance with operational procedures, ERCOT does not have authority over the business activities of its market participants. The economic forces of the market




and signed agreements by the market participants provide the cooperative atmosphere in which the ERCOT system functions.

Figures 8.1-2 and 8.1-3 demonstrate the market economic forces at work. Since 1999, ERCOT market participants have made the economic decision to decommission 95 units with a total generation capacity of 3,536 MW (Figure 8.1-2). These decisions were based on economic parameters such as unit efficiency, age, capacity, cost of operation, outage frequency, outage duration, and fuel cost. Similarly, since 1999, the ERCOT market participants have made the economic decision to add 205 new units and to upgrade 2 units for a total generation capacity of 25,372 MW (Figure 8.1-3). These decisions were based on the same economic parameters that led to decommissioning the 95 older units. Figures 8.1-2 and 8.1-3 show that on a county-by-county basis, in accordance with the market economic forces, the decommissioned units were sometimes replaced by new units and sometimes they were not replaced by new units.

By law, ERCOT must perform extensive annual and semi-annual studies, issue reports, make recommendations for transmission system needs and resource adequacy, and make legislative recommendations to further those objectives [See e. g., Tex. Util. Code Ann. §§ 39.155(b) and 39.904(k)]. ERCOT analyzes the region in the context of the competitive ERCOT market using load growth scenarios, industrial growth projections, regional transmission topology, sub-regional modeling, and new generation characteristics. The development of these reports is subject to vigorous market participant stakeholder input and review. ERCOT only forecasts the generation and transmission capacity that may be necessary to meet the forecast load. The market economic forces drive the market participants' decisions to increase or decrease their generation and transmission capacity.


### 8.1.5 References

- 8.1-1 Official Statement, City of San Antonio, Texas Electric and Gas Systems Revenue Funding Bonds, New Series 206B, dated January 10, 2007, available at [http://www.cpsenergy.com/files/financial\\_data/Bonds\\_New\\_Series\\_2006B\\_OS.pdf](http://www.cpsenergy.com/files/financial_data/Bonds_New_Series_2006B_OS.pdf), accessed on July 11, 2007
- 8.1-2 "Public Utility Commission of Texas Agency Strategic Plan For the Fiscal Years 2007-2011 Period," available at <http://www.puc.state.tx.us/about/stratplan/stratplan.pdf>, accessed on July 11, 2007.
- 8.1-3 "ERCOT Company Profile," available at <http://www.ercot.com/about/profile/index.html>, accessed on June 30, 2007.
- 8.1-4 "ERCOT Governance," available at <http://www.ercot.com/about/governance/index.html>, accessed on June 30, 2007.
- 8.1-5 "ERCOT's Role," available at <http://www.ercot.com/about/ercotrole.html>, accessed on June 30, 2007.
- 8.1-6 "ERCOT History," available at <http://www.ercot.com/about/profile/history/index.html>, accessed on June 30, 2007.
- 8.1-7 Report on the Capacity, Demand, and Reserves in the ERCOT Region, May 2007, available at <http://www.ercot.com/news/presentations/2007/07CDR05172007-final.xls>.
- 8.1-8 "ERCOT Protocols, Section 1: Overview," available at <http://www.ercot.com/mktrules/protocols/current/01-050107.doc>, accessed on July 10, 2007.
- 8.1-9 ERCOT Report on Existing and Potential Electric System Constraints and Needs, December 2006, available at [http://www.ercot.com/news/presentations/2006/2006\\_ERCOT\\_Reports\\_Transmission\\_Constraints\\_and\\_Needs.pdf](http://www.ercot.com/news/presentations/2006/2006_ERCOT_Reports_Transmission_Constraints_and_Needs.pdf).




Reference 8.1-9

**Figure 8.1-1 ERCOT Region**



Reference 8.1-9

Figure 8.1-2 Units Decommissioned Since 1999



Reference 8.1-9

Figure 8.1-3 New ERCOT Generation Since 1999

## 8.2 Power Demand

This section provides a high-level overview of the 2007 ERCOT Long-Term Demand and Energy Forecast (Reference 8.2-1) and all of the tables, figures, and data are taken from the Forecast. The methodology is briefly described, highlighting the major aspects involved in producing the forecast, including the data input used in the process. An historical perspective of the load growth in the ERCOT region is provided, and final results of the forecast peak demands and energy consumption are presented in a graphical form and summarized in table. A discussion of the major drivers of peak demands and energy consumption is included, along with the uncertainties associated with the forecast, and the differences from last year's forecast. A more detailed explanation of the econometric forecasting methodology used by ERCOT is described in Appendix 3 of Reference 8.2-1.

### 8.2.1 Historical Trends

Figure 8.2-1 provides the average hourly load and the annual system peak hour load from 1997 to 2006. The average hourly load growth is almost constant.

The historical annual peak demand for 1997-2006 is included in Figure 8.2-2 and the historical energy consumption for the same period is included in Figure 8.2-3.

Table 8.2-1 provides the historical annual growth percentage of the average hourly load, peak demand, and energy consumption for the period of 1998-2006. Figure 8.2-4 provides the three annual growth percentages graphically.

### 8.2.2 ERCOT Forecast of Long-Term Demand and Energy

The long-term load forecast covers a period from 1 to 15 years using a process and tools developed internally by ERCOT. The forecast is used for (Reference 8.2-2):

- Annual budget development (energy)
- System planning studies
- Resource adequacy assessments
  - Annual Capacity, Demand, and Reserves Report
  - Seasonal and long-term assessments
- Weekly forecast for outage coordination
- Statement of Opportunities Report
- PUCT/NERC/DOE/FERC reporting

### Methodology

The econometric forecasting basics center on a regression analysis, i.e., the development of an equation or set of equations that describes the historical load as a function of independent variables. The regression analysis is used to calculate the appropriate coefficients for each variable and to choose the best equations describing historical patterns (Reference 8.2-2). The forecasting process is shown in Figure 8.2-5. Refer to Appendix 3 of Reference 8.2-1 for a detailed description of the model and methodology.

The long-term forecast was produced with a set of econometric models that use weather, and economic and demographic data, to capture and project the long-term trends from the past five years of historical data. Each of these factors is discussed below.

### Weather

Weather drives most of the variation in electric demand in the short-run. Because weather also affects the variation in the electric demand in the long-run, long-term forecasting uses historical average weather profiles to indicate the future variation in weather. There are eight defined weather zones in ERCOT. The largest metropolitan statistical areas are located in the North Central, South Central, and Coastal zones:

- North Central (Dallas-Ft. Worth)
- South Central (Austin-San Antonio)
- Coastal (Houston)

Twelve years of weather data were available from WeatherBank for 20 ERCOT weather stations. These weather stations were used to develop weighted hourly weather profiles for each of the eight weather zones. These data were used in the load shape models. Monthly cooling degree days and heating degree days were used in the monthly energy models.

A representative hourly load shape by weather zone is forecast using an average weather profile of temperatures, cooling degree hours, and heating degree hours obtained from historical data. Seasonal daily, weekly, monthly, and yearly load variations and holiday events were considered, in addition to various interactions, such as weather, weekends, and weekdays. This hourly load shape only describes the hourly load fluctuations within the year and in itself does not reflect the long-term trend.

The long-term trend was provided by the energy consumption forecast. The monthly energy consumption forecast models by weather zones used cooling degree days and heating degree days to project the monthly energy for the next nineteen years (2007-2025).

One measure of the uncertainty associated with extreme weather impacts on the peak demand can be obtained by using a more extreme weather profile to obtain the forecasts. ERCOT developed weather profiles that rank at the 90th percentiles of all



the temperatures in its hourly temperature database and did the same to develop profiles with the 10th percentile of all temperatures. Strictly speaking these are not confidence bands in the statistical sense, but this term has commonly been used to refer to the results. A more appropriate term would be to use scenarios associated with the 90th percentile temperature distribution or 90th percentile scenario forecasts. ERCOT has also run Monte Carlo simulations to assess the impact of extreme temperatures on the peak demands. Subsection 8.2.3 provided the results of the analysis for both normal and extreme weather patterns.

#### Economic and Demographic Data

Economic and demographic changes can affect the characteristics of electrical demand in the medium- to the long-run. Economic and demographic data at the county level were obtained on a monthly basis from Moody's Economy.com. The data were used as input to the monthly energy consumption models.

The regional economic outlook for Texas is projected to outperform the U.S. as a whole. Three of its major metropolitan areas, Houston, Dallas, and Austin, which are among the top 50 in the U.S., are leading the South. Employment growth in Texas shows a stronger performance for the Dallas-Fort Worth area and the Austin-San Antonio area. The Houston area is expanding, but is expected to lose some momentum due to a slowdown in the energy industry.

Some of the indicators that were used in the forecast are economic and demographic drivers such as real per capita personal income, population, employment in the financial services, non-farm employment, and total employed. These are presented in Figures 8.2-6 through 8.2-10. As discussed in Subsection 8.4.1, actions to reduce the demand for power (i. e., demand-side management or conservation) are taken into account in determining the reserve margin.

### **8.2.3 Results of ERCOT Long-Term Demand and Energy Forecast**

The forecast energy consumption for 2007-2017 using the normal weather scenario is included in Figure 8.2-3. Figure 8.2-11 provides the forecast average hourly load for 2007-2017 using the normal weather scenario.

Figure 8.2-12 shows the forecast peak demand scenarios for 2007-2017 using the extreme weather profiles described above. The red dashed line on the top is a plot of the system peak demand forecast using temperatures above 90% of the historical temperatures (90th percentile) experienced during the last twelve years. This extreme forecast is referred to in the figure as the High Hourly Forecast 90-10. The middle line is the normal weather scenario (Base 50-50). The Low Hourly Forecast 10-90 refers to the forecast obtained by using temperatures above 10% of all temperatures during the last twelve years.

The historical peak demand for 2002-2006 and the forecast peak demand for 2007-2015 for the eight weather zones are shown in Table 8.2-2. The forecasts for the three major zones (North Central, South Central, and Coastal) show a stable and strong

growth. The forecasts for the smaller zones show an average or below-average trend in growth.

A summary of the long-term forecast model results for 2007-2025 peak demand and energy consumption is provided in Table 8.2-3. Table 8.2-4 provides the forecast growth percentages for average hourly load, peak demand, and energy consumption. Figure 8.2-4 provides the three annual growth percentages graphically.

#### Difference between the 2006 and 2007 Forecasts

In the long-term, the 2007 forecast is very similar to the 2006 forecast for the same period. The energy forecast from 2007 to 2015 is 0.06% higher than the 2006 forecast. A one-time adjustment due to economic revisions and other factors, such as Hurricane Katrina, contributed to the growth from the actual energy consumption in 2006 to the forecast for 2007. One of the key factors driving the long-term higher energy consumption is an improvement in the outlook of the overall health of the economy as captured by economic indicators such as the real per capita personal income, population, and various employment measures including non-farm employment and total employment. If income is growing at a faster rate than population, the average person expects to enjoy an overall higher standard of living. A higher standard of living generally translates into an improvement in comfort, which in many cases directly translates into increases in electricity consumption.

The energy consumption forecast scenarios show a rather slight degree of variability between the 90-10 high weather forecasts and the median (50-50) base case. The same holds true for the 10-90 low weather forecast scenario.

Figure 8.2-13 shows the difference between the two forecasts of peak demand for the period of 2007-2015.

#### Accuracy of the Long-Term Forecast

A comparison of the historical actual and forecast peak demand (Figure 8.2-14) and a comparison of the historical actual and forecast energy consumption (Figure 8.2-15) show that since 1999 ERCOT long-term forecasts have been within  $\pm 5\%$  of the actuals. Since 2003 the accuracy of the energy consumption forecast has been very close to  $\pm 1\%$  (Reference 8.2-2).

### 8.2.4 References

- 8.2-1 "2007 ERCOT Planning Long-Term Hourly Peak Demand and Energy Forecast - May 8, 2007" available at [http://www.ercot.com/news/presentations/2007/2007\\_ERCOT\\_Planning\\_Long\\_Term\\_Hourly\\_Demand\\_Energy\\_Forecast\\_.pdf](http://www.ercot.com/news/presentations/2007/2007_ERCOT_Planning_Long_Term_Hourly_Demand_Energy_Forecast_.pdf), accessed on July 13, 2007.
- 8.2-2 "Long Term Demand and Energy Forecasting – Planning," available at [www.ercot.com/meetings/other/keywords/2007/0124-LoadForecast/KDonohoo\\_ERCOTLongTermDemandEnergyForecastingPlanning01242007.ppt](http://www.ercot.com/meetings/other/keywords/2007/0124-LoadForecast/KDonohoo_ERCOTLongTermDemandEnergyForecastingPlanning01242007.ppt), accessed on June 2, 2007.

**Table 8.2-1 Historical Annual Growth of Average Hourly Load, Peak Demand, and Energy Consumption, 1998-2006**

Year	Average Load (MW)	Load Growth (MW)	Load Growth (%)	Peak Demand (MW)	Peak Growth (MW)	Peak Growth (%)	Energy Consumption (TWh)	Energy Growth (TWh)	Energy Growth (%)
1998	30,475	1,986	6.97%	53,691	3,326	6.60%	270	16	6.30%
1999	30,336	-139	0.46%	54,980	1,289	2.40%	269	-1	-0.37%
2000	32,488	2,152	7.09%	57,981	3,001	5.46%	289	20	7.43%
2001	31,623	-865	-2.66%	55,214	-2,767	-4.77%	278	-11	-3.81%
2002	32,052	429	1.36%	56,086	872	1.58%	281	3	1.08%
2003	32,533	481	1.50%	60,037	3,951	7.04%	285	4	1.42%
2004	32,917	384	1.18%	58,506	-1,531	-2.55%	289	4	1.40%
2005	34,161	1,244	3.78%	60,214	1,708	2.92%	299	10	3.46%
2006	34,899	738	2.16%	62,339	2,125	3.53%	306	7	2.34%

Compiled from Reference 8.2-1

**Table 8.2-2 Yearly Coincident Peak Demands by Weather Zone (MW)**

Year	North	North Central	East	Far West	West	South Central	Coast	South	System Load
<b>Historical</b>									
2002	1,904	20,527	2,175	1,830	1,595	9,492	14,578	3,985	56,086
2003	2,070	22,303	2,319	1,805	1,675	10,016	15,823	4,025	60,037
2004	2,047	20,749	2,265	1,658	1,562	9,619	16,611	3,996	58,506
2005	2,080	21,975	2,351	1,661	1,542	10,162	16,282	4,159	60,214
2006	2,361	22,687	2,432	1,598	1,612	10,718	16,739	4,191	62,339
<b>Forecast</b>									
2007	2,086	23,782	2,251	1,412	1,638	11,329	17,174	4,123	63,794
2008	2,117	24,059	2,363	1,415	1,683	11,708	17,631	4,158	65,135
2009	2,145	24,472	2,323	1,429	1,725	12,075	18,112	4,227	66,508
2010	2,183	24,914	2,353	1,435	1,770	12,475	18,554	4,271	67,955
2011	2,229	25,365	2,382	1,441	1,820	12,901	19,002	4,317	69,456
2012	2,263	25,743	2,402	1,442	1,863	13,292	19,377	4,351	70,733
2013	2,325	26,267	2,517	1,448	1,914	13,725	19,794	4,405	72,394
2014	2,377	26,788	2,462	1,509	1,964	14,111	20,312	4,474	73,998
2015	2,447	27,360	2,484	1,461	2,022	14,570	20,727	4,525	75,596

Compiled from Reference 8.2-1

Table 8.2-3 2007 ERCOT Long-Term Forecast Model Results

Year	Forecast Energy Consumption (MWh)	Historical Energy Consumption (MWh)	Peak (MW)
<b>Historical</b>			
2002	281,930,582	280,772,959	56,086
2003	284,207,211	284,983,916	60,037
2004	287,569,872	289,140,984	58,506
2005	300,553,020	299,253,971	60,214
2006	305,552,884	305,687,145	62,339
<b>Forecast</b>			
2007	313,027,658		63,794
2008	319,688,988		65,135
2009	325,408,664		66,508
2010	332,578,515		67,955
2011	340,089,254		69,456
2012	347,087,436		70,733
2013	354,122,426		72,394
2014	361,232,831		73,998
2015	369,322,241		75,596
2016	377,330,064		77,024
2017	384,606,172		78,694
2018	391,597,067		80,161
2019	398,301,224		81,622
2020	404,587,586		82,871
2021	411,162,342		84,363
2022	417,594,564		85,681
2023	423,892,847		87,015
2024	430,373,659		88,180
2025	436,287,512		89,883

Compiled from Reference 8.2-1

**Table 8.2-4 Forecast Annual Growth of Average Hourly Load, Peak Demand, and Energy Consumption, 2007-2017**

Year	Average Load (MW)	Load Growth (MW)	Load Growth (%)	Peak Demand (MW)	Peak Growth (MW)	Peak Growth (%)	Energy Consumption (TWh)	Energy Growth (TWh)	Energy Growth (%)
2007	35,734	835	2.39%	63,794	1,455	2.33%	313	7	2.29%
2008	36,395	661	1.85%	65,135	1,341	2.10%	320	7	2.24%
2009	37,147	752	2.07%	66,508	1,373	2.11%	325	5	1.56%
2010	37,966	819	2.20%	67,955	1,447	2.18%	333	8	2.46%
2011	38,823	857	2.26%	69,456	1,501	2.21%	340	7	2.10%
2012	39,513	690	1.78%	70,733	1,277	1.84%	347	7	2.06%
2013	40,425	912	2.31%	72,394	1,661	2.35%	354	7	2.02%
2014	41,237	812	2.01%	73,998	1,604	2.22%	361	7	1.98%
2015	42,159	922	2.24%	75,596	1,598	2.16%	369	8	2.22%
2016	42,957	798	1.89%	77,024	1,428	1.89%	377	8	2.17%
2017	43,905	948	2.21%	78,694	1,670	2.17%	385	8	2.12%

Compiled from Reference 8.2-1




Figure 8.2-1 Historical Average Load and System Peak Load

Compiled from Reference 8.2-1





Figure 8.2-2 Historical and Forecast Hourly Peak Demands


Reference 8.2-1






Reference 8.2-1

Figure 8.2-3 Historical and Forecast Energy Consumption




Compiled from Reference 8.2-1

Figure 8.2-4 Annual Percentage Growth of Average Hourly Load, Peak Demand, and Energy Consumption




Reference 8.2-1

Figure 8.2-5 ERCOT Long-Term Forecasting Process




Reference 8.2-1

**Figure 8.2-6 Real Personal Per-Capita Income**




Reference 8.2-1

Figure 8.2-7 Population in the ERCOT Region




Reference 8.2-1

Figure 8.2-8 Employment in Financial Services



Reference 8.2-1


Figure 8.2-9 Total Non-Farm Employment



Reference 8.2-1


Figure 8.2-10 Total Persons Employed





Reference 8.2-1

Figure 8.2-11 Forecast Average Load versus Forecast System Peak




Reference 8.2-1

Figure 8.2-12 Historical and Forecast Hourly Peak Demand




Reference 8.2-1

Figure 8.2-13 Comparison of 2006 and 2007 Peak Demand Forecast



Reference 8.2-2

Figure 8.2-14 Historical Accuracy of Peak Demand Forecasts



Reference 8.2-2

Figure 8.2-15 Historical Accuracy of Energy Consumption Forecasts

