

Submitted 6-8-11 INT000040

Operational Impacts at the Proposed Site

- 1 the ABWR severe accident release sequences that might be expected to involve core-concrete
- 2 interactions have frequencies of less than 1 x 10⁻⁸ Ryr⁻¹. On this basis, the NRC staff believes
- 3 that a basemat melt-through probability of 1 x 10⁻⁷ Ryr⁻¹ is reasonable and still conservative.
- 4 The groundwater pathway is more tortuous and affords more time for implementing protective
- 5 actions than the air pathway and, therefore, results in a lower risk to the public. As a result, the
- 6 NRC staff concludes that the risks associated with releases to groundwater are sufficiently small
- 7 that they would not have a significant effect on determination of suitability of the STP site.

8 5.11.2.4 Summary

9 The NRC staff reviewed the risk analyses in the ER, FSAR, and DCD for the purpose of

determining the potential environmental impacts of severe accidents. Based on this review, the

11 NRC staff concludes that the overall severe accident risk for proposed STP Units 3 and 4 is low.

12 The NRC staff is currently reviewing the risk analyses presented in the FSAR to confirm this

13 conclusion and determine compliance with the NRC's safety regulations (10 CFR 52.79) and the

Commission's safety goals. The results of that review will be presented in the Safety Evaluation Report prepared by the staff regarding the COL application. The NRC staff also conducted a

16 confirmatory analysis of the probability-weighted consequences of severe accidents for

proposed STP Units 3 and 4 using the MACCS2 code. The results of both the STPNOC

18 analysis and the NRC staff analysis indicate that the environmental risks associated with severe

accidents if two ABWR reactors were to be located at the STP site would be small compared to

20 risks associated with operation of the current-generation reactors at the STP and other sites.

21 On these bases, the NRC staff concludes that the environmental impact of the probability-

weighted consequences of severe accidents at the STP site would be SMALL for the proposedABWRs.

24 5.11.3 Severe Accident Mitigation Alternatives

25 STPNOC has applied for a license to construct and operate two ABWRs at the STP site. The 26 ABWR design (see Appendix A to Part 52–Design Certification Rule for the U.S. Advanced 27 Boiling Water Reactor) incorporates many features intended to reduce severe accident CDFs 28 and the risks associated with severe accidents. The effectiveness of the ABWR design 29 features is evident in Table 5-18 and Table 5-19, which compare CDFs and severe accident 30 risks for the ABWR with CDFs and risks for current-generation reactors including existing 31 STP Units 1 and 2. CDFs and risks have generally been reduced by a factor of 100 or more 32 when compared to the existing units.

33 The purpose of the evaluation of severe accident mitigation alternatives (SAMAs) is to

34 determine whether there are severe accident mitigation design alternatives (SAMDAs) or

- 35 procedural modifications or training activities that can be justified to further reduce the risks of
- 36 severe accidents (NRC 2000b). Consistent with the direction from the Commission to consider

Operational Impacts at the Proposed Site

1 the SAMDAs at the time of certification, the ABWR vendor (GE 1994) and the NRC staff, in its

2 environmental assessment (EA) accompanying the rule (NRC 1996b), have considered a

3 design alternatives for a ABWR at a generic site. The NRC staff incorporates that EA into this

- 4 EIS by reference.
- 5 On these bases, the NRC staff concluded (NRC 1996b):

6 Because the ABWR design already includes numerous plant features designed to

7 reduce core-damage frequency and risk, additional plant improvements would be

8 unable to significantly reduce the risk of either internally or externally initiated events....

9 Moreover, with the features already incorporated in the ABWR design, the ability to

10 estimate core-damage frequency and risk approaches the limitations of probabilistic

11 techniques. ... Although improvements in these areas may introduce additional

12 contributors to core-damage frequency and risk estimates, the NRC staff does not

- 13 expect that they would be significant in absolute terms.
- 14 Further, 10 CFR Part 52 Appendix A Section VI(B)(7) provides resolution for:

15 All environmental issues concerning severe accident mitigation design alternatives

16 associated with the information in the NRC's final environmental assessment for the

17 ABWR design and Revision 1 of the technical support document for the ABWR, dated

18 December 1994, for plants referencing this appendix whose site parameters are within

19 those specified in the technical support document.

In its ER, STPNOC reasserted the reactor vendor's claim that there were no SAMDAs that
 would be cost beneficial. STPNOC did not do a STP site-specific evaluation of design

alternatives. STPNOC did assess the maximum benefit that would accrue if a single procedural

or training alternative could eliminate all remaining risk associated with the ABWR design by
 updating the analysis submitted for design certification (GE 1994) with STP site specific

25 information and procedures set forth in NUREG/BR-0184 (NRC 1997b). STPNOC determined

that the maximum benefit at the STP site would be less than \$20,000. A more realistic

assessment would show that the potential benefit would be substantially less than the maximum

28 because no alternative can reduce the remaining risk to zero.

29 The NRC staff has limited its review to determination of whether or not the STP site

30 characteristics are within the site parameters specified in the ABWR technical support document

31 (GE 1994). The technical support document does not contain a specific list of site parameters.

32 However, the population dose risk is given as 4.5×10^{-3} person-rem per year. The population

33 dose risk is based on release characteristics including amount and probability, meteorological

34 conditions, and population distribution and is, therefore, the appropriate site parameter for

35 purposes of comparison.

Draft NUREG-1937

Operational Impacts at the Proposed Site

- STPNOC evaluated the population dose risk for the STP site using the MACCS2 code with site 1
- specific meteorological and population distribution. The population dose risk derived from the 2
- 3 site-specific analysis discussed in the ER and shown in Table 5-18 is 4.1 ×10⁻³ person-rem per
- vear. Independent review by the NRC staff confirmed this value. On this basis, the NRC staff 4
- 5 concludes that the STP site characteristics are bounded by the site parameters considered during the ABWR design certification, and that the environmental issues related to the SAMDAs
- 6 7
- have been resolved by rule.
- 8 SAMDAs are a subset of SAMAs. SAMAs also include procedural and training alternatives.
- 9 STPNOC did not develop procedural and training alternatives. In its ER, STPNOC (2009a)
- 10 states that "[e]valuation of specific administrative controls would occur when the proposed Units
- 3 and 4 design is finalized and plant administrative processes and procedures are being 11
- developed." Pursuant to regulatory requirements, procedures must be in place and training 12
- 13 must be completed prior to loading fuel.

14 5.11.4 Summary of Postulated Accident Impacts

The NRC staff evaluated the environmental impacts from DBAs and severe accidents for an 15

ABWR at the STP site. Based on the information provided by STPNOC and NRC's own 16

independent review, the staff concludes that the potential environmental impacts (risks) from a 17

postulated accident from the operation of the proposed Units 3 and 4 would be SMALL and 18

19 additional mitigation would not be warranted.

5.12 Measures and Controls to Limit Adverse Impacts During 20 Operation 21

- In its evaluation of environmental impacts during operation of proposed Units 3 and 4, the 22 23 review team relied on STPNOC's compliance with the following measures and controls that would limit adverse environmental impacts: 24
- 25 Compliance with applicable Federal, State, and local laws; ordinances, and regulations 26 intended to prevent or minimize adverse environmental impacts,
- 27 Compliance with applicable requirements of permits or licenses required for operation of the new unit (e.g., Corps' Section 404 Permit, NPDES). 28
- 29 · Compliance with existing STP Unit 1 and 2 processes and/or procedures applicable to proposed Unit 3 and 4 environmental compliance activities for the STP site, 30
- 31 • Compliance with STPNOC procedures applicable to environmental control and 32 management, and
- 33 • Implementation of BMPs.

8.0 Need for Power

Chapter 8 of the U.S. Nuclear Regulatory Commission's (NRC) *Environmental Standard Review Plan* (ESRP) (NRC 2000) guides the NRC staff's review and analysis of the need for power from
a proposed nuclear power plant. In addition to the ESRP guidance, the NRC addressed need
for power in a 2003 response to a petition for rulemaking (68 FR 55910). In the 2003 response,
the NRC reviewed whether or not need for power should be considered in NRC environmental
impact statements (EISs) prepared in conjunction with applications that could result in
construction of a new nuclear power plant. The NRC (68 FR 55910) concluded that:

9 The need for power must be addressed in connection with new power plant

10 construction so that the NRC may weigh the likely benefits (e.g., electrical power)

11 against the environmental impacts of constructing and operating a nuclear power

12 reactor. The Commission emphasizes, however, that such an assessment

13 should not involve burdensome attempts to precisely identify future conditions.

14 Rather, it should be sufficient to reasonably characterize the costs and benefits

15 associated with proposed licensing actions.

16 While the NRC will perform a need for power analysis in its EIS, the NRC also stated in its

17 response to the petition that (1) the NRC does not supplant the states, which have traditionally

been responsible for assessing the need for power-generating facilities, for their economic
 feasibility and for regulating rates and services; and (2) the NRC has acknowledged the primacy

20 of state regulatory decisions regarding future energy options (68 FR 55910).

21 8.1 Description of Power System

22 8.1.1 Description of STPNOC

23 The purpose of proposed Units 3 and 4 at the South Texas Plant Electric Generating Station 24 (STP) site is to provide baseload generation for use by the owners and/or for eventual sale on 25 the wholesale market. As discussed in Chapter 1, it is planned that Unit 3 would be owned by Nuclear Innovation North America (NINA) South Texas 3 LLC and the City of San Antonio, 26 27 Texas, through the City Public Services Board (CPS Energy), and that Unit 4 would be owned 28 by NINA South Texas 4 LLC and CPS Energy. Both proposed units would be baseload 29 merchant generator plants. NINA South Texas 3 LLC and NINA South Texas 4 LLC intend to 30 sell their share of the power from Units 3 and 4 on the wholesale market. CPS Energy may 31 either use its share of Units 3 and 4 to supply the needs of its service area and/or sell the power 32 on the wholesale market (STPNOC 2009).

1

1 The applicant, STP Nuclear Operating Company (STPNOC), stated in its application for 2 combined licenses (COLs) that proposed Units 3 and 4 at the STP site would be unregulated 3 entities. The electric utility industry in the State of Texas was deregulated in 2002. One of the 4 principal owners of proposed Units 3 and 4 (NINA) is a merchant generator that does not have a 5 specific service area. The other principal owner, CPS Energy, is a municipal utility that sells 6 capacity in excess of its own retail service needs in the San Antonio area into the Electric 7 Reliability Council of Texas (ERCOT) wholesale market (STPNOC 2009). Currently, CPS 8 Energy has several wholesale contracts, for which it is seeking renewal, that amount to firm 9 power obligations. In addition, CPS Energy's native retail service area of Bexar County and the 10 San Antonio vicinity also is growing in population and represents additional potential demand. However, in estimating the need for power for proposed Units 3 and 4, STPNOC is relying on 11 ERCOT's forecast of the overall demand for power in the ERCOT region rather than CPS 12 13 Energy's specific service and contract obligations (STPNOC 2009).

14 8.1.2 Description of ERCOT

15 STPNOC has defined the region of interest for evaluating the need for power as the entire area

16 served by ERCOT, the independent system operator (ISO) for the electric grid for most of the

17 State of Texas (Figure 8-1).



18 19

Figure 8-1. Map of the ERCOT ISO Service Area (STPNOC 2009)

Draft NUREG-1937

ERCOT is a membership-based nonprofit corporation formed under 26 USC 501(c)(6) of the 1 2 Internal Revenue Code. It is governed by a board of directors and subject to oversight by the 3 Public Utility Commission of Texas (PUCT) and the Texas Legislature. ERCOT's members 4 include retail consumers, investor-owned and municipally-owned utilities, rural electric cooperatives, river authorities, independent generators, power marketers, and retail electric 5 providers (ERCOT 2008a). The ERCOT board of directors is made up of independent 6 7 members, consumers, and representatives from each of ERCOT's electric market segments. 8 The board of directors appoints ERCOT's officers, who direct and manage day-to-day 9 operations (ERCOT 2008b). ERCOT's responsibilities include: 10 managing the flow of electric power to approximately 22 million Texas customers.

- 11 representing 85 percent of the State's electric load,
- scheduling power on an electric grid with 40,000 mi of high-voltage transmission lines and
 more than 550 generation units,
- managing financial settlements for the Texas competitive wholesale bulk-power market, and
- administering of customer switching for 6.5 million Texans in competitive choice areas
 (ERCOT 2008c).

17 As explained in STPNOC's environmental report (ER), the history of the deregulation of the previously regulated electric supply market in the ERCOT region began in 1995, when the 18 19 Texas Legislature passed Senate Bill 373, introducing wholesale competition into Texas' 20 intrastate market. PUCT adopted rules requiring all transmission system owners to make their 21 transmission systems available for use by others at prices and on terms comparable to each 22 respective owner's use of its system for its own wholesale transactions. In 1999, by terms of 23 Senate Bill 7, choice was further broadened by allowing retail customers of investor owned 24 utilities (IOUs) to choose their electric energy supplier (electric cooperatives and municipally 25 owned utilities such as CPS Energy had the option not to allow their retail customers to join this 26 arrangement and CPS Energy has not allowed this). Formerly, vertically integrated IOUs had to 27 separate their retail energy service activities from regulated utility activities and to unbundle their 28 generation, transmission/ distribution, and retail electric sales functions into separate units, 29 which could be sold off or else operated as independent entities at arm's length from each 30 other. Transmission and distribution entities (including electric cooperatives and integrated 31 municipally owned utilities) are fully regulated by the PUCT and must make their facilities 32 available on an open and non-discriminatory basis. IOUs and independent power producers 33 owning generation assets must be registered as power generation companies with the PUCT 34 and must comply with certain rules that are intended to protect consumers, but they are 35 otherwise unregulated and may sell electricity in private bilateral transactions and at market 36 prices (STPNOC 2009).

1 As explained in the ER and confirmed in the references below, under deregulation in Texas,

2 utilities no longer perform the comprehensive analysis and planning functions that they once

3 did. The central planning organization under the new Texas market is the ERCOT ISO. State

4 law assigns these obligations to ERCOT, under the oversight of the PUCT. The analyses,

5 reports, system planning processes, and criteria development from ERCOT are the key

6 measures for determining resource needs in the State [see e.g., Texas Utility Code Ann. §§

7 39.155(b) and 39.904(k)] (Texas Utilities Code 2009). STPNOC is relying upon several studies

8 performed for or by ERCOT on need for power in ERCOT's capacity as a regional transmission

9 organization. Regional transmission organizations were created as a result of Order No. 2000

10 issued by the Federal Energy Regulatory Commission (FERC), which encouraged the voluntary

11 formation of such organizations to administer the transmission grid on a regional basis

12 throughout North America (FERC 1999, 2008).

13 The ERCOT ISO region is also the geographic territory of the Texas Regional Entity (Texas RE)

14 (ERCOT 2008g). Texas RE is one of the eight approved regional entities in North America

15 under the North American Electric Reliability Corporation (NERC). NERC's mission is to ensure

the reliability of the bulk power system in North America. NERC develops and enforces

17 reliability standards, monitors the bulk power system, assesses and reports on future

transmission and generation adequacy, and offers education and certification programs to utility

19 industry personnel (NERC 2008a). Texas RE is a functionally independent division of ERCOT

and is independent of all users, owners, and operators of the bulk power system in the State of
 Texas. As mandated by the delegation agreement with NERC approved by FERC, Texas RE

22 performs the regional entity functions described in the Energy Policy Act of 2005 for the ERCOT

region. Texas RE develops, monitors, assesses, and enforces NERC reliability standards within

the ERCOT region. In addition, Texas RE has been authorized by the PUCT and is permitted

25 by NERC to investigate compliance with the ERCOT protocols and operating guides, working

with PUCT staff regarding any potential protocol violations (ERCOT 2008g).

27 The ERCOT region is almost entirely isolated from other NERC regions, electrically speaking. 28 The formation of what is now the ERCOT region dates from the beginning of World War II, when 29 several Texas utilities banded together and interconnected to support the war effort as the 30 Texas Interconnected System (STPNOC 2009). Texas Interconnected System formed ERCOT 31 in 1970 to comply with NERC requirements (ERCOT 2008d). Since the goals of these entities 32 over the years have been to ensure the reliability of the Texas grid rather than to interconnect 33 with the rest of the country, importing electric power into, or exporting electric power out of the 34 ERCOT region effectively is not practicable. As a practical matter this means that electricity 35 demand in the ERCOT region must be served from generation within ERCOT and that power 36 generated in excess of demand within ERCOT cannot effectively reach other markets (STPNOC

37 2009).

1 8.1.3 Description of the ERCOT Analytical Process

.

NRC guidance provides that additional independent review by the NRC may not be needed
when need for power analyses prepared by an independent third party such as an affected
state, NERC reliability council, or regional transmission organization is sufficiently (1)
systematic, (2) comprehensive, (3) subject to confirmation, and (4) responsive to forecasting
uncertainty (NRC 2000). Taken in aggregate, the staff determined that the studies and reports
summarized in Section 8.4 satisfy the four tests .

8 8.1.3.1 Systematic Test

9 The review team determined ERCOT has a systematic and iterative process for load forecasting 10 and reliability assessment that is updated annually. ERCOT is required by the PUCT to provide 11 extensive studies, issue reports, make recommendations for transmission system needs and 12 resource adequacy, and even make legislative recommendations to further those objectives 13 (STPNOC 2009). The essence of ERCOT is that it is a neutral and independent source of 14 information on electricity issues for policymakers. The development of these reports is subject 15 to a vigorous stakeholder input process.

16 Membership in ERCOT is open to any entity that meets any of the segment definitions as set 17 forth in the ERCOT bylaws. Members must be in an organization that either operates in the 18 ERCOT region or represents consumers within the ERCOT region. The members are 19 organized by the following market segments: consumers, cooperatives, independent 20 generators, independent power marketers, independent retail electric providers, investor owned utilities, and municipal utilities (ERCOT 2005b, 2008l). ERCOT uses industry best practices and 21 22 methodological approaches to determine future system reliability and the need for new 23 generating capacity. The forecasts and methods are vetted by ERCOT membership. 24 Moreover, the analyses and actions of ERCOT based on these analyses are overseen by the 25 PUCT.

26 8.1.3.2 Comprehensive Test

27 The review team finds that, in aggregate, the ERCOT studies and reports discussed in Section 28 8.4 are comprehensive. ERCOT (ERCOT 2008e) takes account of trends in customer demand 29 (including the underlying factors of population, income, and employment growth and impacts of 30 both normal and extreme weather conditions. The electricity supply analysis takes into account 31 changes in generation profile and potential generation additions; new generating resources 32 planned for construction in Texas; trends in electric power generation by fuel source; trends in 33 consumption by class of consumer; forecasts of future electricity sales; transmission congestion 34 in Texas; demand side management (DSM), demand response, and distributed generation; and 35 electric reliability assessments. The demand forecasts are fed into the generation and 36 transmission planning process. ERCOT uses industry best practices and methodological

approaches to determine system reliability and the need for new generating capacity (ERCOT
 2008f, i, j, k). Moreover, the forecasts are subject to a vigorous participatory process.

3 The model developers recognize that they have not been successful in the past in including

electricity prices as valid predictive variables in the electricity demand model (ERCOT 2008e,
 2009a):

6 In regard to prices, which are considered an important driver for inclusion in a 7 demand equation, it is not clear as to whether or not the wholesale prices that 8 ERCOT collects are really the most relevant for a forecasting application, in 9 terms of being the prices ultimately faced by the consumer. Since the wholesale 10 prices are collected on an hourly basis, and retail prices are better reflected by 11 an average over a longer time period, such as a month, wholesale hourly prices 12 do not capture the correlation with the MWh consumption correctly. Several attempts to include market clearing prices of energy in the forecasting models 13 14 were made but were unsuccessful. The models obtained showed price to be 15 insignificant or to indicate a nonsensical relationship regarding the direction of the effect of price (wrong sign on the coefficient) and thus should not be included 16 17 in a long-term demand equation. To make matters more challenging in this respect, an objective and credible forecast of these prices would represent a 18 19 major accomplishment in itself. Inclusion of a price variable in the forecasting 20 models could potentially provide a means to calculate an unbiased and credible 21 forecast of the price effect on the long-term load response.

However, reportedly, the constraints have been overcome and all future versions of the demand forecast will include the effects of energy prices (PNNL 2009).

24 8.1.3.3 Subject to Confirmation Test

25 The review team finds that, in aggregate, the studies and reports discussed in Section 8.4 are 26 subject to confirmation. ERCOT's forecasts are independently prepared. These forecasts are 27 then independently reviewed, confirmed, and consolidated by PUCT and NERC. Both the 28 Long-Term Peak Demand study (ERCOT 2008e) and the Capacity, Demand, and Resources 29 Report (CDR) look at historical information as a check on past forecasting performance and 30 these results are published. For example, in 2008 to validate the forecast model, an out-of-31 sample prediction was performed by estimating the model with data up to December 2005 and a 32 forecast was produced for January 2006 to December 2006 using the actual temperatures. A 33 forecast for the summer season only was also produced using the actual temperatures. The 34 system peak that occurred on August 17, 2006, was forecasted for the year 2006 with a 0.78 35 percent error and a 0.45 percent error for the summer alone (ERCOT 2008e). Forecast 36 comparisons for 2008 show a -0.5 percent error for annual energy (with monthly errors from -7.6

percent to plus 6.0 percent). Maximum hourly demand at the August peak had a -1.0 percent
 error and the forecast for annual peak had a -4.2 percent error (ERCOT 2008c)

3 Over a longer term, from 1999 to 2006, the ERCOT peak demand and energy consumption

4 forecasts were within ± 5 percent of the actual values (STPNOC 2009). ERCOT publishes its

5 methodology, key input data, forecast errors, methodological uncertainties and limitations, and

6 conclusions.

7 8.1.3.4 Responsive to Forecasting Uncertainty Test

8 In preparing its load forecasts and reliability assessments, ERCOT takes account of forecasting
9 uncertainty. It also takes into account of the fact that not all proposed new generating units will
10 be built and that some existing generating units may be taken off line for various reasons.

11 8.1.3.5 Summary of ERCOT Analytical Process

Based on its review of ERCOT documents, the review team determined that, in aggregate, the ERCOT forecasts and documents are sufficiently (1) systematic, (2) comprehensive, (3) subject to confirmation, and (4) responsive to forecasting uncertainty to serve the needs of the review team in complying with Section 102 of the National Environmental Policy Act. In keeping with the ESRP (NRC 2000) and the Commission statements at 68 FR 55910, the review team gave particular credence to:

- 18 ERCOT's 2009 long-term demand forecast (ERCOT 2009a),
- 19 ERCOT's 2009 CDR (ERCOT 2009b),
- ERCOT's examination of long-term generation issues associated with wind energy in the
 2008 Long-Term System Assessment (ERCOT 2008f), and
- NERC's evaluation of long term system adequacy (NERC 2008b).

23 8.2 Power Demand

The review team initially relied on the 2007 ERCOT Long-Term Peak Demand and Energy 24 Forecast as its basis for understanding the need for power (ERCOT 2007). Since then, review 25 26 team also has reviewed the 2008 and 2009 long-term demand studies (ERCOT 2008e, 2009a), 27 ERCOT's 2008 Long Term System Assessment Study (ERCOT 2008f), ERCOT's latest CDR 28 (ERCOT 2009b), and the summary of ERCOT findings from the 2008 studies in NERC's 2008 29 Long-Term Reliability Assessment as bases for comparison with the STPNOC's need for power assessment (NERC 2008b). ERCOT's demand forecasting model is described in detail in the 30 31 2009 demand forecast report and is summarized below (ERCOT 2009a).

The ERCOT long-term load forecast covers a period from 1 to 15 years using a process and 1 2 tools developed internally by ERCOT. The forecast is used for a variety of operating and planning purposes, the most important of which for the EIS is system planning. The forecasting 3 model is a set of equations that describes the historical load as a function of independent 4 variables, where the coefficients are estimated by multiple regression methods. The long-term 5 6 forecast was produced with a set of econometric models that use weather and economic and demographic data to capture and project the long-term trends from the past 5 years of historical 7 data. Twelve years of weather data were available from 20 ERCOT weather stations. These 8 9 weather stations were used to develop weighted hourly weather profiles for each of eight weather zones in the ERCOT region. These data were used in the load shape models. Monthly 10 cooling degree days and heating degree days were used in the monthly energy models. 11 Uncertainty in weather effects (especially that of extreme weather) on load was investigated in a 12 13 number of ways, including the running of Monte Carlo simulations, to assess the impact of extreme temperatures on the peak demands. Economic and demographic changes can affect 14 15 the characteristics of electrical demand in the medium- to the long-run. Economic and demographic data at the county level were obtained on a monthly basis from Moody's 16 17 Economy.com. Three of the key economic and demographic variables that drive the forecast 18 are per capita income, population, and employment. The growth rates in these variables have 19 declined during the last three forecasts, but still show largely the same picture for need for 20 power over the next 10 to 15 years.

21 Because the proposed Units 3 and 4 at the STP site would be baseload merchant power plants 22 that are expected to operate more than 90 percent of the time to obtain best cost-effectiveness, 23 the most important part of the ERCOT forecast for purposes of the this review is the growth in 24 annual energy demand and the growth in demand at the near-minimum demand hours, since 25 Units 3 and 4 would address this lowest part of the annual load duration curve. ERCOT, on the 26 other hand, needs to emphasize peak load demand because of its institutional responsibility for 27 meeting peak demand and reserve margin. During the period from 1997 to 2007 the compound 28 growth rates for peak demand and annual energy were 2.3 percent per year and 1.5 percent per 29 year, respectively (ERCOT 2009a). Assuming normal weather, ERCOT projects that peak 30 energy demand would increase at a compounded rate of 2.0 percent per year (13,923 MW total) 31 between 2009 and 2019 and that annual energy (average demand) would grow at a 32 compounded growth rate of 2.04 percent per year (7965 average MW total) (ERCOT 2009a). 33 Figure 8-2 shows the ERCOT 2009 peak and annual average load forecasts for the period 34 2009-2019.

Figure 8-3 shows the 8760-hour load duration curve for the ERCOT region for 2007, the last full year for which data were available. Ninety percent of the hours in the year equals 7884, corresponding to a demand of about 26,000 MW. This is approximately the portion of demand that is addressed by existing nuclear power plants at STP and Comanche Peak (as well as some hydroelectric, coal, and natural gas combined cycle baseload). If minimum annual hourly





demand (equal to 21,817 MW in 2007) and 90th percentile hourly demand both grew at
approximately the rate of annual average hourly demand in the ERCOT region shown in
Figure 8-3, they both would grow by about 27.4 percent by 2019, or by amounts of 5978 MW
and 7124 MW, respectively. These increases exceed the increase of high-availability baseload
capacity represented by proposed Units 3 and 4 at STP. This simple calculation provides an
initial indication that the growth in baseload demand in the ERCOT region would be enough to

10 support additions of two units at both STP and Comanche Peak.

In the 2008 annual NERC report (NERC 2008b) "2008 Long-Term Reliability Assessment 2008-2017, October 2008," it is noted that forecasts of the demand for power declined between the 2007 and 2008 forecasts (after having risen between 2006 and 2007). The decline continued from 2008 to 2009. Figure 8-4 shows the last four summer peak load forecasts compiled by ERCOT. Figure 8-5 shows the difference between annual energy forecasts in 2008 and 2009. The actual 2008 values are below the forecast largely because the peak forecast assumes normal summer weather, and weather was relatively cool on the peak day in 2007.

18 The NERC report for ERCOT (NERC 2008b) states that the lower 2008 forecast takes into account the slowing of the Texas economy:

March 2010

1

8-9

- The lower peak demands reflect the expected state of the economy as represented by economic indicators that have been found to drive electricity use in the ERCOT region's eight weather zones, including real per-capita personal income, population, gross domestic product, and various employment measures including non-farm employment and total employment.
- In the long-term, real personal per-capita income is expected to level-off or decline in a slight to medium fashion due to wage rates experiencing modest growth, only slightly faster than inflation, due to lower productivity growth. Texas non-farm employment continues to grow faster than the U.S. rate. The gross domestic product also shows a lower level and growth rate from 2008 to 2018 when compared to last year's forecast.
- Given the net effects of the economic indicators used in the 2008 Long Term Demand
 Forecast, they indicate slowdown of the economy in the long run. The long-run impact
 on the forecast due to economic slowdown is projected to start around 2010. Its effects
 are projected to translate into a 4.50 percent decline in energy and a 3.31 percent
 decline in peak demand by 2018, when compared to last year's forecast [Note: "last
 year" refers to the 2007 forecast].



1

2

3

45

6

7

8

9

10





Figure 8-3. ERCOT 2007 Load Duration Curve. (Compiled by review team from ERCOT 2008h)

20

Draft NUREG-1937



1

2 3

3 4 Figure 8-4. ERCOT 2006, 2007, 2008, and 2009 Peak Load Forecasts. (Compiled from 2007, 2008, and 2009 ERCOT Long-Term Demand Forecast reports data by review team from ERCOT 2007; ERCOT 2008e; and ERCOT 2009a)

9

5

March 2010

Draft NUREG-1937

The review team notes that the ERCOT 2009 forecast features still further reduced economic 1 growth in the short term as a result of the 2008-2009 economic downturn. However, some of 2 the decline in underlying long-term economic conditions discussed by NERC between 2007 and 3 2008 took a more optimistic turn in the ERCOT 2009 forecast. Figure 8-6 through Figure 8-8 4 5 show the change in key long-term growth variables used as the primary economic drivers for the 6 2009 ERCOT forecasts: population, employment, and per-capita income. ERCOT determined population growth rate would be relatively unchanged due to the economic downturn following 7 8 an initial drop in numbers, but that employment and per-capita income would suffer an initial 9 slump, followed by a faster growth rate than expected in 2008 and which would overtake the 10 2008 forecasted values by about 2013.

11 12

Figure 8-6. Population in the ERCOT Region (ERCOT 2009a)

Figure 8-7. Total Non-Farm Employment in the ERCOT Region (ERCOT 2009a)

Figure 8-8. Per Capita Income in the ERCOT Region (ERCOT 2009a)

- Because it is involved in meeting the maximum demand conditions in its territory, ERCOT pays considerable attention to the summer peak demand and the margin of safety in meeting that peak. The current generation reserve margin requirement for the ERCOT region is 12.5 percent, as approved by the ERCOT Board in August 2002. The following is a brief summary of the methodology for the reserve margin calculation (ERCOT 2005a). The terms used here are
- 6 defined below.
- 7 Firm Load equals:
- 8 long-term forecast model total summer peak demand
- 9 minus loads acting as resources serving as responsive reserve
- minus loads acting as resources serving as non-spinning reserve
- 11 minus balancing up loads.
- 12 Available Resources equals:
- installed capacity using the summer net dependable capability pursuant to ERCOT testing
 requirements (excluding wind generation)
- plus capacity from private networks
- plus effective load carrying capability of wind (determined in a study for ERCOT in 2006 by
 Global Energy to be 8.7 percent of name plate generation (GED 2007)
- 18 plus reliability must run units under contract
- 19 plus 50 percent of non-synchronous ties
- plus summer net dependable capability of available switchable capacity as reported by the
 owners
- plus available "mothballed" generation
- plus planned generation with a signed generation interconnection agreement (SGIA) and a
 Texas Commission on Environmental Quality air permit, if required
- plus effective load carrying capability of planned wind generation with SGIA
- minus retiring units.
- 27 Reserve margin is then defined as (Available Resources Firm Load Forecast/Firm Load28 Forecast).
- 29

1 In the ERCOT methodology, loads acting as resources are capable of reducing or increasing

2 the need for electrical energy or providing ancillary services such as responsive reserve service

3 or non-spinning reserve service. Loads acting as resources must be registered and qualified by

4 ERCOT, and they will be scheduled by a qualified scheduling entity (STPNOC 2009).

5 STPNOC discussed the need for power in the context of declining reserve margins in the

6 ERCOT region (STPNOC 2009). As recently as May 2008, forecasted reserve margin in the

7 ERCOT Demand and Reserves report was expected to fall below the required reserve margin of

8 12.5 percent by 2013. However, the May 2009 update to this report now shows a better

9 capability to meet firm load at least through 2014 (see Table 8-1). ERCOT produces a "top-

10 down" forecast for its major subareas, but does not include separate demand estimates for

11 different end-use sectors. Thus, forecasts do not contain separate forecasts for residential,

12 commercial, and industrial demand.

13 As shown in Table 8-1, the ERCOT 2009 forecasts take into account DSM programs and

14 efficiency programs. As stated in the 2008 Texas State Energy Plan, DSM can be divided into

15 (1) demand-response programs, which are designed to encourage customers to reduce usage

16 during peak times or to shift that usage to other times; and (2) energy efficiency programs,

17 which provide a reduction in the overall quantity of electricity consumed over the year, but may

18 not necessarily reduce the electricity demanded at the hour of system peak (Governor's

19 Competitiveness Council 2008). Under Texas House Bill 3693 (signed into law in 2007),

20 regulated utilities (transmission and distribution utilities [TDUs]) in ERCOT, and the integrated

21 utilities outside of ERCOT, are required by law to offer DSM programs sufficient to offset 15

22 percent of the growth in demand by December 31, 2008, and 20 percent of the growth in

demand by December 31, 2009 (Governor's Competitiveness Council 2008). Although only

regulated utilities are affected inside of ERCOT, success of such programs could affect the

25 overall demand for electricity in the ERCOT region.

Table 8-2 is a less-detailed extension of Table 8-1 to the year 2024 that shows the ERCOT

27 2009 forecast of demand, reserve margin (ERCOT calculates long-term required resources to

28 meet peak demand plus 12.5 percent). Total resources estimates and the need for baseload

29 power are calculated in Section 8.3. The total resources estimate does not include STP Units 3

30 and 4 or other units projected for completion after 2014.

 Table 8-1.
 ERCOT Peak Demand and Calculated Reserve Margin, 2009-2014

	2009	2010	2011	2012	2013	2014
Total Summer Peak Demand (MW)	63,491	64,056	65,494	67,394	69,399	70,837
Less: LAARS Serving as Response Reserve and Spinning Reserve, Balancing–Up Loads	1115	1115	1115	1115	1115	1115
Less Energy Efficiency Program (per HB36693)	110	242	242	242	242	242
Firm Load Forecast (MW)	62,266	62,699	64,137	66,037	68,042	69,480
Required Reserve Margin (12.5%)	7783	7837	8017	8255	8505	8685
Required Resources	70,049	70,536	72,154	74,292	76,547	78,165
Estimated Total Resources (MW) (Table 8-3)	72,712	75,314	76,215	77,287	79,122	79,123
Reserve Margin (Resources - Firm Load Forecast)/Firm Load Forecast)	16.8%	20.1%	18.8%	17.0%	16.3%	13.9%
Source: ERCOT 2009b						

2

1

3

 Table 8-2.
 ERCOT Calculated Reserve Margin, 2009-2024

	2009	2010	2014	2019	2024
Peak Summer Demand, MW	63,491	64,056	70,837	77,414	82,778
Less: LAAR Spinning and Non Spinning reserve and Balancing-up Loads	1115	1357	1357	1357	1357
Firm Load, MW	62,266	62,699	69,480	76,057	81,421
Plus Reserve Requirements (Peak +12.5%)	7936	8007	8855	9677	10,347
Total Resource Requirements, MW	71,427	72,063	76,692	87,091	93,125
Total Resources, No Retirements	72,712	75,314	79,122	79,123	79,123
Reserve Margin Based on Firm Load	16.8%	20.1%	13.9%	4.0%	-2.8%

4 8.3 Power Supply

- 5 ERCOT prepares an annual CDR (ERCOT 2009b) on the supply capacity, demand, and
- 6 reserves in the ERCOT region. It is developed from data provided by the market participants as
- 7 part of the annual load data request, the generation asset registrations, and from data collected
- 8 for the annual U.S. Department of Energy Coordinated Bulk Power Supply Program Report.

- 1 The working paper calculates the generation resources reported to be available by market 2 participants (STPNOC 2009).
- 3 The CDR considers all of the generation resources in the ERCOT region meeting the list in the
- previous section. There are several constraints on which resources are listed as available in the
 CDR.
- Only those new generating resources for which the owners have initiated full transmission
 interconnection study requests through ERCOT are included as planned generation.
- If an air permit is required for a new generating unit, the unit must have received that permit
 before it is included as planned generation.
- Some mothballed resources may be counted, but the probability of these resources being
 able to be returned to service varies by generating technology and declines as the length of
 time they are mothballed increases (ERCOT 2005b).
- Retiring and retired units are not counted.

14 Wind Energy in Texas

- 15 Large amounts of wind energy have or are about to enter the ERCOT region. In the Interim Order on Reconsideration in Docket 33672 (Interim Order), the PUCT designated five zones as 16 17 Competitive Renewable Energy Zones (CREZ), primarily for wind power, in the western and Panhandle areas of Texas. By Texas law this amount of power would have to be accepted by 18 19 the market, if offered to the market, in preference to thermal generation. Installed wind capacity 20 could grow from around 6900 MW to as much as 24,400 MW over the next few years, with a 21 planning value of 18,456 MW in 2018. In response, ERCOT performed a CREZ Transmission 22 Optimization Study (ERCOT 2008j), an extensive study of intrastate transmission bottlenecks 23 that might arise and solutions that might be needed to absorb this new power source.
- 24 The wind generation development scenarios used in the CREZ Transmission Optimization 25 Study were also used to evaluate resource needs in the ERCOT system in the December, 2008 26 Long-Term System Assessment (ERCOT 2008f). The Long-Term System Assessment 27 evaluated the need for other types of generation capacity under the assumption that the 28 projected 2018 load duration curve would be lowered by the maximum possible use of 29 18,456 MW of wind energy. Figure 8-9 shows that at approximately the 80th percentile (a rule-30 of-thumb definition of baseload generation) there would still be a demand for up to 30,852 MW 31 of baseload with 18,456 MW of wind generation installed in the system if natural gas prices 32 remained at about \$7 per million Btu. However, there would be little need for additional 33 baseload generation beyond current levels (nuclear could still substitute for retiring coal and
- 34 natural gas, if needed).

1 Current U.S. Energy Information Administration forecasts of natural gas prices favor a natural

2 gas price to the electricity sector of about \$7 per million Btu through much of the next 20 years,

3 as many new resources come on line, even as economic recovery increases demand (EIA

4 2009). This indicates that the demand in 2018 for baseload capacity (80th percentile of the wind-

5 altered load duration curve) would be close to the 30,852 MW forecast in Figure 8-9. The

6 demand for baseload at the 90th percentile of the wind-altered load duration curve would be

7 about 28,000 MW, an increase of about 2000 MW from current levels. That would not be

8 enough on its own to fully absorb STP Units 3 and 4, but substitution for retiring coal or natural
9 gas-fired plants would still be possible.

10 ERCOT's 2009 Supply Forecast

Table 8-3 provides ERCOT's May 2009 projection of the generating resources of various types
that that would be available to serve the ERCOT region between 2009 and 2024. The 20092014 ERCOT projections anticipate substantial development of wind resources during the 20092014 period, and the review team adopted the view that these resources would be developed

15 and would meet the State's goal of 18,564 MW of installed wind capacity by 2018. If the State

16 falls short of its goal for wind, the demand for STP Units 3 and 4 would be larger than calculated

17 in this section.

18 There is uncertainty as to the timing, type, number, and capacity of generating units that may be

19 retired during the forecast period, which affects the need for replacement generating plants.

20 The age of the power plant being considered for retirement is a factor in the decision to retire

21 the plant. Based on ERCOT's May 2009 CDR, Figure 8-10 shows how the summer capacity of

22 generating resources may be affected by the need of some participants to retire older, less

23 efficient, or polluting power plants. Under any retirement scenario, the replacement of such

24 power plants in the ERCOT region further adds to the need for new generating capacity.

The ERCOT forecast of generating resources shown in Table 8-3 begins with installed capacity of existing generating stations. To that is added generating capacity of private networks

27 (connected to the ERCOT grid, but not directly metered by ERCOT), the effective load carrying

28 capability of existing wind generators (at 8.7 percent of installed capacity), and reliability must-

run (RMR) units that are required for local grid stability. The remaining group of resources
 includes (1) 50 percent of so-called "switchable" resources that could either operate in ERCOT

30 includes (1) 50 percent of so-called "switchable" resources that could either operate in ERCOT 31 or in the Southwest Power Pool; (2) a protected estimate of mothballed resources that could be

32 brought back on line in each year (the actual estimate is an expected value based on detailed

33 computations that involve the age of the unit and the length of time it has been shut down), and

34 (3) planned resources, whose inclusion depends on the phase that each resource is in the

35 required interconnection studies (STPNOC 2009). This resulting estimate is then adjusted

36 downward to account for switchable units known to be unavailable to ERCOT and retiring units.

37 However, because there is also considerable uncertainty concerning whether existing power

plants would be retired, the review team calculated available resources both with and without 1 2 retirements, as shown in Table 8-3.

Net Load Duration Curve - 2018

3 4 5

Capacity (ERCOT 2008f)

6

2024 2014 2019 2009 2010 2011 2012 2013 Installed Capacity, MW 61,800 63,492 61.800 61.800 61.800 61,800 61.800 61.800 Capacity from Private Networks, MW 5313 5318 5318 5318 5318 5318 5318 5318 Effective Load-Carrying Capability (ELCC) 708 708 708 708 708 708 708 708 of Wind Generation, MW RMR Units to be under Contract. MW 115 0 0 0 0 0 0 0 Operational Generation, MW 69,628 67,826 67,826 67.826 67.826 67,826 67,826 67,826 50% of Non-Synchronous Ties, MW 553 553 553 553 553 553 553 553 Switchable Units, MW 2848 2848 2848 2848 2848 2848 2848 2848 479 479 Available Mothballed Generation, MW 0 401 479 479 479 479 Planned Units (not wind) with Signed IA 0 7206 7206 3,769 4389 5414 7206 7206 and Air Permit, MW 0 ELCC of Planned Wind Units with Signed 76 121 211 211 1606 1606 168 IA, MW Total Resources, MW 79.123 80.518 73,029 75.472 76,215 77.287 79.122 80,518 less Switchable Units Unavailable to 317 158 0 0 0 0 0 0 ERCOT. MW less Retiring Units, MW (None through 0 0 0 0 0 0 0 2014, Based on >50 yrs after 2014 Retirements in Based of age >50 yrs after 0 0 0 0 0 0 9289 25,274 2014 Resources, MW (no retirements) 72.712 75.314 76.215 77.287 79.122 79.123 80.518 80,518 Reserve Margin Above Firm Load, No 16.8% 20.1% 18.8% 17..0% 16.3% 13.9% 5.86% -1.11% retirements 55,244 Resources, MW (with retirements) 72,712 76,215 79,122 71,229 75.314 77.287 79,122 Reserve Margin Above Firm Load, With 16.8% 18.8% 17.0% 16.3% 13.9% -6.4% -32.2% 20.1% retirements

Table 8-3, 2009 ERCOT Forecasted Summer Resources, 2009-2024

Source: ERCOT 2009b and review team calculations based on the expanded wind resource availability of 18,564 installed MW by 2018, and the >50-year old generation retirement scenarios in Figure 8-10.

Figure 8-10. Alternative ERCOT Generation Capacity Reduction Scenarios vs. Projected
 Demand (ERCOT 2009b)

4 In Table 8-3, the ERCOT forecast shows that by 2014, the amount of summer resources would

5 be about 79,100 MW and 80,500 MW by 2019. Reserve requirements would be met in 2014,

6 but not by 2019. The reserve margin would fall from 13.9 percent in 2014 to 5.9 percent in 2019.

7 With retirements of older power plants after 2014, the demand and supply would be further out 8 of balance, because the resources needed just to meet firm load would be 76,100 MW. The

9 resources available, accounting for wind generation and retirements, would be only 71,200 MW

10 if only power plants older than 50 years old were retired — an absolute shortage of 5000 MW

and a shortage of 15,900 MW relative to the amount needed to cover the reserve margin. The

reserve margin would be below zero. If retirements of power plants increase, the prospective

13 shortage of generation in the 2014-2019 period would grow still larger

14 STPNOC concluded in its ER (STPNOC 2009), based on the ERCOT 2007 forecasts and

before the 2008-2009 economic recession, which the generation shortage in 2016 could be

16 between 20,000 and 50,000 MW. The shortage in Table 8-3 is 15,900 MW, still substantial.

1

1 In the ERCOT region, STPNOC estimated about 24.5 percent of current generating capacity is 2 currently considered to be baseload and that this percentage would rise to 30.1 percent by 2012 3 (STPNOC 2009) In its ER, STPNOC estimated the combined capacity of baseload generation 4 that addresses ERCOT through the year 2012 based on the ERCOT criteria (Table 8-4). The 5 percentage of baseload may be increasing (STPNOC 2009). STP Units 1 and 2 and Comanche Peak Units 1 and 2 would represent 4892 MW of the 22,178 MW of total summer baseload 6 7 generating capacity needed in the ERCOT region in 2012 (STPNOC 2009). The growth in need for baseload generation in Table 8-4 from 2007 to 2012 is 4557 MW, of which only 2100 MW of 8 9 new coal and gas had been added to the ERCOT forecast. In the longer term, plant retirements and further increases in demand for power allowed STPNOC (STPNOC 2009) to conclude that: 10

11 Thus, the need for new capacity in ERCOT in 2015-2016 is substantially greater than the 12 new capacity to be provided by STP 3 & 4. As a result, not only will there be a need for 13 power from STP 3 & 4, there will be a need for a substantial amount of other new 14 generating capacity.

15 **Table 8-4**. STPNOC Forecasted Summer Capacity, Baseload Generation Units Only

	2007	2008	2009	2010	2011	2012
Resources, MW	71,812	72,048	71,960	72,394	72,939	73,703
Baseload Generation, MW	17,621	17,621	19,057	19,998	21,378	22,178
Percent of Resources that are Baseload Generation	24.50%	24.50%	26.50%	27.60%	29.30%	30.10%
Source: STPNOC 2009	· · · · · · · · · · · ·					

16 Table 8-5 shows an estimate made by the review team of the need for baseload power in 2009-

17 2024 with and without retirement of older power plants. For purposes of this estimate it was

18 assumed that baseload power would represent about 27.5 percent of the identified generating

19 needs in Table 8-3. This percentage is midway between today's 24.5 percent and the

20 30.1 percent calculated by STONOC for the year 2102. Without any retirements, Table 8-5

21 shows that the demand for new baseload is about 1808 MW, a reflection of much higher

22 planned non-wind resources and wind power penetration into the Texas market than assumed

23 in 2007, combined with lower load growth than assumed by STPNOC in their forecast. With

only plants greater than 50 yr old retiring, the demand for new baseload plants not currently in

the ERCOT forecast grows to 4362 MW, more than enough for two new nuclear units.

1 2

Table 8-5 .	ERCOT/Review Team Forecasted Summer Capacity, Baseload Generation Units
	Only ^(a)

	2009	2010	2014	2019	2024		
Power Requirements,							
Including 12.5%	71,427	72,063	79,692	87,091	93,125		
Reserves (MW)							
Current ERC	OT Planned N	lew Generatio	n: No Retirem	ents (MW)			
Generating Resources	73,029	75,472	79,123	80,518	80,518		
Baseload Needed		10 817	21 915	23 950	25 609		
(27.5%)	19,643	19,017	21,515	20,000	20,000		
Baseload Needed		(894)	156	1808	3467		
After 2009	(353)	(004)	100	1000			
Current ERCOT Planned New Generation: Retire Only Plants >50 Yr Old (MW)							
Generating Resources	73,029	75,472	79,123	71,229	55,244		
Baseload Needed		10 917	21 015	23 050	25 600		
(27.5%)	19,643	19,017	21,910	20,000	25,009		
Baseload Needed		(804)	156	4362	10 417		
After 2009	(353)	(034)	100	4002	10,417		
(a) Excludes proposed STP Units 3 and 4							

8.4 Assessment of Need for Power

The review team reviewed reports prepared by ERCOT regional ISO in conjunction with its assessment of the need for power from STPNOC's proposed Units 3 and 4 at the STP site. STPNOC relied on the 2007 versions of these reports, which show a slightly higher need for power than the 2008 and 2009 reports; however, all versions provide essentially the same picture. The review team's key findings from the reports are summarized as follows:

9 The demand for power at the summer peak and the annual demand for energy in the 10 ERCOT region are both projected to rise over the period 2009 through 2019 at 11 approximately 2.0 percent per year compounded. Total demand would be 77,400 MW at 12 peak in 2019, and including a 12.5 percent reserve requirement, resources would need to 13 be about 87,100 MW in that year. If minimum-hour demand and 90th percentile hourly 14 demand also increases at the 2.0 percent rate, by 2019 the ERCOT region would need an 15 additional 6000 MW to 7100 MW of baseload generation due to load growth alone. This 16 estimate, however, does not account for other supply plans.

As noted in Section 8.3, retiring generating units were not counted in the 2009 forecast of
 ERCOT region available resources (they are shown as zero in forecasted resources). Thus,
 depending on the rate of retirement of older generating units, the ERCOT region may need
 substantial additional generating capacity by 2019. The analysis in Table 8-3 shows that if
 only the oldest (greater than 50 years old) are retired after 2014, amount of additional

demand for new generation would be about 9300 MW relative to a case with no retirements.
 About 25 to 30 percent of that growth likely would be baseload generation.

3 The 2009 ERCOT resource forecast contains 8137 MW of current installed capacity in 2009 4 (with 708 MW of average Effective Load Carrying Capability) plus 2425 MW of planned 5 installed capacity (average Effective Load Carrying Capability of 211 MW). However, larger 6 amounts of additional wind generation capacity may be built in the CREZ areas of Texas, 7 ranging up to 24,000 MW installed (average Effective Load Carrying Capability of 2088 8 MW). Large amounts of wind generation would require major investments in transmission 9 resources and improved system controls to manage wind resources, but they could reduce 10 the demand for power during the off-peak portions of the year and may limit the demand for 11 additional intermediate and baseload thermal generating resources. More modest market 12 penetration of wind energy leaves a market for increased baseload generation. The 13 discussion of the CREZ study in Section 8.3 favors a lower wind penetration rate with up to 14 18,546 MW installed capacity, given very aggressive wind development, which still leaves 15 room for 10,000 MW of growth in baseload demand by 2018, and 2000 MW of demand 16 growth at the 90th percentile. Because there is uncertainty in the success of very aggressive 17 wind generation and because nuclear plants can substitute for other potential baseload 18 generation, the review team believes there is a need for the amount of electrical generation 19 represented by STP Units 3 and 4.

The State of Texas has funded an ambitious DSM program that is designed to reduce electricity demand by 15 to 20 percent in the service areas of regulated utilities within ERCOT and integrated Texas utilities outside of ERCOT (Governor's Competitiveness Council 2008). This program is included in the ERCOT forecasts and is part of the 2009 calculation of need for new generating resources.

25 If the Texas DSM program were completely successful, a 15 to 20 percent reduction in load
26 growth in the regulated portion of the ERCOT region would reduce the need for power, but not
27 eliminate it.

28 Table 8-6 summarizes the results of the review team's analysis of the ERCOT electricity 29 demand and supply forecasts that have occurred since STPNOC used the ERCOT 2007 30 forecasts to estimate unmet need for power from STP Units 3 and 4. The staff reviewed the 31 ERCOT 2008 and 2009 demand forecasts, noted the changes since 2007, and decided that 32 while ERCOT's short-term forecast of peak summer demand was heavily influenced by the 33 2008 to 2009 recession, the longer-term estimate of demand is only slightly lower than in the 34 2007 forecast. A more important issue is that the 2007 supply forecast did not include either the 35 impact of Texas's energy conservation plan or the full impact of an ambitious program to 36 significantly expand the scope of wind power in Texas. The review team added these elements 37 to the ERCOT 2009 long-term supply forecast. Finally, the review team examined directly the

- 1 impact of power plant retirements, a factor not specifically included in ERCOT's detailed
- 2 forecasts. Based on information available in STPNOC's need for power analysis, the review
- 3 team translated the modified ERCOT 2009 demand and supply forecasts into an estimate of the
- 4 unmet need for baseload power in ERCOT in the years 2014-2019, which spans the potential
- 5 completion dates for proposed Units 3 and 4.

Table 8-6. ERCOT/Review Team Forecasted Unmet Need for Baseload Generation
 Compared with STPNOC Estimated Need for Baseload Power

	Review Team/ERCOT 2009 (2014 and 2019), MW	STPNOC/ERCOT 2007 (2017) MW	Difference (Review Team/STPNOC) (Smallest to Largest)
Estimated Baseload Demand	21,900 to 24,000 ^(a)	26,600 ^(b)	-4700 to -4500
Estimated Baseload Supply	21,800 to 19,600 ^(c)	9900 to 20,100 ^(d)	-500 to +11,900
Unmet Net Need for Baseload Power	100 to 4400 ^(e)	6500 to 16,700 ^(f)	-2100 to -16,600
Proposed Capacity	2740	2740	0

(a) Table 8-35, 2014 and 2019 power requirements times 27.5%.

(b) STPNOC 2009, Figure 8.4-2, 2017 "Total Requirement:, times 30.1%.

(c) Table 8-3, 2014 and 2019 resources with retirements, times 27.5%.

(d) STPNOC 2009, Figure 8.4-2, 2017 "Capacity less units 50 years old or older," "Capacity less units 30 years old or older," times 30.1%..

(e) Difference between demand and supply.

(f) Difference between demand and supply.

8 Table 8-6 shows that although the demand for baseload power in 2016-2017 has not changed 9 much since the 2007 analysis, the combination of conservation and wind power may have 10 significantly reduced the need for baseload power. However, even though the potential unmet 11 need for power in the review team's alternative estimate is much smaller than STPNOC's 12 estimate, it still shows an unmet need large enough to accommodate proposed Units 3 and 4. In addition, because Units 3 and 4 are merchant plants, they do not need to show an absolute 13 14 shortage of power. The marketplace would decide whether Units 3 and 4 would be able to 15 compete successfully with other potential suppliers of baseload electricity.

16 **8.4.1 Conclusion**

17 The review team concludes that there is an expected future shortage of baseload power in the

18 ERCOT region that could be at least partially addressed by construction of proposed Units 3

and 4 at the STP site. The review team determined that the STPNOC assessment of its need

20 for power in its ER is not unreasonable. Building of the two new units could address (1) growth

21 in demand for baseload power and (2) replacement of retiring baseload generating units

- 1 elsewhere in ERCOT. Based on its analysis, the review team concludes that there is a justified
- 2 need for new baseload generating capacity in the ERCOT region in excess of the planned
- 3 2740 MW capacity output of proposed Units 3 and 4 at STP.

4 8.5 References

- 5 68 FR 55910. September 29, 2003. "Nuclear Energy Institute; Denial of Petition for
- 6 Rulemaking." Federal Register. U.S. Nuclear Regulatory Commission.
- 7 Electric Reliability Council of Texas (ERCOT). 2005a. "Methodology for Reserve Margin
- 8 Calculation," Memorandum from Read Comstock, TAC chair to ERCOT Board of Directors, May 9 10, 2005.
- 10 Electric Reliability Council of Texas (ERCOT). 2005b. Reserve Margin Update House
- 11 *Committee on Regulated Industries; PowerPoint Presentation*. Electric Reliability Council of 12 Texas.
- Electric Reliability Council of Texas (ERCOT). 2007. 2007 ERCOT Planning Long-Term Hourly
 Peak Demand and Energy Forecast, May 8, 2007. Accessed at
- 15 http://www.ercot.com/news/presentations/2007/2007_ERCOT_Planning_Long_Term_Hourly_D
- 16 emand_Energy_Forecast_.pdf. Accession No. ML100600754.
- Electric Reliability Council of Texas (ERCOT). 2008a. ERCOT Company Profile. Accessed
 May 13, 2009 at http://www.ercot.com/about/profile/index.html. Accession No. ML100600754.
- 19 Electric Reliability Council of Texas (ERCOT). 2008b. ERCOT Governance. Accessed May
- 20 13, 2009 at http://www.ercot.com/about/governance/index.html. Accession No. ML100600754.
- Electric Reliability Council of Texas (ERCOT). 2008c. *About ERCOT*. Accessed May 13, 2009
 at http://www.ercot.com/about/index. Accession No. ML100600754.
- 23 Electric Reliability Council of Texas (ERCOT). 2008d. *History of ERCOT*. Accessed May 13, 2000 at http://www.orost.com/obout/profile/biotop/. Accessed May 13, 2000 at http://www.orost.com/obout/profile/biotop/.
- 24 2009 at http://www.ercot.com/about/profile/history. Accession No. ML100600754.
- 25 Electric Reliability Council of Texas (ERCOT). 2008e. 2008 ERCOT Planning Long-Term
- 26 Hourly Peak Demand and Energy Forecast. Accessed June 24, 2009 at
- 27 http://www.ercot.com/content/news/presentations/2008/2008%20Planning%20Long-
- Term%20Hourly%20Demand%20Energy%20Forecast%20Final.doc. Accession No.
 ML100600754.
- 30 Electric Reliability Council of Texas (ERCOT). 2008f. ERCOT Long-Term System Assessment
- 31 December 2008. Accessed June 24, 2009 at

- 1 http://www.ercot.com/content/news/presentations/2008/ERCOT_Long-
- 2 Term_System_Assmt_Dec_2008.pdf. Accession No. ML100600754.
- 3 Electric Reliability Council of Texas (ERCOT). 2008g. Texas Regional Entity. Accessed May
- 4 14, 2009 at http://www.ercot.com/mktrules/compliance/tre/index. Accession No. ML100600754.
- 5 Electric Reliability Council of Texas (ERCOT). 2008h. Hourly Load Data Archives. Accessed
- 6 May 14, 2009 at http://www.ercot.com/gridinfo/load/load_hist/. Accession No. ML100600754.
- 7 Electric Reliability Council of Texas (ERCOT). 2008i. ERCOT Capacity, Demand, Reserves
- 8 Winter Update. Accessed June 24, 2009 at
- 9 http://www.ercot.com/content/news/presentations/2009/ERCOT_CDR_update_12-15-
- 10 08_public.xls. Accession No. ML100600754.
- 11 Electric Reliability Council of Texas (ERCOT). 2008j. Competitive Renewable Energy Zones
- 12 (CREZ) Transmission Optimization Study, ERCOT System Planning, April 2, 2008. Available at
- 13 http://www.ercot.com/news/presentations/2008/index. Accession No. ML100600754.
- 14 Electric Reliability Council of Texas (ERCOT). 2008k. Report on the Capacity, Demand, and
- 15 Reserves in the ERCOT Region, System Planning, May 2008. Available at
- 16 http://www.ercot.com/content/news/presentations/2008/2008_Capacity,_Demand,_Reserves_R
- 17 eport_FINAL.xls. Accession No. ML100600754.
- 18 Electric Reliability Council of Texas (ERCOT). 2008I. *ERCOT Membership*. Accessed May 14, 2009 at http://www.ercot.com/about/governance/members/. Accession No. ML100600754.
- 20 Electric Reliability Council of Texas (ERCOT). 2009a. 2009 ERCOT Planning Long-Term
- 21 Hourly Peak Demand and Energy Forecast. Available at
- 22 http://www.ercot.com/content/news/presentations/2009/2009_Planning_Long-
- 23 Term_Hourly_Demand_Energy_Forecast-av2009.pdf. Accession No. ML100600754.
- Electric Reliability Council of Texas (ERCOT). 2009b. *Report on the Capacity, Demand, and Reserves in the ERCOT Region, System Planning.* Available at
- 26 http://www.ercot.com/content/news/presentations/2009/2009%20ERCOT%20Capacity,%20De
- 27 mand%20and%20Reserves%20Report.pdf. Accession No. ML100600754.
- 28 Energy Information Administration (EIA). 2009. Annual Energy Outlook 2010, Early Release,
- 29 Dec 14, 2009. Accessed at http://www.eia.doe.gov/oiaf/aeo/index.html on January 14, 2009.
- 30 Accession No. ML100600754.

- 1 Federal Energy Regulatory Commission (FERC). 1999. "89 FERC 61,285. United States of
- 2 America Federal Energy Regulatory Commission 18 CFR Part 35 [Docket No. RM99-2-000;
- 3 Order No. 2000], Regional Transmission Organizations (Issued December 20, 1999).
- 4 Federal Energy Regulatory Commission (FERC). 2008. *Regional Transmission Organizations*
- 5 (RTO)/Independent System Operators (ISO). Accessed May 14, 2009 at
- 6 http://www.ferc.gov/industries/electric/indus-act/rto.asp. Accession No. ML100600754.
- 7 Global Energy Decisions (GED). 2007. ERCOT Target Reserve Margin Analysis. Prepared for
- 8 Electric Reliability Counsel of Texas (ERCOT). Date submitted January 18, 2007. Sacramento,
- 9 California.
- Governor's Competitiveness Council. 2008. 2008 Texas State Energy Plan. Governor's
 Competitiveness Council, Austin, Texas.
- 12 National Environmental Policy Act of 1969, as amended (NEPA). 42 USC 4321, et seq.
- 13 North American Electric Reliability Corporation (NERC). 2008a. North American Electric
- 14 Reliability Corporation. Accessed May 14, 2009 at http://www.nerc.com/. Accession No.
- 15 ML100600754.
- 16 North American Electric Reliability Corporation (NERC) 2008b. 2008 Long-Term Reliability
- Assessment 2008-2017. Available at http://www.nerc.com/files/FinalFiled2008LTRA.pdf.
 Accession No. ML100600754.
- 19 Pacific Northwest National Laboratory (PNNL). 2009. Letter from Dave Anderson (PNNL) to
- 20 Paul Hendrickson and Mike Warwick dated April 22, 2009, "Re: ERCOT Meeting." Accession
- 21 No. ML100070666.
- 22 South Texas Project Nuclear Operating Company (STPNOC). 2009. South Texas Project Units
- 23 3 and 4 Combined License Application, Part 3, Environmental Report. Revision 3, Bay City,
- 24 Texas. Accession No. ML092931600.
- Texas Utilities Code. 2009. *Texas Statutes: Utilities Code*. Accessed May 13, 2009 at
 http://tlo2.tlc.state.tx.us/statutes/ut.toc.htm. Accession No. ML100600754.
- 27 U.S. Nuclear Regulatory Commission (NRC). 2000. Environmental Standard Review Plan-
- 28 Standard Review Plans for Environmental Reviews for Nuclear Power Plants. NUREG-1555,
- 29 NRC, Washington, D.C. Includes 2007 updates.