OPERATING DATA REPORT

050-0331 DOCKET NO. DATE Sept. 13, 1979 ED BY J. Van Sickel COMPLETED BY TELEPHONE 319-851-5611

(9/77)

7909190330

OPERATING STATUS

1. Unit Name: <u>Duane Arnold Energy Center</u> 2. Reporting Period: August, 1979	Notes	
3. Licensed Thermal Power (MWt): 4. Nameplate Rating (Gross MWe): 5. Design Electrical Rating (Net MWe): 5. 538		
5. Design Electrical Rating (Net MWE): 545 6. Maximum Dependable Capacity (Gross MWe): 545 7. Maximum Dependable Capacity (Net MWe): 515		

8. If Changes Occur in Capacity Ratings (Items Number 3 Through 7) Since Last Report, Give Reasons:

510 9. Power Level To Which Restricted, If Any (Net MWe):

10. Reasons For Restrictions, 1f Any: <u>Thermal p</u> to MCPR operating limit restrictions. Thermal power limited to approximately 95% due

	This Month	Yrto-Date	Cumulative
11. Hours In Reporting Period	744	5,831	40,151
12. Number Of Hours Reactor Was Critical	744	4,108.3	27,721.1
13. Reactor Reserve Shutdown Hours	0	0	0
14. Hours Generator On-Line	744	4,012.3	26,996.3
15. Unit Reserve Shutdown Hours	0	·Ó	0
16. Gross Thermal Energy Generated (MWH)	1,279,032	5,676,192	33,737,832
17. Gross Electrical Energy Generated (MWH)	379,710	1,925,340	11,262,769
18. Net Electrical Energy Generated (MWH)	357,322	1,811,632	10,527,932
19. Unit Service Factor	100%	68.8%	67.2%
20. Unit Availability Factor	100%	68.8%	67.2%
21. Unit Capacity Factor (Using MDC Net)	93.3%	60.3%	50.9%
22. Unit Capacity Factor (Using DER Net)	89.3%	57.7%	48.7%
23. Unit Forced Outage Rate	0%	31.2%	22.4%
24. Shutdowns Scheduled Over Next 6 Months (Tv	ne. Date, and Duration	of Each)	

۰,

Refueling, February 9, 1979, 12 weeks

25. If Shut Down At End Of Report Period, Estimated Date of Startup:

* Turbine Rating: 565.7 MWe

Generator Rating: 663.5 (MVA) x .90 (Power Factor) = 597 MWe

AVERAGE DAILY UNIT POWER LEVEL

DOCKET NO.	050-0331	
UNIT	Duane Arnold Energy	
DATE	<u>Sept. 13, 197</u> 9	
COMPLETED BY	J. Van Sickel	
TELEPHONE	319-851-5611	

MONT	THAugust, 1979		
DAY	AVERAGE DAILY POWER LEVEL (MWe-Net)	DAY	AVERAGE DAILY POWER LEVEL (MWe-Net)
1	475	17	487
2	472	18	481
3	472	19	464
4	469	20	480
5	459	21	483
6	462	22	484
7	463	23	489
8	472	24	487
9	469	25	486
10	482	26	47.6
11	493	27	488
12	484	28	486
13	492	29	487
14	501	30	483
15	501	31	477
16	485		

INSTRUCTIONS

On this format, list the average daily unit power level in MWe-Net for each day in the reporting month. Compute to the nearest whole megawatt.

Sept. 13, 1979 DATE J. Van Sickel **COMPLETED BY** REPORT MONTH August, 1979 319-851-5611 TELEPHONE Method of Shutting Down Reactor³ Component Code⁵ Reason² Duration (Hours) System Code⁴ Type^l Licensee Cause & Corrective Date No. Event Action to Report # **Prevent Recurrence** None 2 3 F: Forced Reason: Method: Exhibit G - Instructions S: Scheduled A-Equipment Failure (Explain) B-Maintenance or Test I-Manual for Preparation of Data 2-Manual Scram. Entry Sheets for Licensee C-Refueling 3-Automatic Scrain. Event Report (LER) File (NUREG-D-Regulatory Restriction E-Operator Training & License Examination 4-Other (Explain) 0161) F-Administrative 5 G-Operational Error (Explain) Exhibit 1 - Same Source (9/77) H-Other (Explain)

050-0331 DOCKET NO. Duane Arnold Energy Cente UNIT NAME

UNIT SHUTDOWNS AND POWER REDUCTIONS

LEFUELING INFORMATION

Unit Duane Arnold Energy Center Date Sept. 13, 1979 Completed by J. Van Sickel Telephone 319-851-5611

1. Name of facility.

A. Duane Arnold Energy Center

- Scheduled date for next refueling shutdown.
 A. February 9, 1980
- Scheduled date for restart following refueling.
 A. May 3, 1980
- 4. Will refueling or resumption of operation thereafter require a technical specification change or other license amendment?
 - A. Yes. MCPR and MAPLHGR operating limits as derived from transient and accident analyses.
- 5. Scheduled date(s) for submitting proposed licensing action and supporting information.

A. Unknown

6. Important licensing considerations associated with refueling, e.g., new or different fuel design or supplier, unreviewed design or performance analysis methods, significant changes in fuel design, new operating procedures.

A. The reload will consist of up to 92 8x8 2 water rod bundles.

7. The number of fuel assemblies (a) in the core and (b) in the spent fuel storage pool.

A. a) 368 b) 276

8. The present licensed spent fuel pool storage capacity and the size of any increase in licensed storage capacity that has been requested or is planned, in number of fuel assemblies.

A. 2050

9. The projected date of the last refueling that can be discharged to the spent fuel pool assuming the present licensed capacity.

A. 1998

Docket No.	050-0331
Unit_Duan	e Arnold Energy Center
Date	Sept. 13, 1979
Completed	by J. Van Sickel
Telephone	319-851-5611

NARRATIVE SUMMARY OF OPERATING EXPERIENCE

8-1 At the beginning of the report period the plant was operating at 507 MWe.

8-10 During normal operation, operations personnel noted the suppression chamber water level indication on LR 4385 was drifting downscale while redundant indication on LR 4384 was stable.

RO 79-017

- 8-22 The "A" River Water Supply Pump was declared inoperable due to motor problems.
- 8-30 The plant operated base loaded throughout the report period with brief power reductions for turbine control valve and control rod testing.

Docket No. 050-0331 Unit Duane Arnold Energy Center Date Sept. 13, 1979 Completed by J. Van Sickel Telephone 319-851-5611

MAJOR SAFETY RELATED MAINTENANCE

DATE	SYSTEM	COMPONENT	DESCRIPTION
8-01-79	Containment Atmo sph ere Control	Drywell Rad Monitor IC-219A Relay Kl and K2	Installed new contacts and coils
8-13-79	Containment Atmosphere Control	1K-18A containment differential pressure compressor	Replaced unloader valve
8-13-79	Primary Containment	LT 2325	Replaced amplifier card
8-13-79	RHR Service Water	1S-90B	Cleaned Strainer
8-14-79	Containment Atmosphere Control	AN-8181A	Installed new potassium hydroxide solution in cell and recalibrated analyzer.
8-15-79	Containment Atmosphere Control	AN-8181B	Installed new potassium hydroxide solution in cell and recalibrated analyzer.
8-17-79	Standby Diesel Generators	PS-3224A	Replaced pressure switch
8-20-79	RHR Service Water	1S-90B	Cleaned strainer
8-20-79	ESW	1S-89B	Cleaned strainer
8-22-79	RHR	PS-1955	Replaced pressure switch
8-23-79	Neutron Monitoring	RBM "A" Power Supply	Replaced diode
8-23 - 79	Containment Atmosphere Control	AN-8181A, AN-8181B	Recalibrated oxygen analyzers
8-24-79	Containment Atmosphere Control	AN-8181B	Adjusted flow and span gas pressure, recalibrated
·			