

OPERATING DATA REPORT

DOCKET NO. 050-0331
 DATE 1-15-80
 COMPLETED BY J. Van Sickle
 TELEPHONE 319-851-5611

OPERATING STATUS:

1. Unit Name: Duane Arnold Energy Center
2. Reporting Period: December, 1979
3. Licensed Thermal Power (MWt): 1658
- * 4. Nameplate Rating (Gross MWe): 565 (Turbine rating)
5. Design Electrical Rating (Net MWe): 538
6. Maximum Dependable Capacity (Gross MWe): 545
7. Maximum Dependable Capacity (Net MWe): 515
8. If Changes Occur in Capacity Ratings (Items Number 3 Through 7) Since Last Report, Give Reasons:

Notes

9. Power Level To Which Restricted, If Any (Net MWe): _____
10. Reasons For Restrictions, If Any: _____

	This Month	Yr.-to-Date	Cumulative
11. Hours In Reporting Period	<u>744</u>	<u>8760</u>	<u>43,080</u>
12. Number Of Hours Reactor Was Critical	<u>744</u>	<u>6,915.3</u>	<u>30,564.1</u>
13. Reactor Reserve Shutdown Hours	<u>0</u>	<u>0</u>	<u>0</u>
14. Hours Generator On-Line	<u>744</u>	<u>6,832.1</u>	<u>29,819.1</u>
15. Unit Reserve Shutdown Hours	<u>0</u>	<u>0</u>	<u>0</u>
16. Gross Thermal Energy Generated (MWH)	<u>1,045,416</u>	<u>9,067,920</u>	<u>37,129,560</u>
17. Gross Electrical Energy Generated (MWH)	<u>366,935</u>	<u>3,086,937</u>	<u>12,424,366</u>
18. Net Electrical Energy Generated (MWH)	<u>345,093</u>	<u>2,898,764</u>	<u>11,615,063</u>
19. Unit Service Factor	<u>100%</u>	<u>78%</u>	<u>69.2%</u>
20. Unit Availability Factor	<u>100%</u>	<u>78%</u>	<u>69.2%</u>
21. Unit Capacity Factor (Using MDC Net)	<u>90.1%</u>	<u>64.3%</u>	<u>52.4%</u>
22. Unit Capacity Factor (Using DER Net)	<u>86.2%</u>	<u>61.5%</u>	<u>50.1%</u>
23. Unit Forced Outage Rate	<u>0%</u>	<u>22%</u>	<u>20.9%</u>

24. Shutdowns Scheduled Over Next 6 Months (Type, Date, and Duration of Each):
Refueling, February 9, 1980, 12 weeks

25. If Shut Down At End Of Report Period, Estimated Date of Startup: _____

* Turbine Rating: 565.7 MWe
 Generator Rating: 663.5 (MVA) x .90 (Power Factor) = 597 MWe

AVERAGE DAILY UNIT POWER LEVEL

DOCKET NO. 050-0331

UNIT Duane Arnold Energy Center

DATE 1-15-80

COMPLETED BY J. Van Sickle

TELEPHONE 319-851-5611

MONTH December, 1979

DAY	AVERAGE DAILY POWER LEVEL (MWe-Net)
1	344
2	434
3	490
4	473
5	468
6	481
7	482
8	481
9	471
10	452
11	501
12	481
13	477
14	475
15	471
16	460

DAY	AVERAGE DAILY POWER LEVEL (MWe-Net)
17	473
18	470
19	467
20	467
21	463
22	465
23	460
24	460
25	460
26	462
27	462
28	461
29	460
30	451
31	458

INSTRUCTIONS

On this format, list the average daily unit power level in MWe-Net for each day in the reporting month. Compute to the nearest whole megawatt.

UNIT SHUTDOWNS AND POWER REDUCTIONS

DOCKET NO. 050-0331
UNIT NAME Duane Arnold Energy Ctr.
DATE 1-15-80
COMPLETED BY J. Van Sickle
TELEPHONE 319-851-5611

REPORT MONTH December, 1979

No.	Date	Type ¹	Duration (Hours)	Reason ²	Method of Shutting Down Reactor ³	Licensee Event Report #	System Code ⁴	Component Code ⁵	Cause & Corrective Action to Prevent Recurrence
22	791201	S	0	F	4	N/A	RB	Conrod	Power reduction to withdraw control rods

¹
 F: Forced
 S: Scheduled

²
Reason:
 A-Equipment Failure (Explain)
 B-Maintenance or Test
 C-Refueling
 D-Regulatory Restriction
 E-Operator Training & License Examination
 F-Administrative
 G-Operational Error (Explain)
 H-Other (Explain)

³
Method:
 1-Manual
 2-Manual Scram.
 3-Automatic Scram.
 4-Other (Explain)

⁴
 Exhibit G - Instructions for Preparation of Data Entry Sheets for Licensee Event Report (LER) File (NUREG-0161)

⁵
 Exhibit I - Same Source

NARRATIVE SUMMARY OF OPERATING EXPERIENCE

12-1 At the beginning of the report period the plant was operating at 521 MWe. At 0043 hours a load reduction was begun in order to perform control rod withdrawals. Withdrawals were completed and a load increase was begun at 0604 hours.

12-2 During a routine instrument check, FR-4133, off-gas stack flow recorder, was found to be indicating downscale due to problems with its associated transmitter, DPT 4133.

ETSV Report 79-3

12-3 The plant was operating at 524 MWe.

12-21 During normal operation, pen 1 (drywell pressure) on PR 4384 was found to be indicating downscale.

RO Report 79-038

12-25 During the performance of control room panel surveillance testing, a fuse was blown in the power supply to annunciator panels 1C-03, 04 and 05. This caused a loss of both channels of the Core Spray Sparger Break Detection Alarm System. Since one channel is required to be functionally at all times, T.S.3.2.B was violated. Both audio and visual alarm indication was unavailable for approximately 3 hours. The need to bring the reactor to cold shutdown condition within 24 hours was recognized.

RO Report 79-037

12-31 1G-31 Standby diesel generator was declared inoperable due to low lube oil level.

RO Report Pending

12-31 At the end of the report period the plant was in coast down operation with a refueling outage scheduled to begin February 9, 1980.

Docket No. 050-0331
 Unit Duane Arnold Energy Center
 Date 1-15-80
 Completed by J. Van Sickle
 Telephone 319-851-5611

MAJOR SAFETY RELATED MAINTENANCE

DATE	SYSTEM	COMPONENT	DESCRIPTION
12-7-79	Containment Atmospheric Control	AN-8181B	Installed new flowmeter
12-10-79	Neutron Monitoring-	APRM Channel "E"	Replaced zener diode
12-14-79	RHR	Pipe support GBB-5-H19	Constructed and installed support
12-20-79	Containment Atmospheric Control	AN-8181B	Rejuvenated cell
12-20-79	RCIC	MOV 2515	Packed valve
12-22-79	Containment Atmospheric Control	PR-4384	Replaced slide wire
12-26-79	Containment Atmospheric Control	RE 8101B	Replaced detector
12-28-79	Containment Atmospheric Control	SV-8106B	Replaced solenoid

REFUELING INFORMATION

Docket No. 050-0331
at Duane Arnold Energy Center
Date 1-15-80
Completed by J. Van Sickle
Telephone 319-851-5611

1. Name of facility.
A. Duane Arnold Energy Center
2. Scheduled date for next refueling shutdown.
A. February 9, 1980
3. Scheduled date for restart following refueling.
A. May 3, 1980
4. Will refueling or resumption of operation thereafter require a technical specification change or other license amendment?
A. Yes. MCPR and MAPLHGR operating limits as derived from transient and accident analyses.
5. Scheduled date(s) for submitting proposed licensing action and supporting information.
A. January 18, 1980
6. Important licensing considerations associated with refueling, e.g., new or different fuel design or supplier, unreviewed design or performance analysis methods, significant changes in fuel design, new operating procedures.
A. The reload will consist of 88 8 x 8 2 water rod bundles.
7. The number of fuel assemblies (a) in the core and (b) in the spent fuel storage pool.
A. a) 368 b) 276
8. The present licensed spent fuel pool storage capacity and the size of any increase in licensed storage capacity that has been requested or is planned, in number of fuel assemblies.
A. 2050
9. The projected date of the last refueling that can be discharged to the spent fuel pool assuming the present licensed capacity.
A. 1998