

OPERATING DATA REPORT

DOCKET NO. 050-0331
 DATE 2-15-80
 COMPLETED BY J. Van Sickle
 TELEPHONE 319-851-5611

OPERATING STATUS

1. Unit Name: Duane Arnold Energy Center
2. Reporting Period: January, 1980
3. Licensed Thermal Power (MWt): 1658
- * 4. Nameplate Rating (Gross MWe): 565 (Turbine Rating)
5. Design Electrical Rating (Net MWe): 538
6. Maximum Dependable Capacity (Gross MWe): 545
7. Maximum Dependable Capacity (Net MWe): 515
8. If Changes Occur in Capacity Ratings (Items Number 3 Through 7) Since Last Report, Give Reasons:

Notes

9. Power Level To Which Restricted, If Any (Net MWe): _____
10. Reasons For Restrictions, If Any: _____

	This Month	Yr.-to-Date	Cumulative
11. Hours In Reporting Period	<u>744</u>	<u>744</u>	<u>43,824</u>
12. Number Of Hours Reactor Was Critical	<u>744</u>	<u>744</u>	<u>31,308.1</u>
13. Reactor Reserve Shutdown Hours	<u>0</u>	<u>0</u>	<u>0</u>
14. Hours Generator On-Line	<u>744</u>	<u>744</u>	<u>30,563.1</u>
15. Unit Reserve Shutdown Hours	<u>0</u>	<u>0</u>	<u>0</u>
16. Gross Thermal Energy Generated (MWH)	<u>976,200</u>	<u>976,200</u>	<u>38,105,760</u>
17. Gross Electrical Energy Generated (MWH)	<u>343,643</u>	<u>343,643</u>	<u>12,768,009</u>
18. Net Electrical Energy Generated (MWH)	<u>322,176</u>	<u>322,176</u>	<u>11,937,240</u>
19. Unit Service Factor	<u>100%</u>	<u>100%</u>	<u>69.7%</u>
20. Unit Availability Factor	<u>100%</u>	<u>100%</u>	<u>69.7%</u>
21. Unit Capacity Factor (Using MDC Net)	<u>84.1%</u>	<u>84.1%</u>	<u>52.9%</u>
22. Unit Capacity Factor (Using DER Net)	<u>80.5%</u>	<u>80.5%</u>	<u>50.6%</u>
23. Unit Forced Outage Rate	<u>0%</u>	<u>0%</u>	<u>20.5%</u>

24. Shutdowns Scheduled Over Next 6 Months (Type, Date, and Duration of Each):
Refueling, February 9, 1980, 10 weeks

25. If Shut Down At End Of Report Period, Estimated Date of Startup: _____

* Turbine Rating: 565.7 MWe
 Generator Rating: 663.5 (MVA) x .90 (Power Factor) = 597 MWe

8002200

408

AVERAGE DAILY UNIT POWER LEVEL

DOCKET NO. 050-0331

UNIT Duane Arnold Energy Center

DATE 2-15-80

COMPLETED BY J. Van Sickle

TELEPHONE 319-851-5611

MONTH January, 1980

DAY	AVERAGE DAILY POWER LEVEL (MWe-Net)
1	455
2	455
3	454
4	452
5	447
6	450
7	446
8	451
9	442
10	441
11	441
12	439
13	440
14	439
15	436
16	433

DAY	AVERAGE DAILY POWER LEVEL (MWe-Net)
17	435
18	436
19	421
20	351
21	443
22	429
23	428
24	418
25	426
26	423
27	420
28	420
29	418
30	417
31	415

INSTRUCTIONS

On this format, list the average daily unit power level in MWe-Net for each day in the reporting month. Compute to the nearest whole megawatt.

UNIT SHUTDOWNS AND POWER REDUCTIONS

DOCKET NO. 050-0331
 UNIT NAME Duane Arnold Energy Center
 DATE 2-15-80
 COMPLETED BY J. Van Sickle
 TELEPHONE 319-851-5611

REPORT MONTH January, 1980

No.	Date	Type ¹	Duration (Hours)	Reason ²	Method of Shutting Down Reactor ³	Licensee Event Report #	System Code ⁴	Component Code ⁵	Cause & Corrective Action to Prevent Recurrence
None									

¹
 F: Forced
 S: Scheduled

²
 Reason:
 A-Equipment Failure (Explain)
 B-Maintenance or Test
 C-Refueling
 D-Regulatory Restriction
 E-Operator Training & License Examination
 F-Administrative
 G-Operational Error (Explain)
 H-Other (Explain)

³
 Method:
 1-Manual
 2-Manual Scram.
 3-Automatic Scram.
 4-Other (Explain)

⁴
 Exhibit G - Instructions for Preparation of Data Entry Sheets for Licensee Event Report (LER) File (NUREG-0161)

⁵
 Exhibit I - Same Source

REFUELING INFORMATION

Docket No. 050-0331
Unit Duane Arnold Energy Center
Date 2-15-80
Completed by J. Van Sickle
Telephone 319-851-5611

1. Name of facility.
 - A. Duane Arnold Energy Center
2. Scheduled date for next refueling shutdown.
 - A. February 9, 1980
3. Scheduled date for restart following refueling.
 - A. April 10, 1980
4. Will refueling or resumption of operation thereafter require a technical specification change or other license amendment?
 - A. Yes. MCPR and MAPLHGR operating limits as derived from transient and accident analyses.
5. Scheduled date(s) for submitting proposed licensing action and supporting information.
 - A. January 18, 1980
6. Important licensing considerations associated with refueling, e.g., new or different fuel design or supplier, unreviewed design or performance analysis methods, significant changes in fuel design, new operating procedures.
 - A. The reload will consist of up to 88 8 x 8 2 water rod bundles.
7. The number of fuel assemblies (a) in the core and (b) in the spent fuel storage pool.
 - A. a) 368 b) 276
8. The present licensed spent fuel pool storage capacity and the size of any increase in licensed storage capacity that has been requested or is planned, in number of fuel assemblies.
 - A. 2050
9. The projected date of the last refueling that can be discharged to the spent fuel pool assuming the present licensed capacity.
 - A. 1998

Report No. 050-0331
Unit Duane Arnold Energy
Date 2-15-80
Completed by J. Van Sickle
Telephone 319-851-5611

NARRATIVE SUMMARY OF OPERATING EXPERIENCE

At the beginning of the report period the plant was operating at 486 MWe. The plant continued base loaded coast down operation throughout the report period with one power reduction on January 20 to perform control rod scram time testing. An Environmental Technical Specification Violation (ETSV Report 80-1) occurred on January 7 when an off gas stack particulate filter and iodine cartridge were lost within the protected area. A Reportable Occurrence (RO 80-1) occurred on January 24 when both containment oxygen analyzers were out of service for a short time. A Reportable Occurrence Report is pending concerning a HPCI pump seal water supply leak which was found on January 28.

Docket No. 050-0331
Unit Duane Arnold Energy
Date _____
Completed by J. Van Sickle
Telephone 319-851-5611

MAJOR SAFETY RELATED MAINTENANCE

Date	System	Component	Description
1-4-80	HPCI	MOV 2318	Repaired body to bonnet leak
1-9-80	RHR	FY 1971B	Recalibrated
1-9-80	Containment Atmospheric Control	AN-8181A	Recalibrated
1-11-80	Radwaste Sumps	CV-3728	Lubricated Valve Operator
1-16-80	Containment Atmospheric Control	AN-8181A	Rejuvenated Cell
1-17-80	Main Steam Line Rad. Monitoring	RC 4448A	Repaired Test Circuit
1-22-80	Containment Atmospheric Control	AN-8181A	Rejuvenated Cell and Replaced Alarm Point Potentiometer
1-23-80	RHR	MOV-2038	Adjusted Limit Switch
1-25-80	Containment Atmospheric Control	AN-8181B	Cleaned Flow Regulator, Rejuvenated Cell and Calibrated Cell