OPERATING DATA REPORT

DOCKET NO. 050-0331 DATE 7-15-80 COMPLETED BY J. Van Sickel TELEPHONE 319-851-5611

(9/77)

OPERATING STATUS

 Unit Name: <u>Duane Arnold Energy</u> Reporting Period: <u>June</u>, 1980 Licensed Thermal Power (MWt): <u>1658</u> Nameplate Rating (Gross MWe): <u>565 (Tur</u> Design Electrical Rating (Net MWe): <u>538</u> Maximum Dependable Capacity (Gross MWe): Maximum Dependable Capacity (Net MWe): 	Notes		
 8. If Changes Occur in Capacity Ratings (Items N 9. Power Level To Which Restricted, If Any (Net 10. Reasons For Restrictions, If Any:	umber 3 Through 7) Si	nce Last Report, Give Re	asons:
	· · · · · · · · · · · · · · · · · · ·		
	This Month	Yrto-Date	Cumulative
11. Hours In Reporting Period	720	4,367	47,447
12. Number Of Hours Reactor Was Critical	720	2,568.8	33,132.8
13. Reactor Reserve Shutdown Hours	0	0	0
14. Hours Generator On-Line	720	2,486.3	32,305,5
15. Unit Reserve Shutdown Hours	0_	0	0
16 Carson Theory I Day on Contract (100400)	1 056 226	2 007 512	10 227 072

16. Gross Thermal Energy Generated (MWH) 13,472,641 <u>351,949</u> 048,275 17. Gross Electrical Energy Generated (MWH) 330,970 980,643 12,595,706 18. Net Electrical Energy Generated (MWH) 100% 56.9% 68.1% 19. Unit Service Factor 68.1% 100% 56.9% 20. Unit Availability Factor 89.3% 43.6% 51.5% 21. Unit Capacity Factor (Using MDC Net) 85.4% 41.7% 49.3% 22. Unit Capacity Factor (Using DER Net) 0% 6.3% 20.0% 23. Unit Forced Outage Rate 24. Shutdowns Scheduled Over Next 6 Months (Type, Date, and Duration of Each):

25. If Shut Down At End Of Report Period, Estimated Date of Startup:

* Turbine Rating: 565.7 MWe

8007220371

Generator Rating: 663.5 (MVA) x .90 (Power Factor) = 597 MWe

AVERAGE DAILY UNIT POWER LEVEL

DOCKET NO.	050-0331
UNIT	Duane Arnold Engy.
DATE	_7_15_80
COMPLETED BY	<u>J. Van Sickel</u>
TELEPHONE	319-851-5611

MONT	rn June, 1980		
DAY	AVERAGE DAILY POWER LEVEL (MWe-Net)	DAY	AVERAGE DAILY POWER LEVEL (MWe-Net)
1	406	17	495
2	458	18	486
3	490	. 19	493
4	484	20	484
5	458	21	456
6	432	22	485
7	387	23	478
8	307	24	481
9	438	25	481
10	505	26	476
11	499	27	366
12	492	28	329
13	475	29	494
14	481	30	494
15	483	31	
16	499		· · ·

INSTRUCTIONS

On this format, list the average daily unit power level in MWe-Net for each day in the reporting month. Compute to the nearest whole megawatt.

UNIT SHUTDOWNS AND POWER REDUCTIONS

REPORT MONTH June, 1980

DOCKET NO. 050-0331 UNIT NAME Duane Arnold Engy. Ctr. DATE 7-15-80 COMPLETED BY TELEPHONE <u>319-851-5611</u>

No.	Date	Type ¹	Duration (Hours)	Reason ²	Method of Shutting Down Reactor ³	Licensee Event Report #	System Code ⁴	Component Cude ⁵	Cause & Corrective Action to Prevent Recurrence
9.	800608	S	0	В	4		СН	НТЕХСН	Power reduced to perform maintenance on the "A" reactor feed pump oil cooler.
10.	800627	S	Ò	A	4		СВ		Power was reduced to repair the "B" Recirculation System M-G set generator exciter.
								· · · · · · · · · · · · · · · · · · ·	
I F: Fo S: Sch	rced eduled	Reaso A-Equ B-Mai C-Ref D-Reg E-Opo	on: uipment Fai intenance of ueling gulatory Re: erator Train ministrative	lure (Ex Test striction ing & Li	kplain) icense Exa	3 mination	Method 1-Manu 2-Manu 3-Auto 4-Othe	1: ial ial Scram. matic Scram. r (Explain)	4 Exhibit G - Instructions for Preparation of Data Entry Sheets for Licensee Event Report (LER) File (NUREG- 0161)
(9/77)		G-Op	erational Er	ror (Exp	plain)				5 Exhibit I - Same Source

REFUELING INFORMATION



DOCKET NO.	•	050-	-033	I	
Unit Duane	Ar	nola	En	ergy Ce	in
Date 7-15-	-80			¥×	
Completed	by	J.	Van	Sicke	T
Telephone	319	-85	1-56	11	

1. Name of facility.

A. Duane Arnold Energy Center

- Scheduled date for next refueling shutdown.
 A. Spring, 1981
- 3. Scheduled date for restart following refueling.

A. Unknown

- 4. Will refueling or resumption of operation thereafter require a technical specification change or other license amendment?
 - A. No
- 5. Scheduled date(s) for submitting proposed licensing action and supporting information.

A. N/A

6. Important licensing considerations associated with refueling, e.g., new or different fuel design or supplier, unreviewed design or performance analysis methods, significant changes in fuel design, new operating procedures.

A. No licensing action is anticipated.

7. The number of fuel assemblies (a) in the core and (b) in the spent fuel storage pool.

A. a) 368 B) 364

8. The present licensed spent fuel pool storage capacity and the size of any increase in licensed storage capacity that has been requested or is planned, in number of fuel assemblies.

A. 2050

9. The projected date of the last refueling that can be discharged to the spent fuel pool assuming the present licensed capacity.

A. 1998

Docke	t No.	050-	0331			
Dat	July	15,1	980			
Unit	Duane	Arno	old Er	nergy	Center	*******
Comp1	eted b	у J.	Van	Sicke	el	
Telep	hone	319-	851-5	5611		

NARRATIVE SUMMARY OF OPERATING EXPERIENCE

- 6-1 At the beginning of the report period the plant was operating at 459 MWe. At load decrease was begun at 0922 hours in preparation for control rod withdrawals. Control rod withdrawals were completed and a load increase begun at 1318 hours.
- 6-3 During surveillance testing a body to bonnet and packing leak was discovered on a pressure point isolation valve on the RCIC steam supply line. The RCIC system was taken out of service to repair the valve.

RO Report 80-024

The plant was operating at 529 MWe.

6-6 During surveillance testing main steam line leak detection TIS-4478 was found with an out of specification setpoint.

RO Report 80-025

- 6-8 Power was reduced in order to perform maintenance on the "A" reactor feed pump oil cooler. Maintenance was completed and a power increase begun at 2113 hours.
- 6-10 The diesel fire pump was taken out of service for maintenance.

The Plant was operating at 536 MWe.

6-17 During surveillance testing a 4KV emergency bus undervoltage relay was found to have an out of specification time delay.

RO Report 80-026

On this date the diesel fire pump was out of service 7 days and a special report detailing the problems found and corrective action taken became necessary.

- 6-27 The "B" recirculation pump tripped due to problems with the M-G set generator excitor.
- 6-28 The problem with the "B" recirculation system M-G set generator excitor were resolved, the "B" recirc. system placed back in service and a power increase begun.
- 6-30 The plant was operating at 516 MWe.

Docket No. 050-0331 Unit <u>Duane Arnold Energy Center</u> Date-7-15-80 Completed by <u>J. Van Sickel</u> Telephone <u>319-851-5611</u>

MAJOR SAFETY RELATED MAINTENANCE

..

DATE	SYSTEM	COMPONENT	DESCRIPTION
6-03-80	CRD Hydraulic	CRD 10-31	Replaced transistor in rod position indicating system
6-13-80	Containment Atmospheric Control	TR 4386A	Replaced filter capacitor in power supply
6-13-80	Standby Gas Treatment	Cómpressor 1K-4	Rebuilt compressor
6-20-80	Drywell Radiation Monitor	RIT 8102B	Replaced gaseous detector tube
6-20-80	Containment Atmospheric Control	AR 4381A	Changed chemicals in analyzer cell
6-24-80	Containment Atmospheric Control	TT 4325	Replaced circuit board
6-25-80	Reactor Protection	"B" RBM	Replaced relay
6-27-80	Drywell Radiation Monitor	RE 8102B	Replaced detector tube