ACCELERATED DISTRIBUTION DEMONSTRATION

### REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

SYSTEM

I

D

S

A

D

D

S

R

I

D

S

A

D

D

S

ACCESSION NBR:8903280314 DOC.DATE: 89/03/17 NOTARIZED: NO DOCKET # FACIL:50-331 Duane Arnold Energy Center, Iowa Electric Light & Pow 05000331 AUTH.NAME AUTHOR AFFILIATION AXLINE,J.S. Iowa Electric Light & Power Co. HANNEN,R.L. Iowa Electric Light & Power Co. RECIP.NAME RECIPIENT AFFILIATION . RECIPIENT AFFILIATION .

SUBJECT: LER 89-005-00:on 890216, actuation of standby filter unit due to spurious upscale trip of radiation monitor. W/8 ltr.

DISTRIBUTION CODE: IE22D COPIES RECEIVED:LTR ( ENCL / SIZE: TITLE: 50.73 Licensee Event Report (LER), Incident Rpt, etc.

NOTES:

¥.

	RECIPIENT ID CODE/NAME PD3-3 LA HALL,J.R.	COPIES LTTR EN 1 1 1 1	RECIPIENT CL ID CODE/NAME PD3-3 PD	COPI LTTR 1	ES ENCL 1	
INTERNAL:	ACRS MICHELSON ACRS WYLIE AEOD/DSP/TPAB DEDRO NRR/DEST/ADE 8H NRR/DEST/CEB 8H NRR/DEST/ICSB 7 NRR/DEST/MTB 9H NRR/DEST/RSB 8E NRR/DLPQ/HFB 10 NRR/DOEA/EAB 11 NRR/DCEA/EAB 11 NRR/DREP/RPB 10 NUDOCS-ABSTRACT RES/DSIR/EIB RGN3 FILE 01	$ \begin{array}{cccccccccccccccccccccccccccccccccccc$	ACRS MOELLER AEOD/DOA AEOD/ROAB/DSP IRM/DCTS/DAB NRR/DEST/ADS 7E NRR/DEST/ADS 7E NRR/DEST/MEB 9H NRR/DEST/MEB 9H NRR/DEST/SGB 8D NRR/DEST/SGB 8D NRR/DLPQ/QAB 10 NRR/DREP/RAB 10 NRR/DRIS/SIB 9A REG FILE 02 RES/DSR/PRAB	2 1 1 1 1 1 1 1 1 1 1	2 1 2 1 0 1 1 1 1 1 1 1 1 1 1 1	
EXTERNAL:	EG&G WILLIAMS,S H ST LOBBY WARD NRC PDR NSIC MURPHY,G.A	4 4 1 1 1 1 1 1	FORD BLDG HOY,A LPDR NSIC MAYS,G	1 1 1	1 1 1	

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK, ROOM P1-37 (EXT. 20079) TO ELIMINATE YOUR NAME FROM DISTRIBUTION LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTTR 45 ENCL 44

+ + + +

	LICENSEE EVE	NT REPO	)RT (LER)	U.S. N	UCLEAR REGULATORY COMMIS APPROVED OMS NO. 2180-0104 EXPIRES: 8/31/88
ACILITY NAME (1)					· · · · · · · · · · · · · · · · · · ·
Duane Arnold Energy Center (	DAEC)			DISIOID	
Actuation of Standby Fi	Iter Unit Due	to Spuri	ous Upscal	e trip of	Radiation Moni
EVENT DATE (5)	<u>urveillance Te</u>	st	•	- · · · F .9 ·	
MONTH DAY YEAR YEAR SEQUENTIAL	REPORT DAT	E (7)	OTHER	FACILITIES INVO	LVED (SI
NUMBER	NUMBER MONTH DAY	YEAR	FACILITY NA	MES.	DOCKET NUMBER(S)
			None		0 5 0 0 0
	0003117	8 9			
OPERATING THIS REPORT IS SUGMITTED P	URSUANT TO THE REQUIREME	INTE OF 10 CFR	S. (Chert and al man		0 5 0 0 0
20.402(b)	20.406(e)		XX 80,73(a)(2)(iv)	or the following) (1	
20.406(e)(1)(i)	80.38(e)(1)		60.73(a)(2)(v)		73.71(6)
	50.38(e)(2)		80.73(a)(2)(vii)		OTHER (Specify in Anoma
	50,73(a)(2)(l)		60.73(a)(2)(viii)()	N)	ONOW and in Text, NRC Fo. 366A)
20.408 (a) (1) (v)	60.73(s)(2)(H)		80.73(s)(2)(viii)(8	n	
	50.73(s)(3)(iii)		60.73(a)(2)(x)		
ME	LIGENBEE CONTACT	OR THIS LER (	12)	······································	
				AREA CODE T	ELEPHONE NUMBER
<u>Derr S. Axline, Technical Su</u>	upport Engineer			2 . 1	0.0.1
COMPLETE ONE	LINE FOR EACH COMPONENT	FAILURE DESC	AIBED IN THIE REPORT	<u>                                     </u>	8 5 1 - 7 6 0
AUSE SYSTEM COMPONENT MARUFAC. REPA	ORTABLE	CALLER			
		CAUSE SYST	COMPONENT	TURER	TO NPROS
SUPPL\$MENTAL	ASPOAT SEXESTED (14)				•
7				EXPECTED	MONTH DAY FEA
TEACT !!	X vo			OATE (15)	
Un February 16, 1989, the building ventilation isola (SFU) initiated unexpected on the 'B' control building performance of the daily se the button, radiation leve Upscale Check button during spike to recur. The cause of this event was Check button was depressed. The applicable surveillance possibility of an ESF actua operability. This event had no effect on building isolated and the S radiation signal	plant was opera ted and the 'B' ly. The trip of g air intake ra ensor check sur ls indicated no g the surveilla s a spurious si the safe opera FU initiated as	ting at contro ccurred diation veilland rmally. nce test gnal whi e has be rificati ation of s design	100% power 1 building when the U monitor wa ce test. F Subsequen t did not c ich occurre een revised on of radia the plant. ed in respo	when the Standby i Spressed ollowing t operate ause the d when the to note ation mon The co onse to t	e control Filter Unit heck button d during release of on of the upscale e Upscale the itor ntrol he high
and an angliant.					

· **'**1

NRC Form 366A (9-83)	U.S. NUCLEAR REGULATORY COMMISSION
*	LICENSEE EVENT REPORT (LER) TEXT CONTINUATION

APPROVED OMB NO. 3150-0104 EXPIRES: 8/31/88

FACILITY NAME (1)	DOCKET NUMBER (2)	) LER NUMBER(6)			PAGE(3)				
		YEAR		SEQUENTIAL NUMBER	Π	REVISION NUMBER			
Duane Arnold Energy Center	0 5 0 0 0 3 3 1	89	-	005	-	00	2	0F	3
TEXT (It made space is convind use additional time a		· · · · · · · · · · · · · · · · · · ·	1		1				

I. DESCRIPTION OF EVENT:

On February 16, 1989, at 0731 hours, the plant was operating at 100% power when the control building ventilation isolated and the 'B' control building Standby Filter Unit (SFU) (EIIS System Code VI) initiated unexpectedly. The trip occurred when the Upscale Check button on the 'B' control building air intake radiation monitor (IL-RIS, DAEC RIM 6106B) was pressed during performance of the daily sensor check surveillance test. Normally, depression of the upscale check button does not cause the artificial radiation level (see additional information section note for description of artificial radiation source) to exceed the upscale setpoint. In this case the instrument went to full scale.

II. CAUSE OF EVENT:

The cause of this event was a spurious signal which occurred when the Upscale Check button was depressed.

#### III. ANALYSIS OF EVENT:

This event had no effect on the safe operation of the plant. The control building isolated and the SFU initiated as designed in response to the high radiation signal. Had this event occurred under different plant conditions, the effect on the safe operation of the plant would have been the same.

### IV. CORRECTIVE ACTIONS:

Immediate operator action was to determine if a high radiation condition existed. Upon investigation, it was quickly discovered that the upscale signal had occurred coincident with depression of the Upscale Check button. Following release of the button, radiation levels indicated normally. Subsequent operation of the Upscale Check button during the surveillance test did not cause the upscale spike to recur. Upon determining a high radiation condition did not exist, the SFU and control building ventilation was reset.

As followup operation of the Upscale Check button did not indicate a problem with the monitor, no further corrective actions were performed.

The applicable surveillance test procedure has been revised to note the possibility of an ESF actuation during verification of radiation monitor operability.

11 1 5

NRC Form 366A U.S. NUCLEAR REGULATORY COMMISSION (9-83)

## LICENSEE EVENT REPORT (LER) TEXT CONTINUATION

APPROVED OMB NO. 3150-0104 EXPIRES: 8/31/88

FACILITY NAME (1)	DOCKET NUMBER (2)	LER NUMBER(6)						PAGE(3)		
		YEAR	Π	SEQUENTIAL NUMBER	$\square$	REVISION NUMBER		T		
Duane Arnold Energy Center	0 5 0 0 0 3 3 1	89	П	005		00	3	OF	3	
TEXT (If more space is required, use additional NRC Form 366A's) (17) V. ADDITIONAL INFORMATION:		1	<u> </u>	······	<u> </u>		<u> </u>			

### A. Previous Similar Events

NMC Model GA-6M radiation monitors have been in service at the DAEC since November 1986 with the Upscale Check button being pressed daily. No similar events involving this type of radiation monitor have occurred.

NOTE: The detector used in this radiation monitor is of the type which uses a scintillating phosphor crystal to detect radiation. As radiation impinges on the crystal, light pulses are emitted. The number of pulses increases proportionally with respect to the increase in radiation level. These light pulses are detected by a photomultiplier tube and converted to an electronic signal representing the radiation level. To provide an artificial radiation signal, a light emitting diode positioned near the photomultiplier tube is pulsed at a predetermined rate to correspond to the desired radiation level.

# Iowa Electric Light and Power Company

March 17, 1989 DAEC-89-0159

Mr. A. Bert Davis Regional Administrator Region III U. S. Nuclear Regulatory Commission 799 Roosevelt Road Glen Ellyn, IL 60137

> Subject: Duane Arnold Energy Center Docket No: 50-331 Op. License DPR-49 Licensee Event Report #89-005

Gentlemen:

5

In accordance with 10 CFR 50.73 please find attached a copy of the subject Licensee Event Report.

Very truly yours, 3.17-89 Rick<sup>1</sup>L. Hannen

Plant Superintendent - Nuclear

RLH/JSA/go

cc: Director of Nuclear Reactor Regulation Document Control Desk U.S. Nuclear Regulatory Commission Mail Station P1-137 Washington, D. C. 20555

NRC Resident Inspector - DAEC

File A-118a