REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

RIBUTION DEMONSTRATION SYSTEM

SIZE:

ACCESSION NBR:9006210515DOC.DATE: 90/05/31NOTARIZED: NODOCKET #FACIL:50-331Duane Arnold Energy Center, Iowa Electric Light & Pow05000331AUTH.NAMEAUTHOR AFFILIATIONTRAN,H.Iowa Electric Light & Power Co.HANNEN,R.L.Iowa Electric Light & Power Co.RECIP.NAMERECIPIENT AFFILIATION

SUBJECT: Monthly operating rept for May 1990 for Duane Arnold Energy Ctr.W/900615 ltr.

DISTRIBUTION CODE: IE24D COPIES RECEIVED:LTR / ENCL / TITLE: Monthly Operating Report (per Tech Specs)

NOTES:

Í.

CELERATED

D

	RECIPIENT ID CODE/NAME	COPI LT TR	ES ENCL	RECIPIENT ID CODE/NAME	COPI LTTR	ES
	PD3-3 LA	3	3	PD3-3 PD	1	1
	HALL, J.R.	1	1		•	
INTERNAL:	ACRS	10	10	AEOD/DOA	1	1
	AEOD/DSP/TPAB	1	1	IRM TECH ADV	2	2
	NRR/DLPQ/LPEB10	1	1	NRR/DOEA/OEAB11	1	1
	REG_FIII 01	1	1	RGN3	1	1
EXTERNAL:	EG&G STUART,V.A	1	1	LPDR	1	1
	NRC PDR	1	1	NSIC	1	1

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK, ROOM PI-37 (EXT. 20079) TO ELIMINATE YOUR NAME FROM DISTRIBUTION LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTTR 27 ENCL 27

S / A D D S

R

I

D

S

/

A

D

D

S

R

Ι

D

Iowa Electric Light and Power Company

June 15, 1990 DAEC-90-0446

Mr. A. Bert Davis Regional Administrator Region III U. S. Nuclear Regulatory Commission 799 Roosevelt Road Glen Ellyn, IL 60137

> Subject: Duane Arnold Energy Center Docket No: 50-331 Op. License DPR-49 May 1990 Monthly Operating Report

Dear Sirs:

Please find enclosed the Duane Arnold Energy Center Monthly Operating Report for May, 1990. The report has been prepared in accordance with the guidelines of Regulatory Guide 1.16 and distribution has been made in accordance with DAEC Technical Specifications, Section 6.11.1.c.

tery truly/yours, 16-14.90 Rick L. Hannen

Plant Superintendent - Nuclear

RLH/ht Enclosures File A-118d

cc: Dir. of Nuclear Reactor Regulation U.S. Nuclear Regulatory Commission Mail Station P1-137 Washington, D. C. 20555

> Mr. J. R. Hall Project Manager 1 Whiteflint North Mail Stop 13E21 11555 Rockville Pike Rockville, MD 20852

INPO Records Center 1100 Circle 75 Parkway Suite 1500 Atlanta, GA 30339-3064

9006210515 900531

ADOČK

PDR

Mr. Steve Brown Iowa State Utilities Board Lucas State Office Building Des Moines, IA 50319

> 05000331 PDC

Mr. William Loveless U. S. NRC Maryland National Bank Building Mail Stop 7602 Washington, D.C. 20555 (2)

NRC Resident Inspector

Mr. Dennis Murdock Central Iowa Power Cooperative Box 2517 Cedar Rapids, IA 52406

Mr. Dale Aherns Corn Belt Power Cooperative 1300 13th Street North Humboldt, IA 50548

Dr. William R. Jacobs, Jr. GDS Associates, Inc. Suite 720 1850 Parkway Place Marietta, Georgia 30068-8237

> JEPA '|1

General Office • P.O. Box 351 • Cedar Rapids, Iowa 52406 • 319/398-4411

OPERATING DATA REPORT

		DOCKET NO. <u>0</u> DATE <u>6-</u> COMPLETED BY <u>Ha</u> TELEPHONE <u>(3</u>	50-0331 15-90 11 Tran 19) 851-7491	
OPERATING STATUS		Notes	<u>_</u>	
1. Unit Name: <u>Duane Arnold Energy Center</u>				
2. Reporting Period: <u>May 1990</u>				
3. Licensed Thermal Power (MWt): <u>1658</u>				
4. Nameplate Rating (Gross MWe): <u>565 (Turbi</u>	ne)	ν		
5. Design Electrical Rating (Net MWe): 538				
6. Maximum Dependable Capacity (Gross MWe):	565			
7. Maximum Dependable Capacity (Net MWe): 5	38			
8. If Changes Occur in Capacity Ratings (Ite	ms Number 3 th	rough 7) Since		I
the Last Report, Give Reasons: <u>N/A</u>				
·	<u></u>	· · · · · · · · · · · · · · · · · · ·	······	
9. Power Level to Which Restricted, If Any (Net NWe): <u>N/A</u>			
10. Reasons for Restrictions, If Any: <u>N/A</u>	······································	 	. <u>.</u>	
	This Month	Yr-to-Date	Cumulative	
11. Hours in Reporting Period	744.0	3623.0	134375.0	
12. Number of Hours Reactor Was Critical	744.0	3546.5	97416.1	
13. Reactor Reserve Shutdown Hours	0	00	192.8	
14. Hours Generator On-Line	744.0	3533.9	94741.9	
15. Unit Reserve Shutdown Hours	0	0	0	
16. Gross Thermal Energy Generated (NWH)	1012252.8	5426880.0	125507714.8	
17. Gross Electrical Energy Generated (MWH)	331710.0	<u>1820241.0</u>	42155761.0	
18. Net Electrical, Energy Generated (MWH)	310802.4	1712934.8	39519064.4	
19. Unit Service Factor	100.0	97.5	70,5	
20. Unit Availability Factor	100.0	97.5	70.6	
21. Unit Capacity Factor (Using MDC Net)	77.6	87.9	56.9	
22. Unit Capacity Factor (Using DER Net)	77.6	87.9	54.7	
23. Unit Forced Outage Rate	0.0	2.5	14.0	
24. Shutdowns Scheduled Over Next 6 Months (of each: <u>Cycle 10/11 refuel outage June</u>	Гуре, Date, and 28, 1990 - 69	d Duration days	······	

25. If Shutdown at End of Report Period, Est. Date of Startup: _____

1

ιŝ

(9/77)

<u>N/A</u>

AVERAGE DAILY UNIT POWER LEVEL

050-0331
6-15-90
Nai Tran
(319) 851-7491

h

MONTH	<u>May 1990</u>
DAY	AVERAGE DAILY POWER LEVEL
	(MWe-Net)
1	378
2	400
3	423
4	418
5	427
6	394
7	422
8	419
9	422
10	427
11	423
12	423
13	426
14	420
15	419

DAY AVERAGE DAILY POWER LEVEL

(MWe-Net)

16	419
17	426
18	421
19	420
20	422
21	429
22	417
23	427
24	424
25	423
26	422
27	396
28	413
29	411
30	421
31	420

REFUELING INFORMATION

DOCKET NO.	_50-0331
DATE	6-15-90
COMPLETED BY	Hai Tran
TELEPHONE	(319) 851-7491

1. Name of facility.

- a. Duane Arnold Energy Center
- 2. Scheduled date for next refueling shutdown.
 - a. June 28, 1990
- 3. Scheduled date for restart following refueling.
 - a. September, 1990
- 4. Will refueling or resumption of operation thereafter require a technical specification change or other license amendment?

Technical Specification change has been submitted to the NRC for approval.

 Scheduled date(s) for submitting proposed licensing action and supporting information.

N/A

 Important licensing considerations associated with refueling, e.g., new or different fuel design or supplier, unreviewed design or performance analysis methods, significant changes in fuel design, new operating procedures.

104 GE-10 fuel bundles have arrived at DAEC for loading during upcoming refueling outage.

7. The number of fuel assemblies (a) in the core and (b) in the spent fuel storage pool (c) in the dry storage vault.

a. 368 b. 1045 c. 3

- 8. The present licensed spent fuel pool storage capacity and the size of any increase in licensed storage capacity that has been requested or is planned, in number of fuel assemblies.
 - a. 2050 Licensed Capacity or b. 1898 under the presently installed storage rack capacity.
- The projected date of the last refueling that can be discharged to the spent fuel pool assuming the present licensed capacity.
 - a. 2000 Licensed Capacity or b. 1997 under the presently installed storage rack capacity.

Docket No.: 050-0331 Unit: Duane Arnold Energy Center Date: 06-15-90 Completed By: Hai Tran Telephone: (319) 851-7491

- .

UNIT SHUTDOWNS AND POWER REDUCTIONS

.

REPORT MONTH: May 1990

No.	Date	Type(1)	Duration (Hours)	Reason(2)	Method of Shutting (3) Down Reactor	Licensee Event Report #	System Code (4)	Comp. Code (5)	Cause
	05-01-90	F	0.0	A	5	N/A	SB	ISV	Reactor power was reduced to approximately 83% due to the "A" Main Steam Line isolation since 4-22-90. The reason for the isolation was the "A" Inboard Main Steam Isolation Valve failing surveillance testing.
									-
1 - F: S:	Forced Scheduled	2 -	Reason: A-Equipment B-Maintenan C-Refueling D-Regulator E-Operator F-Administr G-Operation H-Other (Exp	Failure (E) ce or Test y Restrictio Training & ative al Error (E) plain)	xplain) on License Examina xplain)	3 - tion	Method 1-Manual 2-Manual 3-Automa 4-Contin 5-Reduce 9-Other	Scram tic Scr ued d Load (Explai	4 - Exhibit G- Instructions for Preparation of Data am Entry Sheets for Licensee Event Report (LER) File (NUREG- n) 0161) 5 - Exhibit 1- Same Source

(9/77)

5

MAJOR/SAFETY RELATED MAINTENANCE

Docket No.: 050-0331 Unit: Duane Arnold Energy Center Date: 6-15-90 Completed By: Hai Tran Telephone: (319) 851-7491

COMPONENT	DESCRIPTION
(HR) Pressure Differential Indicator and Controller for "A" RHR Heat Exchanger	stroller was calibrated per Sance procedure due to instrument
n "C" Pump for RHR SW System The pack due to	king of the pump was retightened its leaking.
vstem Differential Temperature Indicator The con- and Controller for SBGT prefilter mainten drift.	ntroller was recalibrated per nance procedure due to instrument
lve - Inboard Bleed Valve The valv "D" The rela	lve failed to show proper indication. lay was replaced.
	· ·
1 . 1	

h

NARRATIVE SUMMARY OF OPERATING EXPERIENCE

DOCKET NO.	050-0331
DATE	6-15-90
COMPLETED BY	Hai Iran (710) 951-7691
IELEFHUNE	(317) 051-7471

- 05-01-90 At the beginning of the month the plant operating at 74.7 percent of rated thermal power with 377.7 MWe-net being delivered to customers connected to the grid. The reduction in power was due to the "A" Main Steam Line isolation. There was one 10 CFR 50.73 reportable event and one future voluntary reportable event during the month.
- 05-19-90 With the plant operating at 82.9% MWth, during an inspection of the Drywell air gap to look for the source of leakage into the torus area, one control rod drive (CRD) withdraw line was found to be leaking and a CRD insertion line appeared to have a circumferential crack with water in evidence. The leakage does not impact safe operation at this time and a complete inspection of CRD lines found no additional problems. The leaking lines will be replaced during the upcoming refuel outage. A for-information LER will be submitted at that time.
- 05-19-90 At 2351 hours, a control rod pattern adjustment was performed at approximately 75.0% power due to the leakage found earlier on the control rod drive (CRD) lines. The rod with the leaking CRD withdraw line and three symmetric rods were inserted.
- 05-25-90 At 1349 hours, the plant was operating at 83.1% MWth. Investigation of a deviation between recirculation flow indications and the Average Power Range Monitoring (APRM) flow units determined that the APRM flow-biased trip setpoints for the Reactor Protection System were non-conservative. The deviation was the result of the flow units being calibrated to the recirculation pump loop flows required to achieve 100% power during initial plant operation. Over the years the loop flow required to achieve 100% power increased but the flow units were not adjusted accordingly. The result was a deviation of about 5% between the required RPS flow-biased trip setpoint and the actual setpoint. As an immediate corrective action, the Gain Adjustment Factor (GAF) was adjusted 6% upward to correct the flow units to a proper and more conservative value. The long term corrective action is to revise the flow-bias calibration procedure.

(LER 90-005)

05-31-90

At the end of the month the plant was operating at 82.4 percent of rated thermal power with 420.0 MWe-net being delivered to customers connected to the grid.