

Davis-BesseNPEM Resource

From: CuadradoDeJesus, Samuel
Sent: Friday, June 24, 2011 12:36 PM
To: dorts@firstenergycorp.com
Subject: RE: FW: Davis-Besse Conference call

I'll sending a schedule soon

From: dorts@firstenergycorp.com [<mailto:dorts@firstenergycorp.com>]
Sent: Friday, June 24, 2011 11:35 AM
To: CuadradoDeJesus, Samuel
Cc: 'custer@firstenergycorp.com'
Subject: Re: FW: Davis-Besse Conference call

Sam... Tuesday is ok for a conference call. Please let us know the time and call-in information.

Thank you,

Steve Dort
DBNPS License Renewal
419.321.7662 work
412.974.3369 cell

From: "CuadradoDeJesus, Samuel" <Samuel.CuadradoDeJesus@nrc.gov>
To: "custer@firstenergycorp.com" <custer@firstenergycorp.com>, "dorts@firstenergycorp.com" <dorts@firstenergycorp.com>
Date: 06/24/2011 09:41 AM
Subject: FW: Davis-Besse Conference call

Cliff and Steve

Below are the rest of our staff concerns on Structural RAI responses. We'll like to have a conference call early next week, would next Tuesday be ok with you guys?

Regards

From: Sheikh, Abdul
Sent: Friday, June 24, 2011 9:17 AM
To: CuadradoDeJesus, Samuel
Subject: RE: Davis-Besse Conference call

RAI B.2.22-1

Provide basis for selecting only three locations for NDT for such a large area
One time NDT before PEO will not be sufficient to establish a trend before the PEO
FENOC did not provide details on what and how it will inspect the annulus area. Need specific details

RAI B.2.22-2

The RAI response specific actions and details. Need firm plans. Just stating that FENOC plans to access the inside surface of containment is not acceptable.

RAI B.2.22-3

How and when coating is inspected.

RAI B.2.22-4

The response not consistent with GALL recommendations. GALL report, Program XI.S1 states:

"Stainless steel penetration sleeves, dissimilar metal welds, bellows, and steel components that are subject to cyclic loading but have no current licensing basis fatigue analysis are monitored for cracking."

However, LRA states that the program is consistent with GALL.

From: CuadradoDeJesus, Samuel

Sent: Friday, June 24, 2011 8:22 AM

To: Sheikh, Abdul

Subject: Davis-Besse Conference call

Good morning Abdul

Can you please send me the summary of your concerns with DB RAI responses? I'll schedule the conference call for next Tuesday.

Thanks

Samuel Cuadrado de Jesús

Project Manager

Projects Branch1

Division of License Renewal

U.S. Nuclear Regulatory Commission

Phone: 301-415-2946

Samuel.CuadradoDeJesus@nrc.gov

----- The information contained in this message is intended only for the personal and confidential use of the recipient(s) named above. If the reader of this message is not the intended recipient or an agent responsible for delivering it to the intended recipient, you are hereby notified that you have received this document in error and that any review, dissemination, distribution, or copying of this message is strictly prohibited. If you have received this communication in error, please notify us immediately, and delete the original message.

Hearing Identifier: Davis_BesseLicenseRenewal_Saf_NonPublic
Email Number: 77

Mail Envelope Properties (Samuel.CuadradoDeJesus@nrc.gov20110624123600)

Subject: RE: FW: Davis-Besse Conference call
Sent Date: 6/24/2011 12:36:07 PM
Received Date: 6/24/2011 12:36:00 PM
From: CuadradoDeJesus, Samuel

Created By: Samuel.CuadradoDeJesus@nrc.gov

Recipients:
"dorts@firstenergycorp.com" <dorts@firstenergycorp.com>
Tracking Status: None

Post Office:

Files	Size	Date & Time
MESSAGE	3183	6/24/2011 12:36:00 PM

Options
Priority: Standard
Return Notification: No
Reply Requested: No
Sensitivity: Normal
Expiration Date:
Recipients Received: