

Davis-BesseNPEm Resource

From: CuadradoDeJesus, Samuel
Sent: Monday, June 20, 2011 5:02 PM
To: 'custerc@firstenergycorp.com'
Cc: dorts@firstenergycorp.com
Subject: FW: Davis Besse - RAI Responses
Attachments: DB SMP RAI Concerns.docx

Cliff:

As discussed attached is a summary of some of the issues we'll like to discuss early next week on a conference call.

From: Lehman, Bryce
Sent: Monday, June 20, 2011 4:53 PM
To: CuadradoDeJesus, Samuel
Cc: Auluck, Rajender; Sheikh, Abdul
Subject: RE: Davis Besse - RAI Responses

Samuel,

Attached are the issues I would like to discuss with the applicant.

Bryce

From: CuadradoDeJesus, Samuel
Sent: Monday, June 20, 2011 2:00 PM
To: Lehman, Bryce
Subject: RE: Davis Besse - RAI Responses

Hi Bryce:

I spoke with Abdul and I'll be scheduling the teleconference call to be early next week. Abdul will be sending me an e-mail summarizing his concerns on the RAI responses so I can forward them to the applicant and they can be prepared for the teleconference call. Can you do the same for yours?

Regards,

From: Lehman, Bryce
Sent: Monday, June 20, 2011 8:01 AM
To: Sheikh, Abdul; CuadradoDeJesus, Samuel
Cc: Auluck, Rajender; Buford, Angela; Istar, Ata; Dan Naus
Subject: RE: Davis Besse - RAI Responses

I would also like to participate in the call to discuss RAI responses B.2.39-1 and -2.

Thanks,
Bryce

From: Sheikh, Abdul
Sent: Monday, June 20, 2011 7:36 AM
To: CuadradoDeJesus, Samuel
Cc: Auluck, Rajender; Buford, Angela; Lehman, Bryce; Istar, Ata; Dan Naus
Subject: Davis Besse - RAI Responses

I will like to have a telephone call with the applicant about RAI B.22-1 thru B.22-4 responses. I think other persons in RASB will also like some clarifications on other structural RAIs.

Can you please arrange a conference call. I will be out of office from Tuesday afternoon thru Thursday this week.

Abdul

Hearing Identifier: Davis_BesseLicenseRenewal_Saf_NonPublic
Email Number: 99

Mail Envelope Properties (Samuel.CuadradoDeJesus@nrc.gov20110620170100)

Subject: FW: Davis Besse - RAI Responses
Sent Date: 6/20/2011 5:01:35 PM
Received Date: 6/20/2011 5:01:00 PM
From: CuadradoDeJesus, Samuel

Created By: Samuel.CuadradoDeJesus@nrc.gov

Recipients:

"dorts@firstenergycorp.com" <dorts@firstenergycorp.com>
Tracking Status: None
"custerc@firstenergycorp.com" <custerc@firstenergycorp.com>
Tracking Status: None

Post Office:

| Files | Size | Date & Time |
|--------------------------|-------------|------------------------|
| MESSAGE | 1759 | 6/20/2011 5:01:00 PM |
| DB SMP RAI Concerns.docx | 25119 | |

Options

Priority: Standard
Return Notification: No
Reply Requested: No
Sensitivity: Normal
Expiration Date:
Recipients Received:

Davis-Besse SMP RAI Concerns

RAI B.2.39-1

Part 1: We need more information on the core bore results and how they concluded there is no concern with the structural integrity. Applicant should be prepared to discuss the report referenced in the RAI response.

Part 2: We need more details in the commitment, specifically what will be done if the applicant cannot stop the leakage or the leakage begins again at a later date (e.g. core bores, more frequent inspections, etc.).

RAI B.2.39-2

This should be a two-part solution: 1) concrete bores to verify past leakage did not degrade walls, 2) future actions to ensure leakage does not occur again. The applicant addressed part 1; however, they did not adequately address part 2. The applicant should commit to take actions to ensure the leak-chase system remains operable during the PEO (e.g. boroscopic inspections at a technically justifiable interval).