



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D.C. 20555-0001

September 23, 2011


Mr. Mano Nazar  
Executive Vice President and  
Chief Nuclear Officer  
Florida Power and Light Company  
P.O. Box 14000  
Juno Beach, Florida 33408-0420

SUBJECT: TURKEY POINT UNITS 3 AND 4 - CORRECTION OF AMENDMENT NOS. 149  
AND 144 REGARDING ADMINISTRATIVE CHANGES (TAC NOS. 80526 AND  
80526)

Dear Mr. Nazar:

On September 25, 1991, the U. S. Nuclear Regulatory Commission (NRC) issued Amendment No. 149 to Renewed Facility Operating License No. DPR-31 and Amendment No. 144 to Renewed Facility Operating License No. DPR-41 for the Turkey Point Nuclear Plant, Unit Nos. 3 and 4, respectively. The amendment made changes to the Technical Specifications (TSs) by (1) removing outdated material, (2) incorporating administrative clarifications, and (3) correcting typographical errors.

On August 23, 2011, the licensee notified the NRC staff that a minor typo in the issued amendment affecting TS 3.9.11 was inadvertently included within the issuance of the amendment. TS 3.9.11 limiting condition for operation, page 3/4.9-12, stated 56' – 10' [56 feet-10 feet] instead of 56' - 10" [56 feet-10 inches] with the issuance of the amendment. The NRC staff found that the minor typo was not included in the May 28, 1991, application for amendment. The NRC staff determined that this error was inadvertently introduced, and was not the subject of the amendment or the associated notice to the public. Thus, according to the NRC's policy established by SECY-96-238 (Agencywide Documents Access and Management System Accession No. 9611250030), this error can be corrected by a letter. Enclosed please find the replacement TS page, which includes Amendment Nos. 224 and 219. This correction does not change any of the conclusions in the Safety Evaluation associated with the amendment.

Sincerely,  
  
Jason C. Paige, Project Manager  
Plant Licensing Branch II-2  
Division of Operating Reactor Licensing  
Office of Nuclear Reactor Regulation

Docket Nos. 50-250 and 50-251

Enclosure:  
As stated

cc w/enclosures: Distribution via Listserv

## REFUELING OPERATIONS

### 3/4.9.11 WATER LEVEL - STORAGE POOL

#### LIMITING CONDITION FOR OPERATION

---

3.9.11 The water level shall be maintained greater than or equal to elevation 56' - 10" the spent fuel storage pool.\*

APPLICABILITY: Whenever irradiated fuel assemblies are in the storage pool.

ACTION:

- a. With the requirements of the above specification not satisfied, suspend all movement of fuel assemblies and crane operations with loads in the fuel storage areas and restore the water level to within its limit within 4 hours.
- b. The provisions of Specification 3.0.3 are not applicable.

#### SURVEILLANCE REQUIREMENTS

---

4.9.11 The water level in the storage pool shall be determined to be at least its minimum required depth at least once per 7 days when irradiated fuel assemblies are in the fuel storage pool.

---

\*The requirements of this specification may be suspended for more than 4 hours to perform maintenance provided a 10 CFR 50.59 evaluation is prepared prior to suspension of the above requirement and all movement of fuel assemblies and crane operation with loads in the fuel storage areas are suspended. If the level is not restored within 7 days, the NRC shall be notified within the next 24 hours.

September 23, 2011

Mr. Mano Nazar  
Executive Vice President and  
Chief Nuclear Officer  
Florida Power and Light Company  
P.O. Box 14000  
Juno Beach, Florida 33408-0420

SUBJECT: TURKEY POINT UNITS 3 AND 4 - CORRECTION OF AMENDMENT NOS. 149  
AND 144 REGARDING ADMINISTRATIVE CHANGES (TAC NOS. 80526 AND  
80526)

Dear Mr. Nazar:

On September 25, 1991, the U. S. Nuclear Regulatory Commission (NRC) issued Amendment No. 149 to Renewed Facility Operating License No. DPR-31 and Amendment No. 144 to Renewed Facility Operating License No. DPR-41 for the Turkey Point Nuclear Plant, Unit Nos. 3 and 4, respectively. The amendment made changes to the Technical Specifications (TSs) by (1) removing outdated material, (2) incorporating administrative clarifications, and (3) correcting typographical errors.

On August 23, 2011, the licensee notified the NRC staff that a minor typo in the issued amendment affecting TS 3.9.11 was inadvertently included within the issuance of the amendment. TS 3.9.11 limiting condition for operation, page 3/4.9-12, stated 56' – 10' [56 feet-10 feet] instead of 56' - 10" [56 feet-10 inches] with the issuance of the amendment. The NRC staff found that the minor typo was not included in the May 28, 1991, application for amendment. The NRC staff determined that this error was inadvertently introduced, and was not the subject of the amendment or the associated notice to the public. Thus, according to the NRC's policy established by SECY-96-238 (Agencywide Documents Access and Management System Accession No. 9611250030), this error can be corrected by a letter. Enclosed please find the replacement TS page, which includes Amendment Nos. 224 and 219. This correction does not change any of the conclusions in the Safety Evaluation associated with the amendment.

Sincerely,

*/RA/*

Jason C. Paige, Project Manager  
Plant Licensing Branch II-2  
Division of Operating Reactor Licensing  
Office of Nuclear Reactor Regulation

Docket Nos. 50-250 and 50-251

Enclosure:  
As stated

cc w/enclosures: Distribution via Listserv

DISTRIBUTION:

PUBLIC LPL2-2 R/F RidsNrrLABClayton  
RidsNrrPMTurkeyPoint RidsRgn2MailCTR RidsNrrDorLpl2-2  
ADAMS Accession No. ML11236A156

OFFICE	NRR/LPL2-2/PM	NRR/LPL2-2/LA	NRR/LPL2-2/BC	NRR/LPL2-2/PM
NAME	JPaige	BClayton	DBroaddus (FSaba for)	JPaige
DATE	08/24/11	08/24/11	09/23/11	09/23/11

OFFICIAL RECORD COPY