N05/18/18

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS) DISTRIBUTION FOR INCOMING MATERIAL 50-

50-331

REC: NRC

SUBJECT:

ORG: HAMMOND E L IA ELEC LIGHT & PWR

DOCDATE: 05/12/78 DATE RCVD: 05/18/78

DOCTYPE: LETTER NOTARIZED: NO

COPIES RECEIVED LTR 1 ENCL 1

FORWARDING SUBJECT FACILITY"S MONTHLY OPERATING REPT FOR THE MONTH OF APRIL, 1978.

PLANT NAME: DUANE ARNOLD

REVIEWER INITIAL: XJM DISTRIBUTOR INITIAL:

MONTHLY OPERATING REPORT FOR GRAY BOOK PREPARATION. (DISTRIBUTION CODE A003)

ACRS CAT B**W/O ENCL

FOR ACTION: BR CHIEF LEAR**W/2 ENCL

INTERNAL: REG FI

REG FILE ** W7ENGL MIPC FOR ACTION ** W/2 ENCL NRC PDR**W/ENCL

EXTERNAL: LPDR'S CEDAR RAPIDS, IA**W/ENCL TIC**W/ENCL NSIC**W/ENCL BNL(NATLAB)**W/ENCL

DISTRIBUTION: LTR 10 ENCL 10 SIZE: 1P+11P

CONTROL NBR:

781380015

THE END

IOWA ELECTRIC LIGHT AND POWER COMPANY

DUANE ARNOLD ENERGY CENTER P. O. Box 351 Cedar Rapids, Iowa 52406 May 12, 1978 DAEC - 78 - 253

Director, Office of Inspection and Enforcement U. S. Nuclear Regulatory Commission Washington, D. C. 20555

Subject: Monthly Operating Report

File: A-118d

Dear Sirs:

Please find enclosed 10 copies of the Duane Arnold Energy Center Monthly Operating Report for April. The report has been prepared in accordance with the requirements of Regulatory Guide 1.16 and distribution has been made in accordance with Regulatory Guide 10.1.

Very truly yours,

Ellery L. Hammond

Chief Engineer Duane Arnold Energy Center

Directorate of Inspection and Enforcement U. S. Nuclear Regulatory Commission Region III 799 Roosevelt Road Glen Ellyn, Illinois 60137 (1)

Director, Office of Management Information and Program Control U. S. Nuclear Regulatory Commission Washington, D. C. 20555 (2)

ELH/JVS/nf Encl. cc: D. Arnold S. Tuthill J. Wallace J. Rehnstrom L. Root W. Bryant D. Mineck D. Wilson R. Hannen Dennis Murdock George Toyne

A003, 110 M

FILE

ි වි

> iii C

OPERATING DATA REPORT

050-0331
5-12-78
<u>J. Van S</u> ickel
<u></u>

OPERATING STATUS

1. Unit Name: Duane_Arnold_Energy_Center	Notes
2. Reporting Period: <u>Apri1</u>	
3. Licensed Thermal Power (MWt): <u>1658</u>	
4. Nameplate Rating (Gross MWe): <u>565 (Trubine Rating)</u>	
5. Design Electrical Rating (Net MWe): 538	
6. Maximum Dependable Capacity (Gross MWe): <u>545</u>	
7. Maximum Dependable Capacity (Net MWe): <u>515</u>	

8. If Changes Occur in Capacity Ratings (Items Number 3 Through 7) Since Last Report, Give Reasons:

9. Power Level To Which Restricted, 1f Any (Net MWe):

10. Reasons For Restrictions, If Any: _

	This Month	Yrto-Date	Cumulative
11. Hours In Reporting Period	719	2879	28,439
12. Number Of Hours Reactor Was Critical	122.2	1933.5	22,487.5
13. Reactor Reserve Shutdown Hours	0	0	0
14. Hours Generator On-Line	85.6	1887.4	21,970.1
15. Unit Reserve Shutdown Hours	0	0	0
16. Gross Thermal Energy Generated (MWH)	102,432	2,613,864	26,719,080
17. Gross Electrical Energy Generated (MWH)	13,269	868,656	8,898,760
18. Net Electrical Energy Generated (MWH)	11,705	816,515	8,305,254
19. Unit Service Factor	11.9%	65.6%	77.3%
20. Unit Availability Factor	11.9%	65.6%	77.3%
21. Unit Capacity Factor (Using MDC Net)	3.2%	55.1%	56.7%
22. Unit Capacity Factor (Using DER Net)	3.0%	52.7%	54.3%
23. Unit Forced Outage Rate	8.6%	1.7%	5.0%
24 Churddenne Cabid Lid O N . (M	D	· · · ·	

24. Shutdowns Scheduled Over Next 6 Months (Type, Date, and Duration of Each):

25. If Shut Down At End Of Report Period, Estimated Date of Startup:

N/A

* Turbine Rating: 565.7 MWe

Generator Rating: 663.5 (MVA) x .90 (Power Factor) = 597 MWe

AVERAGE DAILY UNIT POWER LEVEL

DOCKET NO.	050-0331			
UNIT	Duane Arnold Energy			
DATE	<u>5-12-78</u>			
COMPLETED BY	J. Van Sickel			
TELEPHONE	319-851-5611			

HApril	·	
AVERAGE DAILY POWER LEVEL (MWe-Net)	DAY	AVERAGE DAILY POWER LEVEL (MWe-Net)
0	17	0.
0	18	0
0	19	0
0	20	0
0	21	00
0	22	0
0	23	0
0	24	0
0	25	0
0	26	0
0	27	30
0	28	120
0	29	144
0	30	189
0	31	······································
0		· · · · · · · · · · · · · · · · · · ·
	April AVERAGE DAILY POWER LEVEL (MWe-Net) 0	April DAY AVERAGE DAILY POWER LEVEL DAY 0 17 0 17 0 18 0 19 0 20 0 21 0 22 0 23 0 23 0 24 0 25 0 26 0 26 0 26 0 26 0 26 0 28 0 29 0 30 0 31

INSTRUCTIONS

On this format, list the average daily unit power level in MWe-Net for each day in the reporting month. Compute to the nearest whole megawatt.

			· · · ·		UNIT	SHUTDOWNS AND	POWER	REDUCTIONS	DOCKET NO. <u>050-0331</u> UNIT NAME <u>Duane Arnold</u> Energy DATE 5-12-78 Center
F		.				REPORT MONTH	<u>Ap</u>	<u>ril</u>	COMPLETED BY TELEPHONE J. Van Sickel 319-851-5611
No.	Date	Type ¹	Duration (Hours)	Reason ²	Method of Shutting Down Reactor ³	Licensee Event Report #	System Code ⁴	Component Cude ⁵	Cause & Corrective Action to Prevent Recurrence
8.	780318	S	625.3	С	1				, Continuation of Refueling Outage
9.	780427	F	8.1	A	1				Main turbine permanent magnet generator failed and had to be removed
I F: For S: Sch (9/77)	rced leduled	Reaso A-Equ B-Mai C-Ref D-Reg E-Ope F-Adr G-Ope H-Oth	on: uipment Fai intenance or ueling gulatory Res erator Train ministrative erational Ern her (Explain	lure (E) Test striction ing & Li ror (Exp)	kplain) icense Exa plain)	3 mination	Method 1-Manu 2-Manu 3-Auto 4-Othe	1: ial ial Scram. matic Scram. r (Explain)	4 Exhibit G - Instructions for Preparation of Data Entry Sheets for Licensee Event Report (LER) File (NUREG- 0161) 5 Exhibit I - Same Source



Narrative Summary of Operating Experience

Unit <u>Duane Arnold Energy</u> Date <u>5-12-78</u> Completed by J. Van Sickel Telephone 319-851-5611

Docket No. 050-0331

- 4-1 At the beginning of the report period the plant was in cold shutdown for refueling and maintenance.
- 4-1 The reactor cavity was drained to the vessel flange.
- 4-1 During the performance of preventive maintenance two control rod drive hydraulic control unit water level switches would not respond to water level increases. The switches were replaced.

RO 78-021

- 4-2 The moisture separator and steam dryer were installed in the reactor vessel and the vessel head was set in place.
- 4-3 During annual surveillance testing of safety/relief valves, one safety valve and three relief valves were found to have out of specification as found setpoints. The valves were reworked as required.

RO 78-018

- 4-4 Control rod friction testing was begun.
- 4-5 During the annual surveillance of standby diesel generator 1G-31, the lower crankshaft main thrust bearing was found wiped on both the journal and thrust surfaces. The bearing was replaced.

RO 78-020

4-6 During surveillance testing two MSIV leakage control system outboard isolation valves did not close properly due to electrical problems which were corrected.

RO 78-022

- 4-7 Control rod friction testing was completed.
- 4-9 Repair work was begun on the reactor water cleanup system pipe crack which was found on 3/25/78.
- 4-10 The radioiodine level in milk samples exceeded ten times the control station value due to atmospheric nuclear weapons testing by the Peoples Republic of China.

ETSV 78-03

- 4-13 The reactor vessel head was retentioned.
- 4-14 The drywell head was reinstalled and torqued down.
- 4-15 The integrated leak rate test of the containment was begun.
- 4-16 The integrated leak rate test of the containment was completed with satisfactory results.

Docket No.	050-0331
Ur Duan	e Arnold Energy Center
Da. 5-12	-78
Completed	by J. Van Sickel
Telephone	319-851-5611

- 4-20 The annual inspection of 1G-31 standby diesel generator was completed.
- 4-20 The LOOP/LOCA testing was completed with satisfactory results.
- 4-23 A hydro of the reactor water cleanup system was completed with satisfactory results.
- 4-24 The mode switch was placed in the startup position. While attempting to start the recirculation pumps, the "B" recirc pump would start but then trip almost immediately. The reactor was taken critical briefly for testing.
- 4-25 The reactor was taken critical briefly several times for training.
- 4-25 The "B" recirc pump was successfully started. The problem had been with a time delay relay in the motor start circuit.
- 4-25 With the reactor at 150 PSI HPCI system and relief valve testing was done.
- 4-26 The reactor vessel and RWCU system pipe repair were hydrostatically tested satisfactorily.
- 4-26 The mode switch was placed in run and the main turbine was rolled.
- 4-27 After several unsuccessful attempts to get the turbine up to speed, the turbine was brought to rated speed and the main generator placed on the line at 0115 hours.
- 4-27 The unit was removed from the line at 1021 hours due to the failure of the turbine permanent magnet generator.
- 4-27 The PMG was removed and the unit placed on the line at 1831 hours.
- 4-28 The plant was operating at approximately 143 MWe and pulling rods to increase power as core thermal limits permit.
- 4-29 A control rod sequence exchange was completed followed by control rod scram time testing.
- 4-30 The plant was operating at 250 MWe with control rod withdrawals in progress.

.

MAJOR SAFETY RELATED MAINTENANCE

Date	System	Component	Description
4/1/78	Standby Diesel Generator 1G-31	IE-53-A Heat Exchanger	Opened, cleaned, inspected and reassembled heat exchanger.
4/1/78	HPCI System	V-22-7 Drain Valve	Replaced broken stem and repacked.
4/2/78	Control Rod Drive System	CRD 10-35	CRD 10-35 was replaced with a rebuilt drive.
4/2/78	Control Rod Drive System	CRD 14-39	CRD 14-39 was replaced with a rebuilt drive.
4/2/78	Control Rod Drive System	CRD 34-11	CRD 34-11 was replaced with a rebuilt drive.
4/5/78	Control Rod Drive System	CRD 34-19	CRD 34-19 was replaced with a rebuilt drive.
4/5/78	Control Rod Drive System	CRD 18-03	CRD 18-03 was replaced with a rebuilt drive
4/5/78	Control Rod Drive System	CRD 38-31	CRD 38-31 was replaced with a rebuilt drive.
4/5/78	Control Rod Drive System	CRD 18-19	CRD 18-19 was replaced with a rebuilt drive.

MAJOR SAFETY RELATED MAINTENANCE

Date	System	Component		Description
4/5/78 ·	Control Rod Drive System	CRD 26-11		CRD 26-11 was replaced with a rebuilt drive.
4/5/78	Control Rod Drive System	CRD 42-27	Ø	CRD 42-27 was replaced with a rebuilt drive.
4/5/78	Control Rod Drive System	CRD 38-19		CRD 38-19 was replaced with a rebuilt drive.
4/6/78	MSIV Leakage Control System	MOV 8402B		Replaced MOV motor starter contactor coil.
4/7/78	MSIV Leakage Control System	MOV 8402C		Cleaned torque switch contacts.
4/9/78	Containment Atmosphere Control System	CV 4309		Disassembled, inspected, lapped, reassembled and tested valve.
4/11/78	Containment Atmosphere Control System	CV4378A		Disassembled, inspected, lapped, reassembled and tested valve.
4/11/78.	Containment Atmosphere Control System	CV 4378B		Disassembled, inspected, lapped, reassembled and tested valve.
4/12/78	Nuclear Boiler System	PSV 4402		Removed, tested, inspected and reinstalled valve.
			•	

MAJOR SAFETY RELATED MAINTENANCE

Date	System	Component	Description
4/12/78	HPCI System	IE-203 Lube Oil Cooler	Cleaned, inspected and tested for leaks.
4/12/78	RCIC System	MOV 2510 Minimum Flow Valve	MOV Motor was rewound and reinstalled.
4/13/78	Control Rod Drive Hydraulic System	4-LDS 1845	HCU level switch was found inoperable and was replaced.
4/13/78	Control Rod Drive Hydraulic System	59-LDS 1845	HCU level switch was found inoperable and was replaced.
4/15/78	Nuclear Boiler System	PSV 4400	Removed, tested, inspected and reinstalled valve.
4/15/78	Nuclear Boiler System	PSV 4401	Removed, tested, inspected and reinstalled valve.
4/15/78	Nuclear Boiler System	PSV 4403	Removed, tested, inspected and reinstalled valve.
4/15/78	Nuclear Boiler System	PSV 4405	Removed, tested, inspected and reinstalled valve.
4/15/78	Nuclear Boiler System	PSV 4406	Removed, tested, inspected and reinstalled valve.
4/15/78	Nuclear Boiler System	PSV 4407	Removed, tested, inspected and reinstalled valve.
		· ·	

Docket	: No	<u>050-03</u>	331 ·
Unit_	Duane	Arnold	Energy
Date	5-12-2	78	
Comple	eted by	/ J. Var	n Sickel
Teleph	none_31	19-851-5	611

MAJOR SAFETY RELATED MAINTENANCE

Date	System	Component	Description
4/17/78	Containment Atmosphere Monitoring System	RE 8102A	Installed new detector tube.
4/17/78	Nuclear Boiler System	PSV 4400	Replaced operator diaphram.
4/17/78	Nuclear Boiler System	PSV 4401	Replaced operator diaphram.
4/17/78	Nuclear Boiler System	PSV 4402	Replaced operator diaphram.
4/17/78	Nuclear Boiler System	PSV 4405	Replaced operator diaphram.
4/17/78	Nuclear Boiler System	PSV 4406	Replaced operator diaphram.
4/17/78	Nuclear Boiler System	PSV 4407	Replaced operator diaphram.
4/18/78	Nuclear Boiler System	CV 4421, MSIV .	Replaced packing.
4/18/78	Nuclear Boiler System	CV 4413, MSIV	Replaced packing.
4/18/78	Nuclear Boiler System	CV 4419, MSIV	Replaced packing.
4/18/78	Nuclear Boiler System	CV 4416, MSIV	Replaced packing.
4/19/78	Nuclear Boiler Bystem	CV 4420, MSIV	Replaced packing.
4/19/78	Nuclear Boiler System	CV 4418, MSIV	Replaced packing.
4/19/78	Standby Diesel Generator 1G-31	1G-31	Performed annual inspection.

MAJOR SAFETY RELATED MAINTENANCE

Date	System	Component	Description
4/20/78	Nuclear Boiler System	CV 4412, MSIV	Replaced packing.
4/20/78	Nuclear Boiler System	-CV 4415, MSIV	Replaced packing.
4/20/78	Reactor Protection System	LIS 4534	Rebuilt switch.
4/20/78	Reactor Building Closed Cooling Water System	MO 4841A	Replaced overload relay and rewound MOV motor.
4/21/78	"B" Core Spray System	MOV 2135	Changed MOV clutch housing.
4/22/78	Neutron Monitoring System	SRM 4573D	Replaced preregulator.
4/22/78	RHR System	MOV 1937	Replaced thermal overload, overload relay and rewound MOV motor.
4/24/78	HPCI System	Shaft Driven Oil Pump	Disassembled, inspected and reinstalled pump.
4/24/78	HPC1 System	Pump and Turbine Bearings	Cleaned and inspected radial and thrust bearings and flushed oil system.
4/25/78	HPCI System	MOV 2315 Test Valve	Replaced stem yoke and adjusted limit
4/26/78	Reactor Protection System	TIS 4443	switches. Replaced a filter capacitor and recalibrated unit.
			· · ·

REFUELING INFORMATION



Date Completed by Telephone

050-0331 5-12-78 J. Van Sickel 319-851-5611

1. Name of facility.

A. Duane Arnold Energy Center

- 2. Scheduled date for next refueling shutdown. A. March 1, 1979
- 3. Scheduled date for restart following refueling.
 - A. June 1, 1979
- 4. Will refueling or resumption of operation thereafter require a technical specification change or other license amendment?
 - A. Yes. MCPR and MAPLHGR operating limits as derived from transient and accident analyses.
- Scheduled date(s) for submitting proposed licensing action and 5. supporting information.

A. January, 1979

6. Important licensing considerations associated with refueling, e.g., new or different fuel design or supplier, unreviewed design or performance analysis methods, significant changes in fuel design, new operating procedures.

A. The reload will consist of up to 100 8 x 8 2 water rod bundles.

The number of fuel assemblies (a) in the core and (b) in the spent 7. fuel storage pool.

A. a) 368 in core b) 276

The present licensed spent fuel pool storage capacity and the size 8. of any increase in licensed storage capacity that has been requested or is planned, in number of fuel assemblies.

A. a) 480 b) 2050

The projected date of the last refueling that can be discharged to 9. the spent fuel pool assuming the present licensed capacity.

A. 1980