

REGULATORY INFORMATION DISTRIBUTION SYSTEM

DOCKET NBR: 50-331 DUANE ARNOLD

DOC DATE: 781117

RECIPIENT: NRC

ACCESSION NBR: 7811280237

ORIGINATOR: HAMMOND, E.L.

COPIES RECEIVED:

COMPANY: IA ELEC LIGHT & PWR

LTR 1 ENCL 0

SUBJECT:

SIZE: 1

Corrects semiannual rept for 3rd & 4th quarter, 1977. Percent of environ tech specs for gaseous effluents during that time should be changed to % of 16% limit: 5.63% third quarter & 6.63% 4th quarter.

NOTARIZED

DISTRIBUTION CODE: A007

DISTRIBUTION TITLE:

PERIODIC ENVIRONMENTAL MONITORING RPTS (ANNUAL, SEMIANNUAL, EFFLUENT, ETC...)

| NAME | ENCL? |
|--------------------|----------|
| BR CHIEF | W/7 ENCL |
| REG FILE | W/ENCL |
| NRC PDR | W/ENCL |
| I & E | W/2 ENCL |
| EEB | W/ENCL |
| ENVIRO SPEC BR | W/ENCL |
| EFFLUENT TREAT SYS | W/ENCL |
| RAD ASSESSMENT BR | W/ENCL |
| EPS BR SD | W/ENCL |
| LPDR | W/ENCL |
| TERA | W/ENCL |
| NSIC | W/ENCL |
| ACRS | W/ENCL |

FOR ACTION

ORB#3 BC

TOTAL NUMBER OF COPIES REQUIRED:

| | |
|------|----|
| LTR | 20 |
| ENCL | 20 |

NOV 30 1978

NOTES:

Enviro 60

IOWA ELECTRIC LIGHT AND POWER COMPANY

DUANE ARNOLD ENERGY CENTER
P. O. Box 351
Cedar Rapids, Iowa 52406

November 17, 1978
DAEC-78-450

Director, Office of Inspection & Enforcement
U. S. Nuclear Regulatory Commission
Washington, D.C. 20555

SUBJECT: Semiannual Operating Report for
Duane Arnold Energy Center

FILE: A-118e

Dear Sir:

Percent of environmental technical specifications for gaseous effluents during the third and fourth quarter of 1977 was reported as percent of the four percent limit. They should have been reported as percent of the sixteen percent limit. The correct values are:

5.63 % third quarter

6.63 % fourth quarter

Please revise your copies of the semiannual report for that period. We apologize for any inconvenience this may have caused.

Very truly yours,

REGULATORY DOCUMENT FILE COPY

Ellery L. Hammond
Ellery L. Hammond
Chief Engineer
Duane Arnold Energy Center

ELH/KDY/lh

7811280 237

A007
S/10

50-331 R