

IOWA ELECTRIC LIGHT AND POWER COMPANY

General Office

CEDAR RAPIDS, IOWA

December 9, 1976

IE-76-1933

LEE LIU

VICE PRESIDENT - ENGINEERING



Mr. George Lear, Chief
Operating Reactors Branch 3
Division of Operating Reactors
Nuclear Regulatory Commission
Washington, D.C. 20555

Dear Mr. Lear:

Your letter of September 3, 1976 requested additional information for evaluating Duane Arnold Energy Center compliance with Appendix I to 10CFR50. The purpose of this letter is to transmit our response to that request for information.

Three originals and 37 copies of this submittal are transmitted herewith. This submittal, consisting of this letter and the attachment hereto, is true and accurate to the best of my knowledge and belief.

Iowa Electric Light and Power Company

By: Lee Liu

Lee Liu

Vice President, Engineering


Subscribed and sworn to before me
on this 9th day of December, 1976.

Wendy A. Rodenbizer
Notary Public in and for the
State of Iowa.

LL/RFS/ms
Attachment

cc: R. Salmon
D. Arnold
R. Lowenstein
L. Root
J. Shea (NRC)
J. Keppler (NRC)
File A-107

See Reports



12851

8805130035 880429
PDR ADDCK 05000331
P PDR

EC

RESPONSES
TO
ADDITIONAL INFORMATION REQUESTED
FOR
DUANE ARNOLD ENERGY CENTER

TABLE OF CONTENTS

1.	Question 1	Pg. 1-1
2.	Question 2	2-1
3.	Question 3	3-1
4.	Appendices	
	A. Source Terms by Radionuclide	
	B. P&ID's for Liquid Radwaste	
	C. P&ID's for Gaseous Radwaste	

1. Provide the information requested in Chapter 4 of NUREG-0016 "Calculation of Release of Radioactive Materials in Gaseous and Liquid Effluents from Boiling Water Reactors (BWR-GALE Code)" April 1976. (formerly Appendix D of Regulatory Guide 1.10). Refer to question No. 1 in Enclosure 2 of our letter of February 17, 1976.

Responses to Information Requested in Chapter 4 of NUREG-0016

<u>Request</u>	<u>Response</u>
4.1 General	
1) Maximum core thermal power	1658 MWt
2) Tritium released from each reactor in	
a) Liquid effluents	20 Ci/yr*
b) Gaseous effluents	21 Ci/yr*
4.2 Nuclear Steam Supply System	
1) Total steam flow rate	7,147,000 lb/hr
2) Mass of reactor coolant in reactor vessel at full power	289,000 lb
4.3 Reactor Coolant Cleanup System	
1) Average flow rate	70,000 lb/hr
2) Demineralizer	
a) Type	Powdex
b) Size	26 ft ³
3) Regeneration frequency	NA
4) Regenerant	
a) Volume	NA
b) Activity	NA

*Note: Based on GALE calculations

RequestResponse

4.4 Condensate Demineralizers

- | | |
|-------------------------------|--|
| 1) Average flow | 14,500 gpm
7.25 x 10 ⁶ lb/hr |
| 2) Demineralizer type | Powdex |
| 3) Demineralizers | |
| a) Number | 5 |
| b) Size | 234 ft ³ |
| 4) Regeneration frequency | NA |
| 5) Ultrasonic resin cleaning | |
| a) Is it used? | No |
| b) Volume associated with use | NA |
| 6) Regenerant | |
| a) Volume | NA |
| b) Activity | NA |

4.5 Liquid Waste Processing Systems

1a.

<u>System</u>	<u>Sources</u>	<u>Flow Rate*</u> <u>(gal/day)</u>	<u>PCA*</u>
High Purity	Equipment Drains:		
	Drywell	3400	1.0
	Containment, Reactor Bldg., Fuel Pool	3720	0.01
	Radwaste Bldg.	1060	0.01
	Turbine Bldg.	2960	0.01

*Note: Based on NUREG-0016

4.5 1a. Continued

<u>System</u>	<u>Sources</u>	<u>Flow Rate*</u> (gal/day)	<u>PCA*</u>
	Resin Rinse	5000	0.002
	Cleanup Phase Separator Decant	640	0.002
	Condensate Demineralizer Backwash	8100	Negligible
Low Purity Floor Drains:			
	Drywell	700	1.0
	Containment, Reactor Bldg., Fuel Pool	2000	0.01
	Radwaste Bldg.	1000	0.01
	Turbine Bldg.	2000	0.01
Chemical	Lab Drains	500	0.02
	Chem Lab.	100	0.02

1b.

<u>System</u>	<u>Collection Time (days)</u>	<u>Processing Time (days)</u>	<u>Discharge Time (days)</u>
High Purity	0.16	0.03	0
Low Purity	0.7	0.03	0
Chemical	2.7	0.6	0

1c.

<u>System</u>	<u>Equipment</u>	<u>Number</u>	<u>Capacity or Process Rate</u>
High Purity	Collection Tanks	1	10,000 gal.
	Filter	1	110 gpm (120 ft ²)
	Ionex	1	110 gpm (35 ft ³)
	Sample Tanks	2	10,000 gal

*Note: Based on NUREG-0016

4.5 1c. Continued

<u>System</u>	<u>Equipment</u>	<u>Number</u>	<u>Capacity or Process Rate</u>
Low Purity	Collection Tank	1	10,000 gal
	Filter	1	110 gpm (120 ft ²)
	Ionex	1	110 gpm (35 ft ³)
	Sample Tank	1	10,000 gal
Chemical	Collection Tank	1	4,000 gal
	Filter	1	2 gpm
	Ionex	1	2 gpm (35 ft ³)
	Sample Tank	1	4,000 gal

1.d

<u>System</u>	<u>Process Step</u>	<u>Decontamination Factors*</u>		
		<u>Iodine</u>	<u>Cesium</u>	<u>Others</u>
High Purity	Collection Tank	1	1	1
	Filter	1	1	1
	Ionex	100	10	100
	Sample Tanks	1	1	1
Low Purity	Collection Tank	1	1	1
	Filter	1	1	1
	Ionex	100	2	100
	Sample Tank	1	1	1

*Note: Based on NUREG-0016

4.5 1d. Continued

<u>System</u>	<u>Process Step</u>	<u>Decontamination Factors*</u>		
		<u>Iodine</u>	<u>Cesium</u>	<u>Others</u>
Chemical	Collection Tank	1	1	1
	Filter	1	1	1
	Ionex	100	2	100
	Sample Tank	1	1	1

1e.

<u>System</u>	<u>Fraction Discharge</u>
High Purity	0.01
Low Purity	0.1
Chemical	1.0

1f. NA

1g. See Appendix A

2. See Appendix B

<u>Request</u>	<u>Response</u>
4.6 Main Condenser and Turbine Gland Seal Air Removal Systems	
1) The holdup time for offgases from the main condenser air ejector prior to processing by the offgas treatment system	0.5 hr
2) Offgas treatment system	
a) Type	** (see next page)
b) Air inleakage per condenser shell	18.5 scfm
c) Number of condenser shells	2

*Note: Based on NUREG-0016.

4.6 2. Continued

**Process Offgas (Steam Jet Air Ejector)

Noncondensable radioactive offgas is continuously removed from the main condenser by the air ejector during plant operation. This is the major source and is larger than all other sources combined. The air ejector offgas will normally contain activation gases, principally N-16, O-19, and N-13. The N-16 and O-19 isotopes have short half-lives and quickly decay. The 10-minute half-life N-13 isotope is present in small amounts which are further reduced by decay. The air ejector offgas also contains the radioactive noble gas parents of biologically significant Sr-89, Sr-90, Ba-140, and Cs-137 isotopes. The concentration of these noble gases depends upon the usually extremely small amount of tramp uranium in the coolant and on the cladding surfaces, and the number and size of fuel cladding leaks.

Radioactive particulate daughters are retained on the HEPA filters and on the charcoal. The offgas is discharged to the environs via the plant stack. The activity of the gas entering and leaving the offgas treatment system is continuously monitored. Thus, the system performance is known to the operator at all times.

Mechanical Vacuum Pump Offgas

During unit startup, air is removed from the main condenser by a mechanical vacuum pump. The mechanical vacuum pump exhaust is

4.6 2. Continued

** Continued

discharged to the plant stack. The mechanical vacuum pump will normally be in service only during startup at a time when little or no radioactive gas is present. It will be isolated upon the receipt of a high radiation signal from the main steam line radiation monitoring system.

<u>Request</u>	<u>Response</u>
d) Iodine source term from condenser	
i) I-131	5 Ci/yr*
ii) I-133	5 Ci/yr*
3) Charcoal Delay System	
a) Mass of Charcoal	37 tons
b) Operating Temperature	77°F
c) Dew point temperature	45°F
d) Dynamic adsorption coefficient for Xe	330 cc/g
e) Dynamic adsorption coefficient for Kr	18.5 cc/g
4) Cryogenic Distillation System	
a) Fraction of gases partitioned	NA
b) Holdup in system	NA
c) Storage following distillation	NA
d) Expected system leakage rate	NA

*Note: Based on GALE Assumptions

RequestResponse

4.6 Continued

5) Gland seal steam

a) Flow rate

7,147 lb/hr

b) Steam source

Primary steam

6) Gland seal condenser

a) Vented gas holdup time

0.029 hrs

b) Iodine partition factor

100

c) Fraction of iodine released through
system vent

1.0

d) Gland seal off-gas system

7) See Appendix C

***Gland Seal Condenser Offgas

The gland seal condenser exhauster discharges into a separate holdup piping system. A holdup of approximately two minutes is provided to permit decay of the short lived radioactive gases present. These are principally N-13, N-16, N-17, and O-19. The release rate of radioactive gas is less than 0.1% of that from the air ejector offgas system. The gland seal exhaust gas flows past the elevated release point radiation monitors prior to release so its contribution to the release rate is included in the measured total.

4.7 Ventilation and Exhaust Systems

1, 2)

<u>Building</u>	<u>Equipment</u>	<u>Decontamination Factors*</u>	
		<u>Iodine</u>	<u>Particulates</u>
Containment	HEPA and Charcoal	10	100
Turbine	None	1	1
Radwaste	None	1	1
Reactor	None	1	1

3) See Appendix A for release rates. The radioactive particulate size distribution information does not exist for Duane Arnold. The gaseous radwaste treatment system meets the requirements of Regulatory Guide 1.112 and satisfies the criteria according to the BWR GALE Code.

4) Duane Arnold Source Parameters

RX Building

Location is 42° 06' 02" N
91° 46' 36" W

Centered on N-S, E-W directions.

Area of roof = 140' x 140'
Height = 896' 5-3/16" - 757' 6"

Turbine Building

Located East of and adjoining RX Building
Area of roof = 257' x 137'
Height = 833' 10" - 757' 6"

*Note: Based on NUREG-0016

4.7 4) Continued

Vent Stacks (3)

Located at NE corner of RX Building

Diameter = 6'

Height - 911' 10-5/8" - 757'6"

Flow Rate - 63,000 cfm

Exit Velocity = $\frac{63 \times 10^3}{60 \pi R^2} = 37.14 \text{ ft/sec}$

Off Gas Stack

Located 180' East and 560' South of RX Building

Diameter = 2'

Height = 1083'6" - 755'6"

Flow rate = 4300 cfm

Exit Velocity = $\frac{4300}{60 \pi R^2} = 22.81 \text{ ft/sec}$

Gaseous effluent temperature information is not measured at Duane Arnold, however, because of the distance between the offgas treatment system and the release point at the stack it is assumed to reach the ambient temperature at time of release.

Offgas flow is measured at Duane Arnold via RTD's.

5) Containment Building

a) Purge frequency: 4/yr

b) Purge duration: 8 hr

c) Continuous purge rate: NA

2. The annual production data of agricultural products for the 50 mile radius as submitted was extrapolated from Linn and Benton Counties. Justify the use of this data in lieu of providing the data by sectors in the manner indicated in Sections 2.1.3.1 and 2.1.3.2 of Regulatory Guide 4.2, Rev 1 as requested.

The annual production data of agricultural products was extrapolated from data for Linn and Benton Counties, because

1. Linn and Benton Counties include most of the land within 20 miles of the plant.
2. Data from other counties was not available.)
3. The production was assumed to be uniform within 50 miles of the plant.
4. If the production rate more than 20 miles from the plant was actually five times that of Linn and Benton Counties, the total population dose would increase about 60%. This would not make any additional equipment cost-beneficial.

The following information is in support of point 4 above.

Milk production was based on data for the area within 50 miles of the plant, thus only meat, fruits and vegetables were extrapolated.

Linn and Benton Counties have a total area of 1435 square miles or 18 percent of the area within 50 miles of the plant. For this analysis these counties will be represented by the area within 20 miles of the plant (1257 square miles or 16 percent of the area within 50 miles of the plant).

The cost-benefit analysis was based on the assumption that the agricultural production rate was uniform over the entire area within 50 miles of the plant. If, in fact, the production rate outside 20 miles is greater than that inside 20 miles, what is the effect on the total population dose?

Table 2 shows the effect of higher production rates outside 20 miles of the plant on crop and meat doses. For example:

If the production rate outside 20 miles were five times that inside 20 miles, the total production would be 4.36 times that used in the cost-benefit analysis. The production weighted dispersion parameters would be smaller however since the parameters for the farther distances would be more heavily weighted. The product of relative total production and the dispersion parameters would be:

- a) $1.83\text{E}-08$ for the stack X/Q
- b) $4.95\text{E}-11$ for the stack relative deposition
- c) $1.02\text{E}-07$ for the vent X/Q
- d) $5.86\text{E}-11$ for the vent relative deposition.

Taking the ratio of these numbers to the similar numbers for the uniform production assumption gives the relative doses for crops and meat via each release point and isotope type. Thus,

- a) C-14 and H-3 doses from the stack would increase by a factor of 3.08.
- b) Iodine and particulate doses from the stack would increase by a factor of 2.17.
- c) C-14 and H-3 doses from the vent would increase by a factor of 2.97.
- d) Iodine and particulate doses from the vent would increase by a factor of 2.02.

Table 2 was derived from Table 1 by weighting the dispersion parameters by the relative production rate in each region.

The table below shows the fraction of the total crop and meat dose which is attributable to each dispersion parameter:

Stack X/Q	0.05
Stack Relative Deposition	0.08
Vent X/Q	<0.01
Vent Relative Deposition	0.87

When these dose fractions are multiplied by the relative doses from Table 2, the following table results:

<u>Relative Production Rate Outside 20 Miles</u>	<u>Relative Dose</u>
1.	1.00
1.5	1.14
2.	1.28
3.	1.54
5.	2.09
10.	3.45

When these relative doses are applied to the meat and crop doses of the Base Case, Table 3 results. This table shows that the population dose increases by 59 percent when the production rate outside 20 miles is five times greater than the production rate inside 20 miles. Table 4 shows that no equipment is closer than a factor of 2.6 to becoming cost-beneficial. Therefore, since the crop production does not vary widely within 50 miles of the plant, extrapolating the Linn and Benton County data to 50 miles did not effect the cost-benefit analysis.

Table 1

Determination of Meteorological Parameters
for All Food Pathways (Grazing Season Values)

page 1 of 3

Direction	Distance	Sector Fraction	Stack		Vent	
			X/Q sec/m ³	Specific Deposition 1/m ²	X/Q sec/m ³	Specific Deposition 1/m ²
N	1-5	0.01	1.65E-07	2.07E-09	1.06E-06	2.24E-09
	5-10	0.03	6.25E-08	2.39E-10	3.87E-07	4.54E-10
	10-20	0.12	2.01E-08	6.47E-11	1.14E-07	9.82E-11
	20-30	0.20	1.08E-08	3.19E-11	5.73E-08	3.63E-11
	30-40	0.28	7.19E-09	2.06E-11	3.78E-08	1.84E-11
	40-50	0.36	5.30E-09	1.37E-11	2.78E-08	1.14E-11
	Total		1.20E-08	5.27E-11	6.79E-08	6.43E-11
NNE	1-5	0.01	9.47E-08	1.57E-09	4.91E-07	1.53E-09
	5-10	0.03	4.15E-08	1.68E-10	2.79E-07	2.75E-10
	10-20	0.12	1.35E-08	4.32E-11	8.36E-08	6.01E-11
	20-30	0.20	7.23E-09	2.08E-11	4.23E-08	2.22E-11
	30-40	0.28	4.84E-09	1.33E-11	2.81E-08	1.13E-11
	40-50	0.36	3.58E-09	8.88E-12	2.07E-08	6.97E-12
	Total		7.90E-09	3.70E-11	4.71E-08	4.09E-11
NE	1-5	0.01	6.75E-08	1.03E-09	3.35E-07	9.93E-10
	5-10	0.03	3.26E-08	1.38E-10	2.09E-07	1.73E-10
	10-20	0.12	1.04E-08	4.02E-11	6.23E-08	3.62E-11
	20-30	0.20	5.48E-09	1.72E-11	3.13E-08	1.33E-11
	30-40	0.28	3.66E-09	9.89E-12	2.08E-08	6.77E-12
	40-50	0.36	2.70E-09	6.19E-12	1.53E-08	4.19E-12
	Total		5.99E-09	2.77E-11	3.47E-08	2.55E-11
ENE	1-5	0.01	7.15E-08	6.07E-10	4.91E-07	7.91E-10
	5-10	0.03	2.07E-08	5.55E-11	1.19E-07	1.15E-10
	10-20	0.02	7.32E-09	1.28E-11	3.70E-08	2.79E-11
	20-30	0.20	4.15E-09	6.06E-12	1.91E-08	1.05E-11
	30-40	0.28	2.84E-09	4.05E-12	1.27E-08	5.44E-12
	40-50	0.36	2.13E-09	2.90E-12	9.44E-09	3.32E-12
	Total		4.61E-09	1.27E-11	2.37E-08	1.95E-11
E	1-5	0.01	9.06E-08	8.41E-10	4.82E-07	9.34E-10
	5-10	0.03	2.08E-08	7.60E-11	7.81E-08	1.14E-10
	10-20	0.12	7.33E-09	1.74E-11	2.39E-08	2.77E-11
	20-30	0.20	4.16E-09	7.87E-12	1.23E-08	1.05E-11
	30-40	0.28	2.85E-09	5.04E-12	8.17E-09	5.46E-12
	40-50	0.36	3.14E-09	3.55E-12	6.03E-09	3.34E-12
	Total		4.81E-09	1.70E-11	1.69E-08	2.09E-11

Table 1

Determination of Meteorological Parameters
for All Food Pathways (Grazing Season Values)

page 2 of 3

Direction	Distance	Sector Fraction	Stack		Vent	
			X/Q sec/m ³	Specific Deposition 1/m ²	X/Q sec/m ³	Specific Deposition 1/m ²
ESE	1-5	0.01	7.02E-08	7.08E-10	3.29E-07	9.35E-10
	5-10	0.03	2.32E-08	6.52E-11	6.20E-08	1.12E-10
	10-20	0.12	8.46E-09	1.53E-11	1.85E-08	2.44E-11
	20-30	0.20	4.86E-09	7.24E-12	9.36E-09	9.04E-12
	30-40	0.28	3.34E-09	4.74E-12	6.18E-09	4.62E-12
	40-50	0.36	2.52E-09	3.26E-12	4.53E-09	2.85E-12
	Total		5.23E-09	1.48E-11	1.26E-08	1.98E-11
SE	1-5	0.01	5.80E-08	1.02E-09	2.22E-07	1.16E-09
	5-10	0.03	2.51E-08	9.74E-11	6.53E-08	1.55E-10
	10-20	0.12	8.93E-09	2.21E-11	1.96E-08	3.64E-11
	20-30	0.20	5.10E-09	9.93E-12	1.00E-08	1.38E-11
	30-40	0.28	3.49E-09	6.35E-12	6.59E-09	7.21E-12
	40-50	0.36	2.62E-09	4.47E-12	4.83E-09	4.44E-12
	Total		5.43E-09	2.11E-11	1.21E-08	2.70E-11
SSE	1-5	0.01	5.06E-08	1.20E-09	1.70E-07	1.24E-09
	5-10	0.03	2.76E-08	1.20E-10	6.29E-08	1.63E-10
	10-20	0.12	1.00E-08	2.71E-11	1.91E-08	3.84E-11
	20-30	0.20	5.83E-09	1.21E-11	9.79E-09	1.46E-11
	30-40	0.28	4.02E-09	7.64E-12	6.46E-09	7.65E-12
	40-50	0.36	3.03E-09	5.38E-12	4.73E-09	4.71E-12
	Total		5.92E-09	2.53E-11	1.13E-08	2.87E-11
S	1-5	0.01	3.78E-08	7.34E-10	1.46E-07	7.68E-10
	5-10	0.03	1.94E-08	7.67E-11	5.84E-08	1.11E-10
	10-20	0.12	7.14E-09	1.72E-11	1.81E-08	2.98E-11
	20-30	0.20	4.19E-09	7.40E-12	9.42E-09	1.16E-11
	30-40	0.28	2.90E-09	4.50E-12	6.25E-09	6.26E-12
	40-50	0.36	2.19E-09	3.19E-12	4.59E-09	3.82E-12
	Total		4.26E-09	1.56E-11	1.07E-08	2.00E-11
SSW	1-5	0.01	3.58E-08	4.89E-10	2.01E-07	6.57E-10
	5-10	0.03	2.15E-08	5.24E-11	1.42E-07	1.43E-10
	10-20	0.02	7.30E-09	1.17E-11	4.27E-08	3.46E-11
	20-30	0.20	4.03E-09	5.40E-12	2.17E-08	1.30E-11
	30-40	0.28	2.73E-09	3.65E-12	1.44E-08	6.68E-12
	40-50	0.36	2.03E-09	2.63E-12	1.06E-08	4.07E-12
	Total		4.18E-09	1.09E-11	2.36E-08	2.09E-11

Table 1

Determination of Meteorological Parameters
for All Food Pathways (Grazing Season Values)

page 3 of 3

Direction	Distance	Sector Fraction	Stack		Vent	
			X/Q sec/m ³	Specific Deposition 1/m ²	X/Q sec/m ³	Specific Deposition 1/m ²
SW	1-5	0.01	4.14E-08	4.79E-10	2.82E-07	7.20E-10
	5-10	0.03	2.07E-08	5.12E-11	2.49E-07	1.70E-10
	10-20	0.12	7.11E-09	1.09E-11	7.80E-08	4.52E-11
	20-30	0.20	3.97E-09	4.65E-12	4.05E-08	1.71E-11
	30-40	0.25	2.69E-09	3.02E-12	2.71E-08	8.85E-12
	40-50	0.36	<u>2.00E-09</u>	<u>2.18E-12</u>	<u>2.01E-08</u>	<u>5.32E-12</u>
	Total		4.16E-09	1.02E-11	4.26E-08	2.55E-11
WSW	1-5	0.01	4.24E-08	4.53E-10	2.14E-07	6.62E-10
	5-10	0.03	2.09E-08	4.81E-11	3.29E-07	1.45E-10
	10-20	0.12	7.01E-09	1.06E-11	1.05E-07	3.70E-11
	20-30	0.20	3.85E-09	4.81E-12	5.46E-08	1.39E-11
	30-40	0.28	2.60E-09	3.24E-12	3.67E-08	7.19E-12
	40-50	0.36	<u>1.92E-09</u>	<u>2.31E-12</u>	<u>2.74E-08</u>	<u>4.34E-12</u>
	Total		4.08E-09	9.96E-12	5.57E-08	2.18E-11
W	1-5	0.01	4.53E-08	5.57E-10	3.28E-07	7.53E-10
	5-10	0.03	1.48E-08	5.68E-11	2.23E-07	1.53E-10
	10-20	0.12	4.78E-09	1.22E-11	7.23E-08	4.18E-11
	20-30	0.20	2.58E-09	5.17E-12	3.83E-08	1.59E-11
	30-40	0.28	1.72E-09	3.26E-12	2.57E-08	8.33E-12
	40-50	0.36	<u>1.26E-09</u>	<u>2.31E-12</u>	<u>1.92E-08</u>	<u>5.00E-12</u>
	Total		2.92E-09	1.15E-11	4.04E-08	2.44E-11
WNW	1-5	0.01	8.78E-08	8.46E-10	5.93E-07	1.06E-09
	5-10	0.03	3.00E-08	1.23E-10	2.29E-07	1.82E-10
	10-20	0.12	9.51E-09	3.62E-11	6.78E-08	3.84E-11
	20-30	0.20	5.02E-09	1.49E-11	3.40E-08	1.42E-11
	30-40	0.28	3.34E-09	8.37E-12	2.25E-08	7.18E-12
	40-50	0.36	<u>2.45E-09</u>	<u>5.12E-12</u>	<u>1.65E-08</u>	<u>4.45E-12</u>
	Total		5.74E-09	2.37E-11	4.00E-08	2.71E-11
NW	1-5	0.01	1.28E-07	1.11E-09	9.40E-07	1.15E-09
	5-10	0.03	3.93E-08	1.70E-10	2.54E-07	2.30E-10
	10-20	0.12	1.23E-08	5.17E-11	7.45E-08	4.84E-11
	20-30	0.20	6.46E-09	2.16E-11	3.73E-08	1.78E-11
	30-40	0.28	4.28E-09	1.23E-11	2.46E-08	9.05E-12
	40-50	0.36	<u>3.14E-09</u>	<u>7.50E-12</u>	<u>1.80E-08</u>	<u>5.60E-12</u>
	Total		7.56E-09	3.29E-11	4.68E-08	3.23E-11
NNW	1-5	0.01	1.31E-07	1.17E-09	1.07E-06	1.48E-09
	5-10	0.03	5.72E-08	2.44E-10	3.49E-07	3.37E-10
	10-20	0.12	1.78E-08	7.64E-11	1.02E-07	6.95E-11
	20-30	0.20	9.25E-09	3.01E-11	5.10E-08	2.55E-11
	30-40	0.28	6.14E-09	1.62E-11	3.36E-08	1.30E-11
	40-50	0.36	<u>4.52E-09</u>	<u>9.75E-12</u>	<u>2.47E-08</u>	<u>8.04E-12</u>
	Total		1.04E-08	4.23E-11	6.19E-08	4.49E-11
Overall Total			5.94E-09	2.28E-11	3.43E-08	2.90E-11

Table 2

Relative Production Rate Outside 20 miles	Relative Production Rate Total	Relative Production Rate Times Dispersion Factor				Ratio			
		Stack X/Q	Stack δ	Vent X/Q	Vent δ	Stack X/Q	δ	Vent X/Q	δ
1.	1.	5.94E-9	2.28E-11	3.43E-8	2.90E-11	1.00	1.00	1.00	1.00
1.5	1.42	7.49E-9	2.62E-11	4.27E-8	3.27E-11	1.26	1.15	1.24	1.13
2.	1.84	9.03E-9	2.95E-11	5.11E-8	3.64E-11	1.52	1.29	1.49	1.26
3.	2.68	1.21E-8	3.62E-11	6.79E-8	4.38E-11	2.04	1.59	1.98	1.51
5.	4.36	1.83E-8	4.95E-11	1.02E-7	5.86E-11	3.08	2.17	2.97	2.02
10.	8.56	3.38E-8	8.29E-11	1.86E-7	9.57E-11	5.69	3.64	5.42	3.30

Table 3

Relative Production Rate Outside 20 miles	Crop and Meat Dose (man-rem)	Total 1980 Population Dose (man-rem)	Increase in Population Dose over Uniform Crop Distribution (%)
1	47.9	88.6	3
1.5	54.6	95.3	8
2	61.3	102.0	15
3	73.7	114.4	29
5	100.0	140.7	59
10	165.1	205.8	132

Table 4
Cost-Benefit Ratios for Alternate Cases

Case	Purpose	Annual Δ Doses		Annual Δ Costs		Cost-Benefit Ratios	
		from Base man-rem	from Prev Case man-rem	from Base dollars	from Prev Case dollars	from Base \$/man-rem	from Prev Case \$/man-rem
	<u>Gland Seal</u>						
D-1	Double holdup time	1.65E-02	-	>5,000	-	>3.0E+05	-
D-2	Add HEPA & charcoal	2.35E 00	-	14,600	-	6.2E+03	-
	<u>SJAE</u>						
E-1	Operate at 0 F dewpont	2.96E 00	-	155,300	-	5.2E+04	-
E-2	Add 2 more beds	1.20E 00	-	45,800	-	3.8E+04	-
E-3	Remove 2 beds	-1.46E 00 ^a	-	-45,800 ^b	-	3.1E+04	-
	<u>Drywell</u>						
F-2	Remove charcoal	-2.39E+01	-	-9,300	-	3.9E+02	-
F-3	Remove HEPA & charcoal	-2.45E+01	6.00E-01	-18,100	-8,800	7.4E+02	1.5E+04
	<u>Turbine Bldg</u>						
G-1	Add HEPA	1.04E-01	-	59,400	-	5.7E+05	-
G-2	Add HEPA & charcoal	2.69E+01	2.68E+01	120,700	61,300	4.5E+03	2.2E+03
G-3	Add clean steam	2.65E+01	-	>150,000	-	>5.7E+03	-
	<u>Auxiliary Bldg</u>						
H-1	Add HEPA	6.25E-01	-	76,200	-	1.2E+05	-
H-3	Add HEPA & charcoal	2.45E+01	2.39E+01	153,100	76,900	6.2E+03	3.2E+03
	<u>Radwaste Bldg</u>						
I-1	Add charcoal	7.02E 00	-	18,100	-	2.6E+03	-
I-2	Remove HEPA	-3.44E 00	-	-17,300	-	5.0E+03	-

a Negative dose changes are increases in dose

b Negative costs are decreases in costs

3. Provide information on grazing season (give dates), feeding regimes for cattle (such as grazing practices, green chop-feeding, corn and grass silage feeding and hay feeding), pasture grass density (Kg/m^2) and yield statistics (Kg/m^2) for harvested forage crops for beef and dairy cattle feeding.

The following information is provided on the grazing season and feeding regimes for cattle. Because there is considerable variability in the production of forages and the feeding and grazing programs for cattle, the data must be considered as estimates for average conditions:

Calendar Dates for Grazing Season and Feeding Pattern

<u>Forage</u>	<u>Range</u>	<u>Intensive Period</u>	<u>Portion of Yr</u>
Grass pastures	Apr. 20-Dec. 1	May 15- Nov. 1	42-50%
Alfalfa	Apr. 15-May 10	Apr. 30 - May 10	42-50%
Alfalfa	Oct. 20-Dec. 1	November	12.5%
Red Clover	Apr. 15-May 10	May 1-Oct. 1	25-42%
Corn stalks	Oct. 1-Apr. 1	Oct. 1-Jan. 1	25-33%
Green Chop	May 1-Oct. 1	May 20-Sept. 20	33%
Silage	All year feeding practice by some	Dec. 15-May 15	42%
Hay	All year feeding practice by some	Dec. 15-May 15	42%

3. Continued

Pasture Grass Density. This is difficult to assess since the density varies throughout the year, and the pasture grass is not normally harvested and stored. However, using the values which are common to hay harvesting, which should add some conservatism, it is estimated that the pasture grass density is 0.4 kg/m^2 of dry matter.

Annual Yield of Forage Crops. This yield is based upon the average harvest which is estimated as 1.2 kg/m^2 of dry matter.

APPENDIX A

SOURCE TERMS BY RADIONUCLIDE

05/17/76

17.30.02

PAGE 3

DUANE ARNOLD
BASE CASE

GASEOUS RELEASE RATE

%CURIES PER YEAR

NUCLIDE	COOLANT CONC. %MICROCURIES/G	CONTAINMENT BLDG.	TURBINE BLDG.	AUXILIARY BLDG.	RADWASTE BLDG.	GLAND SEAL	AIR EJECTOR	MECH VAC PUMP	TOTAL
KR-83M	1.100E-03	0.0	0.0	0.0	0.0	2.5E 01	2.4E 01	0.0	4.9E 01
KR-85M	1.900E-03	3.0E 00	6.8E 01	3.0E 00	0.0	4.3E 01	2.3E 03	0.0	2.4E 03
KR--85	6.000E-06	0.0	0.0	0.0	0.0	0.0	1.4E 02	0.0	1.4E 02
KR--87	6.600E-03	3.0E 00	1.3E 02	3.0E 00	0.0	1.5E 02	6.0E 00	0.0	2.9E 02
KR--88	6.600E-03	3.0E 00	2.3E 02	3.0E 00	0.0	1.5E 02	1.5E 03	0.0	1.9E 03
KR--89	4.100E-02	0.0	0.0	0.0	0.0	6.4E 02	0.0	0.0	6.4E 02
XEL31M	4.700E-06	0.0	0.0	0.0	0.0	0.0	4.8E 01	0.0	4.8E 01
XEL33M	9.000E-05	0.0	0.0	0.0	0.0	2.0E 00	3.3E 01	0.0	3.5E 01
XE-133	2.600E-03	6.6E 01	2.5E 02	6.6E 01	1.0E 01	5.9E 01	1.0E 04	2.3E 03	1.3E 04
XEL35M	8.400E-04	4.6E 01	6.5E 02	4.6E 01	0.0	1.8E 01	0.0	0.0	7.6E 02
XE-135	7.200E-03	3.4E 01	6.3E 02	3.4E 01	4.5E 01	1.6E 02	0.0	3.5E 02	1.3E 03
XE-137	4.700E-02	0.0	0.0	0.0	0.0	7.8E 02	0.0	0.0	7.8E 02
XE-138	2.800E-02	7.0E 00	1.4E 03	7.0E 00	0.0	5.9E 02	0.0	0.0	2.0E 03
TOTAL NOBLE GASES									2.3E 04
I--131	4.912E-03	1.7E-02	1.9E-01	1.7E-01	5.0E-02	2.2E-02	0.0	3.0E-02	4.8E-01
I--133	1.936E-02	6.8E-02	7.6E-01	6.8E-01	1.8E-01	8.8E-02	0.0	0.0	1.8E 00
C---14		0.0	0.0	0.0	0.0	0.0	9.5E 00	0.0	9.5E 00
AR--41		2.5E 01	0.0	0.0	0.0	0.0	0.0	0.0	2.5E 01
H----3		0.0	1.1E 01	0.0	0.0	0.0	1.1E 01	0.0	2.1E 01

0.0 APPEARING IN THE TABLE INDICATES RELEASE IS LESS THAN 1.0 CI/YR FOR NOBLE GAS, 0.0001 CI/YR FOR I

05/17/76

17.30.02

PAGE 4

DUANE ARNOLD
BASE CASEAIRBORNE PARTICULATE RELEASE RATE
%CURIES PER YEAR

NUCLIDE	CONTAINMENT BLDG.	TURBINE BLDG.	AUXILIARY BLDG.	RADWASTE BLDG.	MECH VAC. PUMP	TOTAL
CR--51	3.0E-06	1.3E-02	3.0E-04	9.0E-05	0.0	1.3E-02
MN--54	3.0E-05	6.0E-04	3.0E-03	3.0E-04	0.0	3.9E-03
FE--59	4.0E-06	5.0E-04	4.0E-04	1.5E-04	0.0	1.1E-03
CO--58	6.0E-06	6.0E-04	6.0E-04	4.5E-05	0.0	1.3E-03
CO--60	1.0E-04	2.0E-03	1.0E-02	9.0E-04	0.0	1.3E-02
ZN--65	2.0E-05	2.0E-04	2.0E-03	1.5E-05	0.0	2.2E-03
SR--89	9.0E-07	6.0E-03	9.0E-05	4.5E-06	0.0	6.1E-03
SR--90	5.0E-08	2.0E-05	5.0E-06	3.0E-06	0.0	2.8E-05
ZR--95	4.0E-06	1.0E-04	4.0E-04	5.0E-07	0.0	5.0E-04
SB-124	2.0E-06	3.0E-04	2.0E-04	5.0E-07	0.0	5.0E-04
CS-134	4.0E-05	3.0E-04	4.0E-03	4.5E-05	3.0E-06	4.4E-03
CS-136	3.0E-06	5.0E-05	3.0E-04	4.5E-06	2.0E-06	3.6E-04
CS-137	5.5E-05	6.0E-04	5.5E-03	9.0E-05	1.0E-05	6.3E-03
BA-140	4.0E-06	1.1E-02	4.0E-04	1.0E-06	1.1E-05	1.1E-02
CE-141	1.0E-06	6.0E-04	1.0E-04	2.6E-05	0.0	7.3E-04

05/17/76

17-36.42

PAGE 3

DUANE ARNOLD
BASE CASE

LIQUID EFFLUENTS

NUCLIDE	HALF-LIFE %DAYS	CONCENTRATION IN PRIMARY		ANNUAL RELEASES TO DISCHARGE CANAL				ADJUSTED TOTAL %CI/YR	DETERGENT WASTES %CI/YR	TOTAL %CI/YR
		COOLANT MICRO CI/ML	HIGH PURITY %CURIES	LOW PURITY %CURIES	CHEMICAL %CURIES	TOTAL LWS %CURIES				
		CORROSION AND ACTIVATION PRODUCTS								
NA 24	6.25E-01	7.65E-03	0.000335	0.000541	0.000000	0.000876	0.01527	0.0	0.01500	
P 32	1.43E-01	1.83E-04	0.000009	0.000018	0.000000	0.000027	0.00047	0.0	0.00047	
CR 51	2.78E-01	4.58E-03	0.000220	0.000464	0.000001	0.000685	0.01194	0.0	0.01200	
MN 54	3.03E-02	5.50E-05	0.000003	0.000006	0.000000	0.000008	0.00014	0.0	0.00014	
MN 56	1.07E-01	3.86E-02	0.000955	0.000713	0.000000	0.01668	0.02907	0.0	0.02900	
FE 55	4.50E-02	3.16E-04	0.000044	0.000094	0.000000	0.00138	0.00241	0.0	0.00240	
FE 54	4.50E-01	2.73E-05	0.000001	0.000003	0.000000	0.000004	0.000007	0.0	0.000007	
CO 58	7.13E-01	1.83E-04	0.000009	0.000014	0.000000	0.000028	0.00048	0.0	0.00048	
CO 60	1.42E-03	3.67E-04	0.000018	0.000038	0.000000	0.000055	0.00096	0.0	0.00096	
NI 65	1.07E-01	2.31E-04	0.000006	0.000004	0.000000	0.000010	0.00017	0.0	0.00017	
CU 64	5.33E-01	2.60E-02	0.01087	0.01680	0.000001	0.02767	0.04823	0.0	0.04800	
ZN 65	2.45E-02	1.83E-04	0.000009	0.000014	0.000000	0.000028	0.00048	0.0	0.00048	
ZN 64M	5.75E-01	1.74E-03	0.000073	0.000116	0.000000	0.00184	0.00330	0.0	0.00330	
ZN 64	5.46E-02	0.0	0.000061	0.000119	0.000000	0.00180	0.00314	0.0	0.00310	
W 182	5.46E-01	2.66E-04	0.000012	0.000021	0.000000	0.000033	0.00058	0.0	0.00058	
NP 239	2.35E-00	6.32E-03	0.000245	0.000580	0.000001	0.000875	0.01525	0.0	0.01500	
FISSION PRODUCTS										
BR 83	1.00E-01	2.64E-03	0.000063	0.000045	0.000000	0.00108	0.00188	0.0	0.00190	
BK 84	2.21E-02	3.78E-03	0.000014	0.000007	0.000000	0.000021	0.00036	0.0	0.00036	
RB 84	1.07E-02	3.27E-03	0.000022	0.000053	0.000000	0.000075	0.00130	0.0	0.00130	
SR 84	5.20E-01	3.16E-05	0.000004	0.000009	0.000000	0.000014	0.00024	0.0	0.00024	
SR 90	1.03E-04	5.50E-06	0.000000	0.000001	0.000000	0.000001	0.000001	0.0	0.000001	
SR 91	4.03E-01	3.41E-03	0.00136	0.00193	0.000000	0.00329	0.00574	0.0	0.00570	
Y 91M	3.47E-02	0.0	0.000071	0.000118	0.000000	0.000189	0.000329	0.0	0.000330	
Y 91	5.88E-01	3.66E-05	0.000002	0.000005	0.000000	0.000007	0.000012	0.0	0.000012	
SR 92	1.13E-01	7.75E-03	0.00198	0.00151	0.000000	0.00349	0.00609	0.0	0.00610	
Y 92	1.47E-01	4.76E-03	0.00238	0.00287	0.000000	0.00526	0.00916	0.0	0.00920	
Y 93	4.25E-01	3.42E-03	0.00159	0.00159	0.000000	0.00317	0.00588	0.0	0.00590	
ZR 95	6.50E-01	6.41E-06	0.000000	0.000001	0.000000	0.000001	0.000002	0.0	0.000002	
NB 95	3.50E-01	6.41E-06	0.000000	0.000001	0.000000	0.000001	0.000002	0.0	0.000002	
NB 98	3.54E-02	2.82E-03	0.000023	0.000012	0.000000	0.000035	0.00061	0.0	0.00061	
MO 99	2.79E-00	1.81E-03	0.000085	0.000169	0.000000	0.000254	0.00443	0.0	0.00440	
TC 94M	5.50E-01	1.65E-02	0.00611	0.00777	0.000000	0.01384	0.02421	0.0	0.02400	
TC 101	4.72E-03	5.46E-02	0.000030	0.00014	0.000000	0.00044	0.00077	0.0	0.00077	
RU 103	3.46E-01	1.83E-05	0.000001	0.000002	0.000000	0.000003	0.000005	0.0	0.000005	
RH 103M	3.46E-02	0.0	0.000001	0.000002	0.000000	0.000003	0.000004	0.0	0.000004	
TC 104	1.25E-02	5.34E-02	0.000055	0.000027	0.000000	0.000082	0.00142	0.0	0.00140	
RU 105	1.85E-01	1.62E-03	0.000052	0.000052	0.000000	0.000105	0.00182	0.0	0.00180	
RH 105M	5.21E-04	0.0	0.000052	0.000052	0.000000	0.000105	0.00183	0.0	0.00180	
RH 105	1.50E-00	0.0	0.000003	0.000012	0.000000	0.000015	0.000027	0.0	0.000027	
TE 123M	3.40E-01	3.66E-05	0.000002	0.000004	0.000000	0.000005	0.000010	0.0	0.000010	
TE 129	4.74E-02	0.0	0.000001	0.000002	0.000000	0.000003	0.000006	0.0	0.000006	
TE 131M	1.25E-00	8.52E-05	0.000004	0.000007	0.000000	0.000011	0.000020	0.0	0.000020	
TE 131	1.74E-02	0.0	0.000001	0.000001	0.000000	0.000002	0.000004	0.0	0.000004	
TE 132	3.25E-00	4.07E-06	0.000001	0.000001	0.000000	0.000001	0.000002	0.0	0.000002	
TE 133	8.75E-01	1.44E-02	0.000255	0.01486	0.000008	0.01031	0.01797	0.0	0.01800	
TE 134	3.67E-02	5.55E-02	0.00080	0.00245	0.000000	0.00725	0.01264	0.0	0.01300	
CS 134	7.45E-02	2.75E-05	0.000013	0.000141	0.000000	0.000154	0.00268	0.0	0.00270	

05/17/76

17.36.42

PAGE 4

DUANE ARNOLD
BASE CASE

LIQUID EFFLUENTS %CONTINUED%

NUCLIDE	HALF-LIFE %DAYS	CONCENTRATION IN PRIMARY		ANNUAL RELEASES TO DISCHARGE CANAL				ADJUSTED TOTAL %CI/YR	DETERGENT WASTES %CI/YR	TOTAL %CI/YR
		COOLANT %MICRO CI/ML	HIGH PURITY %CURIES	LOW PURITY %CURIES	CHEMICAL %CURIES	TOTAL LWS %CURIES				
1135	2.74E-02	1.88E-02	0.00692	0.00846	0.00001	0.01539	0.02682	0.0	0.02700	
CS137	1.30E-01	1.82E-05	0.00009	0.00092	0.00000	0.00100	0.00175	0.0	0.00170	
CS137	1.10E-04	6.42E-05	0.00031	0.00329	0.00000	0.00359	0.00626	0.0	0.00630	
BA137M	1.77E-03	0.0	0.00024	0.00307	0.00000	0.00336	0.00586	0.0	0.00590	
CS138	2.24E-02	6.67E-03	0.00254	0.00621	0.00000	0.00875	0.01525	0.0	0.01500	
BA137	5.76E-02	7.30E-03	0.00109	0.00062	0.00000	0.00171	0.00297	0.0	0.00300	
BA140	1.26E-01	3.66E-04	0.00013	0.00037	0.00000	0.00054	0.00095	0.0	0.00095	
LA140	1.67E-00	0.0	0.00001	0.00005	0.00000	0.00006	0.00011	0.0	0.00011	
BA141	1.25E-02	6.67E-03	0.00007	0.00003	0.00000	0.00010	0.00018	0.0	0.00018	
LA141	1.62E-01	0.0	0.00018	0.00016	0.00000	0.00034	0.00059	0.0	0.00059	
CE141	3.24E-01	2.75E-05	0.00001	0.00003	0.00000	0.00004	0.00008	0.0	0.00008	
BA142	7.64E-03	3.95E-03	0.00001	0.00000	0.0	0.00001	0.00002	0.0	0.00002	
LA142	6.34E-02	3.68E-03	0.00070	0.00041	0.00000	0.00111	0.00193	0.0	0.00190	
CE143	1.36E-00	2.68E-05	0.00001	0.00002	0.00000	0.00004	0.00006	0.0	0.00006	
PK143	1.37E-01	3.66E-05	0.00002	0.00004	0.00000	0.00005	0.00010	0.0	0.00010	
ALL OTHERS		1.98E-03	0.00001	0.00003	0.00000	0.00004	0.00007	0.0	0.00007	
TOTAL										
%EXCEPT TRITIUM		4.08E-01	0.06374	0.11794	0.00020	0.20188	0.35189	0.0	0.35000	

TRITIUM RELEASE

20 CURIES PER YEAR

05/27/76

12.51.00

PAGE 3

DUANE ARNOLD
COMPLIANCE BASE CASE B

LIQUID EFFLUENTS

		CONCENTRATION		ANNUAL RELEASES TO DISCHARGE CANAL				ADJUSTED TOTAL %CI/YR	DETERGENT WASTES %CI/YR	TOTAL %CI/YR
NUCLIDE	HALF-LIFE %DAYS	IN PRIMARY COOLANT %MICRO CI/ML	HIGH PURITY %CURIES	LOW PURITY %CURIES	CHEMICAL %CURIES	TOTAL LWS %CURIES				
CORROSION AND ACTIVATION PRODUCTS										
NA 24	6.25E-01	7.85E-03	0.00335	0.00541	0.00021	0.00897	0.01544	0.0	0.01500	
NA 23	1.43E-01	1.83E-04	0.00007	0.00018	0.00003	0.00030	0.00051	0.0	0.00051	
CR 51	1.28E-01	4.58E-03	0.00220	0.00464	0.00072	0.00756	0.01302	0.0	0.01300	
MN 54	1.03E-02	5.50E-05	0.00003	0.00006	0.00001	0.00009	0.00016	0.0	0.00016	
MN 56	1.07E-01	3.86E-02	0.00455	0.00713	0.00001	0.01169	0.02873	0.0	0.02900	
FE 55	4.50E-02	1.16E-04	0.00044	0.00094	0.00015	0.00153	0.00264	0.0	0.00260	
FE 59	1.07E-01	7.5E-05	0.00001	0.00003	0.00000	0.00005	0.00008	0.0	0.00008	
CO 58	7.13E-01	1.83E-04	0.00009	0.00019	0.00003	0.00030	0.00052	0.0	0.00052	
CO 60	1.13E-01	3.67E-04	0.00018	0.00038	0.00001	0.00061	0.00105	0.0	0.00110	
NI 65	1.07E-01	3.1E-04	0.00006	0.00004	0.00000	0.00010	0.00017	0.0	0.00017	
CU 64	1.07E-01	2.60E-02	0.01087	0.01600	0.00055	0.02821	0.04856	0.0	0.04900	
CU 65	2.45E-02	1.83E-04	0.00009	0.00019	0.00003	0.00031	0.00053	0.0	0.00053	
ZN 69M	5.75E-01	1.74E-03	0.00073	0.00116	0.00004	0.00193	0.00333	0.0	0.00330	
ZN 69	3.46E-02	0.0	0.00061	0.00114	0.00004	0.00185	0.00318	0.0	0.00320	
W 187	1.96E-01	2.66E-04	0.00012	0.00021	0.00001	0.00034	0.00059	0.0	0.00059	
NP 239	2.35E-00	1.32E-03	0.00295	0.00580	0.00061	0.00935	0.01610	0.0	0.01600	
FISSION PRODUCTS										
BR 83	1.00E-01	2.64E-03	0.00063	0.00045	0.00000	0.00108	0.00186	0.0	0.00190	
BR 84	2.21E-02	3.78E-03	0.00014	0.00007	0.00000	0.00021	0.00036	0.0	0.00036	
RB 84	1.07E-02	3.27E-03	0.00022	0.00053	0.00000	0.00075	0.00128	0.0	0.00130	
SR 84	1.20E-01	1.1E-05	0.00004	0.00009	0.00001	0.00015	0.00027	0.0	0.00027	
SR 90	1.03E-04	5.50E-06	0.00000	0.00001	0.00000	0.00001	0.00002	0.0	0.00002	
SR 91	4.03E-01	3.41E-03	0.00136	0.00193	0.00004	0.00334	0.00574	0.0	0.00570	
Y 91M	3.47E-02	0.0	0.00071	0.00118	0.00003	0.00192	0.00330	0.0	0.00330	
Y 91	1.58E-01	3.5E-05	0.00002	0.00005	0.00001	0.00008	0.00013	0.0	0.00013	
SR 92	1.13E-01	7.7E-03	0.00198	0.00151	0.00000	0.00349	0.00601	0.0	0.00600	
Y 92	1.47E-01	4.76E-03	0.00238	0.00287	0.00002	0.00527	0.00908	0.0	0.00910	
Y 93	4.25E-01	3.42E-03	0.00138	0.00199	0.00005	0.00342	0.00589	0.0	0.00590	
ZR 95	1.50E-01	6.41E-06	0.00000	0.00001	0.00000	0.00001	0.00002	0.0	0.00002	
NP 95	1.50E-01	6.41E-06	0.00000	0.00001	0.00000	0.00001	0.00002	0.0	0.00002	
NE 98	1.54E-02	1.82E-03	0.00023	0.00012	0.00000	0.00035	0.00060	0.0	0.00060	
MO 99	1.79E-00	1.81E-03	0.00085	0.00169	0.00014	0.00273	0.00469	0.0	0.00470	
TC 99M	1.50E-01	1.6E-02	0.00611	0.00777	0.00025	0.01413	0.02433	0.0	0.02400	
TC 101	1.22E-03	5.9E-02	0.00030	0.00014	0.00000	0.00044	0.00076	0.0	0.00076	
RU 103	3.96E-01	1.83E-05	0.00001	0.00002	0.00000	0.00003	0.00005	0.0	0.00005	
RH 103M	3.96E-02	0.0	0.00001	0.00002	0.00000	0.00003	0.00005	0.0	0.00005	
TC 104	1.25E-02	5.34E-02	0.00055	0.00027	0.00000	0.00082	0.00140	0.0	0.00140	
RU 105	1.85E-01	1.62E-03	0.00052	0.00052	0.00000	0.00105	0.00181	0.0	0.00180	
RH 105M	1.85E-01	0.0	0.00052	0.00052	0.00000	0.00105	0.00181	0.0	0.00180	
RH 105	1.50E-00	0.0	0.00003	0.00012	0.00002	0.00017	0.00029	0.0	0.00029	
TEL 29M	3.40E-01	3.6E-05	0.00002	0.00004	0.00001	0.00007	0.00010	0.0	0.00010	
TEL 29	4.74E-02	0.0	0.00001	0.00002	0.00000	0.00004	0.00006	0.0	0.00006	
TEL 31M	1.25E-00	8.92E-05	0.00004	0.00007	0.00001	0.00012	0.00021	0.0	0.00021	
TEL 31	1.74E-02	0.0	0.00001	0.00001	0.00000	0.00002	0.00004	0.0	0.00004	
TEL 32	8.05E-00	4.91E-03	0.00234	0.00487	0.00069	0.00791	0.01361	0.0	0.01400	
TEL 32	3.25E-00	4.07E-06	0.00000	0.00001	0.00000	0.00001	0.00002	0.0	0.00002	
TEL 33	1.50E-02	2.63E-02	0.00605	0.00426	0.00009	0.01032	0.01776	0.0	0.01800	
TEL 34	1.44E-01	1.94E-02	0.00855	0.01486	0.00082	0.02424	0.04172	0.0	0.04200	
TEL 34	3.67E-02	5.59E-02	0.00480	0.00745	0.00000	0.00725	0.01249	0.0	0.01200	
CS 134	2.49E-02	2.7E-05	0.00013	0.00141	0.00023	0.00177	0.00304	0.0	0.00300	

05/27/76

12.51.00

PAGE 4

DUANE ARNOLD
COMPLIANCE BASE CASE B

LIQUID EFFLUENTS %CONTINUED

NUCLIDE	HALF-LIFE DAYS	CONCENTRATION	ANNUAL RELEASES TO DISCHARGE CANAL			TOTAL LWS %CURIES	ADJUSTED TOTAL %CI/YR	DETERGENT WASTES %CI/YR	TOTAL %CI/YR
		IN PRIMARY COOLANT %MICRO CI/ML	HIGH PURITY %CURIES	LOW PURITY %CURIES	CHEMICAL %CURIES				
I135	2.79E-01	1.88E-02	0.00692	0.00846	0.00010	0.01548	0.02665	0.0	0.02700
CS136	1.30E-01	1.82E-05	0.00009	0.00092	0.00014	0.00114	0.00196	0.0	0.00200
CS137	1.10E-04	6.42E-05	0.00031	0.00329	0.00053	0.00413	0.00710	0.0	0.00710
BA137M	1.77E-03	0.0	0.00029	0.00307	0.00050	0.00386	0.00664	0.0	0.00660
CS138	2.24E-02	6.67E-03	0.00254	0.00621	0.00000	0.00875	0.01506	0.0	0.01500
BA137	5.76E-02	7.30E-03	0.00104	0.00062	0.00000	0.00171	0.00294	0.0	0.00290
BA140	1.28E-01	3.66E-04	0.00018	0.00037	0.00005	0.00060	0.00103	0.0	0.00100
LA140	1.67E-00	0.0	0.00001	0.00005	0.00003	0.00009	0.00016	0.0	0.00016
BA141	1.25E-02	6.67E-03	0.00007	0.00003	0.00000	0.00010	0.00018	0.0	0.00018
LA141	1.62E-01	0.0	0.00018	0.00016	0.00000	0.00034	0.00058	0.0	0.00058
CE141	3.24E-01	2.75E-05	0.00001	0.00003	0.00000	0.00005	0.00008	0.0	0.00008
BA142	7.64E-03	3.95E-03	0.00001	0.00000	0.0	0.00001	0.00002	0.0	0.00002
LA142	6.39E-02	3.68E-03	0.00070	0.00041	0.00000	0.00111	0.00191	0.0	0.00190
CE143	1.38E-00	2.68E-05	0.00001	0.00002	0.00000	0.00004	0.00006	0.0	0.00006
PR143	1.37E-01	3.66E-05	0.00002	0.00004	0.00001	0.00006	0.00010	0.0	0.00010
ALL OTHERS		1.98E-03	0.00001	0.00003	0.00000	0.00004	0.00007	0.0	0.00007
TOTAL									
%EXCEPT TRITIUM		4.08E-01	0.08374	0.11794	0.00627	0.20796	0.35796	0.0	0.36000

TRITIUM RELEASE

20 CURIES PER YEAR

APPENDIX B

PIPING AND INSTRUMENTATION DRAWINGS

for

LIQUID RADWASTE

**OVERSIZE
DOCUMENT
PAGE PULLED**

SEE APERTURE CARDS

NUMBER OF OVERSIZE PAGES FILMED ON APERTURE CARDS

4

**APERTURE CARD/HARD COPY AVAILABLE FROM RECORD SERVICES BRANCH
FTS 492 - B989**