

Appendix A

NOTICE OF VIOLATION

Iowa Electric Light and Power Co.

Docket No. 50-331

Based on the inspection conducted on December 18-20, 1979, it appears that certain of your activities were in noncompliance with NRC requirements, as noted below. This item is an infraction.

Environmental Technical Specification 2.2.1 requires that residual chlorine concentrations in plant cooling tower effluent be limited to 0.1 mg/l or less at all times.

Contrary to the above, on November 8, 1979, water discharged from plant cooling towers contained residual chlorine concentrations in excess of 0.1 mg/l.

8002250462