

JAN 23 1975

DISTRIBUTION:

NRC PDR
Local PDR
✓ Docket
KRGoller
TJCarter
Paulson
ORB#3 rdg
SATEets
OELD
IO&E (3)
Lear
ACRS (16)
extra cps

Docket No. 50-331

Iowa Electric Light and Power Company
ATTN: Mr. Duane Arnold, President
Security Building
P. O. Box 351
Cedar Rapids, Iowa 52406

Gentlemen:

We have completed a review of the General Electric Company proprietary topical report NEDE-10958, "General Electric BWR Thermal Analysis Basis (GETAB): Data, Correlation and Design Application" (NEDE-10958 is the non-proprietary version). Enclosed is our evaluation of this report.

As a result of our review, we have concluded that the above report provides an acceptable boiling transition correlation and an acceptable method of thermal analysis of GE BWR 8x8 and 7x7 fuel assemblies.

In this regard, the analyses supporting the proposed GETAB-based Technical Specifications for the Duane Arnold Energy Center should be submitted no later than the submittal date of your ECCS re-evaluation required by the Order transmitted to you on December 27, 1974.

Sincerely,

Original Signed

George Lear, Chief
Operating Reactors Branch #3
Division of Reactor Licensing

Enclosure:
Evaluation of Report

cc: See next page

*See Docket No. 50-237
for enclosure.*

OFFICE➤	WAP ORB#3	ORB#3				2	ms jr
SURNAME➤	Paulson/dg	Lear 6L					
DATE➤	1/22/75	1/22/75					

Iowa Electric Light & Power Company

- 2 -

JAN 23 1975

cc: w/enclosure

Reference Service
Cedar Rapids Public Library
426 Third Avenue, S. E.
Cedar Rapids, Iowa 52401

Anthony Z. Roisman, Esquire
Berlin, Roisman & Kessler
1712 N. Street, N. W.
Washington, D. C. 20036

Jack R. Newman, Esquire
Harold F. Reis, Esquire
Lowenstein, Newman, Reis, and Axelrad
1025 Connecticut Avenue, N. W.
Washington, D. C. 20036

OFFICE >						
SURNAME >						
DATE >						