NRC DISTRIBUTION FOR PART 50 DOCKET MATERIAL
(TEMPORARY FORM)

CONTROL NO: 2502

FILE:

FROM:	DATE OF DOC	DATE REC'D	LTR	TWX	RPT	OTHER
Iowa Electric Light&Pwr Cedar Rapids, Iowa G G Hunt	2-26-75	3-6-75	XXX			

TO:	ORIG	CC	OTHER	
Mr Case	one signed			SENT AEC PDR XX SENT LOCAL PDR XX

CLASS	UNCLASS	PROP INFO	INPUT	NO CYS REC'D	DOCKET NO:
	XXXXXX			1	50-331

DESCRIPTION:

Ltr advising that the self-equalizing float type level switches in the scram discharge volume.....as noted in their 2-13-75 ltr... have been replaced.....

ENCLOSURES:

DO NOT REMOVE

ACKNOWLEDGED

PLANT NAME: Duane Arnold

FOR ACTION/INFORMATION 3-6-75 ehf

BUTLER (L) W/ Copies
CLARK (L) W/ Copies
PARR (L) W/ Copies
KNIEL (L) W/ Copies
SCHWENCER (L) W/ Copies
STOLZ (L) W/ Copies
VASSALLO (L) W/ Copies
PURPLE (L) W/ Copies
ZIEMANN (L) W/ Copies
DICKER (E) W/ Copies
KNIGHTON (E) W/ Copies
YOUNGBLOOD (E) W/ Copies
REGAN (E) W/ Copies
LEAR (L) W/6 Copies
SPELS W/ Copies
W/ Copies

INTERNAL DISTRIBUTION

REG FILE
NRC PDR
OGC, ROOM P-506A
GOSSICK/STAFF
CASE
GIAMBUSSO
BOYD
MOORE (L)
DEYOUNG (L)
SKOVHOLT (L)
GOLLER (L) (Ltr)
P. COLLINS
DENISE
REG OPR
FILE & REGION (2)
T.R. WILSON
STEELE

TECH REVIEW
SCHROEDER
MACCARY
KNIGHT
PAWLICKI
SHAO
STELLO
HOUSTON
NOVAK
ROSS
IPPOLITO
TEDESCO
LONG
LAINAS
BENAROYA
VOLLMER

DENTON
GRIMES
GAMMILL
KASTNER
BALLARD
SPANGLER

ENVIRO
MULLER
DICKER
KNIGHTON
YOUNGBLOOD
REGAN
PROJECT LDR

HARLESS

LIC ASST
R. DIGGS (L)
H. GEARIN (L)
E. GOULBOURNE (L)
P. KREUTZER (E)
J. LEE (L)
M. MAIGRET (L)
S. REED (E)
M. SERVICE (L)
S. SHEPPARD (L)
M. SLATER (E)
H. SMITH (L)
S. TEETS (L)
G. WILLIAMS (E)
V. WILSON (L)
R. INGRAM (L)

A/T IND
BRAITMAN
SALTZMAN
MELTZ

PLANS
MCDONALD
CHAPMAN
DUBE (Ltr)
E. COUPE
PETERSON
HARTFIELD (2)
KLECKER
EISENHUT
WIGGINTON

misc (4)

EXTERNAL DISTRIBUTION

1 – LOCAL PDR Cedar Rapids, Ia
1 – TIC (ABERNATHY)
1 – NSIC (BUCHANAN)
1 – ASLB
1 – Newton Anderson
14 – ACRS ~~HOLDING~~/SENT TO L.A. Teets

(1)(2)(10) – NATIONAL LABS
1 – W. PENNINGTON, Rm E-201 GT
1 – CONSULTANTS NEWMARK/BLUME/AGBABIAN

1 – PDR-SAN/LA/NY
1 – BROOKHAVEN NAT LAB
1 – G. ULRIKSON, ORNL
1 – AGMED (RUTH GUSSMAN) Rm B-127 GT
1 – J. D. RUNKLES, Rm E-201 GT

IOWA ELECTRIC LIGHT AND POWER COMPANY

General Office

CEDAR RAPIDS, IOWA

DUANE ARNOLD ENERGY CENTER
PALO, IOWA
FEBRUARY 26, 1975
DAEC-75-72

RECEIVED
MAR 6 1975

Mr. Edson G. Case, Acting Director
Office of Nuclear Reactor Regulation
Nuclear Regulatory Commission
Washington, D. C. 20545

SUBJECT: Scram Discharge Volume Level Switches

REFERENCE: General Electric letter to Mr. E. Case, USAEC, dated August 16, 1974, Subject: Scram Discharge Volume Level Switch.

Dear Mr. Case:

This letter is to advise you that replacement of the self-equalizing float type level switches in the scram discharge volume, in accordance with the recommendations of the referenced letter, was completed on February 13, 1975. The replacement level switches are not subject to the sinking phenomena explained in the referenced letter.

Following installation, the replacement switches were hydrostatically tested at 1250 psig, calibrated, and functionally tested.

Very truly yours,

G. G. Hunt
Chief Engineer
Duane Arnold Energy Center

DLW:GGH:bh

CC: J. A. Wallace
E. L. Hammond
J. H. Gebert
B. R. York
D. L. Wilson
File: A-104

DOCK.
3-6-75
U.S. NUCLEAR REGULATORY COMMISSION

2502