

**AEC DISTRIBUTION FOR PART 50 DOCKET MATERIAL
(TEMPORARY FORM)**

CONTROL NO: 5799

FILE: MISU

FROM: Iowa Electric Light & Power Co. Cedar Rapids, Iowa G. G. Hunt		DATE OF DOC 6-13-74	DATE REC'D 6-24-74	LTR X	TWX	RPT	OTHER
TO: James Keppler		ORIG 1 signed	CC	OTHER	SENT AEC PDR XXX SENT LOCAL PDR XXX		
CLASS	UNCLASS	PROP INFO	INPUT	NO CYS REC'D	DOCKET NO:		
	XXX			1	50-331		

DESCRIPTION:

Ltr furn info re surveillance test procedure #48A003, Standby Diesel Generators Fuel Tests and Data Collection.....

ENCLOSURES:

**ACKNOWLEDGED
DO NOT REMOVE**

PLANT NAME: DUANE ARNOLD

FOR ACTION/INFORMATION 6-26-74

✓ BUTLER (L) W/ 9 CYS	SCHWENCER (L) W/ CYS	ZIEMANN (L) W/ CYS	REGAN (E) W/ CYS
CLARK (L) W/ CYS	STOLZ (L) W/ CYS	DICKER (E) W/ CYS	W/ CYS
DARR (L) W/ CYS	VASSALEO (L) W/ CYS	KNIGHTON (E) W/ CYS	W/ CYS
KNIEL (L) W/ CYS	PURPLE (L) W/ CYS	YOUNGBLOOD (E) W/ CYS	W/ CYS

INTERNAL DISTRIBUTION

✓ REG FILE	TECH REVIEW	DENTON	LIC ASST	A/T IND
✓ AEC PDR	HENDRIE	GRIMES	DIGGS (L)	BRAITMAN
✓ OGC	SCHROEDER	GAMMILL	GEARIN (L)	SALTZMAN
MUNTZING/STAFF	MACCARY	KASTNER	GOULBOURNE (L)	B. HURT
CASE	KNIGHT	BALLARD	KREUTZER (E)	
GIAMBUSSO	PAWLICKI	SPANGLER	LEE (L)	<u>PLANS</u>
BOYD	SHAO		✓ MAIGRET (L)	MCDONALD
MOORE (L)(LWR-2)	STELLO	<u>ENVIRO</u>	REED (E)	CHAPMAN
✓ DEYOUNG (L)(LWR-1)	HOUSTON	MULLER	SERVICE (L)	DUBE w/input
SKOVHOLT (L)	NOVAK	DICKER	SHEPPARD (L)	E. COUPE
GOLLER (L)	ROSS	KNIGHTON	SLATER (E)	
P. COLLINS	IPPOLITO	YOUNGBLOOD	SMITH (L)	D. THOMPSON (2)
DENISE	TEDESCO	REGAN	TEETS (L)	KLECKER
✓ REG OPR	LONG	PROJECT MGR	WILLIAMS (E)	EISENHUT
FILE & REGION (3)	LAINAS	<u>ST. MARY</u>	WILSON (L)	
MORRIS	BENAROYA	HARLESS		
STEELE	VOLLMER			

EXTERNAL DISTRIBUTION


✓ 1 - LOCAL PDR CEDAR RAPIDS, IOWA			
✓ 1 - TIC (ABERNATHY)	(1)(2)(10)-NATIONAL LABS		1-PDR-SAN/LA/NY
✓ 1 - NSIC (BUCHANAN)		1-ASLBP(E/W Bldg, Rm 529)	1-BROOKHAVEN NAT LAB
1 - ASLB		1-W. PENNINGTON, Rm E-201 GT	1-G. ULRIKSON, ORNL
1 - P. R. DAVIS		1-B&M SWINEBROAD, Rm E-201 GT	1-AGMED (RUTH GUSSMAN)
✓ 16 - ACRS HOLDING		1-CONSULTANTS	Rm B-127 GT
Sent to Lic Asst Maigret 6-26-74		NEWMARK/BLUME/AGBABIAN	1-RD..MUELLER, Rm F-309
			GT

IOWA ELECTRIC LIGHT AND POWER COMPANY

General Office

CEDAR RAPIDS, IOWA
DUANE ARNOLD ENERGY CENTER
PALO, IOWA
JUNE 13, 1974
DAEC - 74 - 224

Mr. James Keppler, Director
Regulatory Operations Regional Office
U. S. Atomic Energy Commission
799 Roosevelt Road
Glen Ellyn, Illinois 60137



SUBJECT: License DPR-49, Duane Arnold Energy Center, Unit, Specification 4.8.A.1.d of Appendix A to the Operating License.

REFERENCE: DAEC Surveillance Test Procedure No. 48A003, Standby Diesel Generators Fuel Tests and Data Collection.

FILE: A-110
A-117

Dear Mr. Keppler:

This letter is to report to you with respect to certain Technical Specification Surveillance requirements at the DAEC.

Problem

Specification 4.8.A.1.d states, "Once a month a sample of diesel fuel shall be checked for viscosity, water and sediment. The values for viscosity, water and sediment shall be within the acceptable limits specified in Table 1 of ASTM D975-68 and logged. On May 25, 1974, while reviewing the surveillance test results for April it was noted that Surveillance Test Procedure No. 48A003 covering the above noted requirement was not performed.

Investigation

The subject surveillance test prior to the month of April was performed by the Operations Group. Beginning in April the Radiation Protection Group (Chemistry) was to assume responsibility for performing the test, but due to a misunderstanding on when the transition was to take place the surveillance test was not performed.

JUN 7 1974

REGULATORY DOCKET FILE COPY

5799

Corrective Actions

Personnel responsible for conducting surveillance tests are now knowledgeable of which tests are in their area of responsibility.

Very truly yours,



G. G. Hunt
Chief Engineer
Duane Arnold Energy Center

OCS/GGH/bh

- CC: John O'Leary
Washington, D.C.
C. W. Sandford
J. A. Wallace
E. L. Hammond
B. R. York
D. L. Wilson
H. W. Rehrauer - Chairman, Safety Committee
L. D. Root
J. R. Newman
B. L. Hopkins
O. C. Schellberg