	DUANE ARNOLD ENERGY CENTER	Page		1	of		73
TITLE:	INSERVICE TESTING PROGRAM						
		Date	04,	/01/8	7	Rev.	8

DUANE ARNOLD ENERGY CENTER

INSERVICE TESTING PROGRAM

APPROVED BY: R. E. He TUTUL

PLANT PERFORMANCE SUPERVISOR

4-30-87

DATE

APPROVED BY:

Kozman NGINEERINO SUPERVISOR SYST

DATE

AY 87

APPROVED BY:

REVIEWED BY:

DLM

PLANT SUPERINTENDENT - NUCLEAR

OPERATION'S COMMITTEE CHAIRMAN

DATE

8705060269 PDR ADDC/ DODDS1

Effective Date: MAY 1, 1987

	i			
DUANE ARNOLD ENERGY CENTER	Page	2	of	73
TITLE: INSERVICE TESTING PROGRAM	Date O	4/01/8	87 R	ev. 8

.

List of Effective Pages

TITLE: Duane Arnold Energy Center Inservice Testing Program

Page Number	Revision	Date
IST Program 1 - 73	8	04-01-87
Appendix A 1 - 4	8	04-01-87
Appendix B 1 - 69	8	04-01-87
Appendix C 1	8	04-01-87
Appendix D 1-3	8	04-01-87

DUANE ARNOLD ENERGY CENTER

TITLE: INSERVICE TESTING PROGRAM

Date 04/01/87 Rev. 8

73

Iowa Electric Light and Power Company Duane Arnold Energy Center (Docket No. 50-331)

ASME INSERVICE TESTING PROGRAM

FOR

PUMPS AND VALVES

RECORD OF REVISIONS

REVISION

DATE

Original	March 1, 1978
Rev. 1	October, 1978
Rev. 2	May 1, 1980
Rev. 3	November 1, 1980
Rev. 4	January 1, 1983
Rev. 5	December 23, 1983
Rev. 6	August 1, 1984
Rev. 7	November 1, 1985
Rev. 8	April 1, 1987

DUANE ARNOLD ENERGY CENTER

TITLE: INSERVICE TESTING PROGRAM

TABLE OF CONTENTS

	Page
Title Page	1
List of Effective Pages	2
Record of Revisions	3
Table of Contents	4
List of Tables	5
List of Figures	6
1.0 INTRODUCTION	7
2.0 TESTING PROGRAM FOR PUMPS	8
2.1 General Information	8
 2.1.1 Applicable Code 2.1.2 Pump Program Tables 2.1.3 Measurement of Test Quantities 2.1.4 Allowable Ranges of Test Quantities 2.1.5 Bearing Lubricant 2.1.6 Instrument Accuracy 	8 9 9 9 9
2.2 Relief Requests for Pump Testing Program	10
3.0 TESTING PROGRAM FOR VALVES	23
 3.1 General Information 3.2 Deferred Testing 3.3 Valve Program Table 3.4 Relief Requests for Valve Testing Program 	23 23 23 29
Appendix A - Pump Testing Program	
Appendix B - Valve Testing Program	
Appendix C - ASME Letter	
Appendix D - Cold Shutdown Testing Justifications	

DUANE ARNOLD ENERGY CENTER	Page	5	of	73
TITLE: INSERVICE TESTING PROGRAM			0.7	
	Date (04/01/	87	Rev. 8

ī

LIST OF TABLES

Table	Title	Page
3.1-1	Inservice Valve Test	26,27
3.1-2	Test Frequency	28

		L			
	DUANE ARNOLD ENERGY CENTER	Page	6	of	73
TITLE:	INSERVICE TESTING PROGRAM				
		Date 04	/01/8	7 F	Rev. 8

LIST OF FIGURES

Figure

<u>Title</u>

Page

PR-5.1	Alternate Testing Approach	for
	Determination of Hydraulic	Change 14

	DUANE ARNOLD ENERGY CENTER	Page	7	of		73
TITLE:	INSERVICE TESTING PROGRAM					
		Date	04/01	./87	Rev.	8

1.0 INTRODUCTION

Revision 8 of the Duane Arnold Energy Center (Unit 1) ASME Inservice Testing Program for Pumps and Valves will be in effect through February 1, 1995, the end of the second 120-month (10-year) inspection interval, unless changed for other reasons. The program will be updated prior to the start of the third inspection interval in accordance with the requirements of 10CFR 50.55a(g).

This document outlines the inservice testing (IST) program for Duane Arnold Energy Center, based on the requirements of Section XI of the ASME Boiler & Pressure Vessel Code, 1980 Edition through the Winter 1981 Addenda. All references to IWP or IWV in this document correspond to Subsections IWP or IWV, respectively, of ASME Section X1, 1980 Edition through the Winter 1981 Addenda unless otherwise noted.

- Title 10, Code of Federal Regulations, Part 50, paragraph 50.55a(g)
- NRC Regulatory Guides-Division 1
- Standard Review Plan 3.9.6, "Inservice Testing of Pumps and Valves"
- Division 1 (Draft) Regulatory Guide and Value/Impact Statement,
 "Identification of Valves for Inclusion in Inservice Test Programs"
- "NRC Staff Guidance for Preparing Pump and Valve Testing Programs and Associated Relief Request," January 1978
- Updated Final Safety Analysis Report, Duane Arnold Energy Center
- . Technical Specifications, Duane Arnold Energy Center
- Safety Evaluation via D. B. Vassallo's letter to L. Liu dated September 26, 1983.

The inservice tests identified in this program will verify the operational readiness of pumps and valves whose functions are required to mitigate the consequences of an accident or to bring the reactor to a cold shutdown condition. The ISI classification of each pump and valve matches the ISI classification indicated on the P&IDs excepting those pumps and valves in the IST boundaries that are identified as non-classed (NC).

INSERVICE TESTING PROGRAM

Date 04/01/87 Rev. 8

73

2.0 TESTING PROGRAM FOR PUMPS

- 2.1 General Information
- 2.1.1 Applicable Code

TITLE:

This Inservice Testing Program for pumps meets the requirements of Subsection IWP of Section XI of the ASME Boiler and Pressure Vessel Code, 1980 Edition through the Winter of 1981 Addenda. Where these requirements are determined to be impractical, specific requests for relief are included in Section 2.2.

2.1.2 Pump Program Tables

Appendix A lists the pumps included in the Duane Arnold Energy Center IST Program. Data contained in these tables identifies those pumps subject to inservice testing with the respective inservice test quantities, testing intervals, and any applicable remarks. The column headings are explained below:

- PUMP NUMBER: The pump identification number
- <u>PUMP NAME</u>: The system of which the pump is a component.
- <u>CLASS:</u> The ISI classification of the pump
- <u>P&1D:</u> The DAEC drawing number for the P&ID referring to the pump
- <u>COOR:</u> The drawing coordinate location of the pump on the P&ID
- SPEED, INLET PRES, DIFF PRES, FLOWRATE, VIBRATION

AND BEARING TEMP: Inservice test quantities to be measured. When the character "Y" appears in a particular test quantity column, that quantity will be measured during inservice testing in accordance with Subsection IWP. If a modified test is planned or if the character "N" appears in a particular test quantity column, a request for relief number will be referenced. Requests for relief are identified PR-XX. Requests for relief are included in Section 2.2.

- TEST INTERVAL: The frequency of testing.
- <u>REMARKS</u>: Remarks in the IST Program are coded as NOTE 001, NOTE 002, etc.

•

-	DUANE ARNOLD ENERGY CENTER	Page	9	of	73
TITLE:	INSERVICE TESTING PROGRAM	Date 04	/01/8	7 R	ev. 8

2.1.3 Measurement of Test Quantities

- SPEED: Per Subarticle IWP-4400, shaft speed measurements are not applicable (NA) for pumps directly coupled to synchronous or induction-type drivers. For variable speed pumps, the pump speed is set at the reference speed per Subarticle IWP-3100.
- INLET PRESSURE: For pumps taking suction from a tank or the residual heat removal (RHR) service water complex basin, inlet pressure may be calculated (using appropriate correction factors) from a measured tank or basin level. (See Relief Request No. PR-4) All other inlet pressure measurements will be taken using pressure instruments at or near the pump inlet.
- <u>DIFFERENTIAL PRESSURE</u>: Differential pressure will be calculated from inlet and discharge pressure measurements or measured directly from differential pressure instrumentation.
- <u>FLOWRATE:</u> Pump flowrate will be measured by direct reading based on inline flow instrumentation or will be calculated from tank level change over an elapsed time interval.
- VIBRATION: Pump vibration will be measured when accessibility allows.
- 2.1.4 Allowable Ranges of Test Quantities

The allowable ranges specified in Table IWP-3100-2 will be used for differential pressure, flow, and vibration measurements except as discussed in PR-8 and PR-13. In some cases, the performance of a pump may be adequate to fulfill its safety function even though there is some parameter variation outside of the allowable ranges as set forth in Table IWP-3100-2. Should a measured test quantity fall outside the allowable range, an expanded allowable range may be determined, on a case basis, in accordance with ASME Code interpretation XI-1-79-19.

2.1.5 Bearing Lubricant

As specified in Table IWP-3100-1, pump bearing lubricant level or pressure will be observed during inservice testing, when practical.

2.1.6 Instrument Accuracy

Instrument accuracies for the DAEC IST Program will generally conform to those given in Table IWP-4110-1. In some cases, relief has been requested from the requirements of Table IWP-4110-1. (See Relief Requests Nos.-PR-7, PR-11 and PR-12).

DUANE ARNOLD ENERGY CENTER	Page	10	of		73
TITLE: INSERVICE TESTING PROGRAM	Date	04/01/8	37	Rev.	8

SECTION 2.2

RELIEF REQUESTS FOR PUMP TESTING PROGRAM

	DUANE ARNOLD ENERGY CENTER	Page	11	of	73
TITLE:	INSERVICE TESTING PROGRAM				
		Date	04/01/8	7	Rev. 8

RELIEF REQUEST NO. PR-1

PUMP NUMBER:

DIESEL FUEL OIL TRANSFER 1P-44A, B

SECTION XI REQUIREMENT:

Measure pump vibration amplitude quarterly. (IWP-3100).

BASIS FOR RELIEF:

The diesel fuel oil pumps and motors are submerged inside the diesel fuel oil tank (IT-35) and thus are inaccessible for the purpose of taking such measurements.

ALTERNATE TESTING:

No alternate testing is proposed.

12

of

73

RELIEF REQUEST NO. PR-4

PUMP NUMBER:

RHR SERVICE WATER 1P-22A, B, C, D ESW 1P-99A, B RIVER WATER 1P-117A, B, C, D DIESEL FUEL OIL TRANSFER 1P-44A, B STANDBY LIQUID CONTROL 1P-230A, B

SECTION XI REQUIREMENT:

Measure pump inlet pressure before starting the pump and during the test. (Table IWP-3100-1)

BASIS FOR RELIEF:

The above listed pumps, except for 1P-230 A & B, are submerged and have inlet pressures which correspond to levels of the wet pit, the river, or diesel oil storage tank. Because these levels remain relatively constant before and during the test, only one measurement per test is necessary.

In the case of the standby liquid control (SBLC) pumps, 1P-230 A & B, no gauge is installed at the pump suction and suction pressure is assumed to be equivalent to the static head corresponding to the average height of test tank level above the pump suction.

ALTERNATE TESTING:

One inlet pressure, based on wet pit, river, or oil tank level, will be calculated per test for pumps other than 1P-230 A & B.

One suction pressure for the SBLC Pumps will be calculated from the average test tank level during the test.

RELIEF REQUEST NO. PR-5

PUMP NUMBER:

All pumps in Program

SECTION XI REQUIREMENT:

Reference values shall be at points of operation readily duplicated during subsequent inservice testing. (IWP-3110)

BASIS FOR RELIEF:

Operating experience has shown that flowrates (independent variables during inservice performance testing) cannot be readily duplicated with the present flow control systems. Efforts to exactly duplicate reference values would require excessive valve manipulation which could ultimately result in damage to valves or operators.

ALTERNATE TESTING:

DAEC will implement two alternate means of measuring pump performance.


Alternate 1:

Reference values for flowrate (Qr) and differential pressure (dPr) will be established during the reference value tests. In lieu of duplicating Qr during subsequent inservice performance tests, a flowrate (Q1), lower than Qr, will be obtained and recorded along with the corresponding differential pressure (dP1). Next, a flowrate (Qh), higher than Qr, will be obtained and recorded along with its corresponding differential pressure (dPh). These two points, (Q1, dP1) and (Qh, dPh), define a small portion of the pump curve which includes the point Qr (See Figure Pr-5.1). Using linear interpolation between the two points, a differential pressure (dP) will be computed from Qr. This computed value for dP will be recorded and compared to the reference differential pressure (dPr) per Table IWP-3100-2.


The alternate testing procedure described above assumes that the pump curve is nearly linear between Ql and Qh. Procedural limits for Ql and Qh have been established and individual pump curves have been analyzed to ensure near linearity between Ql and Qh.

Alternate 2:


During pump reference tests, a reference pump curve will be established or the manufacturer's pump curve will be confirmed. In lieu of duplicating a specific flowrate (Qr) during subsequent inservice performance tests, a flowrate (Qa) will be obtained and recorded along with the corresponding differential pressure (dPa). The differential pressure measurement (dPa) will be compared to the theoretical differential pressure (dP+) corresponding to the measured flowrate (Qa) on the pump curve and evaluated per the requirements of Table IWP-3100-2.



graph







Flow Rate

Figure PR-5.1 Alternate Testing Approach for Determination of Hydraulic Change

RELIEF REQUEST NO. PR-7

PUMP NUMBER:

CORE SPRAY 1P-211A & B HIGH PRESSURE COOLANT INJECTION (HPCI) 1P-216

SECTION XI REQUIREMENT:

Instrument accuracy shall be within the limits of Table IWP-4110-1. (IWP-4110)

BASIS FOR RELIEF:

The instrumentation loop accuracies listed below do not meet the requirements of Table IWP-4110-1.

FUNCTION	LOOP ACCURACY (<u>+</u> %)
Core Spray Pump Disc. Press	2.24
HPCI Pump Disc. Press	2.24
HPCI Pump Suction Press.	2.06
HPCI Pump Turbine Speed	2.26

Suitable 1E-qualified instrument loop elements needed to replace those existing that contribute to the problem are not commercially available at this time.

ALTERNATE TESTING:

Inservice test measurements of pressure and speed, as discussed above, will be made using instruments with loop accuracies that are less than or equal to \pm 2.26 percent of full scale.

RELIEF REQUEST NO. PR-10

PUMP NUMBER:

DIESEL FUEL OIL TRANSFER 1P-44A, B

SECTION XI REQUIREMENT:

Pump test results shall be analyzed per Subarticle IWP-3200.

BASIS FOR RELIEF:

The ASME recognizes that the characteristics of systems containing other than steam or water (eg. fuel oil) may not necessarily lend themselves to the type and detailed test requirements as specified by Subsection IWP. This is so stated in the ASME response to WPPSS inquiry, File no. BC 77-666/NI 77-371 dated 1/8/79. (See Appendix C) In cases where test data is erratic or questionable, strict compliance with the Section XI requirements will likely result in unnecessary pump maintenance and excessive testing of the fuel oil pumps and the emergency diesel generators.

ALTERNATE TESTING:

Analysis of the quarterly test data will be based on Subarticle IWP-3200 or Relief Request PR-13. In those cases where the test results are obviously erratic or misleading, alternate acceptance criteria will be applied.

RELIEF REQUEST NO. PR-11

PUMP NUMBER:

All pumps in Program.

SECTION XI REQUIREMENT:

The full-scale range of each instrument shall be three times the reference value or less. (IWP-4120)

BASIS FOR RELIEF:

The commercially available instruments used for measuring pump vibration do not provide range selections that guarantee adherence to the range limitations per Subsubarticle IWP-4120. Specifically, for the instrument used at DAEC, the scale ranges are 0 - 0.3, 0 - 1.0, 0 - 3.0, 0 - 10, and 0 - 30 mils or in/sec. Vibration measurements will be made with the instrument range selection at the lowest possible scale that includes the measured parameter.

ALTERNATE TESTING:

No alternate method for vibration monitoring is proposed.

Date 04/01/87 Rev. 8

RELIEF REQUEST NO. PR-12

PUMP NUMBER:

CORE SPRAY 1P-211A, B RESIDUAL HEAT REMOVAL SERVICE WATER 1P-22A, B, C, D HIGH PRESSURE COOLANT INJECTION 1P-216

SECTION XI REQUIREMENT:

The full-scale range of each instrument shall be three times the reference value or less. (IWP-4120)

BASIS FOR RELIEF:

In several instances the accuracy of installed flowrate instrumentation is unacceptable with respect to the requirements of Subsubarticle IWV-4110 and from the practical aspect of test result repeatability. In these instances, temporary instrumentation is used to replace inaccurate panel meters. However, the available electronic instruments suitable for this service generally do not meet the range limitations imposed by Subsubarticle IWP-4120 in that the instrument ranges exceed the respective reference values by greater than a factor of 3. Since the accuracies of the instruments in question are based on the actual indicated reading and not on the full-scale range of the instruments, this is considered to be acceptable. The specific systems affected are listed below:

SYSTEM	REF. VALUE	(1) INST. RANGE	(1) ACCURACY
Core Spray	30ma	0 - 200ma	+ 0.325 ma
RHR Service Water	25ma	0 - 200ma	+ 0.288 ma
H. P. Coolant Inj.	50mv	0-200mv	<u>+</u> 0.15 mv

(1) Based on FLUKE Model 8024B Digital Multimeter

ALTERNATE TESTING:

No alternate method of measurement is proposed.

RELIEF REQUEST NO. PR-13

PUMP NUMBER:

All pumps in Program.

SECTION XI REQUIREMENT:

The allowable ranges of inservice test quantities in relation to the reference values are tabulated in Table IWP-3100-2. This table limits the acceptable performance of each pump dependent variable (flowrate or differential pressure) to a maximum of 103 percent of the respective reference value. If the test parameter should exceed this limit, it shall be declared inoperative and removed from service. (IWP-3200)

BASIS FOR RELIEF:

The requirement to declare a pump inoperative when a test parameter exceeds the reference value by 3 percent is not technically justified, sound engineering judgement, nor acceptable plant operating practice for the following reasons:

- * Indiscriminately declaring safety system pumps inoperative results in excessive and unneeded testing of other plant safeguard systems and components. Such testing could ultimately detract from the overall reliability of the plant safety systems. In addition, unwarranted testing unnecessarily adds to the burden of the operations force and dilutes efforts focused on the performance of their primary duties. Also, operators are subjected to additional, and unnecessary radiation exposure.
- * The case where a test parameter exceeds the reference value is not necessarily indicative of pump degradation. It may merely signify that the reference value is probably at the lower side of the statistical scatter of the test data and the specific test in question is on the upper side. Note that the reference values are subject to the same elements of statistical error associated with any other individual test.
- * The 3-percent limitation is overly restrictive when compared to the accuracy of the instrumentation used to gather the test data. Analysis has shown that, in order to consistantly remain below the 3-percent limit, instrument loop accuracies in the range 0.5 to 0.75 percent would be required. This represents a significantly more restrictive requirement than that established by Paragraph IWP-4110 (+ 2 percent).
- * Power plant operating systems are not configured in a manner that provides the laboratory-type conditions demanded to meet the repeatability implied by the 3-percent restriction. Several of the tests require throttling with large gate or butterfly valves using remote manual control. Thus, non-quantifiable system flow conditions are created that are certain to affect measured test quantities.

	DUANE ARNOLD ENERGY CENTER	Page	20	of		73
TITLE:	INSERVICE TESTING PROGRAM	Date	04/01/8	87	Rev.	8

RELIEF REQUEST NO. PR-13 (CONT)

- * To ensure that reference values do not reflect operations at the lower end of the performance spectrum and, thus, ultimately be reflected in frequently exceeding the upper performance limits as a result of instrument drift, all related instrumentation is calibrated on a frequent basis.
- * This requirement provides no additional measure of reliability to the equipment.
- * When the upper limits are exceeded, the only reasonable way of correcting the inoperative condition is to conduct an analysis to ensure that the pump is indeed operable and capable of meeting its intended function. When this is done, in accordance with Subsubarticle IWP-3230 (c), a new reference value must be established. Due to the test conditions and methods of testing at DAEC, any change in the reference point eliminates the correlation of future test results with past pump performance. Because, the usefulness of any past data in determining a trend for pump performance is essentially eliminated a primary goal and basis for the inservice testing program could be jeopardized.

ALTERNATE TESTING:

Pumps will be tested in accordance with Subsection IWP with the following exceptions:

- a) The Required-action range (HIGH) will be eliminated for test quantities flowrate and differential pressure; and
- b) The Alert-range (HIGH) will be above a value equal to 105 percent of the reference value for test quantities of flowrate and differential pressure.

RELIEF REQUEST NO. PR-14

PUMP NUMBER:

All pumps in Program.

SECTION XI REQUIREMENT:

The temperature of all centrifugal pump bearings outside the main flow path shall be measured at points selected to be responsive to changes in the temperature of the bearings. (IWP-4310)

BASIS FOR RELIEF:

- * Bearings of the selected pumps addressed in the DAEC IST Program are water cooled -- cooling water supplied from the flowstream or the Emergency Service Water System. Thus, bearing temperature measurements are highly dependent on the temperature of the cooling medium.
- * The data associated with bearing temperatures taken at one-year intervals provides little statistical basis for determining the incremental degradation of a bearing or any meaningful trending information or correlation.
- * Vibration measurements are a significantly more reliable indication of pump bearing degradation than are temperature measurements. All pumps addressed by this relief request are subjected to vibration measurements on a quarterly basis in accordance with Subarticle IWP-4500.
- * Although excessive bearing temperature is an indication of an imminent or existing bearing failure, it is highly unlikely that such a condition would go unnoticed during routine monthly and quarterly surveillance testing since it would manifest itself in other obvious indications such as audible noise, reduced pump hydraulic performance, unusual vibration, increased motor current, etc.
- * The gain from taking bearing measurements, which in most cases would be done locally using portable instruments, cannot offset the cost in terms of dilution of operator effort, distraction of operators from other primary duties, excessive operating periods for pumps, and personnel radiation exposure.

ALTERNATE TESTING:

None

DUANE ARNOLD ENERGY	CENTER
---------------------	--------

Date 04/01/87 Rev. 8

3.0 INSERVICE TESTING PROGRAM FOR VALVES

3.1 General Information

This testing program for valves meets the requirements of Subsection IWV of Section XI of the ASME Boiler and Pressure Vessel Code, 1980 Edition through the Winter 1981 Addenda. Where these requirements are determined to be impractical, specific requests for relief are included in Section 3.2.

3.2 Deferred Testing

When a valve in a redundant system is determined to be inoperable, non-redundant valve(s) in the other train may not be tested (exercised), as required by plant procedures or this Program, but may be tested after the inoperable valve(s) are returned to service.

3.3 Valve Program Table

Appendix B lists all ISI Class 1, 2, 3, and NC valves included in the DAEC IST Program. The following information is included for each valve:

- VALVE NUMBER: The valve identification number.
- P&ID COORDINATE: The valve location coordinates on the P&ID.
- CLASS: The ISI classification of the valve.
- VALVE CATEGORY: The category(s) assigned to the valve based on the definitions per Subarticle IWV-2200. Four (4) separate categories are defined in the Code:
 - <u>CATEGORY A</u> Valves for which seat leakage is limited to a specific maximum amount in the closed position for fulfillment of their safety function.
 - <u>CATEGORY B</u> Valves for which a specific amount of leakage in the closed position is not measured but which require stroke testing to verify their ability to fulfill their safety function.
 - <u>CATEGORY C</u> Valves which are self-actuating in response to some system characteristic, such as pressure (relief valves) or flow direction (check valves).
 - <u>CATEGORY D</u> Valves which are actuated by an energy source capable of only a single operation (eg. explosively-actuated valves).
- VALVE SIZE: The nominal size of the valve in inches.

DUANE ARNOLD ENERGY CENTER	Page	23	of	73
TITLE: INSERVICE TESTING PROGRAM	Date	04/01/8	37 R	ev. 8
• <u>VALVE TYPE:</u> The valve body design as ind abbreviations:	licated by t	he fol	lowing	ļ
ANGLE			ANG	

	ANG
BALL	BAL
BUTTERFLY	BTF
CHECK	СК
EXCESS FLOW CHECK	XFC
GATE	GA
GLOBE	GL
NEEDLE	NDL
NOTCHED GLOBE	NGL
PLUG	PLG
RELIEF	RV
RUPTURE DIAPHRAGM	RPD
SAFETY	SV
SHEAR	SH
STOP CHECK	SCK
3-WAY	3WY
4-WAY	4WY

• ACTUATOR TYPE: The type of valve actuator as indicated by the following abbreviations:

MOTOR OPERATOR	MO
AIR-PILOT OPERATOR	AP
AIR OPERATOR	AO
SOLENOID OPERATOR	S0
HYDRAULIC OPERATOR	HO
EXPLOSIVE ACUTATOR	EXP
MANUAL	М
SELF ACTUATED & MANUAL OPERATED	MSA
SELF ACTUATED	SA
SELF ACTUATED & MOTOR OPERATED	SAM
SELF ACTUATED & PILOT OPERATED	SAP
SELF ACTUATED, TESTABLE CHECK	SAT

	DUANE ARNOLD ENERGY CENTER	Page	24	of	73
TITLE:	INSERVICE TESTING PROGRAM	Date 04	4/01/8	7	Rev. 8

• NORMAL POSITION: The position of the valve during normal plant , operation, specified as follows:

0 C O/KL O/FO	Normally Open Normally Closed Normally Open/Key Locked Normally Open/Fail Open
0/FC	Normally Open/Fail Closed Normally Open/Key Locked and
07 KU	Fail Open
C/KL	Normally Closed/Key Locked
C/FO	Normally Closed/Fail Open
C/FC	Normally Closed/Fail Closed
C/KC	Normally Closed/Key Locked and
	Fail Closed
NE	Normally Energized
ND	Normally De-energized

Valves with fail-safe positions are indicated as either FO-fail open or FC-fail closed.

- TEST: The test(s) that will be performed to fulfill the requirements of Subsection IWV. The test definitions and abbreviations used are identified in Table 3.1-1.
- <u>TEST FREQUENCY</u>: The frequency at which the required tests will be performed. Test frequencies are defined in Table 3.1-2.
- <u>MAXIMUM STROKE TIME</u>: The limiting maximum value of full stroke time, in seconds, for power-operated values in Category A or B.
- MAXIMUM LEAKAGE: The leakrate acceptance criteria for valves are set forth in the plant records.
- <u>RELIEF REQUEST</u>: The reference to a relief request in Section 3.2 for valve testing. Requests for relief are identified as VR-XX.
- <u>REMARKS:</u> Remarks in the IST Program are coded as NOTE 001, NOTE 002, etc.

DUANE ARNOLD ENERGY CENTER

TITLE: INSERVICE TESTING PROGRAM

•

Page 25 of 73

Date 04/01/87 Rev. 8

·	TABLE 3.1-1:	INSERVICE VALVE TESTS
TEST	TEST NAME	TEST DESCRIPTION
AT-1	Type C leaktest	Containment isolation valves will be Type C leak tested in accordance with DAEC Technical Specifications, Section 4.7.A.2.c and 10CFR50 Appendix J.
AT-2	Excess flow check valve test	Excess flow check valves will be tested for operability in accordance with DAEC Technical Specifications, Section 4.7.D.1.d.
AT-4	Vacuum breaker leaktest	The suppression chamber-drywell vacuum breakers will be leak tested in accordance with DAEC Technical Specification, Section 4.7.A.4.d.
AT - 5	Pressure isolation valve leaktest	Those valves so designated will be leak tested in accordance with Subsubarticle IWV-3420 per the NRC SER dated 9/26/83.
AT-6	Accumulator check valve test	Leaktesting of air/nitrogen accumulator check valves.
BTPC	Partial-stroke exercise test to the CLOSED position (IWV-3412)	Exercise test in the closed direction, verified by stroke time measurement, will be performed to confirm partial stroke capacity from intermediate position to the fully closed position.
BTO	Full-stroke exercise test to the OPEN position (IWV-3412 and 3413)	Exercise testing in the open direction, verified by stroke time measurement, will be performed to confirm the full stroke capability of each valve. The stroke direction is based on the direction the valve disk must travel to fulfill a safety function.
BTC	Full-stroke exercise test to the CLOSE position (IWV-3412 and 3413)	Exercise testing in the closed direction, verified by stroke time measurement, will be performed to confirm the full stroke capability of each valve. The stroke direction is based on the direction the valve disk must travel to fulfill a safety function.
BTD	Full-stroke exercise test to de-energize position	Solenoid valves, which direct control air to main air-operated valves, are shown to stroke to their de-energized position by the proper operation of the associated main valves.

DUANE ARNOLD ENERGY CENTER

TITLE: INSERVICE TESTING PROGRAM

٠

Date 04/01/87 Rev. 8

73

TABLE 3.1-1: INSERVICE VALVE TESTS

TEST	TEST NAME	TEST DESCRIPTION
BTE	Full-stroke exercise test to energized position	Solenoid valves, which direct control air to main air-operated valves, are shown to stroke to their energized position by the proper operation of the associated main valves.
CT-CO	Check valve exercise test to OPEN position (IWV-3522)	Check valves will be exercised from the fully closed to the open positions. Verification of safety basis system flow through check valve shall be an adequate demonstration that the valve is open. The stroke direction tested (open) is based on the direction the valve disk must travel to fulfill a safety function.
CT-CC	Check valve exercise test to CLOSED position (IWV-3522)	Check valves will be exercised from the open to the closed positions. The stroke direction tested (closed) is based on the direction the valve disk must travel to fulfill a safety function.
CT-CPO	Check valve partial- stroke exercise test to the OPEN position (IWV-3522)	Check valves will be tested from the closed to a partially-open position.
CT-SP	Safety/relief valve set point verification test (IWV-3510)	Relief and safety valve set points will be verified in accordance with IWV-3510.
DT	Explosive valve test (IWV-3610 and 3620)	Explosively-actuated valves will be tested in accordance with IWV-3610.
FST	Fail-safe test (IWV-3415)	Valves with fail-safe actuators will be tested to verify proper fail-safe operation upon loss of actuator power.
PIT	Position indication checks (IWV-3300)	Valves with position indicators will be checked to verify that remote valve indicators accurately reflect valve position.

TABLE 3.1-2: TEST FREQUENCY . (1)

TEST FREQUENCY	OPERATIONAL CONDITION	FREQUENCY OF TESTING	
OP	Power operation	At least once per 92 days	
CS	Cold shutdown	See (2) below	
RR	Refueling	Nominally every two years - during reactor refueling	
SP	See appropriate relief request	See appropriate relief request	
5Y	No operational condition limitations	Every five years (see Paragraph IWV-3511). Applies to CT-SP test.	
2Y	No operational condition limitations	Every two years (see Subarticle IWV-3300). Applies to PIT test.	

(1) Operational conditions are defined in DAEC Technical Specifications, page 1.0-3.

- (2) Inservice valve testing will commence within 48 hours of reaching the cold shutdown condition as defined in the DAEC Technical Specifications. Testing not completed before startup may be completed during subsequent cold shutdowns. Valve testing need not be performed more often than once every three months. In the case of extended cold shutdowns, the testing need not be started within the 48-hour limitation. However, in these instances, all valves must be tested prior to startup.
- NOTE: It is expected that the required testing will normally be completed within 96 hours following cold shutdown. However, completion of all valve testing during cold shutdown is not required if plant operating conditions do not permit testing of specific valves.

	DUANE ARNOLD ENERGY CENTER	Page	28	of	73
TITLE:	INSERVICE TESTING PROGRAM				
		Date 04	4/01/8	7	Rev. 8

SECTION 3.4

RELIEF REQUESTS FOR INSERVICE VALVE TESTING PROGRAM

Page 29

Date 04/01/87

of

73

Rev. 8

RELIEF REQUEST NO. VR-1

SYSTEMS:

RHR Service Water

COMPONENTS:

MO-1947 MO-2046

CATEGORY:

В

FUNCTION:

These valves provide a return path for RHR service water from the RHR heat exchangers to the cooling towers. They are normally throttled to maintain a predetermined differential pressure across the RHR heat exchanger tubes and to prevent runout of the RHR service water pumps.

TEST REQUIREMENT:

Category B valves shall be full-stroke exercised as required by IWV-3412.

BASIS FOR RELIEF:

These valves are electrically interlocked with their respective pumps such that they open automatically with pump start and cannot be opened without at least one pump in operation. During system operation, they are only partially opened.

ALTERNATE TESTING:

Each valve will be operated in conjunction with RHR service water pump testing. In lieu of measuring stroke times, the necessary valve disc position and motion will be determined by observing system test parameters (flowrate and pressure) as permitted by IWV-3412(b).

DUANE ARNOLD ENERGY CENTER

TITLE: INSERVICE TESTING PROGRAM

RELIEF REQUEST NO. VR-2

SYSTEMS:

Various

COMPONENTS:

All solenoid and air-pilot operator valves without individual position indication.

CATEGORY:

A & B

FUNCTION:

Solenoid and air-pilot operators are used to control actuators on many valves.

TEST REQUIREMENT:

Stroke time evaluation per Subparagraph IWV-3413 (b).

BASIS FOR RELIEF:

Solenoid and air-pilot valves which control the air supply to a main valve usually do not have indicator lights. However, the operation of the main valve within its stroke time limit implies that the solenoid and/or air-pilot valve is performing satisfactorily.

ALTERNATE TESTING:

For solenoid-operated and air pilot-operated valves which control the air supply to air-operated valves and have no individual position indication, verification that the main valve has stroked to the correct position within its respective time limits will provide adequate evidence that the solenoid or air pilot-operated valve has stroked to its proper position within the required time. When the letters "NA" appear in the stroke time column of the Inservice Testing Program Listing, the valve's stroke time is verified indirectly by the stroke time measurement of its associated main valve.

DUANE ARNOLD ENERGY CENTI

RELIÉF REQUEST NO. VR-3

SYSTEMS:

Residual Heat Removal

COMPONENTS:

V-19-0149 V-20-0082

CATEGORY:

A/C

FUNCTION:

These valves open to provide a pathway for LPCI flow into the recirculation system and close to isolate the RHR system from the high pressure of the recirculation system.

TEST REQUIREMENT:

Check valves shall be exercised at least every 3 months. (IWV-3521)

BASIS FOR RELIEF:

During plant operation, manual stroking of these valves is not possible due to their location inside the drywell and stroking using system flow is precluded by the inability of the RHR pumps to overcome recirculation system pressure. When the plant is in cold shutdown, cooling water flow is normally directed through only one of these valves. While shifting system operation to the idle loop is possible, it is a time consuming and generally unnecessary evolution.

ALTERNATE TESTING:

V-19-0149 and V-20-0082 will be exercised by using a mechanical exerciser on a refueling outage basis.

DUANE ARNOLD ENERGY CENTER	Page	32	of		73
TITLE: INSERVICE TESTING PROGRAM	Date O	4/01/8	37	Rev.	8

RELIEF REQUEST NO. VR-4

SYSTEM:

NUCLEAR BOILER

COMPONENTS:

V-14-1

CATEGORY:

A/C

FUNCTION:

This valve is the reactor feedwater supply inboard isolation valve. It opens for feedwater flow and RCIC injection into the vessel and acts as a containment isolation valve.

TEST REQUIREMENT:

Check valves shall be exercised at least every 3 months. (IWV-3521)

BASIS FOR RELIEF:

It is impractical to exercise this valve during normal plant operation due to the possibility of thermal shock to the reactor vessel feedwater nozzles and spargers and the potential for plant trip due to potentially severe reactor vessel water level transients. It is impractical to exercise this valve during cold shutdown as it is required to remain open for continued operation of the reactor water cleanup system.

ALTERNATE TESTING:

This valve will be exercised closed during each refueling outage and verified open during normal plant operation.

	DUANE ARNOLD ENERGY CENTER	Page	33	of	-	73
TITLE:	INSERVICE TESTING PROGRAM			_	_	_
		Date 04	1/01/8	7	Rev.	8

RELIEF REQUEST NO. VR-5

SYSTEM:

Various

COMPONENTS:

PSV-1988	PSV-2109	PSV-4439A
PSV-2068	PSV-2129	PSV-4439B
PSV-1911	PSV-2223	PSV-4439C
PSV-1952	PSV-2228	PSV-4439D
PSV-2043	PSV-2301	PSV-4439E
		PSV-4439F

CATEGORY:

С

FUNCTION:

These valves provide overpressure protection to the associated system components.

TEST REQUIREMENT:

Safety and relief values shall be tested in accordance with Subsection ${\rm IWV-3510}$.

BASIS FOR RELIEF:

ANSI/ASME OM-1-1981 - Requirements for Inservice Performance testing of Nuclear Power Plant Pressure Relief Devices, was developed to supersede the requirements of Subsubsection IWV-3510. This standard is more definitive and better suited to operational testing than is ASME/PTC 25.3 which is referenced in IWV-3510.

ALTERNATE TESTING:

Safety and relief valves will be tested in accordance with the requirements of ANSI/ASME OM-1-1981.

RELIEF REQUEST NO. VR-6

SYSTEM:

NUCLEAR BOILER

COMPONENTS:

Reactor Relief Valves

Solenoid Valves

PIS No.

PIS No.

PSV-4400 *		SV-4400
PSV-4401		SV-4401
PSV-4402 *		SV-4402
PSV-4405 *		SV-4405
PSV-4406 *		SV-4406
PSV-4407		SV-4407
tomatic Doproccurization	Suct on	(ADS)

*Automatic Depressurization System (ADS)

CATEGORY:

B/C for the relief valves B for solenoid valves

FUNCTIONS:

The functions of the relief valves are to (1) open upon receipt of an ADS signal to blowdown the reactor vessel (for the ADS valves only) and (2) act as primary system safety valves actuating on high system pressure or capable manual actuation from the control room.

The function of the solenoid valves is to energize upon receipt of a manual or ADS actuation signal and, in so doing, vent the poppet valve assembly causing the associated main valves to open.

TEST REQUIREMENT:

Exercise and time valves every three months (BTO).

DUANE ARNOLD ENERGY CENTER

Date 04/01/87 Rev. 8

RELIEF REQUEST NO. VR-6 (continued)

BASIS FOR RELIEF:

Relief is requested from the Section XI required testing frequency of once every three months. Exercising these valves during normal operation would cause primary system pressure spikes and reactor power fluctuations which could lead to a reactor scram.

Relief is also requested from the stroke timing requirements of Section XI. It is impractical to measure stroke times for relief and solenoid valves since the stroke times are on the order of 100 milliseconds. An abrupt change in the turbine bypass valve position will verify that the solenoid and relief valves have satisfactorily performed their function.

NOTE: Stroke timing requirements for the solenoid valves are discussed in Relief Request No. VR-2.

ALTERNATE TESTING:

These valves will be exercised once per operating cycle as specified in DAEC Technical Specifications, Section 4.6.D.3. With reactor pressure >100 psig and turbine bypass flow to the main condenser, each relief valve will be manually opened and verified open by turbine bypass valve position decrease and the response of pressure switches and thermocouples downstream of the relief valves. Stroke times will not be measured.

DUANE	ARNOLD	ENERGY	CENTER
-------	--------	--------	--------

Date 04/01/87 Rev. 8

73

RELIEF REQUEST NO. VR-7

SYSTEM:

Diesel Generator

COMPONENTS:

SV-3261A, SV-3261B SV-3262A, SV-3262B

CATEGORY:

В

FUNCTIONS:

These valves are the air start solenoid valves for the A & B Standby Diesel Generators. When the start sequence for the diesel generators is initiated, these valves open to allow pressurized air stored in air receivers to charge the diesel generator air start headers.

TEST REQUIREMENT:

Exercise and time valves every three months (BTO).

BASIS FOR RELIEF:

Relief is requested for the stoke time requirements of Section XI. It is impractical to measure the stroke time of the air start valves directly, since there is no visible stem movement and the valves have no position indicators.

ALTERNATE TESTING:

Starting the Standby Emergency Diesel Generators using the air start system will be considered demonstration of proper operation of the air start solenoids. Therefore, the air start solenoids will be tested when the diesel generators are tested in accordance with Technical Specification 4.8.A.1.a.1. Technical Specification Section 4.8.A.1.a.1 states that the diesel generators shall be manually started once each month. Each air start solenoid will be exercised during this testing at least quarterly.

Date 04/01/87 Rev. 8

RELIEF REQUEST NO. VR-8

SYSTEM:

NUCLEAR BOILER, REACTOR RECIRCULATION, REACTOR CORE ISOLATION COOLING, CORE SPRAY, HIGH PRESSURE COOLANT INJECTION, AND REACTOR VESSEL INSTRUMENTATION

COMPONENTS:

Excess flow check valves

CATEGORY:

A/C

FUNCTION:

Excess flow check valves limit leakage from the reactor coolant system in the event of an instrumentation piping failure outside containment. They also perform a containment isolation function if an instrument line were to fail inside and outside of the containment vessel.

TEST REQUIREMENT:

Exercise in the closed direction every three months (CT-CC). Conduct valve seat leakage tests once every two (2) years. (AT-1)

BASIS FOR RELIEF:

Exercising of these valves is impractical during normal operation since it requires isolating instrumentation downstream of the excess flow check valves. Additionally, this testing involves a total of 94 valves which would require excessive cold shutdown time solely to accomplish this testing and would greatly increase total personnel radiation exposure.

The excess flow check valves, designated FLO-FUSE by the manufacturer (Marietta Valve Corp., Boonton, New Jersey), have no provision for leaktesting nor are there such provisions in the upstream side of the lead-in tubing from the root valves. Thus, there is no practical method of conducting leaktests of these vales.

It should be noted that these valves see little or no flow and function essentially only during the exercise testing described below. Also, the significant internal components are fabricated from corrosion-resistant materials that are not expected to degrade during the plant lifetime. For these reasons, general seat degradation is highly unlikely. Gross failure of the seat, if present, will be identified during exercise testing.

					1
	DUANE ARNOLD ENERGY CENTER	Page	38	of	73
TITLE:	INSERVICE TESTING PROGRAM	Date 04	1/01/8	37	Rev. 8

RELIEF REQUEST NO. VR-8 (continued)

ALTERNATE TESTING:

These valves will be exercised in accordance with DAEC Technical Specifications, Section 4.7.D. During these tests, downstream tubing will be vented and drained and valve performance monitored by individual valve position indication and the cessation of flow from the instrument tubing. Following testing, each valve is opened by actuating a solenoid-operated bypass valve that equalizes pressure and allows the valve to reset (open). Individual valve position is provided.

· · · · · · · · · · · · · · · · · · ·				
DUANE ARNOLD ENERGY CENTER	Page	39	of	73
TITLE: INSERVICE TESTING PROGRAM	Date O	4/01/8	37	Rev. 8

SYSTEM:

CONTAINMENT ATMOSPHERE CONTROL

COMPONENTS:

CV-4327A	CV-4327F
CV-4327B	CV-4327G
CV-4327C	CV-4327H
CV-4327D	

CATEGORY:

A/C

FUNCTION:

These are the pressure suppression chamber to drywell vacuum breaker valves which equalize the pressure between the two volumes should the suppression chamber pressure exceed that in the drywell.

TEST REQUIREMENT:

Measure valve seat leakage and compare the measured leakage to a specific maximum leakage for each valve (IWV-3426).

BASIS FOR RELIEF:

A specific maximum leakage per valve is not applicable to the vacuum breaker valve testing. As part of the containment integrity testing, a pressure decay test is performed on the pressure suppression chamber in accordance with DAEC Technical Specifications Section 4.7.A.4.d. This test is designed to verify leak tightness between the drywell and the suppression chamber and thus the aggregate leak tightness of the vacuum breaker valves.

ALTERNATE TESTING:

The leak tightness of the pressure suppression chamber to drywell vacuum breakers will be demonstrated during containment integrity testing. This test consists of establishing a drywell to suppression chamber pressure differential of 1.1 psi and measuring the suppression chamber pressure increase over a ten (10) minute period. If this pressure increase is less than 0.009 psi/min the vacuum breakers have demonstrated adequate leak tightness.

	DUANE ARNOLD ENERGY CENTER	Page	41	of	73
TITLE:	INSERVICE TESTING PROGRAM			_	
		Date 04	4/01/8	57	Rev. 8

SYSTEM:

L

CONTROL ROD DRIVE (CRD) HYDRAULIC

COMPONENTS:

SV-1840 A & B CV-1849 CV-1850 SV-1855 SV-1856 SV-1868 A & B SV-1869 A & B V-18-118 thru 206 V-18-919 thru 1007 V-18-1453 thru 1541

CATEGORY:

Category B -- CV-1849, CV-1850, SV-1840 A&B, SV-1855 and SV-1856 Category C -- V-18-118 thru 206, V-18-919 thru 1007 an V-18-1453 thru 1541

FUNCTION:

SV-1840 · A & B	-	Backup Scram valves; bleed off scram air header upon receiving a SCRAM signal from the reactor protection system.
CV-1849 ·	-	Opens with SCRAM signal to pressurize lower side of CRD piston from accumulator.
CV-1850 ·	-	Opens with SCRAM signal to vent top of CRD piston to scram discharge header.
SV-1855 & SV-1856 -		Pilot valves for CV-1849 & CV-1850, respectively. Open on SCRAM signal to vent air operators.
V-18-118 thru 206 ·	-	Prevent bypassing SCRAM water (from the accumulator) to charging water header (if depressurized); open to charge accumulators following SCRAM.
V-18-919 thru 1007	-	Prevent backflow into cooling water header during SCRAM; allow cooling water circulating during normal operation.
V-18-1453 thru 1541		Open to allow flow from top of CRD pistons to the scram discharge header.
SV-1868 A and SV-1869 A		B - Safety related pilot valves for CV-1859A & B and CV-1867 A & B. Open on SCRAM signal to vent air operators. B

Relief Request No. VR-13 (continued)

TEST REQUIREMENTS:

Exercise and time air-operated and solenoid valves every three months (BTO, BTC). Exercise check valves every three months (CT-CO, CT-CC).

The corresponding fail-safe test is discussed in VR-17.

BASIS FOR RELIEF:

Individual testing of the backup scram valves requires modifying the electrical configuration of the reactor protection system by jumpers, etc and inserting a scram signal to each valve - a complex test.

Except for the backup scram valves, these valves can only be tested by scramming each individual control rod. Due to the extensive effort and operational constraints associated with scram testing, this is impractical to accomplish on a quarterly basis or even during cold shutdown periods.

Exercising and measuring the individual stroke times of the air-operated scram valves (CV-1849 and CV-1850) is impractical due to design limitations. There is a single position indicating light for both valves that is energized only when both valves are not in the fully-closed position. Thus, in order to accurately measure stroke time, additional individual position indicating circuitry is required. Such a backfit would be costly and could possibly detract from the basic reliability of the present configuration.

Except for V-18-118 thru V-18-206, proper operation of the check valves is monitored during plant operation. Failure of any of these valves manifests itself in abnormal operation of the associated control rod drive which would be noted (and corrected) by the plant staff.

Exercising and measuring the individual stroke times for the solenoid valves is impractical since they possess no indicator lights. Operation of the main valve implies that the solenoid valve is performing satisfactorily. The only method of exercising these solenoids with their respective main valves is to simulate or experience a RPS trip. To simulate a RPS trip would require modifying the electrical configuration of the reactor protection system by jumpers, etc. and inserting a scram signal to each valve - a complex task.

ALTERNATIVE TESTING:

Proper operation of these valves is demonstrated by testing performed during plant operation or each refueling outage. SV-1840 A & B are tested once per operating cycle as required by a commitment (NG-84-0825). During the test, valve operation is locally observed upon initiation of a manual scram. This testing of the backup SCRAM valves meets the requirements of NUREG-0979, "Safety Evaluation Report Related to the Fuel Design Approval of the GESSAR II, BWR/6 Nuclear Island Design."



Relief Request No. VR-13 (continued)

ALTERNATE TESTING: (continued)

CV-1849, CV-1850, SV-1855, SV-1856, V-18-1453 thru V-18-1541, and V-18-919 thru V-18-1007 -

These valves are tested once each operating cycle per DAEC Technical Specifications, Section 4.3.C. Following each refueling outage, all operable control rods are SCRAM time tested from the fully withdrawn position with nuclear system pressure above 950 psig. The time-position performance of each control rod and all rods collectively are compared against the acceptance criteria established for various rod insertion positions per DAEC Technical Specifications, Section 3.3.C.

V-18-118 thru V-18-206 -

Once each operating cycle, the CRD charging header is depressurized and HCU accumulator levels monitored over a period of time. Proper operation of these valves is verified by each accumulator remaining in a charged condition during the test.

V-18-919 thru V-18-1007 -

During normal plant operation at power, each partially or fully withdrawn operable control rod is exercised one notch at least once each week (Technical Specification, Section 4.3.A.2.a). Excessive backleakage through these valves would prevent rod movement.

SV-1868 A & B and SV-1869 A & B -

These valves are tested with the associated main valves (CV-1957A&B and CV-1967A&B). The main valves are exercised closed and the stroke times are verified to be within specified limits, during the Mode Switch Placed in Shutdown test, performed every refueling.

RELIEF REQUEST NO. VR-17

SYSTEM:

ALL SYSTEMS

COMPONENTS:

All valves equipped to fail open or closed.

CATEGORY:

A and B

FUNCTIONS:

Upon loss of actuator power (electrical or pneumatic), the valve must stroke to its fail-safe position.

TEST REQUIREMENT:

When practical, valves with fail-safe actuators shall be tested by observing the operation of the valves upon loss of actuator power. (IWV-3415)

BASIS FOR RELIEF:

Solenoid valves which control the air supply to air-operated valves and direct solenoid-operated valves must stroke to their fail-safe position upon interruption of their electric power supply. (FST)

De-energizing the solenoid valve has the same effect as loss of electrical power or loss of control air. Therefore, stroking the valve from the control room (BTO, BTC) to its fail-safe position constitutes a fail-safe test.

The additional procedural requirements to perform fail-safe stroke testing of main steam isolation valves, MSIVs, of each cold shutdown represents an excessive operational burden. Confirmation of the capability of these valves to function with only their accumulator air supply once per reactor refueling is adequate.

ALTERNATE TESTING:

With the exception of the MSIV's, normal stroking (BTO, BTC), to the fail-safe position of valves equipped to fail open or closed constitutes an FST. No additional testing is necessary.

MSIV's will be stroke tested with only the air supply stored in accumulators at each refueling outage.

DUANE ARNOLD ENERGY CENTER	Page	45	of	73
TITLE: INSERVICE TESTING PROGRAM	Date O4	4/01/8	37	Rev. 8

SYSTEM:

NUCLEAR BOILER

COMPONENTS:

V-14-9	V-14-32	V-14-112
V-14-14	V-14-100	V-14-116
V-14-15	V-14-104	V - 14-120
V-14-16	V-14-108	V-14-124

CATEGORY:

A/C

FUNCTION:

These valves must close upon loss of normal air or nitrogen supply to the automatic depressurization system (ADS) relief valve accumulators and the main steam isolation valve accumulators.

TEST REQUIREMENT:

Exercise valves in the closed direction every three months (CT-CC).

BASIS FOR RELIEF:

The position of these valves cannot be verified during normal operation since they are simple check valves and have no position indicators. In addition, access to these valves is limited since they are located either inside the drywell or the steam tunnel.

ALTERNATE TESTING:

These valves will be exercised during refueling. More frequent testing is not practical because a leaktest must be performed to verify that they close.

RELIEF REQUEST NO. VR-20

SYSTEM:

STANDBY LIQUID CONTROL (SBLC)

COMPONENTS:

V-26-08 V-26-09 -

CATEGORY:

A/C

FUNCTIONS:

The functions of these check valves are to open during SBLC injection and close for containment isolation.

TEST REQUIREMENT:

Exercise value in the open and closed directions every three months (CT-CO, CT-CC).

BASIS FOR RELIEF:

These check valves are normally closed. They can only be stroked closed during seat leakage tests performed during reactor refueling. To stroke these valves open, the SBLC pumps must discharge directly into the reactor vessel through explosively-actuated isolation valves. This cannot be done during normal operation or cold shutdown since the SBLC system must be drained and flushed to prevent contamination of the reactor coolant with sodium pentaborate. In addition, extensive testing is required to replace the explosive charges of the isolation valves.

ALTERNATE TESTING:

These valves will be exercised open and closed during operational tests and leak testing performed each cycle in accordance with DAEC Technical Specifications 4.4.A.2.b and 4.7.A.2.c., respectively. Technical Specification 4.4.A.2.b requires demonstration of design flow through the system and into the reactor vessel. Section 4.7.A.2.c refers to Appendix J, Type C leak testing.

Date 04/01/87 Rev. 8

RELIEF REQUEST NO. VR-21

SYSTEM:

HIGH PRESSURE COOLANT INJECTION (HPCI)

COMPONENTS:

V-23-01

CATEGORY:

С

FUNCTIONS:

This values is designed to prevent backflow into the suppression pool in the event of pump suction shift from the condensate storage tank (CST) to the suppression pool. The safety-related function of this value is to open to provide flow from the suppression pool to the HPCI pump.

TEST REQUIREMENT:

Exercise every three months (CT-CO).

BASIS FOR RELIEF:

There is no convenient method for verifying the ability of this valve to swing to the full-open position. The system test piping circuits utilize the CST for pump suction rather than the suppression pool. Taking suction from the suppression pool during testing is undesirable because, in so doing, torus water would be transferred to the condensate storage tank. Torus water is not demineralized, thus the entire condensate storage tank inventory would require processing following each test. Since this valve has no function during normal operation, no internal wear-induced degradation is expected.

ALTERNATE TESTING:

In lieu of the Code-required full-stroke test, valve operability will be demonstrated by disassembling the valve during each refueling outage and verifying that the valve disk swings freely to the open position.

· · · · · · · · · · · · · · · · · · ·	DUANE ARNOLD ENERGY CENTER	Page	48	of	73
TITLE:	INSERVICE TESTING PROGRAM	.Date O	4/01/8	37	Rev. 8

SYSTEM:

CONTAINMENT ATMOSPHERE CONTROL

COMPONENTS:

V-43-214

CATEGORY:

A/C

FUNCTIONS:

This valve prevents backflow from the containment into the drywell nitrogen supply line and also functions as a primary containment isolation valve.

TEST REQUIREMENT:

Check valve shall be exercised at least once every three months, except as provided by IWV-3522. (IWV-3521)

BASIS FOR RELIEF:

This check valve cannot be remotely operated. It is located inside primary containment and is not accessible for testing during reactor operation. Additionally, the primary containment is inerted with nitrogen during plant operation. De-inerting and re-inerting the containment atmosphere each cold shutdown solely for the purpose of conducting valve testing would represent an excessive operational burden. This valve can be exercised closed during leakrate testing performed during refueling outage.

ALTERNATE TESTING:

This valve will be checked in the closed position during leaktesting conducted in accordance with DAEC Technical Specification 4.7.A.2.c. (Appendix J, Type C leak test.)

	DUANE ARNOLD ENERGY CENTER	Page	49	of	73	3
TITLE:	INSERVICE TESTING PROGRAM					
		Date 04	\$/01/8	37	Rev. 8	3

SYSTEM:

L

NEUTRON MONITORING

COMPONENT:

TIP-CK

CATEGORY:

A/C

FUNCTION:

This valve provides containment isolation for the nitrogen purge portion of the TIP system.

TEST REQUIREMENT:

Check valves shall be exercised at least once every three months, except as provided by IWV-3522. (IWV-3521)

BASIS FOR RELIEF:

This valve is a simple check valve and thus the only practical method to verify closure is by performing a leaktest. Conducting such tests every three months is excessively time consuming and difficult.

ALTERNATE TESTING:

This valve will be checked in the closed position during leaktesting conducted once each cycle in accordance with DAEC Technical Specification 4.7.A.2.c. (Appendix J, Type C leaktest.)

					1
DUANE ARNOLD ENERGY CENTER	Page	50	of	73	
TITLE: INSERVICE TESTING PROGRAM	Date 04	/01/8	37	Rev. 8	

SYSTEM:

CONTAINMENT ATMOSPHERE MONITORING SYSTEM

COMPONENTS:

SV-8106A
SV-8106B
SV-8107A
SV-8107B
SV-8108A
SV-8108B SV-8109A
SV-8109A
SV-8110A
SV-8110B

CATEGORY:

А

FUNCTION:

These valves provide containment isolation for the containment atmosphere monitoring system.

TEST REQUIREMENT:

Exercise valves in the closed direction every three months (BTC). The stroke time of all power-operated valves shall be measured. (IWV-3413)

BASIS FOR RELIEF:

These valves are not provided with individual position indicators and the only reasonable means of verifying the close position is by performing leaktests--tests that are impractical to perform during normal operation. Also, meaningful stroke time measurements cannot be taken.

ALTERNATE TESTING:

These valves will be exercised every three months. Verification of the closed position will be performed during leaktesting conducted once each cycle in accordance with DAEC Technical Specification 4.7.A.2.c. (Appendix J, Type c leaktest.) Stroke times will not be measured.

	DUANE ARNOLD ENERGY CENTER	Page	51	of	73
TITLE:	INSERVICE TESTING PROGRAM				

Date 04/01/87

Rev. 8

RELIEF REQUEST NO. VR-33

SYSTEM:

CORE SPRAY

COMPONENTS:

V-21-072 V-21-073

CATEGORY:

С

FUNCTIONS:

These check valves provide a flowpath for core spray to the reactor vessel and prevent backflow from the reactor vessel to the core spray system.

TEST REQUIREMENT:

Check valves shall be exercised at least once every three months, except as provided in IWV-3522. (IWV-3521)

BASIS FOR RELIEF:

These check valves are normally closed. To open the valves, the core spray pumps must be operated at rated flow discharging directly into the reactor vessel. This cannot be done during normal operation because the core spray pumps are not capable of overcoming reactor pressure. Core spray injection during cold shutdown with the reactor head in place is impractical due to the difficulty of controlling reactor vessel water level.

ALTERNATE TESTING:

These valves will be exercised at each refueling outage by verifying that each division of core spray can deliver rated flow to the reactor vessel.

DUANE ARNOLD ENERGY CENTER	Page	52	of	7	3
TITLE: INSERVICE TESTING PROGRAM	Date O	4/01/8	87	Rev.	8

SYSTEM:

CONTAINMENT ATMOSPHERE DILUTION (CAD) NEUTRON MONITORING POST-ACCIDENT SAMPLING SYSTEM (PASS)

COMPONENTS:

SV-4331A	SV-4333A	TIP-BAL A	SV-4594A
SV-4331B	SV-4333B	TIP-BAL B	SV-4594B
SV-4332A	SV-4334A	TIP-BAL C	SV-4595A
SV-4332B	SV-4334B		SV-4595B
			SV-8772A

CATEGORY:

А

FUNCTIONS:

The PASS system valves provide a flow path for post-accident sampling of the reactor recirculation system and return of the sample flowstream to the torus.

SV-8772B

The CAD System valves function to provide a flowpath into the containment in the event that containment dilution is required during an accident and serve as containment isolation valves.

The TIP System valves function as containment isolation for the TIP tube penetrations.

TEST REQUIREMENT:

Evaluate stroke times in accordance with IWV-3413 (b).

BASIS FOR RELIEF:

It is impractical to apply the requirements of IWV-3413 (b) to valves with stroke times less than 2 seconds without installing sophisticated timing devices. Operator reaction times could easily vary by .5 seconds or more, thereby invalidating the 50% criteria for increasing the surveillance frequency.

There have been several instances when the internal position indicating switches of the CAD system valves malfunction and corrective maintenance during plant operation is impractical. If this should occur, then accurate stroke time measurements are not possible.

Date 04/01/87 Rev. 8

RELIEF REQUEST NO. VR-34

(CONTINUED)

ALTERNATE TESTING:

Stroke times for these valves will be measured. The frequency of testing will be increased to once each month if an increase in measured stroke time of 100% or more from the previous test is observed and the stroke time is greater than 2 seconds. Valves exceeding the maximum allowable stroke time will be declared inoperable.

When CAD system SV valves position indication is inoperable, stroke time will be estimated by a flow test through the valve. The results of this test will be evaluated with respect to the maximum allowable stroke time but will not be compared to previous tests per the criteria set forth above or in IWV-3413(b).

DUANE ARNOLD ENERGY CENTER	Page	54	of	73
TITLE: INSERVICE TESTING PROGRAM	Date 04	./01/8	37	Rev. 8

SYSTEM:

EMERGENCY SERVICE WATER (ESW)

COMPONENTS:

CV-1956 A	CV-2080
CV-1956 B	CV-2081

CATEGORY:

В

FUNCTION:

CV-1956 A & B open to provide a return path for ESW cooling water from the control building chillers.

 $\mathsf{CV}\text{-}2080$ and $\mathsf{CV}\text{-}2081$ are ESW supply values to the emergency diesel generators.

TEST REQUIREMENT:

Stroke time shall be measured during exercise testing. (IWV-3413)

BASIS FOR RELIEF:

CV-1956 A & B are actuated by the starting logic of the associated emergency service water pump, with no individual control handswitch. Also, there are no position indicators for these valves. For these reasons precise stroke time measurements are impractical.

CV-2080 and CV-2081 do not have position indication, thus stroke time measurements are impractical.

ALTERNATE TESTING:

These valves will be exercised every three months. During this testing, valve operation will be observed. Based on visual observation, any erratic operation or excessively long stroke time will be cause for failure or investigation.

	DUANE ARNOLD ENERGY CENTER	Page	55	of	73	3
TITLE:	INSERVICE TESTING PROGRAM					
		Date O4	\$/01/8	7	Rev. 8	3

SYSTEM:

VARIOUS

COMPONENTS:

PENETRATIONS		VAL	VES	
X 9A X 9B X 2 3A X 2 3B	MO-4441 MO-4442 CV-5718A CV-5718B	MO-2312 MO-2512 V-57-77 V-57-78	MO-2740	
X24A X24B X25 X26 X41	V-57-75 V-57-76 CV-4302 CV-4306 CV-4639	CV-5704A CV-5704B CV-4303 CV-4307 CV-4640	CV-4308	
N205 N212 N214 N222 N231	CV-4300 V-24-8 V-22-16 V-22-21 CV-4305	CV-4301 V-24-23 V-22-17 V-22-22 CV-4304	V-43-168	V-43-169

CATEGORY:

A & C

FUNCTIONS:

Containment isolation valves

TEST REQUIREMENT:

Category A valves shall be seat leak tested to a specific maximum amount for each valve in the closed position for fulfillment of their safety function at least once every 2 years. (IWV-3420, 3421, 3422, 3426)

BASIS FOR RELIEF:

The configuration of the piping systems is such that individual testing of these valves is not possible.

ALTERNATE TESTING:

The valves will be tested in multiple arrangements with a maximum leakage rate established for each combination of valves, as appropriate.

DUANE ARNOLD ENERGY CENTER	Page	56	of	73
TITLE: INSERVICE TESTING PROGRAM	Date O	4/01/8	37	Rev. 8

SYSTEMS:

EMERGENCY SERVICE WATER (ESW)

COMPONENTS:

V-46-18 V-46-21

CATEGORY:

С

FUNCTION:

These are the ESW pump discharge check valves that provide a flow path to the ESW piping system and prevent backflow through an idle pump.

TEST REQUIREMENTS:

Check valves shall be exercised at least once every three months, except as provided by IWV-3522. (IWV-3521)

BASIS FOR RELIEF:

There is no sure method of ensuring that these valves stroke to their fully-closed positions.

ALTERNATE TESTING:

The valves will be exercised to the open position during operational testing of the ESW pumps. Once every two years, each valve will be disassembled and inspected to ensure proper operation.

DUANE ARNOLD E	NERGY CENTER
----------------	--------------

RELIEF REQUEST NO. VR-40

SYSTEMS:

NUCLEAR BOILER, REACTOR FEEDWATER

COMPONENTS:

MO-4441 MO-4442

CATEGORY:

A/C

FUNCTION:

Provide primary containment outboard isolation for the reactor feedwater supply piping.

TEST REQUIREMENTS:

When a valve or its control system has been replaced or repaired or has undergone maintenance that could affect its performance, and prior to the time it is returned to service, it shall be tested to demonstrate that the performance parameters which could be affected by the replacement, repair, or maintenance are within acceptable limits. (IWV-3200)

Valves that are normally open during plant operation and whose function is to prevent reverse flow shall be tested in a manner that proves that the disk travels to the seat promptly on cessation or reversal of flow. Confirmation that the disk is on its seat shall be by visual observation, by an electrical signal initiated by a position indicating device, by observing of appropriate pressure indications in the system, or by other positive means. (IWV-3522[a]) (CT-CC)

BASIS FOR RELIEF:

These valves are lift-type stop check valves and have no mechanism for opening other than that induced by feedwater flow to the reactor vessel. If maintenance (e.g., disassembly, lapping, or component replacement) is performed which could potentially affect their capability to close, post-maintenance testing would require plant startup and operation at full-power to fully open the valve, followed by plant shutdown to close the valve. Testing in this manner would be contrary to the requirements of IWV-3200 which prohibit plant operation prior to testing. Since the disk does not possess position indication, a leakage test would be required subsequent to plant shutdown to demonstrate that the valve had stroked to its fully-closed position. Cycling the plant in this manner, in order to perform a test, is considered undesirable and impractical. DUANE ARNOLD ENERGY CENTER

TITLE: INSERVICE TESTING PROGRAM

Date 04/01/87 Rev. 8

RELIEF REQUEST NO. VR-40

BASIS FOR RELIEF: (CONTINUED)

Maintenance activities associated with these valves fall under the cognizance of the DAEC Operational Quality Assurance Program. Thus, reassembly errors, the most probable source of failure, are unlikely. Gross errors would be detected during leak rate testing that would follow reassembly.

ALTERNATE TESTING:

When these valves are subjected to repair or maintenance that could affect their performance, a leak rate test will be performed to ensure that the valve will perform its containment isolation function.

DUANE ARNOLD ENERGY CENTER	Page	59	of	73
TITLE: INSERVICE TESTING PROGRAM	Date O	4/01/87	7	Rev. 8

SYSTEMS:

NUCLEAR BOILER, REACTOR FEEDWATER

COMPONENTS:

V-14-1 V-14-3

CATEGORY:

A/C

FUNCTION:

These valves have a dual function capability as they perform safety-related functions in both the open and closed positions. Specifically, they provide primary containment inboard isolation for the reactor feedwater supply piping. V-14-1 and V-14-3 provide injection paths to the reactor vessel for RCIC and HPCI, respectively.

TEST REQUIREMENTS:

When a valve or its control system has been replaced or repaired or has undergone maintenance that could affect its performance, and prior to the time it is returned to service, it shall be tested to demonstrate that the performance parameters which could be affected by the replacement, repair, or maintenance are within acceptable limits. (IWV-3200)

Valves that are normally open during plant operation and whose function is to prevent reverse flow shall be tested in a manner that proves that the disk travels to the seat promptly on cessation or reversal of flow. Confirmation that the disk is on its seat shall be by visual observation, by an electrical signal initiated by a position indicating device, by observing of appropriate pressure indications in the system, or by other positive means. (IWV-3522[a]) (CT-CC)

Valves that are normally closed during plant operation and whose function is to open on reversal of pressure differential shall be tested by proving that the disk moves promptly away from the seat when the closing pressure differential is removed and flow through the valve is initiated. (IWV-3522[b]) (CT-CO)

Date 04/01/87 Rev. 8

RELIEF REQUEST NO. VR-41

(CONTINUED)

BASIS FOR RELIEF:

These check valves have no mechanism for opening other than that induced by feedwater (or HPCI or RCIC) flow to the reactor vessel. If maintenance (e.g., disassembly, lapping, or component replacement) is performed which could potentially affect their capability to close, post-maintenance testing would require plant startup and operation at full-power to fully open the valve, followed by plant shutdown to close the valve. Testing in this manner would be contrary to the requirements of IWV-3200 which prohibit plant operation prior to testing. Cycling the plant in this manner in order to perform a test, is considered undesirable and impractical. Maintenance activities associated with these valves fall under the cognizance of the DAEC Operational Quality Assurance Program. Thus, reassembly errors, the most probable source of failure, are unlikely. Gross errors would be detected during leak rate testing that would follow reassembly. Proper stroking of these valves to the open position is verified by satisfactory operation of the reactor feedwater system during power operation of the plant.

ALTERNATE TESTING:

When these valves are subjected to repair or maintenance that could affect their performance, a leak rate test will be performed to ensure that the valve will perform its containment isolation function.

DUANE ARNOL	D ENERGY CENTER	Page	61	of		73
TITLE: INSERVICE T	ESTING PROGRAM					
		Date	04/01/8	37	Rev.	8

SYSTEMS:

CONTROL ROD DRIVE (CRD) HYDRAULIC

COMPONENTS:

V-18-919 through V-18-1007 V-18-1453 through V-18-1541

CATEGORY:

С

FUNCTION:

V-18-919 through V-18-1007

Prevent backflow into the cooling water header during a SCRAM; allow cooling water circulation during normal operation.

V-18-1453 through V-18-1541

Open to allow flow from the top of the CRD pistons to the SCRAM discharge header.

TEST REQUIREMENTS:

When a valve or its control system has been replaced or repaired or has undergone maintenance that could affect its performance, and prior to the time it is returned to service, it shall be tested to demonstrate that the performance parameters which could be affected by the replacement, repair, or maintenance are within acceptable limits. (IWV-3200)

Valves that are normally open during plant operation and whose function is to prevent reverse flow shall be tested in a manner that proves that the disk travels to the seat promptly on cessation or reversal of flow. Confirmation that the disk is on its seat shall be by visual observation, by an electrical signal initiated by a position indicating device, by observing of appropriate pressure indications in the system, or by other positive means. (IWV-3522[a]) (CT-CC)

Valves that are normally closed during plant operation and whose function is to open on reversal of pressure differential shall be tested by proving that the disk moves promptly away from the seat when the closing pressure differential is removed and flow through the valve is initiated. (IWV-3522[b]) (CT-CO)

Date 04/01/87 Rev. 8

RELIEF REQUEST NO. VR-43

(CONTINUED)

BASIS FOR RELIEF:

These valves open with CRD process system flow. If maintenance (e.g. disassembly, lapping, or component replacement, etc.) is performed on any of these valves that could potentially affect their capability to open or close, post-maintenance testing would require operation of the CRD system and the affected control rod to determine proper valve operation.

Maintenance activities associated with these valves fall under the DAEC Operational Quality Assurance Program. Thus, reassembly errors, the most probable source of failure, are unlikely. As required by the DAEC Technical Specifications, proper operation of these valves is verified by satisfactory operation of the reactor CRD system and individual control rods during startup and power operation of the plant.

ALTERNATE TESTING:

When these valves are subjected to repair or maintenance that could affect their performance, control rod operation and response will be monitored during the normal course of plant startup and operation following completion of maintenance activities.

	DUANE ARNOLD ENERGY CENTER	Page	63	of		73
TITLE:	INSERVICE TESTING PROGRAM					
		Date O4	1/01/8	7 1	Rev.	8

SYSTEMS:

HIGH PRESSURE COOLANT INJECTION (HPCI)

COMPONENTS:

V-22-16 V-22-17 V-22-21 V-22-22

CATEGORY:

A/C

FUNCTION:

Provide primary containment (torus) isolation for the HPCI steam exhaust (V-22-16 and V-22-17) and HPCI condensate return (V-22-21 and V-22-22) piping.

V-22-16 and V-22-17 provide an exhaust path to the suppression pool for the HPCI turbine.

V-22-21 and V-22-22 provide a path for condensate from the HPCI exhaust drain pot to the suppression chamber.

TEST REQUIREMENTS:

When a valve or its control system has been replaced or repaired or has undergone maintenance that could affect its performance, and prior to the time it is returned to service, it shall be tested to demonstrate that the performance parameters which could be affected by the replacement, repair, or maintenance are within acceptable limits. (IWV-3200)

Valves that are normally open during plant operation and whose function is to prevent reverse flow shall be tested in a manner that proves that the disk travels to the seat promptly on cessation or reversal of flow. Confirmation that the disk is on its seat shall be by visual observation, by an electrical signal initiated by a position indicating device, by observing of appropriate pressure indications in the system, or by other positive means. (IWV-3522[a]) (CT-CC)

Valves that are normally closed during plant operation and whose function is to open on reversal of pressure differential shall be tested by proving that the disk moves promptly away from the seat when the closing pressure differential is removed and flow through the valve is initiated. (IWV-3522[b]) (CT-CO) DUANE ARNOLD ENERGY CENTER

TITLE: INSERVICE TESTING PROGRAM

Date 04/01/87 Rev. 8

RELIEF REQUEST NO. VR-44

(CONTINUED)

BASIS FOR RELIEF:

These valves are check valves and have no mechanism for opening other than that induced by steam exhaust or condensate flow to the suppression pool. If maintenance (e.g., disassembly, lapping, or component replacement, etc.) is performed on any of these valves that could potentially affect its capability to open or close, post-maintenance testing would require plant startup and HPCI system operation to open the valve(s), then shutting down the HPCI system to close the valve. Following shutdown of the HPCI system, a leaktest would be required to prove that the valve(s) stroked from the open to the closed positions. Plant startup cannot be initiated with any of these valves in an inoperable status as this would be contrary to the requirements of IWV-3200. Since conducting a leaktest of these valves would render the HPCI system inoperable during the test, it would be imprudent to conduct such a test with the plant in any condition other than cold shutdown. Cycling the plant in such a manner would be undesirable and impractical.

Maintenance activities associated with these valves fall under the DAEC Operational Quality Assurance Program. Thus, reassembly errors, the most probable source of failure, are unlikely. Gross errors would be detected during leak rate testing that would follow reassembly. Proper stroking of these valves to the open position is verified by satisfactory operation of the HPCI turbine during surveillance testing as required by the Technical Specifications.

ALTERNATE TESTING:

When these valves are subjected to repair or maintenance that could affect their performance, a leak rate test will be performed to ensure that the valve will perform it's containment isolation function. Following plant startup, HPCI system operational tests will be conducted to confirm valves operate properly to the opened position.

	DUANE ARNOLD ENERGY CENTER	Page	65	of		73
TITLE:	INSERVICE TESTING PROGRAM					
		Date 04	/01/8	7	Rev.	8

SYSTEMS:

HIGH PRESSURE COOLANT INJECTION (HPCI)

COMPONENTS:

V-22-26 V-22-28 V-22-29

CATEGORY:

С

FUNCTION:

V-22-26 HPCI condensate pump discharge V-22-28 HPCI condensate return to the HPCI pumps suction V-22-29 HPCI condensate to the HPCI turbine lube oil cooler

TEST REQUIREMENTS:

When a valve or its control system has been replaced or repaired or has undergone maintenance that could affect its performance, and prior to the time it is returned to service, it shall be tested to demonstrate that the performance parameters which could be affected by the replacement, repair, or maintenance are within acceptable limits. (IWV-3200)

Valves that are normally open during plant operation and whose function is to prevent reverse flow shall be tested in a manner that proves that the disk travels to the seat promptly on cessation or reversal of flow. Confirmation that the disk is on its seat shall be by visual observation, by an electrical signal initiated by a position indicating device, by observing of appropriate pressure indications in the system, or by other positive means. (IWV-3522[a]) (CT-CC)

BASIS FOR RELIEF:

These check valves have no mechanism for opening other than that induced by condensate flow from the HPCI condensate pump. If maintenance (e.g., disassembly, lapping, or component replacement, etc.) is performed on either of these valves that could potentially affect its capability to open, post-maintenance testing would require plant startup and HPCI system operation to operate the condensate pump and thus open the valve(s). Plant startup cannot be initiated with either of these valves in an inoperable status, as this would be contrary to the requirements of IWV-3200.

Date 04/01/87 Rev. 8

RELIEF REQUEST NO. VR-45

BASIS FOR RELIEF: (CONTINUED)

Maintenance activities associated with these valves fall under the DAEC Operational Quality Assurance Program. Thus, reassembly errors, the most probable source of failure, are unlikely. Proper stroking of these valves to the open position is verified by satisfactory operation of the HPCI turbine during surveillance testing as required by the Technical Specifications.

ALTERNATE TESTING:

When these valves are subjected to repair or maintenance that could affect their performance, operability to the open position will be demonstrated during HPCI system testing following plant startup.

Date 04/01/87 Rev. 8

RELIEF REQUEST NO. VR-46

SYSTEMS:

HIGH PRESSURE COOLANT INJECTION (HPCI)

COMPONENTS:

V-23-14

CATEGORY:

С

FUNCTION:

V-23-14 HPCI minimum flow check valve

TEST REQUIREMENTS:

When a valve or its control system has been replaced or repaired or has undergone maintenance that could affect its performance, and prior to the time it is returned to service, it shall be tested to demonstrate that the performance parameters which could be affected by the replacement, repair, or maintenance are within acceptable limits. (IWV-3200)

Valves that are normally open during plant operation and whose function is to prevent reverse flow shall be tested in a manner that proves that the disk travels to the seat promptly on cessation or reversal of flow. Confirmation that the disk is on its seat shall be by visual observation, by an electrical signal initiated by a position indicating device, by observing of appropriate pressure indications in the system, or by other positive means. (IWV-3522[a]) (CT-CC)

BASIS FOR RELIEF:

These check valves have no mechanism for opening other than that induced by flow from the HPCI pump. If maintenance (e.g., disassembly, lapping, or component replacement, etc.) is performed on this valve that could potentially affect its capability to open, post-maintenance testing would require plant startup and HPCI system operation to open the valve. Plant startup cannot be initiated with either of these valves in an inoperable condition, as this would be contrary to the requirements of IWV-3200. DUANE ARNOLD ENERGY CENTER

TITLE: INSERVICE TESTING PROGRAM

RELIEF REQUEST NO. VR-46

BASIS FOR RELIEF: (CONTINUED)

Maintenance activities associated with these valves fall under the DAEC Operational Quality Assurance Program. Thus, reassembly errors, the most probable source of failure, are unlikely. Proper stroking of these valves to the open position is verified by satisfactory operation of the HPCI turbine during surveillance testing as required by the Technical Specifications.

ALTERNATE TESTING:

When these valves are subjected to repair or maintenance that could affect their performance, operability to the open position will be performed during HPCI system test following plant startup.

DUANE	ARNOLD	ENERGY	CENTER
-------	--------	--------	--------

RELIEF REQUEST NO. VR-47

SYSTEMS:

REACTOR CORE ISOLATION COOLING (RCIC)

COMPONENTS:

V-24-8 V-24-23

CATEGORY:

A/C

FUNCTION:

Provide primary containment (torus) isolation for the RCIC steam exhaust.

Provide an exhaust path to the suppression pool for the RCIC turbine.

TEST REQUIREMENTS:

When a valve or its control system has been replaced or repaired or has undergone maintenance that could affect its performance, and prior to the time it is returned to service, it shall be tested to demonstrate that the performance parameters which could be affected by the replacement, repair, or maintenance are within acceptable limits. (IWV-3200)

Valves that are normally open during plant operation and whose function is to prevent reverse flow shall be tested in a manner that proves that the disk travels to the seat promptly on cessation or reversal of flow. Confirmation that the disk is on its seat shall be by visual observation, by an electrical signal initiated by a position indicating device, by observing of appropriate pressure indications in the system, or by other positive means. (IWV-3522[a]) (CT-CC) DUANE ARNOLD ENERGY CENTER

TITLE: INSERVICE TESTING PROGRAM

Date 04/01/87 Rev. 8

RELIEF REQUEST NO. VR-47

(CONTINUED)

BASIS FOR RELIEF:

Valves V-24-8 and V-24-23 are stop and swing check valves, respectively, and have no mechanism for opening other than that induced by steam exhaust flow to the suppression pool. If maintenance (e.g., disassembly, lapping, or component replacement, etc.) is performed on any of these valves that could potentially affect its capability to open or close, post-maintenance testing would require plant startup and RCIC system operation to open the valve(s), then shutting down the RCIC system to close the valve. Following shutdown of the RCIC system, a leaktest would be required to prove that the valve(s) stroke from the open to the closed position. Plant startup cannot be initiated with any of these valves in an inoperable status, as this would be contrary to the requirements of IWV-3200. Since conducting a leaktest of these valves would render the RCIC system inoperable during the test, it would be inprudent to conduct such a test with the plant in any condition other than cold shutdown. Cycling the plant in this manner in order to perform a test, is undesirable and impractical.

Maintenance activities associated with these valves fall under the DAEC Operational Quality Assurance Program. Thus, reassembly errors, the most probable source of failure, are unlikely. Gross errors would be detected during leak rate testing that would follow reassembly. Proper stroking of these valves to the open position is verified by satisfactory operation of the HPCI turbine during surveillance testing as required by the Technical Specifications.

ALTERNATE TESTING:

When these valves are subjected to repair or maintenance that could affect their performance, a leak rate test will be performed to ensure that the valve will perform it's containment isolation function.

DUANE ARNOLD ENERGY CENTER

TITLE: INSERVICE TESTING PROGRAM

RELIEF REQUEST NO. VR-48

SYSTEMS:

VARIOUS

COMPONENTS:

Valves that cannot be exercised during plant operation.

CATEGORY:

A and B

FUNCTION:

Various

TEST REQUIREMENTS:

If, for power operated valves, an increase in stroke time of 25% or more from the previous test for valves with full-stroke times greater than 10 sec or 50% or more for valves with full-stroke times less than or equal to 10 sec is observed, test frequency shall be increased to once each month until corrective action is taken, at which time the original test frequency shall be resumed. [IWV-3417(a)]

BASIS FOR RELIEF:

Strict adhearance to this requirement as stated would require a plant shutdown or operation under unusual conditions each month for testing until it is determined that the valve is operating satisfactory and has not undergone significant degradation or some corrective maintenance action is performed to correct the condition.

Since valve stroke time would be less than the maximum allowable, it would continue to be considered operable and thus corrective maintenance, along with the accompanying time and personnel exposure costs, may not be warranted or justified.

ALTERNATE TESTING:

If valve testing should result in valve stroke increases as stated in Article IWV-3417(a) requiring increased frequency of testing, the subject valves will be full-stroke tested only during cold shutdowns on a frequency determined by the intervals between shutdowns as follows:

- * for intervals of 1 month (30 days) or longer, tests will be performed during each shutdown;
- * for intervals of less than 1 month (30 days), full-stroke exercise will not be performed unless 1 month (30 days) has passed since the last shutdown exercise test.

Rev. 8

Date 04/01/87

RELIEF REQUEST NO. VR-49

SYSTEMS:

CONTAINMENT ATMOSPHERE CONTROL

COMPONENTS:

CV-4300	CV-4301
CV-4302	CV-4303
CV-4306	CV-4307
CV-4308	

FUNCTION:

Provide ventilation and purging for the drywell and torus.

TEST REQUIREMENTS:

The limiting value of full-stroke time of each power-operated valve shall be specified by the Owner. Full-stroke time is that time interval from initiation of the actuating signal to the end of the actuating cycle.

The stroke time of all power-operated valves shall be measured to the nearest second, for stroke times 10 seconds or less, or 10% of the specified limiting stroke times longer than 10 seconds whenever such a valve is full stroke tested.

BASIS FOR RELIEF:

These valves are blocked to limit opening stroke to approximately 30% per Generic Issue B-24 and implementation of Item B.4 of Branch Technical Position (BTP) CSB 6-4. Exercising these valves to full-stroke is thus impractical.

ALTERNATE TESTING:

These valves will be partial-stroke exercised.

DUANE ARNOLD ENERGY CENTER	Page	73	of		73
TITLE: INSERVICE TESTING PROGRAM	Date (04/01/8	37	Rev.	8

SYSTEMS:

CONTAINMENT ATMOSPHERE CONTROL

COMPONENTS:

CV-4327A	CV-4327F
CV-4327B	CV-4327G
CV-4327C	CV-4327H
CV-4327D	

CATEGORY

A/C

FUNCTION:

These are the pressure suppression chamber to drywell vacuum breaker valves which open to equalize the pressure between the two volumes should the drywell pressure decrease below that of the suppression chamber. These valves in conjunction with the torus to reactor building vacuum breakers protect the drywell if the drywell pressure becomes less then the reactor building.

TEST REQUIREMENTS:

Check valves shall be exercised at least once every three months, except as provided by IWV-3522. (IWV-3521)

Valves that are normally closed during plant operation and whose function is to open on reversal of pressure differential shall be tested by proving that the disk moves promptly away from the seat when the closing pressure differential is removed and flow through the valve is initiated, or when a mechanical opening force is applied to the disk. If the test is made without flow through the valve, a mechanical exerciser shall be used to move the disk. The force or torque delivered must be limited to less than 10% of the equivalent force . . ., except that for vacuum breaker valves, the exerciser force or torque delivered to the disk may be equivalent to the desired functional pressure differential force. This implies that force or torque measurements are required.

BASIS FOR RELIEF:

These valves are located inside the torus and, as such, are not readily accessible for obtaining the required measurements during reactor operation or when the containment is inerted.

ALTERNATE TESTING:

The valves will be full stroked quarterly during plant operation using installed air operators without any quantitative set point measurements. Additionally, each will be tested to open with the mechanical exerciser obtaining set point measurements at least once each refueling cycle. APPENDIX A

.

PUMP LISTING

	RED BY : AM : PRI				ISI CLAS DUANE	VICE TEST S 1, 2, 3 ARNOLD E	AND NC PI NERGY CEN	UMPS	,	IOWA	ELECTRIC L AND POWER	IGHT
							157	PROGRAM R	FAG EVISION		/15/87	
						INSERVICE	TEST Q	UANTITIES				
PUMP NUMBER	Pump Name	IST CLASS	P&ID	P&1D COOR	SPEED	INLET FRESS	DIFF(1) PRESS	FLOW(1) RATE	(2 VIBRA	TEMP	TEST INTERVAL	REMARK S
P-022A	RHRSW	3	M-146	B-8	NA	Y∶FR-4	Y	Y PR-12	Y	N:PR-14	QUARTERLY	
P-022B	RHRSW	3	M-146	B8	NA	Y:PR-4	Y	Y PR-12	Y	N:PR-14	QUARTERLY	
F-022C	RHRSW	3	M-146	B-8	NA	Y : FR-4	Y	Y PR-12	Y	N:PR-14	QUARTERLY	
P-022D	RHRSW	3	M-146	B8	NA	Y:PR-4	Y	Y PR-12	Y	N:PR-14	QUARTERLY	
F-044A	DFO	NC	M-132	A-2	NA	Y : PR-4	Y : FR-5	Y : FR-5	N : PR-1	N:FR-14	QUARTERLY	NOTE-001
F-044B	DFO	NC	M-132	A3	NA	Y:PR-4	Y : PR-5	Y:PR-5	N : PR-1	N:PR-14	QUARTERLY	NOTE-001
F-099A.	ESW	3	M-146	B-7	NA	Y : FR-4	Y : PR-5	Y : FR-5	Y	N:PR-14	QUARTERLY	
P-099B	ESW	3	M-146	B6	NA	Y:PR-4	Y : PR-5	Y : PR-5	Y	N:PR-14	QUARTERLY	, •
P-112A	SCREEN	NC	M-129	C-7	NA	Y	Y : FR−5	Y : FR-5	γ ·	N∶PR-14	QUARTERLY	
P-112B	SCREEN	NC	M-129	C-3	NA	Y	Y : PR-5	Y : PR-5	Y	N:PR-14	QUARTERLY	
P-117A	₽Ŵ	3	M-129	D-7	NA	Y:PR-4	Y : PR-5	Y : FR-5	Y	N:FR-14	QUARTERLY	
P-1178	R₩	3	M-129	D4	NA	Y : PR-4	Y : PR5	Y : PR-5	Y	N:PR-14	QUARTERLY	
P-117C	₩	3	M-129	D-6	NA	Y∶₽R−4	Y : F·R-5	Y ፡ ዮጽ ~5	Ŷ	N:PR-14	QUARTERLY	
F-117D	RW	3	M-129	D3	NA	Y:PR-4	Y : PR5	Y : PR-5	Y	N:PR-14	QUARTERLY	
P-211A	CS	2	M-121	C-3	NA	Y	Y : FR-5	Y : FR-5	Y	N : FR-14	QUARTERLY	NOTE-003
P-211B	CS	2	M-121	C-4	АИ	Y	Y:PR-5	Y : PR-5	Y	N:PR-14	QUARTERLY	NOTE-003
P-216	HPCI	2	M-123	D-2	Y	Y	Y : PR-5	Y : F·R-5	м	N: FR-14	QUARTERLY	NOTE-003
P-229A	RHR	2	M-120	B-3	NA	Y.	Y:PR-5	Y:PR-5	Y	N:PR-14	QUARTERLY	NOTE-002

.

.

• •

.

	RED BY : Am : Pri				ISI CLAS	VICE TEST SS 1, 2, 3 E ARNOLD E	AND NC P	UMPS		IOWA	ELECTRIC L AND POWER	IGHT
						*	IST	PROGRAM R		E 2 008 04	/15/87	
						INSERVICE	TEST Q	UANTITIES				
PUMP NUMBER	PUMP NAME	IST CLASS	P&ID	P&ID COOR	SPEED	INLET. PRESS	DIFF PRESS	FLOW RATE	VIBRA	BEAR TEMP	TEST INTERVAL	REMARK S
IP-229B	RHR	2 .	M-119	B-7	NA	Y	Y : FR-5	Y : F·R-5	Y	N:PR-14	QUARTERLY	NOTE-002
IP-2290	RHR	2	M-120	₿-2	NA	Y	Y : PR-5	Y : PR-5	Y	N:PR-14	QUARTERLY	N01E-002
1P-229D	RHR	2	M-119	B-8	NA	Y	Y∶₽R-5	Y : FR-5	Y	N: PR-14	QUARTERLY	NOTE-002
F-230A	SBLC	NC	M-126	D-5	NA	Y PR-4	Y : PR-5	Y : PR-5	Υ	N:PR-14	QUARTERLY	
1P-230B	SBLC	NC	M-126	C-5	NA	Y PR-4	Y FR-5	Y : F·R−5	Y	N: FR-14	QUARTERLY	



PREPARED BY : TELP

PROGRAM : PRISIM





INSERVICE TESTING PROGRAM

ISI CLASS 1, 2, 3 AND NO PUMPS DUANE ARNOLD ENERGY CENTER

IOWA ELECTRIC LIGHT AND POWER


PAGE 3 ISI PROGRAM REVISION: 008, 04/15/87

.

FOOTNOTES FOR PUMP LISTING

(1) SEE PR-13

(2) SEE PR-11



PREPARED BY : IELP PROGRAM : PRISIM

ISI CLASS 1, 2, 3 AND NC PUMPS DUANE ARNOLD ENERGY CENTER

IOWA ELECTRIC LIGHT AND POWER

FAGE 4 IST PROGRAM REVISION: 008, 04/15/87

PUMP IST PROGRAM REMARKS

NOTE 001: ALTHOUGH THE DIESEL FUEL OIL TRANSFER PUMPS (1P-44A & B) ARE INCLUDED IN THE PROGRAM, THEY DO NOT STRICTLY FALL WITHIN THE JURISDICTION OF THE ASME B & FV PROGRAM, SECTION XI. (REFERENCE ASME RESPONSE TO WPPSS INQUIRY, FILE NO. BC 77-666/NI 77-371 DATED 1/8/79) SEE RELIEF REQUEST NO. PR-10 FOR FURTHER DISCUSSION OF THIS ISSUE.

NOTE 002: SEE RELIEF REQUEST PR-12.

NOTE 003: SEE RELIEF REQUEST PR-7 AND PR-12.

APPENDIX B

VALVE LISTING





INSERVICE TESTING PROGRAM

PREPARED BY : JELP FROGRAM : FRISIM

ISI CLASS 1, 2, 3, AND NC VALVES DUANE ARNOLD ENERGY CENTER -

IOWA ELECTRIC LIGHT AND POWER

							** ** ** ** ** ** ** ** **		*** ** ** ** ** **				** -* ** ** ** ** ** ** **
VALVE NUMBER	P&ID COOR	IST CLASS	VAL.VE CAT	VALVE SIZE	VAL.VE TYPE	ACTUATOR TYPE	NORMAL POSITION	TEST	TEST FREQ	MAXIMUM STROKE TIME	MAXIMUM LEAKAGE	RELIEF REQUEST	REMARKS
TIP-BALA	42 W4 -44	NC	A	.375	BAL.	20	C	AT-1 BTC PIT	RR OP 2Y	005	NA	VR-34	
TIP-BALB		NC	A .	.375	BAL.	50	C	AT-1 BTC PIT	RR OP 2Y	005	NA	VR-34	,
TIP-BALC	*** == =*	NC	A	.375	BAL.	50	C	AT-1 BTC PIT	RR OP 2Y	005	NA	VR-34	ina kali kali kali kali kali ka
TIP-CK		NC	A/C	.375	CK	SA	C	AT1 CT-CC	RR RR		NA	VR-31	and the and and and the for any the de
TIP-SHA		NC	D		SH	EXP	0	DT	ŔŔ				
TIP-SHB		NC	D		SH	EXP	0	рт	ŔŔ				*** *** *** *** *** ** **
TIF-SHC		NC	D		Sн	EXP	0	DT	££		** ** ** ** <u>.</u> ** ** ** ** ** ** ** ** ** **		





INSERVICE TESTING PROGRAM

PREPARED BY : IELP PROGRAM : PRISIM

ISI CLASS 1, 2, 3, AND NO VALVES

IOWA ELECTRIC LIGHT AND POWER

	DUANE	ARNOLD ENERGY C	ENTER	
·····	109 IDENSATE & DEMINERALIZED		ST PROGRAM REVISION	

VALVE NUMBER	F&ID COOR	IST ČLASS	VAL.VE. CAT	VALVE SIZE	VALVE TYPE	ACTUATOR TYPE	NORMAL	TEST	TEST FREQ	MAXIMUM STROKE TIME	MAXIMUM LEAKAGE	RELIEF REQUEST	REMARKS	•
V-09-055	6-2	NC	A	í	GA	м	Ċ	AT-1	RR		NA		PASSIVE	
V-09-111	G-2	NC	A	1	GA	м	С.	AT-1	RR	and and and and and and and and and	NA	a dina dang kang dang dang dang dan dang dan	PASSIVE	-

000000	1.6115 F1.14				1	NSERVICE T	ESTING FRO	GRAM					
	ΥΥΥ ΥΜ : F'R	: IELF		11 1-12 1127 0-11 1000 301- 2015 0-0		LASS 1, 2, IANE ARNOLD					IOWA ELECTRIC AND FOWE		
	Բ&1 ՏҰՏ		1-112 REACTOR	BUILDIN	G COOL 1	NG WATER	15	T PROGRA	M REVI	FAGE SION : 001	: 3 8 , 04/15/87		
VALVE NUMBER	ዮጲ10 COOR	IST CLASS	VALVE CAT	VALVE SIZE	VALVE TYPE	ACTUATOR TYPE	NORMAL FOSITION	TEST	TEST FREQ	MAXIMUM STROKE TIME	MAXIMUM LEAKAGE	RELIEF REQUEST	REMARKS
MO-4841A	E-3	NC	A A	4	GA	ho	Û	AT-1 BTC PIT	RR CS 2Y	020	NA		
MO-4841B	F-3	NC	A	4	GA	MO	0	AT-1 BTC PIT	RR CS 2Y	020	NA		·

.

.

•

.

.

	KED BY AM : PR			, 	ISI C DL	LASS 1, 2, IANE ARNOLI	ESTING PRO 3, AND NC DENERGY CE	VALVES NTER			IOWA ELECTRI AND POU	JER	
	F&1 SYS	TEM : R	I−113 HR & EM	IERGENCY	SERVIC	E WATER	12	T PROGR	AM REVI	PAGE : SIUN : 008			
VALVE NUMBER	F&ID COOR	IST CLASS	VALVE CAT		•	ACTUATOR TYPE	NORMAL POSITION	TEST	FREQ	MAXIMUM STROKE TIME	MAXIMUM LEAKAGE	RELIEF REQUEST	REMARKS
CV-1956A	H3	3	B	4	GA	AŬ	C/FO	BTO FST	OP OF	NA		VR-35 VR-17	
CV-1956B	H-2	3	B	4	GA	AÜ	C/FO	BTO FST	0P 0P	NA		VR-35 VR-17	
CV2080	G~5	3	B	6	GL.	AÜ	C/FO	BTO FST	OP • OF	NA		VR-35 VR-17	
CV-2081	G-5	3	B	6	GL	ÂÛ	C/F0	BTO FST	0P 0P	NA		VR-35 VR-17	
MO-1943A	G8	3	B	12	GA	MO	C/KL	BTC FIT	0P 2Y	072		N 946 946 946 947 947 947 948 948 948 948 948 948 948 948	996 - 1 Mar Pinge Alffer & dit Bad , Enge Same ad
MO-1943B	G~8	3	₿	12	GA	MO	C/KL	BTC PIT	0P 2Y	072			he an an ao ao ao ao ao a
MD-1947	D6	3	ß	14	GA	МО	C	BTO PIT	0P 2Y	NA	19 (19 1) <mark>1</mark> para para para c ana mana para para para para pa	VR1	αθμά διαχοι βιαμα οικοι κατι τι του τιμου μοπο του
MO-2039A	H-4	NC	B	4	'GA	MO	· O	BTC PIT	0F 2Y	070	• •• •• •• •• •• •• •• •• •• •• •• ••		
10-2039B	H3	NC	В	4	GA	MQ	Û	BTC PIT	0P 2Y	070	nt 1760 pape pape pape bay, bay, basi unit dan bagi bagi dan ba		
10-2046	D~5	3	в	14	GA	MO	C	BTO PIT	0P 2Y	NA '		VR-1	
10-2077	H-3	3	B	4	GA	MO	0	BTC FIT	0F 2Y	070	ne din far par en lan ann an an an an an an	1 1998 200 1 1991 1992 1997 1997 1997 1997 1997 199	
10-2078	H-2	3	В	4	GA	MO	0	BTC PIT	0P 2Y	070			

.

•

.

.

•

					 I	NSERVICE T	ESTING FRO	IGRAM	n# ## ar ## 4/2 in	•			
PREPAR		: IELP ESIM					3, AND NO Energy Ce				IOWA ELECTRI , AND FOW		
	149 272		-113 HR & EM	IERGENCY	SERVIC	E WATER	13	T, FROGRA	M REVI		5 8 , 04/15/87		
VALVE NUMBER	P&ID COOR	IST CLASS	VALVE CAT	VAL.VE SIZE	VALVE TYPE	ACTUATOR TYPE	NORMAL POSITION	TEST	TEST FREQ		MAXIMUM LEAKAGE	RELIEF REQUEST	REMARK
FSV-1988	E-7	3	С	. 75	Ŕ٧	SA	С	CT-SF	5Y			VR-5	
FSV-2068	E5	3	С	.75	R¥ .		C	CT-SP	5Y		 	VR-5	
SV-1956A	H-3	NC	B		3 WY	20	NE	BTD	OF	NA	2 8 88 88 88 88 88 88 88 88 88 88 28 28 28	VR-2	,
SV-1956B	H-2	NC	B	·	3WY	20	NE	BTD	٥P	NA	44 dh dh dh qo qo dh an su ad ba qo an ag qo ,	VR-2	
SV2080	G-5	NC	B		ЗWY	02	NE 1	BTD	0F [,]	NA	** ** ** ** ** ** ** ** ** ** ** ** **	VR-2	
SV-2081	G-5	NC	 Fe			02	NE	BTD	ÛF	NA	*** ** ** ** ** ** ** ** ** ** ** ** **	VR-2	

. • .

· ·

.

۰.,

· · ·

•

. .

,

•..

· .

• PREPARED BY : IELP PROGRAM : PRISIM

ġ

ISI CLASS 1, 2, 3, AND NC VALVES DUANE ARNOLD ENERGY CENTER

IOWA ELECTRIC LIGHT AND POWER

	- F'& I SYS	D M TEM : N	1-114 IUCLEAR	BOILER			15	T PROGR	AM REVI	FAGE SION : 008	: 6 , 04/15/87		
VALVE NUMBER	F&ID COOR	IST CLASS	VALVE CAT	VALVE SIZE	VAL VE TYPE	ACTUATOR TYPE	NORMAL POSITION	TEST	TEST FREQ	TIME	MAXIMUM LEAKAGE	RELIEF REQUEST	REMARKS
AP-4412A	G-3	NC	В	-	4WY	AP	NE	BTD FST	0P 0P	NA	, · · ·	VR-2 VR-17	
AF-4412B	G-3	NC	B		4WY	AF	NE	BTD FST	OF OP	NA	** ** ** ** ** ** ** ** ** ** ** ** **	VR-2 VR-17	
AP-4413A	G-1	NC	В	·	4WY	AF	NE	BTD FST	0F 0F	NA		VR-2 VR-17	1-4 1-4 0-9 0-9 0-9 0-9 0-9 0-9 0-9 0-9
AF'-4413B	G-1	NC	B		4WY .	. AF	NE	BTD FST	. OP OP	NA		VR-2 VR-17	*****
AF-4415A		NC	В		4WY	AP	NE	BTD FST	OP OP	NA	ter er få tid er for en som som som gar par og som	VR-2 VR-17	
AF-4415B		NC	·B		4WY	A۴	NE	BTD FST	OF OP	NA		VR-2 VR-17	44 8 4 47 48 48 48 48 48 48 48 48
AP-4416A		NC	B	4	4 WY	AP	ŅE .	BTD FST	OP OP	NA	ner men som när hen som som som som som som som som	VR-2 VR-17	
AF-4415B		NC	B	***	4WY	AF [.]	NE	BTD FST	0F 0P	NA		VR-2 VR-17	
AP-4418A		NC	B	~~	4 WY	AF .	NE	BTD FST	0P 0P	NA		VR-2 VR-17	ine ofte the back poor the top and and
AF-44188	(NC	£		4WY ·	AF	NE	BTD FST	OF OP	NA	-	VR-2 VR-17	
AF-4419A		NC	₿		4WY	AP	NE	BTD FST	OP OF	NA		VR-2 VR-17	1.00 0.00 0.00 0.00 0.00 0.00 0.00 0.00
AF-4419B		NC	B		AWY	AP	NE	BTD FST	0P 0P	NA		VR-2 VR-17	N, 22 41 21) 22 20 107 22 23





PREPARED BY : IELP PROGRAM : PRISIM

ISI CLASS 1, 2, 3, AND NC VALVES DUANE ARNOLD ENERGY CENTER IOWA ELECTRIC LIGHT -AND FOWER

.

VALVE NUMBER	₽&ID COOR						· 15	T PROGRA	M REVI	SION : 00	7 B , 04/15/87		
	****	IST CLASS	VAL VE CAT			ACTUATOR TYPE		TEST	TEST FREQ	MAXIMUM STROKE TIME	MAXIMUM LEAKAGE	RELIEF REQUEST	REMARK S
AF-4420A		NC	B		4WY	AF	NE	BTD FST	0F 0P	NA		VR-2 VR-17	
AF-4420B		NC	В		4WY	AF'	NE	BTD FST	OF OF	NA	από της π <i>ας</i> τ <i>ας τ</i> ας από από του του που πός που <u>του</u> <u>το</u> <u>το</u> <u>τ</u>	VR-2 VR-17	
AP-4421A		NC	B		4WY	AF [.]	NE	BTD FST	0 P 0P	NA		VR-2 VR-17	••• ••• ••• ••• ••• ••• ••• •••
AF-4421B		NC	В	• • • • • • • • • • • • • • • • • • •	4WY	À۴	NE	BTD FST	OF OF	NA	1999 (1997 (2007 (2007 (2007 (2007 (2007 (2007 (2007 (2007 (2007 (2007 (2007 (2007 (2007 (2007 (2007 (2007 (200	VR-2 VR-17	
CV-4412	E-3	1	A	20	GL.	AÜ	0/FC .	AT-1 BTC FST PIT	RR OP RR 2Y	005 ·	NA	VR-17	
CV-4413	E-2	1	A	20	GL.	AO	0/FC	AT-1 BTC FST FIT	RR OP RR 2Y	005	NA	VR-17	
CV-4415	C-7	í	A	20	GL.	AÜ	0/FC	AT-1 BTC FST PIT	RR OF RR 2Y	005	NA	VR-17	A 4 0 4 0
CV-4415	C8	1	A	20	GL.	AD	0/FC	AT-1 BTC FST FIT	RR OF RR 2Y	005	NA	Vk-17	
CV-4418	C3	1	A	20	GL	A0	0/FC	AT-1 BTC FST PIT	RR OP OP 2Y	005	NA	VR-17	•

• •





.



PREPARED BY : IELP . PROGRAM : PRISIM

ISI CLASS 1, 2, 3, AND NC VALVES DUANE ARNOLD ENERGY CENTER

IOWA ELECTRIC LIGHT AND FOWER

	1 & 4 2 Y 2	DN STEM : N	1-114 RUCLEAR	BOILER				T PROGR	AM REVI	PAGE SION : 008	, 04/15/87		
VALVE NUMBER	P&ID COOR	IST CLASS	VALVE CAT	VALVE SIZE	VALVE TYPE	ACTUATOR TYPE	NORMAL POSITION	TEST	TEST FREQ	MAXIMUM STROKE TIME	MAXIMUM LEAKAGE	RELIEF REQUEST	REMARKS
CV-4419	C-2	1	A	20	նԼ	ΑQ	0/FC	AT-1 BTC FST PIT	* **** RR DP RR 2Y	005	NA	VR-17	
CV-4420	E7	1	A	20	GL.	AÜ	0/FC	AT-1 BTC FST PIT	RR OP RR 2Y	005 •	NA	VR-17	
CV-4421	E-8	1	A	20	GL	AO	0/FC	AT-1 BTC FST PIT	RR OP RR 2Y	005	NA	¥R~17	
MO-4423	B3		A	3	GA .	MO	С	AT-1 BTC PIT	RR 0P 2Y	015	NA		-
10-4424	B3	1	A	3	GA	MO	C .	PIT	RR OP 2Y	015	NA	fan gen and fait fan fan ann an an an	
10-44 41	B3	1	A/C	16	SCK	Sam	0/KL	AT-1 BTC CT-CC FIT	RR CS CS 2Y	053	NA	VR-37	
10-4442	B-7	í	A/C	16	SCK	Sam	0/KL	AT-1 BTC CT-CC PIT	RR CS CS 2Y	053	NA	VR-37	



PREPARED BY : IELP PROGRAM : PRISIM

ISI CLASS 1, 2, 3, AND NC VALVES DUANE ARNOLD ENERGY CENTER IOWA ELECTRIC LIGHT AND FOWER

	P&1 SYS	D M TEM : N	i- 114 IUCLEAR	BOILER			12	T PROGRA	M REVI		: 9 9 , 04/15/87		
VALVE NUMBER	P&ID COOR	IST CLASS	VALVE CAT	VALVE SIZE	VAL.VE TYPE	ACTUATOR TYPE	NORMAL FOSITION	TEST	TEST FREQ	MAXIMUM STROKE TIME	MAXIMUM LEAKAGE	RELIEF	REMARKS
FSV-4400	E-5	1	₿∕C	6	Ŕ٧	SAF	С	BTO CT-SP	ያዮ 5 የ	NA		VR6	
PSV-4401	E4	1	B/C	6	RV	Sap	С	BTO CT-SP	SF 5Y	NA	der 1000 filte fore som och och och den som and som som som som som	VR-6	
F'SV-4402	6-3	1	B/C	6	₽V	SAP	C .	BTO CT-SP	SF 5Y	NA	17 79 32 5 7 58 58 58 59 10 10 40 40 50 50 50 50 50 50	VR-6	
PSV-4403	C ~6	1	С	6	٧2	SA	C	CT-SF	5Y		ar an bai bai tar ak ak ba an an	a anto della addi anti bila koni pili kan pan	
PSV-4404	C~5	1	С	6	S۷	SA	С	CT-SP	5Y		An ann ann 26an ann 28a ann an a	a Maja dalar dalar unit oner mala dalar over ener	tan min min kali any min par dia dia 1
PSV-4405	C4	1	B/C	6	RV	SAP	С	BTO CT-SP	SF 5Y	•NA	nn ann ann ann ann ann ann an an an an a	VR-6	
FSV-4405	E-6	1	B/C	6	κ٧	SAP	C	BTO CT-SP	ሪዮ 5 የ	NA		VR-6	••• •• •• •• •• •• •• •• •• •• ••
F SV4407	E-6	í	B/C	6	RV	SAP	С	BTO CT-SP	SF [.] 5Y	NA	an ann an can tar an	VR-6	
PSV-4439A	H-4	3	C	6	R¥	SA	C	CT-SF	5Y	** ** ** ** ** ** ** ** ** **	• • • • • • • • • • • • • • • • • • •	VR-5	
FSV-4439B	£1-4	3	C	6	RV	SA	С	CT-SF	5Y	Ft en u u 4.3 LT FN AL AL 44 .	** ** ** *** *** *** *** *** *** *** *	VR-5	
PSV-4439C	A-5	3	C	6	ϜV	SA	С	CT-SF	5Y	en ee		VR-5	
F'S'V4439D	B-4	3	C	6	ŔΫ	SA	C	CT-SF	5Y	••• •• •• •• •• •• •• •• •• •	• • • • • • • • • • • • • • • • • • •	VR-5	
FSV-4439E	A-5	3	С	6	Ŕ٧	SA	C	CT-SF	5Y			VR-5	
F'SV-4439F	A-4	3	C	6	R۷	SA	C	CT-SP	5Y			VK-5	





PREPARED BY : IELP PROGRAM : PRISIM

ISI CLASS 1, 2, 3, AND NC VALVES DUANE ARNOLD ENERGY CENTER IOWA ELECTRIC LIGHT AND POWER

	F&I SYS	D M TEM : N	I-1 14 IUCLEAR	BOILER			. 15	T PROGRA	M REVI		: 10 B , 04/ 15/8 7		
VALVE NUMBER	F&1D COOR	IST CLASS	VALVE CAT	VALVE Size	VAL.VE TYPE	ACTUATOR TYPE	NORMAL POSITION	TEST	TEST FREQ	MAXIMUM STROKE TIME	MAXIMUM LEAKAGE	RELIEF REQUEST	REMARKS
SV4400	E-5	NC	в	-n '	3WY	20	ND	BTE	ያዮ	NA		VR-6	
SV-4401	E4	NC	В		3WY	so .	ND	BTE	SP	NA		VR-6	900 2001 2001 2002 2004 2007 2007 200
SV-4402	C6	NC	В		3WY	50	ND	BTE	SP	NA		VR-6	
SV-4405	C-4	NC	B		3WY	20	ND	BTE	SP	NA	an tar bar san dan dan diki tak dan dan pan taki akt diki diki di	VR-6	
SV-4406	E6	NC	B	**	3WY	50	ND	BTE	SF	NA	Af data dara bar bar anti mda anno ann page page page page page page	VR-6	
SV-4407	E6	NC	B		3WY	50	ND	, BTE	SP	NA	ne dala anti anti cici con tico anti cica nella bila dala anti anti	VR-6	Adad (da, 1991) -000, 1992 (and 1992 (da, 1997 (mag))
SV-4412A	G~8	NC	B		3WY	S 0	NE	BTD	OP	NA	en lann anns kinn fann anns anns anns gans anns anns anns a	VR-2	ting page ting ting ting that that can pair allo
SV-44128	G~8	NC	B		3WY	S 0	NE	BTD	OP	NA	we have not over the over and and and end over any over $a_{\rm end}$ and $a_{\rm end}$	VR-2	*** 848 -44 -44 -44 -44 -44 -44 -44 -44 -44
SV-4 41 3A	F-2	NĊ	B		3WY	\$0	NE	BTD	OP	NA		VR-2	
SV4413B	F-2	NC	B	•••	3WY	20	NE	BTD	OP	NA	ar ann ann ann ann ann ann ann ann ann a	VR2	anna 4009 600: 200- 0-10 200- 2014 8128 2000 4
SV-4415A	G-8	NC	B		3WY	50	NE	BTD	0P	NA	na alla dana alla bish kari fan ann fan ann ann ann ann ann ann	VR-2	
SV-4415B	G8	NC	B		зыл	50	NE	BTD	٥P	ŅA		VR-2	
SV-4415A	· G8	NC	B	**	3₩Y	so`	NE ·	BTD	0P	NA	n bila ann ann ann Ann ann ann ann ann ann an	VR-2	
SV-4416B	G-8	NC	В		3WY	· S0	NE	BTD	٥P	NA		VR-2	



PREPARED BY : IELP FROGRAM : FRISIM

ISI CLASS 1, 2, 3, AND NO VALVES DUANE ARNOLD ENERGY CENTER

IOWA ELECTRIC LIGHT AND POWER

	F&1 SYS	D M TEM : N	-114 UCLEAR	BOILER			15	T PROGRA	M REVI	PAGE SION : 00	: 11 8 , 04/15/87		
VALVE NUMBER	P&ID COOR	IST CLASS	VALVE CAT	VALVE S'IZE	VALVE TYPE	ACTUATOR TYPE	NORMAL FOSITION	TEST	TEST FREQ	MAXIMUM STROKE TIME	MAXIMUM LEAKAGE	RELIEF REQUEST	REMARKS
SV-4418A	G-8	NC	Ŀ		ЗМХ	02	NE	BTD	<u>u</u> P	NA		VR-2	
SV-4418B	G~8	NC	В		3WY	20	NE .	BTD	OF	NA	·· ·· ·· ·· ·· ·· ·· ·· ·· ·· ·· ·· ··	VR-2	
SV-4419A	G8	NC	B		3WY	\$0	NE	BTD	ÛP	NA		VR-2	
SV-4419B .	G-8	NC	B		3WY	2.0	NE	BTD	UF	NA		 VR-2	
SV-4420A	G-8	NC	·В		3WY	02	NE	BTD	ÛP	NA		VR-2	
SV-4420B	G-8	NC	B		3WY	2.0	NE	BTD	0P	NA		VR-2	
SV-4421A	G-8	NC	В		3WY	SÖ	NE	BTD	0P	NA		VR-2	
SV-4421B	G-8	NC	B		3WY	\$ 0	NE	BTD	0P	NA	** ** ** ** ** ** ** ** ** ** ** ** **		
V-14-001	₿6	1	A/C	16	СК.	SA	0	AT-1 CT-CC CT-CO PIT	RR RR 0P 2Y		NA	VR-4	
V-14-003	B4	1	A/C	16	СК	SA	0	AT-1 CT-CC CT-CO FIT	RR C S OP 2Y		NA		
/-14-009	F-6	NC	A/C	2	СК	۶A	C.	AT-6 CT-CC	RR RR		NA	VR-19	· · · · · · · · · · · · · · · · · · ·
V-14-014	D6	NC	A/C	2	CK	SA	С	AT-6 CT-CC	RR RR	*** * ** / ** / ** * *** *** **** **** ***	NA	VR-19	

PREPARED BY : IELP -PROGRAM : PRISIM

ISI CLASS 1, 2, 3, AND NC VALVES DUANE ARNOLD ENERGY CENTER

IOWA ELECTRIC LIGHT AND POWER

	F&I SYS		-114 UCLEAR	BOILER			15	T PROGRA	M REVI	PAGE : SION : 008 ,			
VALVE NUMBER	P&ID COOR	IST CLASS	VALVE CAT	VALVE SIZE	VALVE TYPE	ACTUATOR TYPE	NORMAL POSITION	TEST	FREQ	MAXIMUM STROKE TIME	MAXIMUM LEAKAGE		REMARKS
V-14-015	G5	· NC	A/C	2	СК	SA	C,	AT-6 CT-CC	RR RR		NA	VR-19	·
V-14-015	D-5	NC	A/C	2	СК	AZ	C	AT-6. CTCC	RR RR		NA	VR-19	
V-14-032	F-1	NC	A/C	.75	CK	SA	0	AT-6 CT-CC	RR RR	ne parte parte forte dans dans diver dans dans dans dans dans dan	NA	VR-19	Net for any set of part of the for
V-14-100	G-8	. NC	A/C	. 75	СК	SA	0	AT-6 CT-CC	RR RR		NA	VR-19	
V-14-104	G8	NC	A/C	.75	СК	SA	Û.	AT-6 CT-CC	RŔ ŔŔ	n 1999 - Sala Anna Sala Sala Sala Sala Sala Sala Sala S	NA	۷⊼-19	
V-14-108	G-8	NC	A/C		CK	SA	0	AT-6 CT-CC	RR RR		NA	VR-19	
V-14-112	G-8	NC	A/C	.75	СК	SA	0.	AT-6 CT-C C	RŔ RR		NA	VR-19	
V-14-116	6-8	NC	A/C	. 75	СК	AZ	0	AT-6 CT-CC	RR RR	· · · · · · · · · · · · · · · · · · ·	NA	VR-19	Ru
V-14-120	G-8	NC	A/C	. 75	СК	۶A	0	AT-6 CT-CC	RR RR		NA	VR-19	an an an an 2n 2n 2n an 4a ar
V-14-124	G~8	NC	A/C	.75	СК	SA	0	AT-6 CT-CC	RR RR	. 1996 and - 2000 and	NA	VR-19	
XFV4453A	E-3	2	.A/C	1	XFC	SA .	0.	AT-2 CT-CC PIT	RR RR 2Y			V R8	
XFV-4453B	D-3	2	A/C	1	XFC	SA	0	AT-2 CT-CC PIT	RR RR 2Y	• •	*******	VR-8	ha at an as ar an ar an ar



PREPARED BY : IELP PROGRAM : PRISIM

,

ISI CLASS 1, 2, 3, AND NC VALVES DUANE ARNOLD ENERGY CENTER IOWA ELECTRIC LIGHT AND POWER

•		TEH : N	UCLEAR				12	T PROGRA	M REVI	FAGE SION : 008	: 13 3 , 04/15/87		
VALVE NUMBER	FAID COOR	IST CLASS		VAL.VE STZE		ACTUATOR TYPE		TEST	FREQ	MAXIMUM STROKE TIME	MAXIMUM LEAKAGE	REQUEST	REMARK
XFV-4 4 54A	E-3	2	A/C	1	XFC	SA	0 ·	AT-2 Ct-CC PIT	RR RR 2Y			_ VR-8	
XFV-4454B	D1	2	A/C	1	XFC	SA	0	AT-2 CT-CC PIT	RR RR 2Y	· ·		VR-0	
XFV-4455A	C-3	2	A/C	1	XFC	SA	0	AT-2 CT-CC PIT	RR RR 2Y			VR-8	
XFV-4455B	C-3	2	A/C	1	XFC	SA	0	AT-2 CT-CC PIT	RR RR 2Y		• •• • • • • • • • • • • • • • • • • •	VR-8), 4, 4, -, -, ,, ,, ,, ,, ,,
XFV-4456A	C-3	2	A/C	1	XFC	SA	0	AT-2 CT-CC PIT	RR RR 2Y			VR-8	
XFV-4456B	C-3	2	A/C	1	XFC	SA	0	AT-2 CT-CC PIT	RR RR 2Y	•,, •• •• •• •• •• •• •• •• •• ••	• • • • • • • • • • • • • • • • • • •	VR-8	
XFV-4457A	E-7	2	.A∕C	1	XFC	SA	•	AT-2 CT-CC PIT	RR RR 2Y			VR8	
XFV-4457B	D7	2	A/C	1	XFC	SA	0	AT-2 CT-CC PIT	RR RR 2Y	** ** ** ** ** ** ** ** ** **	··	VR8	
XFV4458A	E-7	2	A/C	1	XFC	۶۵	0	AT-2 CT-CC PIT	RR RR 2Y			VR-8	

.

						19 109 101 ² 109 241 14 9 141 141 141 140 140					. Page dage bank bank bank bank bank bank bank bank		e '	
	KED BY M : PR	: IELP ISIM	· · · · · · · · · · · · · · · · · · ·		ISI C	LASS 1, 2,	TESTING PROG 3, AND NC D ENERGY CE	VALVES			IOWA ELECTRIC AND FOWE	C LIGHT . Er		ł
	F&1 SYS		1-114 IUCLEAR	BOILER			IS	T PROGRA	M REVI	FAGE ISION : 008	: 14 , 04/15/87			
VALVE NUMBER		IST CLASS	VAL.VE CAT	VAL VE SIZE	ͳϒϜ·ℇ	ACTUATOR TYPE	NORMAL POSITION		TEST FREQ	MAXIMUH STROKE . TIME	MAXIMUM LEAKAGE	RELIEF REQUEST	REMARKS	•
XFV-4458B	D7	2	A/C	1	XFC	SA	0	AT-2 Ct-Cc Pit				V⊼~8		
XFV-4459A	C7	2	A/C	1	XFC	SA	0	AT-2 CT-CC PIT	RŔ ŔR 2Y	,,		VR-8	• • • • • • • • • • • • • • • • • • •	
XFV-44598	G7	2	A/C	1	XFC	SA	0	AT-2 CT-CC PIT	RR RR 2Y			_VR-8		
XFV-4460A	C-7	2	A/C	1	XFC	SA	0.	AT-2 CT-CC PIT	RR RR 2Y			VƘ-8	r anne baile quait anne a ngo puar ango mga gga	
XFV-4460B	C7	2	A/C	1	XFC	SA	0	AT-2 CT-CC PIT	<u></u> Я В 2 Ү	e ant fait fait fait an		VR-8		

· ·

•

. .

•

• •			**	•	• ••• ••• ••• ••• ••• •••		.						
PREPAR PROGRA		: IELF ISIM		L) 401 411 111 411 411 411 411 411	1.51 (LASS 1, 2,	ESTING PRO 3, AND NC ENERGY CE	VALVES	,		IOWA ELECTRI AND FOW		
	SYS	TEM : F	1-115 REACTOR	VESSEL	INSTRUM	IENTATION	. 15	T PROGRA	M REVI	PAGE : SION : 008			
VALVE NUMBER	F&ID	IST CLASS	VALVE CAT	VALVE STZE	VALVE TYPE	ACTUATOR Type	NORMAL FOSITION	TEST	TEST FREQ	MAXIMUM STROKE TIME	MAXIMUM LEAKAGE	RELIEF REQUEST	REMARKS
SV-4594A	D-3	2	. A		GL.	50	С	AT-1 BTC FST PIT	RR OP OP 2Y	5	NA	VR34 VR17	
V4594B	D-3	2	A	1	GL.	50 ,	C	AT-1 BTC FST FIT	RR OF OP 2Y	* 5	NA	VR-34 VR-17	HAR DAR LAR C ALL AND AND AND AND A
V-4595A *	D-3	NC	A	1	GL.	50	C	AT-1 BTC FST PIT	RR OF OP 2Y	5	NA	VR-34 VR-17	
SV-4595B	D6	NC	A	1	GL	50	C	AT-1 BTC FST PIT	RR OP OP 2Y	5	NA	VR-34 VR-17	444 (Mai (Agi, Cal) (Agi, Cal) (Agi, Cal)
(FV-4501A	E-3	2	A	1	XF'C	SA	0.	AT-2 CT-CC PIT	ћћ R r 21			VR8	
FV-4501B	E-3	2	A	1	XFC	SA	0	AT-2 CT-CC FIT	RR RR 2Y			VR-8	
FV-4503	E-3	2	A	1.	XFC	SA .	0	AT-2 CT-CC PIT	RR RR 2Y			VR-8	
(FV-4504	E-6	2	A	1	XFC	SA	0 ·	AT-2 CT-CC PIT	RŔ RR 2Y		199	VR8	

•

· · ·

.

.

10WA ELECTRIC LIGHT AND POWER

PREPARED BY : TELF PROGRAM : PRISIM

ISI CLASS 1, 2, 3, AND NC VALVES DUANE ARNOLD ENERGY CENTER

- 1	r r(u	GIVH	C1	: 1	- F S 4	13.	1.61	

		TEM F	i-115 EACTOR		INSTRUM	ENTATION	15	T PROGRA	M REVI	FAGE SION : 008	: 16 , 04/15/87		
VALVE NUMBER	F&ID	IST CLASS	VAL VE CAT	VAL VE SIZE	VAL.VE TYPE	ACTUATOR TYPE	NORMAL POSITION	TEST	FREQ	MAXIMUM STROKE TIME	MAXIMUM LEAKAGE	RELIEF REQUEST	REMARKS
XEV-4505	C-3	2	A	1	XFC	SA	0	AT-2 Ct-CC PIT '	RR RR 2Y			VR-8	
XFV-4506	B3	2	A	1	XFC	SA	0	AT-2 CT-CC PIT	RR RR 2Y		nan tana 1921 ang tang tang tang tang tang tang tang	VR-8	at tau tau tau tau t au tau tau tau ta
XFV-4507/	B-3	2	A	í	XFC	SA :	0	AT-2 CT-CC PIT	RŔ ŔR 2Y	• • • • • • • • • • • • • • • • • • •		VR-8	
XFV-4508	B-3	2	A	1	XFC	SA	0	AT-2 CT-CC P1T	RR RR 2Y		ana ang kak kak kak gan dan gan kak kap p	VR-8	97 page 9649 pilo Lap 1996 est y an e
XFV-4510Ą	E-6	2	A	1	XFC	SA	0	AT-2 CT-CC PIT	RŔ RR 2Y	a man daan daan tada cada yaan aan cada kada yaan		VR-8	- 246 ,48 246 246 246 246 246 246 246 246 246 246
XFV-4510B	E7	2	. A	i	XFC	SA	0	AT-2 CT-CC PIT	RR RR 2Y			VR-8	,,
XFV-4511	B -3	2	A	1	XFC	SA	0	AT-2 CT-CC FIT	RR RR 2Y		1999 1999 1999 1999 1999 1999 1999 199	VR-8	11 Jun 10, 10, 10, 10, 10, 10, 10, 10, 10, 10,
XFV-4512	B-3	2	A	1	XFC	SA	0.	AT-2 CT-CC FIT	RR RR 2Y		11u .u .u .u .u .u .u .u .u .u	٧κ−8	
XFV-4513	B-3	· 2	A	1	XFC	SA	0	AT-2 CT-CC PIT	RR RR 2Y			VR-8	

PREPARED BY : IELP PROGRAM : PRISIM

ISI CLASS 1, 2, 3, AND NC VALVES DUANE ARNOLD ENERGY CENTER

.

IOWA ELECTRIC LIGHT. AND POWER

					DL	JANE AKNULI	ENERGY CE	NTER					,
	F & I S Y S	D M TEM : F	1-115 REACTOR	VESSEL	INSTRUM	IENTATION	IS	T PROGRA	M REVI	FAGE 510N : 008	, 04/15/87		
VALVE NUMBER		IST CLASS	CAT		< TYPE	TYPE	NORMAL	TEST	TEST FREQ	MAXIMUM STROKE TIME	MAXIMUM LEAKAGE	REQUEST	REMARKS
XFV-4514	B-3	2	A	ţ.	XFC	SA	0.	AT-2 Ct-CC Pit	RR RR 2Y			VR-8	
XFV-4515	B-3	2	A	1	XFC	SA	0	AT-2 CT-CC PIT	RR RR 2Y		1991 - 1997 - 1994 - 1994 - 1994 - 1997 - 1997 - 1997 - 1997 - 1997 - 1997 - 1997 - 1997 - 1997 - 1997 - 1997 -	VR-8	
XFV4516	B-3 .	2	A		XFC	SA	0.	AT-2 CT-EC PIT	RR RR 2Y	n (N)	nit fan die fan ter ter om aak een oor ger ger gevoer	VR8	-86, 944, 964, 474, 477, 477, 478, 548, 546, 54
XFV-4518	D&	2	A	1	XFC		0	AT-2 CT-CC PIT	RR RR 2Y	Ann Inn Ann Ann	an bat fak fak fak fak han bak bak bak bak bak bak	VR8	68,,
XFV-4519	D-3	- 2	A	1	XF C	5A	0	AT-2 CT-CC PIT	RR RR 2Y		• .	VR-8	to an av to an ac at a -
XFV-4528	D6	2	A	1	XFC	SA	0	AT-2 CT-CC PIT	RR RR 2Y	· · · · · · · · · · · · · · · · · · ·		VR-8	** ** ** ** ** ** ** ** **
XFV-4562	, E-3	2	· A	1	XFC	SA	Ó	AT-2 CT-CC PIT	RR RR 2Y			VR-8	
XFV-4578	F6	2	A	1	XFC	SA	0	AT-2 CT-CC PIT	RR RR 2Y			_VR-8	** ** ha =* di. <u>-</u> * <u>-</u> * -* -
XFV-4579	F6	2		i		SA	0	AT-2 CT-CC PIT	RR RR 2Y	*** ** ** ** * * ** ** ** ** **		VR8	*****
		*** *** #** -** -* *** **											

IOWA ELECTRIC LIGHT AND POWER

PREPARED BY .: IELP PROGRAM : PRISIM

FAID

ISI CLASS 1, 2, 3, AND NC VALVES DUANE ARNOLD ENERGY CENTER M-115 FAGE : 18 SYSTEM : REACTOR VESSEL INSTRUMENTATION IST PROGRAM REVISION : 008 , 04/15/87

VALVE NUMBER	F&ID COOR		VALVE CAT	VAL VE SIZE	VALVE TYPE	ACTUATOR TYPE	NORMAL POSITION	TEST	TEST FREQ	MAXIMUM STROKE TIME	MAXIMUM LEAKAGE	RELIEF REQUEST	REMARKS
XFV-4580	F-6	2	A	1	XFC	SA	0	AT-2 CT-CC PIT	RR RR 2Y			٧&8	
XFV-4581	E-6	2	A	t	XFC	SA	0	AT-2 CT-CC PIT	RR RR 2Y			VR-8	· · · · · · · · · · · · · · · · · · ·
XFV-4582	E-6	. 2	A	1	XFC	SA	0	AT-2 CT-CC FIT	RR RR 2Y			VR-8	
XFV4583	E-6	2	A	i	XFC	SA	0	AT-2 CT-CC PIT	RR RR 2Y			VR-8	
XFV-4584	D3	2	A	1	XFC	SA	0	AT-2 CT-CC FIT	RR RR 2Y			VR-8	
XFV-4585	D-6	2	A	1	XFC	SA	0	AT-2 CT-CC PIT	RR RR 2Y			VR-8	
XFV-4583	F-3	2	A	1	XFC	SA	0	AT-2 CT-CC FIT	RR RR 2Y			VR8	•
XFV-4587	F3	2	A	i .	XFC	SA	0.	AT-2 CT-CC PIT	RR RR 2Y	3 3 3 3 .		VR-8	
XFV-4588	′ F-3	2	A	i	XFC	SA	0	AT-2 CT-CC FIT	ŘŘ RR 2Y		40 40 4	VR-8	
		*** *** *** *** *** *** ***	······ ··· ··· ··· ··· ···	*****	*****	•							



.



INSERVICE TESTING PROGRAM

PREFARED BY : IELP PROGRAM : PRISIM

ISI CLASS 1, 2, 3, AND NC VALVES DUANE ARNOLD ENERGY CENTER IOWA ELECTRIC LIGHT AND POWER

	F&I SYS		I-115 EACTOR	VESSEL	INSTRUM	ENTATION	15	T PROGRA	M REVI	FAGE SION : 00	19 8 , 04/15/87		
VALVE NUMBER	F&ID COOR	IST CLASS	VALVE CAT	VALVE SIZE	VALVE TYPE	ACTUATOR TYPE	NORMAL POSITION	TEST	TEST FREQ	MAXIHUM STROKE TIME	MAXIMUM LEAKAGE	RELIEF REQUEST	REMARKS
XFV-4589	E3	2	A	1 .	XFC	SA	0	AT-2 Ct-CC Pit	RR KR 2Y			VR-8	
XFV-4590	D-3	2	A	1	XFC	SA	0	AT-2 CT-CC P1T	RR RR 2Y			VR-8	
XFV-4591	D3	2	A	1	XFC	SA	0	AT-2 CT-CC PIT	RR RR 2Y		an Mit tan fall fur tan san ant an ing tan an an an	VR-8	nan dan yan tan yan dan tan tan an



PREPARED BY : IELP PROGRAM : PRISIM

ISI CLASS 1, 2, 3, AND NC VALVES DUANE ARNOLD ENERGY CENTER IOWÀ ELECTRIC LIGHT AND FOWER

•.	P&I SYS		-116 EACTOR	RECIRCU	LATION		rs	T PROGRA	M REVI	PAGE SION = 008	, 04/15/87		
VALVE NUMBER	P&ID COOR	IST CLASS	VAL VE CAT	VAL.VE SIZE	VALVE TYPE	ACTUATOR TYPE	NORMAL POSITION	TEST	FREQ	MAXIMUM STROKE TIME	MAXIMUM LEAKAGE	RELIEF REQUEST	REMARKS
CV4639	F6	2	A	. 75	GL.	AÜ	0	AT-1 BTC PIT	RR OP 2Y	005	Na	VR-37	
CV4640	F6	NC	A	. 75	GL.	AÜ	O	AT-1 BTC PIT	RR 0P 2Y	005	NA	Vk-37	
M0-4627	C-2	1	₿	22	GA	ЮM	0	BTC PIT	CS 2Y	036			ena yan iyu yan yin kan kan kan uma w
M0-4628	C-8	1	B	22	GA	MO	0	BTC PIT	CS 2Y	036			·· · ·
MO-4629	C3	t	В	4	GA	MO	0	BTC PIT	C <i>S</i> 2Y	036			
MO-4630	с8 '	1	B	4	GA	мо	0	BTC P1T	CS 2Y	036			
SV-4639	F∹6	NC	B		3WY	SO	ND	BTD	0P	NA	funn ban, finne bake finne eren gang, diese dage ginge ginge gen	VR-2	
SV-4640	F6	NC	в		3WY	20	ND	•BTD	0F	NA	famm dan sina para dak tak pang dagi ang baga baga dagi	VR-2	
XFV-4607	A5	2	A/C	1	XFC	SA	0	AT-2 CT-CC P1T	RR RR 2Y		for our con the set to read and and and and the set	VR-8	
XFV-4608	A-5	2	A/C	1.	XFC	SA	0	AT-2 CT-CC PIT	RR RR 2Y	, 		VR-8	
XFV-4611	A-5	2	A∕Ç	1	XFC	SA	0.	AT2 CT-CC PIT	RR RR 2Y	,,,,		VR−8	*** ***

PREPARED BY : IELP PROGRAM : PRISIM

IST CLASS 1, 2, 3, AND NC VALVES DUANE ARNOLD ENERGY CENTER . In 1981 man, oler day and task ball take that bade and task and and and take and take take task task task daw ta

IOWA ELECTRIC LIGHT AND FOWER

		TEM : R					. 15				: 21 , 04/15/87		
VALVE NUMBER	F&ID COOR	IST CLASS	VALVE CAT		VAL.VE TYPE	ACTUATOR TYPE	NORMAL POSITION	TEST	TEST FREQ	MAXIMUM STROKE TIME	MAXIMUM	RELIEF REQUEST	REMARKS
XFV-4612	A5	2	A/C	1	XFC	SA	O	AT-2 Ct-CC Pit	RŘ ŘŘ 2Y			VR-8	
XFV4637	E6	2	A/C	1	XFC	SA	0 ·	AT-2 CT-CC PIT	RR RR 2Y		• •	VƘ-8	
XFV-4638	E6	2		í	XFC	. SA	0	AT-2 CT-CC PIT	КК КК 2Ү			VK-8	var 24, til fat fat fat fær fær fær
KFV4641A	H-7	2	A/C	1	XFC	SA	0	AT-2 CT-CC PIT	ƙR ƙR 2Y	a nar ann ann ann ann ada ada ann ann ann ann	,	VR-8	
XFV4641B	H-3	2	A/C	1 -	XFC	SA	0	AT-2 CT-CC P1T	RR RR 2Y			VR-8	248 - 742 (19) 199 - 199 - 199 - 199 - 199 - 199
XFV-4642A	<u></u> G7	2	A/C	1	XFC	SA	Q.	AT-2 CT-CC PIT	RR RR 2Y	r off the off the fact and		VR-8	
XFV-46428	G3	2	A/C	1	XFC	SA	0	AT-2 CT-CC PIT	RR RR 2Y		, ar far far far olf mer far far far far far her her her her far her her her her her her her her her he	VR-8	and and conjust and all one and
XFV-4643A	G-7	2	A/C		XFC	SA	0	AT-2 CT-CC FIT	RR RR 2Y			VR-8	
XFV-4643b	G-3	2	A/C		XFC	SA	0	AT-2 CT-CC FIT	RR RR 2Y			VR-8	* ** ••* •** * ** * ** ••* •** •**



1.





INSERVICE TESTING PROGRAM

PREPARED BY : IELP PROGRAM : PRISIM


PROGRAM : PRISIM ISI CLASS 1, 2, 3, AND NC VALVES DUANE ARNOLD ENERGY CENTER

IOWA ELECTRIC LIGHT AND POWER

	F&I SYS		I-116 EACTOR	RECIRCU	LATION		15	T PROGRA	M·REVI	FAGE : STON : 008	22 , 04/15/87		
VALVE NUMBER	F&ID COOR	IST CLASS	VAL.VE CAT	VALVE SIZE	τγρε		NORMAL POSITION	TEST	TEST FREQ	MAXIMUN STROKE TINE	MAXIMUM LEAKAGE	RELIEF REQUEST	REMARKS
(FV-4544A	G-7	2	A∕C	1	XFC	SA	0 :	AT-2 Ct-CC PIT	RR RR 2Y			VR-8	
(FV-4644B	G3	2	A∕C	1	XFC	SA	0	AT-2 CT-CC PIT	RR RR 2Y		,	. VR−8	
(FV4663	F-4	2	A/C	1	XFC	SA	0	AT-2 CT-CC PIT	RR RR 2Y			VK-8	tal nam ann tái nan na, is tar an
(FV-4664	F-4	2	A/C	1	XFC	SA	0	AT-2 CT-CC PIT	RR RR 2Y			VR-8	· · · · · · · · · · · · · · · · · · ·
(FV-4665	F-4	2	A/C	1	XFC	SA	0	AT-2 CT-CC PIT	RR RR 2Y		· · · · · · · · · · · · · · · · · · ·	VR-8	
(FV-4666	F4	2	A/C	1	XFC	۶A	0	AT-2 CT-CC FIT	RR RR 2Y			VR8	
FV-4667	E-4	2	A/C	1	XFC	SA	0	AT-2 CT-CC PIT	RR RR 2Y			VR-8	
FV-4358	E-4	2	A/C	1	XFC	SA ·	Ò	AT-2 CT-CC PIT	RR RR 2Y			VR-8	
FV-4669	E-4	2	A/C	í	XFC	ςΆ	Û	AT-2 CT-CC F1T	RR RR 2Y	······································		VR-8	··· •• •• •• •• •• •• •• •• •• •• ••







PREPARED BY : IELP PROGRAM : PRISIM

ISI CLASS 1, 2, 3, AND NC VALVES DUANE ARNOLD ENERGY CENTER

IOWA ELECTRIC LIGHT AND POWER

	F&I SYS		I-116 EACTOR	RECIRCU	LATION		15	T PROGRA	M REVI	FAGE SION : 008	, 04/15/87		
VALVE NUMBER	F&ID COOR	-IST CLASS	VALVE CAT	VAL VE SIZE	VALVE TYPE	ACTUATOR TYPE	NORMAL POSITION	TEST	TEST FREQ	MAXIMUM STROKE TIME	MAXIMUM LEAKAGE	RELIEF REQUEST	REMARKS
XFV4670	E-4	2	A/C	1	XFC	SA	0 ·	AT-2 Ct-CC PIT	RR RR 2Y			VR8	
XFV-4671	E-4	2	A/C	í	XFC	SA	O	AT-2 CT-CC PIT	RR RR 2Y		** ** ** ** ** ** ** ** ** ** ** ** **	Vƙ-8	
KFV-4672	E4	2	A/C	1	XFC	SA	0	AT-2 CT-CC PIT	RR RR 2Y			VR-8	
KFV-467 3	E4	2	A/C	í	XFC	SA	0	AT-2 CT-CC PIT	RR RR 2Y		an an dh'ud an an an an na an an an an an an an a	VR-8	· • • · · · · · · · · · · · · · · · · ·
KFV-4674	E-4	2	A/C	1	XFC	SA	0	AT-2 CT-CC PIT	RR RR 2Y			VR-8	
KFV-4675	D-4	2	A/C	í	XFC	SA	0.	AT-2 CT-CC PIT	RŔ RR 2Y		· · · · · ·	Vƙ8	
<fv4676< td=""><td>D-4</td><td>2</td><td>A/C</td><td>í</td><td>XFC</td><td>SA</td><td>0</td><td>AT-2 CT-CC PIT</td><td>RR RR 2Y</td><td></td><td></td><td>VR-8</td><td></td></fv4676<>	D-4	2	A/C	í	XFC	SA	0	AT-2 CT-CC PIT	RR RR 2Y			VR-8	
(FV-4677	D4	2	A/C	i .	XFC	SA	0	AT-2 CT-CC PIT	RR RR 2Y			VR8	
(FV-4678	D4	2	A/C	1	XFC	SA	0	AT-2 CT-CC PIT	RR RR 2Y	*** ** *** *** *** *** ** ** **		Vr:-8	· · · · · · · · · · · · · · · · · · ·





PREPARED BY : IELP PROGRAM : PRISIM

IST CLASS 1, 2, 3, AND NC VALVES DUANE ARNOLD ENERGY CENTER IOWA ELECTRIC LIGHT AND FOWER

PAID M-116 PAGE : 24 IST PROGRAM REVISION 008 , 04/15/87 SYSTEM : REACTOR RECIRCULATION ------MAXIMUM VALVE PAID IST VALVE VALVE VALVE ACTUATOR NORMAL TEST STROKE MAXIMUM RELIEF NUMBER COOR CLASS CAT SIZE TYPE TYPE FOSITION TEST FREQ TIME LEAKAGE REQUEST REMARKS **13 13 13 13 13 13 13 13 13 15 15 15 13 13** 13 **13 55 35 15 3**2 **42 25 5**5 53 **1**5 <u> 22 22 23 23 23</u> **62 14 14 1**4 14 14 10, 11 20 20 21 40 20 20 **10 10 10 10** 20 20 20 20 20 20 20 **** 62** 32 52 52 62 62 63 64 63 64 **22 4**2 23 13 13 13 12 22 Hananaus XFV-4379 2 A/C A-1 XFC 1 SA Ο. AT-2 RR CT-CC RR VR~8 PIT 2YXFV-4380 A-7 2. A/C 1 XFC SA 0 AT-2 **R**R CT-CC ŔŔ VR--8 PIT 2Y -----. XFV--4381 A~3 2 A/C XFC SA 0 AT-2 1 ŔŔ CT-CC RR VR-8 PIT 2Y -----. XFV-4682 A-3 2 XFC A/C 1 SA 0 AT-2 ĸR CT-CC RR VR-8 PIT 2Y







PREPARED BY : IELP PROGRAM : PRISIM


ISI CLASS 1, 2, 3, AND NC VALVES DUANE ARNOLD ENERGY CENTER IOWA ELECTRIC LIGHT AND POWER

	DUANE ARNOLD ENERGY CENTER													
	F&I SYS		I-117 ONTROL	ROD DRI	VE HYDR	AULIC	12	T PROGRA	M REVI		25 8 , 04/15/87			
VALVE NUMBER	F&1D COOR	IST CLASS	VALVE CAT	VALVE SIZE	VALVE TYPE	ACTUATOR Type	NORMAL POSITION	TEST	TEST FREQ	MAXIMUM STROKE TIME	MAXIMUM LEAKAGE	RELIEF REQUEST	REMARK S	
CV-1804A	A5	NC	Ϋ́Α	i	Gt.	AŪ.	0 . ,	AT-1 BTC PIT	RR OP 2Y	005	NA			
CV-1804B	'A-5	NC	A	1	GL.	AŪ	0.	AT-1 BTC PIT	RR 0P 2Y	005	NA	a nat file des cel ap ap au cel ce ce	· · · · · ·	
SV-1804A	A5	NC	В		3WY	S 0	NE	BTD	0P	NA		VR-2	ange nam tre tre ten are the test and and the test	
SV-1804B	A-:5	NC	B		3WY	50	NE	BTD	0P	NA		VR-2		
SV-1840A	G6	NC	В	1	3WY	50	NE	BTD	RŔ	NA	ante foi ante can any ante tan tan tan tan tan ante ante ante		NOTE-006	
SV-1840B	6-6	NC	B	í	3WY	S 0	NE	BTD	RR	NA	986 - 149 - 149 - 147 - 147 - 488 - 149 - 149 - 149 - 149 - 149 - 149 - 149 - 149 - 149 - 149 - 149 - 149 - 149		NOTE-006	
V-17-052	E3	í	A/C	3	СК	SA	С	AT-1	ŔŔ	a gane ayan gane gane kane nage nage dage dage	NA		PASSIVE	
V-17-053	_E-2	1	A/C	3	СК	SA	C	AT1	R R		NA	· ···· ··· ··· ··· ··· ··· ··· ··· ···	PASSIVE	
V-17-083	A6	2	A/C	1	CK	SA	0	AT-1 CT-CC	RR RR	•	NA	VR-12	, and and an experimental production of the second	
V-17-096	A ~-4	2	A/C	i	CK	S'A	0 ·	AT-1 CT-CC	RR RR		NA	VR-12	40 40 50 50 70 24 40 50 52 4 5	

· · · ·







PREPARED BY : IELP PROGRAM : PRISIM

.

ISI CLASS 1, 2, 3, AND NC VALVES DUANE ARNOLD ENERGY CENTER IOWA ELECTRIC LIGHT AND FOWER

.

•	P&1 SYS		1-118 CONTROL	ROD DEI	VE HYDR	AULIC	15	T FROGRA	AM REVI	PAGE SION : 008	: 26 , 04/15/87		
VALVE NUMBER	P&ID COOR	IST CLASS	VALVE CAT	VALVE STZE	VALVE TYPE	ACTUATOR TYPE	NORMAL POSITION	TEST	TEST FREQ	MAXIMUM STROKE TIME	MAXINUM LEAKAGE	RELIEF REQUEST	REMARKS
CV-1849	D-7	2	в	. 75	GA	AO	C/F0	BTO FST	SF SP	NA	· ·	VR-13 VR-17	NOTE-001
CV-1850	D-6	2	В	.75	GA	AÜ	C/FU	BTO FST	ሪኬ ሪኮ	NA	1991 1992 1993 1993 1993 1993 1993 1994 1995 1995 1995 1995 1995 1995 1995	VR-13 VR-17	NOTE-001
CV-1859A	G4	NC	В	í	GL	AÜ	0/FC	BTC FST FIT	0P 0P 2Y	030		VR-17	
CV-1859B	G-4	2	В	í	GL.	AO	0/FC	BTC FST PIT	0P 0P 2Y	007	······	VR-17	· •• •• •• •• •• •• •• •• •• •• •• •• ••
CV-1867A	D-5	NC	B	2	GL	AO	0/FC	BTC FST PIT	- 0P 0P 2Y	032		VR-17	
CV-18675	D-5	. 2	F	2	GL.	ÂŬ	0/FC	BTC FST PIT	0F 0P 2Y	007		VR-17	
SV-1855	E-6	NC	В		3WY	20	NE	BTD	SP	NA		VR-13	
SV-1856	E-6	NC	Ë		ЗШҮ	50	NE	BTD	S۴	NA	•• •• •• •• •• •• •• •• •• •• •• •• ••	VR-13	
SV-1868A	D-4	NC	B.	.25	3WY	\$0	NE	BTD	SP	NA		VR-13	
SV-1838B	D-4	NC	Đ	. 25 [.]	∉3WY	2.0	NE	BTD	SF	NA		VR-13	
SV-1839A	Ď4	NC	В	. 25	3WY	20	NE	HTD	S۴	NA	•• •• •• •• •• •• •• •• •• •• •• •• ••	VR-13	
SV-1989B	D4	NC	B	. 25	3WY	20	NE	BLD	SF	NA		VR-13	
V-18-0118	B-8	2	С	.5	СК	SA	С	CT-CC	SF	NA	** ** ** ** ** ** ** ** ** ** ** ** **		NOTE-002
V-18-0919	E-7	2	С	.5	СК	SA	0	CT-CC	SF	NA NA			• NUTE-003
V-18-1453	Dፊ	2	С	. 5	СК	SA	C	CT-CO	SF	NA		VR-13	NOTE-004



PREPARED BY : IELF PROGRAM : PRISIM

.

ISI CLASS 1, 2, 3, AND NC VALVES DUANE ARNOLD ENERGY CENTER IOWA ELECTRIC LIGHT AND POWER

141 141 142 144 144 144 144 144 144 144		TEM : R		HEAT R			15	T PROGRA	NA REVI	SION : 00	: 27 8 , 04/15/87		
VAL VE NUMBER	F&ID COOR	IST CLASS				ACTUATOR TYPE	NORMAL POSITION	TEST	TEST FREQ	MAXIMUM	' MAXIMUM LEAKAGE	KELIEF REQUEST	REMARKS
MO-1902	G-7	2	В	10	GA	MO	C	BTC PIT	0₽ 2Y	014			
MU-1903	6-6	2	В	10	GL	MO	C/KL	BTC PIT	OF 2Y	014			.
MU-1904	E6	2	В	20	ANG	мо	0	BTO PIT	0P ' 2Y	037	ter met ann fan fan som fan	n ann ann ann ann ann ann ann ann ann a	
M0-1905	E6	í	A	20	GA	MO	C	AT-5 BTC BTO PIT	RR OP OP 2Y	037 037	NA		
MD-1908	E-8	í	A	18	GA	MO	C .	AT-5 BTC PIT	RR CS 2Y	022	NA		
10-1909	E-8	1	A	18	GA	MÜ	С	AT-5 BTC PIT	RR CS 2Y	022	NA '		
MO-1912	C-7	. 2	В	18	GA	MO	C.	BTC PIT	0P 2Y	084			

··· .

۰.


- (.) ·	



PREFARED BY : TELF PROGRAM : PRISIM

ISI CLASS 1, 2, 3, AND NC VALVES DUANE ARNOLD ENERGY CENTER IOWA ELECTRIC LIGHT AND POWER

		TEM : F	1-119 RESIDUAL				15	T PROGRA	IN REVI	FAGE STON : QOB	, 04/15/87		
VALVE NUMBER	F&ID COOR	IST CLASS		VALVE Size			NORMAL POSITION	TEST	TEST Freq	MAXIMUM STROKE TIME	MAXIMUM LEAKAGE	REQUEST	REMARKS
MO-1913	C7	2	₿	18	GA	MO	0/KL	ВТС Вто PIT	0P 0P 2Y	084 084 -		·	
MD-1920	C8	2	B	18	GA	MO	C	BTC PIT	0F 2Y	084	1991 - 1997 - 1999 - 1999 - 1999 - 1999 - 1999 - 1999 - 1999 - 1999 - 1999 - 1999 - 1999 - 1999 - 1999 - 1999	1999 1999 2000 1993 2000 2000 2000 2000 2000 2000	tani kang pusa pang tang tang tang ang pung ngan
M0-1921	C-7	2	В	18	GA	MÜ	07KL	BTC BTO PIT	0F 0F 2Y	084 084	<u></u>	** ** =* =* =* ** ** ** ** **	
MD-1932	F-5	2	Б	12	GA .	MO	C/KL	BTC BTO FIT	0F 0F 2Y	083 083	** *** *** *** *** *** *** *** *** ***	· · · · · · · · · · · · · · · · · · ·	
MO-1933	F-5	2	B	4	GL	MO	C	BTC PIT	0F 2Y	009			
MO~1934	F-5	2	B	12	GL.	MO	C `	BTC BTO PIT	OF OF 2Y	041 041			nen ber udt utt utt net net net som som
MO-1935	C5	2	В	З	GA	MO	0,	BTC BTO PIT	0P 0F 2Y	019 019	an a		••••••••••••••••••••••••••••••••••••••
MO-1936	D5	NC	B	4	GL.	MO	C.	BTC PIT	0P 2Y	006			
MO-1937	D6	2	Ð	4	GA	MO	C	BTC PIT	0P 2Y	019			
MD-1939	D 4	2	В	12	GA .		Ø∕KL_	BTC Bto PIT	0P 0P 2Y	080 080		** *** *** *** *** *** *** *** *** ***	*** *** *** *** *** *** *** ***



PREPARED BY : _ IELP FROGRAM : FRISIM

ISI CLASS 1, 2, 3, AND NC VALVES DUANE ARNOLD ENERGY CENTER

IOWA ELECTRIC LIGHT AND FOWER

	134 242	TEM : R	ESIDUAL	HEAT R	EMOVAL		ĩ S	T FROGRA	AM REVI	PAGE SION : 008	: 29 , 04/15/87		
VALVE NUMBER	P&1Ď COOR		VALVE CAT	VALVE SIZE	VALVE TYPE		•	TEST	TEST FREQ	MAXIMUM STROKE TIME	MAXIMUM LEAKAGE	RELIEF REQUEST	REMARKS
MD-1940	E-4	2	в	18	GL.	MO	0	BTC BTO PIT	0F 0P 2Y	040 060 •			
MO-1941	E-3	5	F	18	GA	MO	U/KL	BTC BTO PIT	0F 0P 2Y	080 080			
40- 194 9A	D-4	NC	B	1	GL	MO ·	С	BTC PIT	0F 2Y	018			
40-19498	D4	2	B	1	GL.	MO	C	BTC PIT	0P. 2Y	018 .			
40-1967	E-2	NC	Đ	4	GA	MO	С	BTC BTO FIT	0P 0P 2Y	030 030			· ·
MO-1970	E-3	NC	B	4	GA	мо	C	BTC PIT	0P 2Y	017		** ** ** ** ** ** ** ** **	
MD1989.	D7	2	B	24	GA	· MO	0/KL	BTC BTO PIT	0P 0P 2Y	1 40 1 40		40) 147 (01) 747 (14 7 (147 (147 (147 (147 (147 (147 (147 (14	
PSV-1911	D8	2	С	i	RV	SA	С	CT-SP	5Y	*** **** *** *** *** *** *** *** *** *		VR-5	
PSV-1952	D-4	2	С	4	₽V	SA	C.	CT-SP	5Y			VR-5	
V-19-001	A-7	2	C	12	СК	SA	С	CT-CC CT-CO	OP OP		ant ters fant fant dat han taan taan sam anne pan kan ta		
V-19-003	A-5	2	С	12	СК	SA	C	CT-CC CT-CO	0f [.] 0f [.]	· · · · · · · · · · · · · · · · · · ·	1999 - 1999 - 1999 - 1999 - 1999 - 1997 - 1997 - 1997 - 1997 - 1997 - 1997 - 1997 - 1997 - 1997 - 1997 - 1997 -		
V-19-014	A-8	- 2	С	3	СК	SA	С	СТ-СС СТ-СО	0P 0P				




PREPARED BY : IELP PROGRAM : PRISIM

ESI CLASS 1, 2, 3, AND NC VALVES DUANE ARNOLD ENERGY CENTER

IOWA ELECTRIC LIGHT AND POWER

	F&I • SYS	D N TEM : R	-119 ESIDUAL	HEAT R	EMOVAL	PAGE : 30 IST FROGRAM REVISION : 008 , 04/15/87									
VALVE NUMBER	F&ID COOR	IST CLASS	VALVE	VAL VE SIZE	VALVE TYPE	ACTUATOR TYPE	NORMAL POSITION	TEST	TEST FREQ	MAXIMUM STROKE TIME	MAXIMUM LEAKAGE	RELIEF REQUEST	REMARKS		
V-19-013	B5	2	С	3	CK .	SA	C	CT-CC CT-CO	0P 0P						
V-19-020	B9	2`	₿/C	1	'2,CK	MS'A	0	CT-CC	0F						
V-19-023	B6	- 2	B/C	1	2.CK	MSA	0	CT-CC	OF	** ** ** ** ** ** ** ** <u>**</u> .	*	·	*** ** *** ** ** ** ** *** **		
V-19-128	₽ -6	2	B/C	í	2.CK	MSA	0	CT-CC	0F	•					
V-19-149	Ė7	1	A/C	20	CK	S'A	C	AT-5 CT-CC CT-CO	RR RR RR	•	NA	VR-3 VR-3			







FREPARED BY : IELP PROGRAM : PRISIM

·

IST CLASS 1, 2, 3, AND NC VALVES DUANE ARNOLD ENERGY CENTER

		TEM : R	-120 ESIDUAL				15	T PROGRA	M REVI	FAGE STON : 008	: 31 , 04/15/87		
VAL VE NUMBER	F&ID Coor	IST CLASS		·	VALVE TYPE	ACTUATOR TYPE	NORMAL POSITION		TEST FREQ	MAXINUM STROKE TIME	MAXIMUM LEAKAGE	RELIEF REQUEST	REMARKS
M0-2000	G2	2	B	10	GA	MO	C.	BTC PIT	0P. 2Y	014			
M0-2001	G - 4	2	В	10	GL	MO	C/KL.	BTC PIT	0F 2Y	014		, 44 4 4 48 48 48 4 7 55 44 -4 -4	48 84 47 68 87 44 64 64
MU-2003 (F4	1	A	20	GA .	MO	C :	AT-5 BTC BTO PIT	RR 0P 0P 2Y	037 037	NA	1 6 6 6 1 1 1 1 1 1 1 1 1 1	
MO-2004	F4	2	В	20	, ANG	MŪ	0	BTO PIT	0P 2Y	037			** 84 ** 84 24 ** ** ** an an
MD-2005		2	B	12	GA	мO	C/KL	BTC BTO PIT	0P 0F 2Y	083 083 •		- 191 199 199 199 199 199 199 199 199 19	100 100 100 100 100 100 100 000 000 000
MD-2005	F-4	2	в	4	GL.	MO ·	C .	BTC FIT	0P 2Y	009	nat bint bat fan inne fan han bint bin		
	F-5	2	ŀ	12	GL	MO	С	BTC BTO PIT	0F 0P 2Y	041 041			
MD-2009	C-4	2	F	3	GA	СМ	· 0	BTC BTO FIT	0F 0P 2Y	019 019			
M0-2011	C-3	2	ß	14	GA	MO		HTC PIT	0F 2Y	084			

—	•									•			
	RED BY AM : PR		p.		T Z T C T Z T C	ALASS 1, 2, IANE ARNOLD	ESTING PRO 3, AND NC ENERGY CE	VALVES			IOWA ELECTRI AND FOW		
	۲&۹ ۲۲۵		M-120 RESIDUAL	HEAT F	EMOVAL			T FROGRA	M REVI	PAGE SION -: 008	32 , 14/15/87		•
VALVE NUMBER	P&ID COOR	IST CLASS	VALVE CAT	VALVE	VAL VE TYPE		NORMAL FOSITION	TEST	TEST FREQ	MAXIMUM STROKE TIME		RELJEF REQUEST	REMARKS
10-2012	C-3	2	в	14	GA .	MO	0/KL	BTC BTO PIT	08 08 24	0 84 084			
40-2015	C3	2	'B	.14	GA	MO .	0/KĽ ,	BTC BTO PIT	0F 0P 2Y	084 084			
18-2015	C-2	2	B	14	GA	MO	C .	BTC PIT	0F 2Y	084			
10-2029	D~5	2	B	12	GA	MO	0	BTC BTO PIT	0P 0P 2Y	080 080	ana ana ana ina ana ana ana ana ana ana		
10-2030	E5	2	B	18	Gt.	MO	0	BTC BTO PIT	0F 0F 2Y	060 060	200 tot tot (an any in par set on an an an an an	, and and part that any any any any any any	49 486 446 496 497 497 498 498 498 498 498 498
10-2031	E7	2	В	12	. GA	MO	0	BTC BTO · PIT	0P 0P 2Y	080 080			an tao ing tao
10-2035	E-8	NC	В	4	GA	MO	C	BTC BTO PIT	0P 0P 2Y	030 030	Ann ann ann ann ann agu agu ann ann ann ann ann ann	. Ban Um 189 187 18 7 187 199 199 199 199 199 199 199	n
102038	E7	NC	B	4	GA	MQ	C	BTC PIT	0P 2Y	017		, par tan fan fan nie tek tek tek tek fan fan tak	ar bee toe toe fac to the sector and and and
10204 4 A	D6	NC	В	1	GL	MO	C	BTC PIT	0F 2Y	018			
10-20448	D3	2	в	í	GL.	ŇO	C	BTC FIT	0P 2Ý	018	nin vin <i>for t</i> an oon t <u>a</u> r <u>tar</u> <u>tar</u> <u>tar</u> <u>tar</u> <u>tar</u> <u>tar</u> <u>tar</u>		

PREPARED BY : IELP PROGRAM : PRISIM

ISI CLASS 1, 2, 3, AND NC VALVES DUANE ARNOLD ENERGY CENTER TOWA ELECTRIC LIGHT

							• • • • •					· · · · · · · · · · · · · · · · · · ·	
VALVE NUMBER	F&1D COOR	IST CLASS	VALVE CAT	VALVE SIZE	VALVE TYPE	ACTUATOR TYPE	NORMAL POSITION	TEST	TEST FREQ	MAXIMUM STROKE TIME	MAXIMUM LEAKAGE	RELIEF REQUEST	REMARKS
M0-2069	D-3	2	₿	24	GA	MO	O/KL	BTC Bto Pit	0F 0P 2Y	140 140			
PSV-2043	D3	2	С	4	RV	SA	С́.	CT-SP	5Y		Mill 1993 (Mil 2007 (Mil 2007 (Mil 2007 and 2007 (Mil 2007 (Mil 2007 (Mil 2007	VR-5	r fann banne daair fann 'theb rige f oot wake gene
V-20-001	83	2	С	12	СК	SA	C	CT-CC CT-CO	0P 0F	t vers corr cast case and cast cast cast	nan vine fan fan fan dae Min Min And fan fan dae gan yn yn		
V-20-003	A-5	2	C	12	СК	SA	C	CT-CC CT-CO	0F 0P				
V-20-008	B4	2	Ċ	3	СК	SA	C.	CT-CC CT-CO	0P 0P	, 1997 - 1997 - 1997 - 1997 - 1997 - 1997 - 1997 - 1997 - 1997 - 1997 - 1997 - 1997 - 1997 - 1997 - 1997 - 1997	nan pan pan pan ang pan pan pan pan pan pan pan ban ban ban ban ban pan pan pan ban ban ban pan pan pan pan pan	- 186 - 484 - 200 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 1	
V-20-008	₿-2	2	C	3	СК	SA		CT-CC 01-C0	0P 0P				WA WA 40
V-20-082	F-3	1	A/C	20	CK	SA	С	AT5 CTCC CTCO	RR RR RR		NA	VR-3 VR-3	1

.

· . . ·

•

-





PREPARED BY : IELP FROGRAM : FRISIM

ISI CLASS 1, 2, 3, AND NC-VALVES DUANE ARNOLD ENERGY CENTER

IOWA ELECTRIC LIGHT AND POWER

	P&1 \$Y\$		I-121 ORE SPR	(AY			1 S	T PROGRA	M REVI	PAGE STON : 008	: 34 , 04/15/87		
VALVE NUMBER	F&ID COOR	IST CLASS	VALVE	VALVE SIZE		ACTUATOR TYPE	NORMAL POSITION	TEST	FREQ	MAXIMUM STROKE TIME	MAXIMUM LEAKAGE	RELIEF REQUEST	REMARKS
MO-2100	B5	2	B	12	GA	HO	0/KL	BTO PIT	· 0P. 2Y	078			
MD-2104	D-3	2	B	2	GA	MO	0	BTC PIT	0F 2Y	013			**
M0-2112	F-5	.2	В	8	GL.	MO	C	BTC FIT	0P 2Y	033	, and any loss out out out and and and and any loss out out ou	84 867, 2747 2869 2767 2767 2767 2767 2767 2767	
MO-2115	G-5	2	A	8	GA	МО	0	AT-1 BTC BTO PIT	RR 0P 0F 2Y	008 008	NA	· · · · · · · · · · · · · · · · · · ·	
10-2117	G4	i	A	8	GA	МО	C .	AT-1 AT-5 BTC BTO PIT	RR RR OP OP 2Y	008 008	NA NA	1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1	
MO-2120	C-5	2		12	GA	MO	0/KL	BTO PIT	0P 2Y	078			
10-2124	D-4	2	B	2	GA	мо	0	BTC PIT	0F 2Y	013			** ** ** ** ** ** ** **
10-2132	E5	2	B	8	GL.	MO .	C	BTC PIT	0P 2Y	033			ann mair inn ann ann ann ann an

	RED BY AM : F'F	IELF RISIM	•		151 (LASS 1, 2,	TESTING PRO 3, AND NO D ENERGY CE	VALVES			IOWA ELECTRIC AND POWE		
	P&1 SYS	D M TEM C	I-121 Ore SPF	KAY .			I S	T FROGRA	M REVI	PAGE : SION : 008			1 000 000 000 000 000 000 000 000 000 0
VALVE NUMBER	P&ID COOR	IST CLASS	VALVE			ACTUATOR TYPE	NORMAL FOSITION	TEST	FREQ	MAXIMUM STROKE TIME	MAXIMUM LEAKAGE	RELIEF REQUEST	REMARK <i>S</i>
MO-2135	E-5	2	A	8	GΑ	MO	Û	AT-1 BTC BTO .PIT	КR ОР ОР 2Ү	008 008	NA		
M0-2137	, Е-6	ſ	A	8	GA	MO	C	AT-1 AT-5 BTC BTO PIT	RR RR 0P 0P 2Y	008 008	NA NA		
M0-2146	C5	, 2	В	12	GA	MO	0/KL.	BTC BTO PIT	0F 0F 2Y	078 078			, may day ib,
M0-2147	B-2	2	В	12	GA	MO	0/KL	BTC BTO PIT	0P 0F 2Y	078 078			
PSV-2109	G-4	2	С	2	Ŕ٧	SA	C	CT-SF	5Y			VR-5	* **** **** **** *** *** *** *** ***
PSV-21291	E-4	2	С	2	R٧	SA	С	CT-SP	5Y	t 1992 part ford data data pint anti-pint data pint pint a	**************************************	VR-5	
V-21-007	D3	2	С	10	СК	SA	. C	CTCO	0P	, ener vær per som offer som gan som om som som og	طا عليه ومنه وهي ومن المراجع والمراجع والمراجع والمراجع والمراجع والمراجع والمراجع والمراجع والمراجع والمراجع		, 2000 8000 2000 2000 2000 2000 2000 200
V-21-009	D3	2	С	2	СК	SA	C`	CT-CO	0P		ny tan' ban dani any any any any ada dan dan dan da		
V-21-010	D-4	2	С	10	СК	SA .	С	C1-C0	0P		er, viti fall takk tige lagu jake falt (bet dan) van gegt en		
V-21-012	D-4	2	С	2	CK	SA	C	CT-CO	0P	- THE PAR INT IN COLOR OF A STREET	un tar fan Sam Ante fan die sam tan Sam and		

С

С

..... V-21-072

V-21-073 F--6

E-6

1

1 I

A/C 8

8

A/C

СК

СК

SA

SA

AT-5 CT-CC CT-CO

AT-5 CT-CC CT-CO

RR RR RR

RR

RR RR

NA

NA

VR-33 VR-33

VR-33 VR-33





INSERVICE TESTING PROGRAM

IOWA ELECTRIC LIGHT AND POWER

PREPARED BY : IELP PROGRAM : PRISIM

ISI CLASS 1, 2, 3, AND NC VALVES DUANE ARNOLD ENERGY CENTER

	F&I SYS	D M TEM I C	-121 ORE SPR	AY			15	T PROGRAM	M REVI	FAGE STON : 00			
VALVE NUMBER	F&ID COOR	IST CLASS	VALVE	VALVE SIZE	VALVE TYPE	ACTUATOR TYPE	NORMAL POSITION	TEST	TEST FREQ	MAXIMUM STROKE TIME	MAXIMUM LEAKAGE	RELIEF REQUEST	REMARKS
XFV-2119	G7	2	A/C	1	XFC	Sa	Û	AT-2 CT-CC CT-CO	RR RR 2Y			Vi∹-B	·
XFV-2139	G7	2	A/C	1	XFC	SA	Û .	AT-2 CT-CC PIT	RR RR 2Y			VR-8	· ····· · ···· · · · · · · · · · · · ·

Ŀ	





PREPARED BY : IELP PROGRAM : PRISIM

ISI CLASS 1, 2, 3, AND NC VALVES DUANE ARNOLD ENERGY CENTER

								·· ·· •· •· ·· ·· ·· ·· ·· ·· ·· ·· ··					** ** ** ** ** ** ** ** *
	F& I SY S	TEM : H	1-122 IPCI - S	TEAM SI	DE		- 15	T PROGRA	M REVI	STON : 008	: 37 , 04/15/87		
VALVE NUMBER	F&1D COOR	IST CLASS	VALVE		VAL.VE TYPE	ACTUATOR TYPE	NORMAL POSITION	TEST	TEST FREQ	MAXIMUM STROKE TIME	MAXIMUM	RELIEF REQUEST	REMARKS
CV-2206	D-2	2	₿	1	GA	A0	C/FC	BTC FST PIT	0P. 0P 2Y	005		VR-17	
CV-2211	C-2	NC	A	i	GA	AD	O/FC	AT-1 BTC FST FIT	RR OP OP 2Y	005	NA	VR-17	•
CV-2212	C-2	NC	A	1	GA	AO	0/FC	AT-1 BTC FST PIT	RR OP OF 2Y	005	NA	VR-17	
HV-2201	E3	2	В	10	GŁ.	НО	С	BTO FIT	0P 2Y	030			
M0-2202	E-3	2	В	10	GA	MO	C	BTO PIT	0P 2Y	021			
	G-6	1	A ·	10	GA	MÜ	0	AT-1 BTC BTO PIT	RR CS CS 2Y	013 013	NA		· · · ·
40-2239	G-5	1	A	10	GA	MO	0	AT-1 BTC BTO PIT	RR OP OP 2Y	013 [.] 013	NA		
10-2247	D-5	2	в	2	GL.	мо	C	BTO PIT	0P 2Y	011	ann an tar	99 600, 6000 0.00, 0.00, 0.00, part 200, 0.00, 0.00	





FREFARED BY : IELF PROGRAM : PRISIM

ISI CLASS 1, 2, 3, AND NC VALVES DUANE ARNOLD ENERGY CENTER

	F&I SYS	D M TEM : H	-122 PCI - S	TEAM SI	DE .		21	T PROGRA	M REVI	FAGE SION 008	38 3 , 04/15/87		
VALVE NUMBER	F&ID COOR	IST CLASS	VALVE CAT	VALVE SIZE	VALVE TYPE	ACTUATOR TYPE	NORMAL POSITION	TEST	FREQ	MAXIMUM STROKE TIME	MAXIMUM LEAKAGE	RELIEF REQUEST	REMARKS
MO-2290A	B-8	NC	A	2	GA .	MD	`O	AT-1 BTC BTO PIT	кк ОР ОР 24	010 010	NA		
MO-2290B	B8	NC	A	2	GA	MD	0	AT-1 BTC BTO PIT	RR OP OP 2Y	010 010	NA		· · · · · · · · · · · · · · · · · · ·
PSV-2223	C-3	2	С	1.25	RV	SA	C	CT-SP	5Y	, 1991 Anna Anna 242, 242, 242, 243, 244, 244, 244, 2	•	VR-5	
PSV-2228	C4	2	C	í	R٧	, SA	С	CT-SF	5Y		"", "", "", ",", ",", ",", ",", ",", "	VR-5	
SV-2206	D2	NC	B		3MJ	02	ND	BTD	OP	NA	an das 1860 1861 1861 2060 2060 2060 2060 2060 2060 2060 20	VR-2	
SV-2211	C-2	NC	В		3WY	50	NE	BTD	OP			VR-2	
SV-2212	C-2	NC	В		3WY	50	NE	BTD	0P	1497 8-97 8-97 9-98 940 140 948 948 948 948 9	997 9947 9967 9967 9967 9967 9967 9967 9	VR-2	
V-22-016	B-7	2	A/C	16	СК	SA	C	AT-1 CT-CC CT-CO	OP	,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,	NA	VR-37	1997 (
V-22-017	<u> </u>	2	A/C	13	SCK	SA	Ċ	AT-1 CT-CC CT-CO	RR CS OP		NA	VR-37	
V-22-021	B7	NC	A/C	2	СК	SA	C	AT-1 CT-CC CT-CO	RR CS OP	1997 - 1997 - 1997 - 1997 - 1997 - 1997 - 1997 - 1997 - 1997 - 1997 - 1997 - 1997 - 1997 - 1997 - 1997 - 1997 -	NA	VR-37	1947 TATI TATI TATI TATI TATI TATI TATI
V-22-022	B7	NC	A/C	2	SCK	MSA	C	AT-1 CT-CC CT-CO	RR CS OP		NA	VR-37	

											· - · · · · · · · · · · · · · · · · · ·		
PREPAR PROGRA		: IELP ISIM	,		ISI C DU	LASS 1, 2,	ESTING FRO 3, AND NC ENERGY CEI	VALVES			IOWA ELECTRI AND FOW	C LIGHT IER	
		D. М ТЕМ : Н		TEAM SI	DE		15	I PROGRA	M REVI	FAGE SION 008	39 3,04/15/87		
VALVE NUMBER	P&1D COOR	IST CLASS	VALVE CAT	VAL VE SIZE	VALVE Type	ACTUATOR TYPE	NORMAL POSITION	TEST	FREQ	MAXIMUM STROKE TIME	MAXIMUM Leakage	RELIEF REQUEST	REMARK
V-22-026	B-3	2	C	2	CK	SA	C ·	CT-CO	OP.				
V-22-028	B4	2	С	2	СК	SA	С	CT-CO	OP	· • • • • • • • • • • • • • • • • • • •	n sila suu uus ada daa sad yaya tay yaya ama ayaa kaya wa		
V-22-029	B -5	2	С	2	СК	SA	C .	CT-CO	0P	une per par ter des rus dat un ad u			
V-22-063	₿-8	2	A/C	3	СK	SA	C ,	AT-1 CT-CC CT-CO	RR CS 0P		NA		
V-22-054	B8	NC	A/C	3	СК .	SA	С	AT-1 CT-CC CT-CO	ጽጽ ርያ ዐዖ	488 - 484 - 1889 - 1989 - 1989 - 1989 - 1989 - 1989 - 1984 - 1989 - 1984 - 1989 - 1984 - 1989 - 1984 - 1984 -	NA		
XFV-2246A	F-6	2	A	1	XFC	SA	Q	AT-2 CT-CC PIT	RR RR 2Y	***	, ann an	VR-8	189 - 1984 - 1994 - 1994 - 1994 - 1994 - 1994 - 1994 - 1994
XFV-2246B	F-6	2	A	í	XFC	SA	0	AT-2 CT-CC PIT	RR RR 2Y			VR-8	99) - 144, ado - 2994 - 2007 - 2004, 2004, 2004, 2004
XFV-2246C	F-6	2	A	í	XFC	SA	0	AT-2 CT-CC FIT	RR RR 2Y	147 990 990 141 141 141 147 147 147 147 147 147 148 148		VR-8	
XFV-2246D	E-6	2	A	1	XFC	A2	0	AT-2 CT-CC PIT	RR - RR - 2Y	•		VR-8	IN av 44 ap as as as an an

· · ·

.

,

•

. .

•







PREFARED BY : IELF PROGRAM : PRISIM

.

ISI CLASS 1, 2, 3, AND NC VALVES DUANE ARNOLD ENERGY CENTER

IOWA ELECTRIC LIGHT AND POWER

		TEM : H	i-123 IPCI - W				12	T PROGRA	AM REVI	FAGE 510N : 008	: 40 , 04/15/87		
VALVE NUMBER	F&ID COOR	IST CLASS	VAL VE Cat	SIZE	VALVE TYPE	ACTUATOR TYPE	NORMAL POSITION	TEST	FREQ	MAXIMUM STROKE TIME	MAXIMUM LEAKAGE	RELIEF REQUEST	REMARKS
CV-2315	E6	2	B	8	GL	΄AΟ	C	BTC PIT	0P. 2Y	024			
MD-2300	F-4	2	B	14	GA	MO	0	BTC PIT	0P 2Y	077			te dt ek ee en ee en ee en en ge
MO-2311	C-6	2	ย่	12	GA	МО	0	BTO PIT	0P 2Y	018	ann a na hann ann ann ann ann ann ann an		MAA MAA AMI INI INI INI INI INI INI INI
MO-2312	C-7	1	A	12	GA	MO	C	AT-1 BTC BTO PIT	RR OP OF 2Y	020 020	· NA	VR-37	
M0-2316	E6	NC	B	8	GA	MÜ	С	BTC PIT	0P 2Y	024	1997 - 1999 - 1997 - 1997 - 1997 - 1997 - 1997 - 1997 - 1997 - 1997 - 1997 - 1997 - 1997 - 1997 - 1997 - 1997	, 1899 - 189 - 98 9 - 974 - 786 - 786 - 887 - 189 - 1	1467 - adi add - adi - adi - adi
MO-2318	C-5	2	B	4	GL.	MO	C	BTC BTO FIT	0P 0P 2Y	018 018			
MO-2321	A-7	2	F	14	GA	MO	C	BTC BTO PIT	0F 0P 2Y	077 077		*** *** *** *** *** *** *** ***	
MO-2322	F-4	2	В	14	GA	MO	С	BTO PIT	0F 2Y	077		** *** *** *** *** *** ***	
PSV-2301	F-3	2	С	1.5	ŔΫ	SA	C ·	CT-SF	57Y	1.000 (100, 000, 000, 0.00, 0.0, 0.0, 0.0, 0.00, 0.00, 0.00	العلم المراجع المراجع المراجع المراجع	VR-5	
V-23-001	A6	2	C	14	СК	SA	C	CT-CO	RŔ			VR-21	
V-23-014	C4	2	C	4	CK	SA	С	CTCO	0P	· · · · · · · · · · · · · · · · · · ·			
V23049	C-7	1	С	12	CK ,	SA	C	CT-CC CT-CO	C S C S		ant for some some some some some some some some		





PREPARED BY : IELF PROGRAM : PRISIM

ISI CLASS 1, 2, 3, AND NC VALVES DUANE ARNOLD ENERGY CENTER

•	F&1 SYS	D M TEM : R	-124 CIC - S	TEAM SI	DE		15	T PROGRA	M REVI	FAGE SION : 00	: 41 8 , 04/15/87		
VALVE NUMBER	F&ID COOR	IST CLASS			VAL VE TYPE	· ACTUATOR TYPE	NORMAL POSITION		TEST FREQ	MAXIMUM	MAXIMUM LEAKAGE	REL IEF REQUEST	REMARKS
CV-2410	D-3	NC.	A	i	GA	AO	Ø∕FĊ	AT-1 BTC FST PIT	RR - OP OP 2Y	005	NA	VR-17	
CV-2411	D-3	NC	A	1	GA	AÛ	0/FC	AT-1 BTC FST PIT	RR OP OF 2Y	005	NA	VR-17	
MD-2400	G6	1	A	4	GA	MO	0	AT-1 BTC PIT	. RR CS 2Y	020	NA	e name paper part part vide vide vide vide vide part	
40-2401	G5	1	A	4	GA	MO	0	AT-1 BTC PIT	RK OF 2Y	020	NA		NEY COL BUT LOS IN THE SHE CAN AN
	D7	NC			Ĵ SCK	MSA	C	AT-1 CT-CC	RR CS	ANT ANT 199 (49 (49 (49 (49 (49 (49 (49 (49 (49 (NA	VR-37	ana din din ang ang ang ang ang ang ang ang ang an
/-24-023	D-7	NC	A/C	10	CK	SA	C	AT-1 CT-CC	RR CS		NA	VR-37	
/-24-046	D-7	NC	A/C	3	СК	SA	C	AT-1 CT-CC.	RR C S	the des and has the off our off and the	NA	- 1000 - 2001 - 100 - 201 - 201 - 201 - 201 - 201 - 201 - 201	
/24047	D-7	NC			CK	SA	C	AT-1 CT-CC			NA	· •• •• •• •• •• •• •• •• •• •• ••	





IÓWA ELECTRIC LIGHT AND POWER

ISI CLASS 1, 2, 3, AND NC VALVES DUANE ARNOLD ENERGY CENTER

P&ID M-125 PAGE : 42 SYSTEM : RCIC - WATER SIDE IST PROGRAM REVISION : 008 , 04/15/87 MAXIMUM VALVE F&ID IST VALVE VALVE VALVE ACTUATOR NORMAL TEST STROKE -MAXIMUM RELIEF FOSITION TEST FREQ NUMBER COOR CLASS CAT SIZE TYPE TYPE TIME REQUEST REMARKS LEAKAGE **50 20 5**0 47 45 52 52 52 55 52 52 52 52 an 22 12 19 19 1: M0-2512 D-6 í A 4 GA MO С AT-1 RR NA VR-37 BTC 90 015 · PIT 2Y

PREPARED BY : IELP

PROGRAM : PRISIM

PREPARED BY : TELP PROGRAM : PRISIM

.

ISI CLASS 1, 2, 3, AND NC VALVES DUANE ARNOLD ENERGY CENTER

IOWA ELECTRIC LIGHT

	212	TEM : S	TANDET	LIGUID	CUNTROL.		15	T PRUGRA	M REVI	SION : 000	B , 04/15/87	Pr 1-80 B-07 State 4081 1-94 - 1086 B-111 - 1884 - 1444	
VAL VE NUMBER	F&ID COOR	IST CLASS	VALVE CAT	VAL VE SIZE	VAL VE TYPE	ACTUATOR TYPE	NORMAL POSITION	TEST	TEST FREQ	MAXIMUM STROKE TIME	MAXIMUM LEAKAGE	RELIEF	REMARKS
PSV-2607	E5	NC	C	í	*,RV	SA	C	CT-SP	5Y.				
PSV-2609	B5	NC	С	1	RV	SA	C .	CT-SP	5Y				tide Balt same and Balt same and and
V-26-004	D-5	NC	C.	1.5	СК	SA	С	CTCO	OF	. 1997 1997 1997 1997 1996 2996 2996 2996 2996 2996 2		n (mr + n, , nr 1.11 + n, 1.14 + n, 4 + 1.14 + 1.14 + 1.14 + 1.14 + 1.14 + 1.14 + 1.14 + 1.14 + 1.14 + 1.14 + 1	
V-26-005	C-5	NC	C	1.5	СK	SA	Ĉ	CT-CO	0P [°]				140 640 - 116 - 110 - 140 - 140 - 140 - 140 - 140 - 140 - 140 - 140 - 140 - 140 - 140 - 140 - 140 - 140 - 140 -
V-26-008	F-7	í	A/C	1.5	СК	SA	C .	AT-1 CT-CC CT-CO	RR RR RR		NA ·	VR-20 VR-20	•••• ••• ••• ••• ••• ••• ••• ••• ••• •
V-26-009	D8	í	A/C	1.5	СК	SA	C	AT-1 CT-CC CT-CO	RR RR RR	,, No, and Law and and the fact and a	NA	VR-20 VR-20	And Tak 20 (10) (<i>11)</i> (10) (10) (10)
XS-2318A	F-6	NC	D	i.5	GA	EXP	С	DT	ŔŔ		•		
XS2618B	D6	NC	D	1.5	GA	EXP	С	DT	RR:				

PREPARED BY : IELP PROGRAM : PRISIM

ISI CLASS 1, 2, 3, AND NC VALVES DUANE ARNOLD ENERGY CENTER

	P&1 SYS	D M TEM : R	-127 EACTOR	WATER (LEANUP		15	T FROGRA	M REVI	PAGE SION : 00	: 44 8 , 04/15/87		
VALVE NUMBER	P&ID COOR		VALVE CAT	VALVE SIZE	VALVE TYPE	ACTUATOR TYPE	NORMAL FOSITION	TEST	· TEST FREQ	MAX1MUM STROKE TIME	MAXIMUM LEAKAGE	RELIEF REQUEST	REMARK S
MU-2700	F-8	1	A	4	GA	MO	0	AT-1 BTC PIT	RR 0P 2Y	020	NA		
MD-2701	F-7	í	A	4	GA	MO	0	AT-1 BTC PIT	КК ОР 2Y	020	NA		/ 4N 4N 2N NE NE NE EN EN EN EN EN
MO-2740	G4	1	A	4	GL.	MO	0	AT-1 BTC PIT	RR OP; 2Y	010	NA	VR-37	







PREPARED BY : IELP PROGRAM : PRISIM

ISI CLASS 1, 2, 3, AND NC VALVES DUANE ARNOLD ENERGY CENTER

	F&1 SYS	D M TEM : R	-129 IVER WA	TER SUP	PLY - I	NTAKE	15	T PROGRAM	1 REVI	FAGE SION : 00	: 45 8 , 04/15/87		
VALVE NUMBER	F&ID COOR	IST CLASS	VALVE CAT	VALVE SIZE	VALVE TYPE	ACTUATOR TYPE	NORMAL POSITION	TEST	TEST FREQ	MAXIMUM STROKE TIME	MAXIMUM LEAKAGE	RELIEF REQUEST	REMARKS
V-29-001	D6	3	C	18	СК	SA	0	CT-CC CT-CO	0F 0F				
V-29-003	D-5	3	C .	18	СК	SA	0	CT-CC CT-CO	OF OP			, , , , , , , , , , , , , , , , , , ,	
V-29-005	D-5	3	· C	18	СК	SA	0.	CT-CC CT-CO	0P 0P				ann ann an am ann ann ann
/29007	D4	3	С	18	СК	SA	0	CT-CC CT-CO	OF OP		A	** ** ** ** ** **	

					1	NSERVICE T	ESTING PRO	IGRAM					
	(ED) BY AM : PR	: IELP ISIM				LASS 1, 2, ANE ARNOLD				÷	IOWA ELECTRIC AND FOWE		
	P& I SY S	D M TEM : C	i-130 WAFRESS	ED AIR		,	1 S	T, FROGRA	M REVI	PAGE SION : 00	: 46 8 , 04/15/87	, mar dala suk tur bur da nak tak tak	7
VALVE NUMBER	F&ID COOR	IST CLASS	VALVE CAT	VALVE SIZE	VALVE TYPE	ACTUATOR TYPE	NORMAL FOSITION	TEST	TEST FREQ	MAXIMUM STROKE TIME	MAXIMUM Leakage	RELIEF REQUEST	REMARK.
/30287	B-8	NC	A	i	ĢA	'n	C	AT-1	ĸĸ		NA		PASSIVE

.

•

•

• .

•

.

5

•

۵

:

• .

۰.

.





FREFARED BY : IELF PROGRAM : PRISIM

ISI CLASS 1, 2, 3, AND NC VALVES DUANE ARNOLD ENERGY CENTER

	F & I S Y S		IESEL G	ENERATO	R SYSTE	MS	15	T PROGRA		FAGE \$10N : 008	, 04/15/87		
VALVE NUMBER	F&1D COOR	IST CLASS	VALVE CAT	VALVE SIZE	VALVE TYPE	ACTUATOR TYPE	NORMAL POSITION	TEST	TEST FREQ	MAXINUM STROKE TIME	MAXIMUM LEAKAGE	RELIEF REQUEST	REMARKS
SV-3261A		NC	в	1,.5	ЗWY	50	C	B TO	0P			VR-7	· .
SV-3261B		NC	₿	1.5	3WY	50	C .	BTO	0P	• 100 146 644 644 pm the pm the first set	an 'na' kai kai kai kan ta suk ku kai ku kai kai kai kai kai kai kai	VR-7	
SV-3262A		NC	B	1.5	3WY	20	С	BTO	0P	,, , , , , , , , , , , , , , , , , , ,	ar ann fan ban ban ann fan bar gan bar gan gan gan gan gan	VR-7	944. 519 - 449 - 649 - 949 - 6-67 - 540 - 746 - 440
SV-3262B		NC	ß	1.5	зыл	50	С	BLO	٥Þ			VR-7	
V-32-005	B-3	NC	С	1.5	Ск	SA	С	CT-CO	OP			dh balla part adan 3-16 part anno 2007 bar balla	·
V-32-010/	B-2	NC	C	1.5	СК	SA	· C	CT-CO	OP	, and and an one on an one on one of a	an an ta	., 141 141 141 141 141 141 141 141 141 14	
v-32-032	G-7	NC	A/C	.75	СК	SA	C	AT-6 CT-CC CT-CO	RR OF OF		NA	A 199 197 199 197 197 197 197 197 198 199	
V-32-034	D-7	NC	A/C	.75	СK	SA	C	AT-6 CT-CC CT-CO	RR OF OP		NA		
/-32-043	F-8	NC	С	2	CK	SA	C	CT-CC CT-CO	0P 0P	t tabl dan			
V-32-045	F-7	NC	С	2	CK	SA	C	CT-CC CT-CO	OP OP			- 44 44 24 14 14 14 14 14 14 14 14	
/-32-052	C-8	NC	с `	2	CK	SA	C	CT-CC CT-CO	0P 0P	, 1977 1977 2077 2077 2077 1977 2077 2077 2077 2077 2077 2077 2077 2			· · · · ·
/-32-054	C-7	NC	C ·	2	СК	SA	C	CT-CC CT-CO	OP OP			· · ·	



INSERVICE TESTING FROGRAM

PREPARED BY : TELP FROGRAM : FRISIM

ISE CLASS 1, 2, 3, AND NO VALVES

IOWA ELECTRIC LIGHT AND FOWER

DUANE ARNOLD ENERGY CENTER
 P&ID
 M-137
 PAGE : 48

 SYSTEM : RADWASTE SUMP
 IST FROGRAM REVISION : 008 , 04/15/87

	د ۱ د. د ۱ د		нрмнатс	2 30HF			. 13	I PROGRA	IN REVI	12104 : 00	8 , 04/15/87		
VALVE NUMBER	P&1D COOR	IST CLASS	VALVE CAT	VAL.VE SIZE	VALVE TYPE	ACTUATOR TYPE	NORMAL FOSITION	TEST	TEST FREQ	MAXIMUM STROKE TIME	MAXIMUM LEAKAGE	RELIEF REQUEST	REMARKS
CV-3704	H-7	3	Ą	3	GA .	AÜ	0/FC	AT-1 BTC FST PIT	RR OP OF 2Y	004	NA	VR-17	
CV-3705 •	H7	3	A	3	GA	AQ	0/FC	AT-1 BTC FST PIT	RR OF OP 2Y	004	NA	VR-17	
CV-3728	D-6	3 .	A	3	GA	AÜ	0/FC	AT-1 BTC FST PIT	К К ОР ОР 2Ү	004	NA	V&-17	
CV-3729	D-3	3	A	3	GA	AD	0/FC	AT-1 BTC FST FIT	RR OP OP 2Y	004	NA	VR-17	
SV-3704	G-7	NC	B		3WY	02	· NE .	BLD	OP	NA		VR-2	
SV-3705	G-7	NC	B	• • • • • • • • • • • • • • • • • • •	3WY	50	NE	BTD	ÛF	. NA		VR-2	
SV-3728	C-6	NC	B			50	NE	BLD	0F [.]	NA		VR-2	
SV-3729	C-6	NC	В		3WY	50	NE	BTD	٥F	NA		V&-2	

FREPARED BY : IELF PROGRAM : PRISIM

ISI CLASS 1, 2, 3, AND NC VALVES DUANE ARNOLD ENERGY CENTER

IOWA ELECTRIC LIGHT AND POWER

	F & I S Y S		I-143 ONTAINM	ENT ATM	OSPHERE	CONTROL	12			SION : 008	: 49 , 04/15/87		
VALVE NUMBER	F&ID COOR	IST CLASS	VALVE Cat	VALVE SIZE	VAL VE TYPE	ACTUATOR Type	NORMAL POSITION	TEST	TEST FREQ	MAXIMUM STROKE TIME	MAXIMUM LEAKAGE	RELIEF REQUEST	REMARKS
CV4300	C-7	NC	A	18	BTE	AŬ	C/FC	AT-1 BTC FST PIT	ОР ОР 2Ү	005	NA	VR-37 VR-49 VR-17	. ·
CV-4301	C-8	NC	A	18	BTF	ΟÂ	C/FC .	AT-1 BTC FST PIT	RR OP OF 2Y	005	NA	VR-37 VR-49 VR-17	• • • • • • • • • • • • • • • • • • •
CV-4302 .	1)-7	NC	A	18	BTF	A0	C/FC	AT-1 BTC FST FIT	RR OP OP 2Y	005	NA	VR-37 VR-49 VR-17	αν ακά δας ταξι (α) και και τα
CV-4303	D-7	NC	A	18	BTF	AÜ	C/FC	AT-1 BTC FST PIT	RR OP OF 2Y	005	NA	VR-37 VR-49 VR-17	
CV-4304	B-7	NC	A	20	BTF	AD	C/FO	AT-1 BTC BTO FST PIT	RR OP OP OF 2Y	005 005	NA	VR-37 VR-17	
CV-4305 ′	B7	NC `	A	20	BTF	A0	C/F0	AT-1 BTC BTO FST FIT	RR OF OF OF 2Y	005 005	NA	VR-37 VR-17	
V-4306	E-1	NC	A	18	BTF	AŬ ,	CZEC	AT-1 BTC FST FIT	RR OF OP 2Y	• •005 •	NA	VR-37 VR-49 VR-17	



PREPARED BY : IELP PROGRAM : PRISIM

ISI CLASS 1, 2, 3, AND NC VALVES DUANE ARNOLD ENERGY CENTER IOWA ELECTRIC LIGHT AND POWER

.

.

	P&1 SYS		-143 ONTAINM	ENT ATM	OSTHERE	CONTROL	· _ 15	T PROGRA		SION : 00	50 8 , 04/15/87		
VALVE NUMBER	F&ID COOR	IST CLASS	VALVE CAT	VALVE	VALVE TYPE	ACTUATOR TYPE	NORMAL FOSITION	TEST	TEST FREQ	MAXIMUM	MAXIMUM LEAKAGE	RELIEF REQUEST	REMARKS
CV-4307	E-3	NC	A	18	BTF	A O	C/FC	AT-1 BTC FST PIT	RR 0P 0P 2Y	005	NA	VR-37 VR-49 VR-17	
CV-4308	E-3	NС	A	18	BIF	ΔÖ	C/FC	AT-1 BTC FST FIT	RR OF OF 2Y	005	NA	VR-37 VR-49 VR-17	
CV4309	₽-7	NC	A	2	GA	AD	C/FC	AT-1 BTC FST FIT	КК ОР ОГ 2 Ү	005	NA	VR-17	
CV-4310	D7	NC	A	2	GA	AD	C/FC	AT-1 BTC FST FIT	RR OP OP 2Y	005	NA	VR-17	
CV-4311	F-3	NC	A	6	GA	AÜ	C/FC	AT-1 BTC FST PIT	RR OP OF 2Y	005	NA	VK-17	
CV-4312	F-3	NC	A	6	GA .	AÜ	€/FC	AT-1 BTC FST FIT	RR OF OP 2Y	005	NA	VR-17	
CV-4313	F-3	NC	A	6	GA	AÜ	C/FC	AT-1 BTC FST FIT	RR OP OF 2Y	005	NA	VR-17	
CV-4327A .	C7	NC	A/C	18	СК	SAT	С •	AT-4 CT-CC CT-CO PIT	RR OF* OP 2Y		NA . ·	VR-11 VR-50 VR-50	

, ,

PREPARED BY : TELF

PROGRAM : PRISIM




INSERVICE TESTING PROGRAM

ISI CLASS 1, 2, 3, AND NC VALVES DUANE ARNOLD ENERGY CENTER

IOWA ELECTRIC LIGHT

•	F& I SY S	TEM : C								SION : 008	51 , 04/15/87		
VALVE NUMBER	F&ID COOR	IST CLASS	VAL VE CAT			ACTUATOR TYPE	NORMAL POSITION		TEST FREQ	MAXIMUM STROKE TIME	MAXIMUM LEAKAGE	RELIEF REQUEST	REMARKS
CV-43278	C-7	NC	A/C	18	СК	SAT	C	AT-4 CT-CC CT-CO PIT	RR OP OP 2Y		NA	VR-11 VR-50 VR-50	
CV-4327C	C-7	NC	A/C	18	CK ,	SAT	C	AT-4 CT-CC CT-CO PIT	ŘК ОР ОР 2Y	an an an an an ar ar ân an ar an a	NA	VR-11 VR-50 VR-50	
CV-4327D	. C7	NC	A/C	18	. СК	SAT	С.	AT-4 CT-CC CT-CO PIT	RK OF OF 2Y	. Los las con per est foi las est est est e	• NA	VR-11 VR-50 VR-50	
CV-4327F	C-7	NC	A/C	18	СК	SAT	C	AT-4 CT-CC CT-CO PIT	RR OP OP 2Y		NA	VR-11 VR-50 VR-50	
CV-4327G	C7	NC	A/C	18	Сĸ	SAT	C	AT-4 CT-CC CT-CO PIT	RR OF OF 2Y		NA	VR-11 VR-50 VR-50	
CV-4327H	C-7	ŃC	A/C	18	. CK	SAT	C	- AT-4 CT-CC CT-CO PIT	RR OP OP 2Y		NA	VR-11 VR-50 VR-50	
CV-4371A	E-5	NC	A	2	GA .	AQ	O/FC	AT-1 BTC FST FIT	RR OF OP 2Y	005	NA	VR-17	
CV-4371C	F-5	NC	. A	2	GA	AÜ	0/FC	AT-i BTC FST FIT	RR OF • OF 2Y	005	NA	VR-17	



PREPARED BY : IELP PROGRAM : PRISIM

IST CLASS 1, 2, 3, AND NC VALVES DUANE ARNOLD ENERGY CENTER

	P&1 SYS		1-143 CUNTAINM	ENT AT	IUSPHERE	CONTROL	15	T FROGR	AM REVI	PAGE : SION : 008	52 04/15/87		
VALVE NUMBER .	F&ID COOR	IST CLASS	VALVE CAT	VALVE Size	VAL VE TYPE	ACTUATOR TYPE	NORMAL POSITION	TEST	TEST FREQ	TIME	MAXIMUM LEAKAGE	RELIEF REQUEST	REMARKS
CV-4378A	E-5	NC	A	2	, GA	AŬ	0/FC ,	AT-1 BTC FST PIT	RR 0P 0P 2Y	025	NA~	VR-17	
CV-4378B	E-5	NC	A	2	GA	AO	0/FC	AT-1 BTC FST PIT	RR OP OP 2Y	· 025	NA	VK-17	** ** ** ** ** ** ** ** **
10-4320A	C-3	NC	В	2	GA	MÜ	C ·	BTC Bto Pít	0F 0F 2Y	012 012		.	
10-43208	Ċ-4	NC	В	2	GA	MO	С	BTC BTO PIT	0F 0F 2Y	012 012			
10-4323A	B-3	NC	B	2	GL.	MÜ	С	BTO FIT	-0P 2Y	040		- 1489 - 1680 - 1680 - 1680 - 1699 - 1698 - 1697 - 1697 - 169	
10-4323B ·	£-4 ·	NC	B	2	GL	MO	C	BTO PIT	0F 2Y	040			
'V-4300	C7	NC	В		3WY	SO	ND	BTD	0P	NA			
V-4301	C8	NC	В		3WY	<u>S0</u>	NI)	BTD	OP	NA		V8-2	, 149 ann 249 ann 241 ann 241 ann 2
V-4302	D7	NC	В		зшү	50	ND	BTD	0P	NA	de ener part date side tide ange part and side side side	VR-2	
V-4303	D-7	NC	В		3MX	50	ND	BTD	_ OP	NA	de sage good odle nod, over kede kan sage odd fde sam	VR-2	
V-4304	B-7	NC	В	. 75	3WY	S0	NE	BTD BTE	OF OF	NA NA	49 (147 647 647 647 647 647 647 647 647 647 6	VR-2 VR-2	
V4305	B-7-	NC	B	. 75	3WY	2.0	NE	BTD BTE	0P 0P	NA NA		VR-2 VR-2	





INSERVICE TESTING FROGRAM


PREPARED BY : IELP PROGRAM : PRISIM

1

ISI CLASS 1, 2, 3, AND NC VALVES DUANE ARNOLD ENERGY CENTER IOWA ELECTRIC LIGHT AND POWER

		D M TEM C		IENT ATM	OSPHERE	CONTROL	ť S	T PROGRA	M REVI		: 53 8 , 04/15/87		·
VALVE NUMBER	F&ID COOR	IST CLASS	VALVE CAT	VALVE Size	VALVE TYPE	ACTUATOR TYPE	NORMÁL POSITION	TEST	FREQ	MAXIMUM STROKE TIME	MAXIMUM LEAKAGE	RELIEF REQUEST	REMARKS
SV-4306	E-1	NC	в		3MX	50	ND	BTD	0P	NA		VR-2	
SV-4307	E3	'NC	B		ЗШҮ	<i>S</i> 0	Ъ	BTD	0P	NA		VR-2	
SV-4308	E-3	NC	B		ЗWХ	50	ND	BLD	OP	NA		VR-2	, Mart Elle, Brig Star -ten Jike gast Jike Sin
SV-4309	D7	NC	B		ЗМА	S0	ND	BTD	OP	NA	tan ber ett tet per ter sen and and and and and and and and and an	VR2	
SV-4310	D-7	NC	B		ЗМХ	20	ND	BTD	0P	NA	· •	VR-2	
<u>SV-4311</u>	F-3	NC	В		ЗМА	SÜ	ND	BTD	OP	NA		V&2	
SV-4312	F-3	NC	В		3WY	SO	ND	BLD	90	NA		VR-2	
SV4313	F3	Ю	В		3WY	S0 -	ND	BTD	0P	NA		VR-2	
SV-4331A	C-2	2	A	5	GA	02	С/КС	AT-1 BTC BTO FST PIT	RR OP OP OP 2Y	005 005	NA	VR-34 VR-34 VR-17	
SV-4331B	C-2	NC	A .	2	GA	<i>5</i> 0 .	C/KC	AT-1 BTC BTO FST PIT	RR OP OP OF 2Y	005 005	NA	VR-34 VR-34 VR-17	- - -
SV-4332A	C-2	2	A	2	GA	S O	C/KC	AT-1 BTC BTO· FST PIT	RR OP OP OP 2Y	005 005	NA 	VR-34 VR-34 VR-17	
SV-43328	C-2	NC	A	2	GA .	50	C/KC	AT-1 BTC BTO FST PIT	RR OP OP OP 2Y	005 005	NA	VR-34 VR-34 VR-17	





PREPARED BY : IELP PROGRAM : PRISIM

IST CLASS 1, 2, 3, AND NC VALVES DUANE ARNOLD ENERGY CENTER IOWA ELECTRIC LIGHT AND FOWER

		TEM : C				CONTROL	IS			PAGE : SION : 008			
VAL.VE NUMBER	F&ID COOR	IST CLASS	VAL VE CAT	VALVE SIZE	VALVE TYPE		NORMAL POSITION		TEST FREQ	MAXIMUM	MAXIMUM LEAKAGE	RELIEF REQUEST	REMARKS
SV-4333A	C-2	2	A	2	GA	20	C/KC	AT-1 BTC BTO FST PIT	RR OP OP OP 2Y	005 005	NA	VR-34 VR-34 VR-17	
SV-43338	C-2	NC	A	2	GA	50	C/KC	AT-1 BTC BTO FST PIT	RR OP OP OP 2Y	005 005	NA	VR-34 VR-34 VR-17	
SV-4334A	B-2	2	A .	2	GA	S0	C/KC	AT-1 BTC BTO FST PIT	RR OP OP OP 2Y	005 005	NA	VR-34 VR-34 VR-17	
SV-4334B •	8-2	NC	A	2	GA	50	C/KC	AT-1 BTC BTO FST PIT	RR OF OP OF 2Y	005 005	NA .	VR-34 VR-34 VR-17	
SV-4371A	£5	NC	B		3MX	so	NE	BTD	0P	NA	an same tyde fan tyde kann saks fan ande fan den fan teke	VR-2	
SV-4371C	F5	NC	₿		ЗШҮ	50	NE .	BTD	OP	NA	an gan san tan dan dan san sat bar sat bar at dan an bar bar	VR-2	PR- 18- 14- 14- 14- 14- 14- 14- 14- 14- 14- 14
SV-4378A	E-5	NC	B		ЗШҮ	<i>s</i> 0	NE	BTD	08	NA		VR-2	
SV-43788	E5	NC	в		ЗШХ	50	NE	BTD	0P	NA		VR-2	-
V-43-082	C-3	NC	С	2	СК	SA	C.	CT-CO	0P				
V-43-084	C-3	NC	С	2	СК	SA	С,	CTCO	0P		مرا المراد ا مراد المراد ا		

-CO 0P

IOWA ELECTRIC LIGHT AND POWER

ISI CLASS 1, 2, 3, AND NO VALVES DUANE ARNOLD ENERGY CENTER

	ዮል I S Y S		I-143 CONTAINM	ЕНТ АТМ	IOSPHERE	CONTROL	. 12	T PROGRAM	M REVI	PAGE SION : 00			. ·
VALVE NUMBER	F&ID COOR	IST CLASS	VAL VE CAT	VAL VE S I ZE	VALVE TYPE	ACTUATOR TYPE	NORMAL POSITION	TEST	TEST FREQ	MAXIMUM STROKE TIME	MAXIMUM LEAKAGE	RELIEF REQUEST	REMARKS
V-43-083	C-3	NC	С	2	CK	SA	C ·	CT-C0	٥P				
V-43-088	B-3	NC	С	2	CK	SA	С	CT-CO	0P	a ann ann a suit bar suis aine san suit san suir		ar badi kana amin'ny kana pamin'ny kaominina dia mampina dia	
V-43-168	A-7	NC	A/C	20	СК	SA	C	AT-1 CT-CC	RR' OP	·	NA	VR-37	· · · · · · · · · · · · · · · · · · ·

								CT-CO FIT	0P 2Y		•	
V-43-169	A-7	NC	A/C	20	СК	SA	C	AT-1 CT-CC CT-CO PIT	ћћ Ор Ор 24	NA	VR-37 .	4 <i>4 94 9</i> 4 94 94 94
V-43-214	F4	NC	A/C	2	ск	SA	С.,	AT-1 CT-CC	RR RR	NA	VR-25	

PREPARED BY : JELP FROGRAM FRISIM

•						(WER RELIEF REQUEST	•
	KED BY M : PR		•		ISI (DL	NSERVICE T LASS 1, 2, JANE ARNOLD	3, AND NC ENERGY CE	VALVES NTER			IOWA ELECTRI AND POW		•
		ל D TEM : 5	1-146 Service	WATER P	ump hou		-	•		PACE	56 , 04/15/87		
VALVE NUMBER	F&ID COOR	IST CLASS	VAL.VE CAT	VALVE SIZE	VAL VE TYPE	ACTUATOR TYPE	NORMAL POSITION	TEST	TEST FREQ	MAXIMUM STROKE TIME	MAXIMUM LEAKAGE	RELIEF REQUEST	REMARKS
CV-4909	H6	3	B	24	BTF	AÜ	0/FC	BTC FST PIT	0P 0F 2Y	060		۲	
CV-4910A	H7	3	В	24	BTF	0A	0/FC	BTC FST PIT	0F - 0F 2Y	060		VR-17	
CV-4910B	H7	3	B	24	BTF	AO	0/FC .	BTC FST PIT	0P 0F 2Y .	060	en dala tuen nam tang sam tan tan tala nam dala dala tala	VR-17	
SV-4909	H6	NC	. B	, 1997 Mar 2007 July 1997 Anto 2007 July	ЗWY	50	NE	BTC FST	0P 0P	NA	n fan van der ein och den van ger by, den gen her ger		ant daha daha ting dan ting dan dan dah
SV-4910A	H-7		B		3MX .	2.0	NE	BTC FST	0F' 0P	NA			
SV-4910B	H-7	NC	B		3WY	20	NE	BTC FST	0P 0P	NA	n bar fan san bar em om om om om om om bar bar bar		
/46011	8-5	3	С	12	СК	SA	C ,	CT-CC CT-CO	OF OP				** *** ** ** ** ** **
/-46-013	B5	3	С	12	СК	SA	С	CT-CC CT-CO	0P 0P	, fait 100, fait più ave fait can can bai più an			
/-46-018	C3	3	C	8	СК	SA	C .	CT-CC CT-C0	RR 0P			VK-39	
1-46-021	C-4	3	C	8	CK	SA	С	CT-CC CT-CO	RR OP	, that dae had and the bar and the second		VR-39	
(-45-026	B-7	3	С	12	СК	S'A	С	СТ-СС СТ-СС'	 0F 0P		· · · · · · · · · · · · · · · · · · ·		

. .

•

-

	KED BY Am : Fr	: IELF ISIM			ISI C DU	LASS 1, 2, IANE ARNOLD	ESTING PRO 3, AND NC ENERGY CE	VALVES NTER			IOWA ELECTRI AND POW			
		TEM : S		WATER F	, -		I <i>S</i> .	T FROGRA	M REVI	SION : 008	: 57 , 04/15/87		1897 (1897 (1897 (1897 (1897 (1897 (1897 (1897 (1897 (1897 (1897 (1897 (1897 (1897 (1897 (1897 (1897 (1897 (1897	
VALVE NUMBER	PAID	IST CLASS			VALVE TYPE	ACTUATOR TYPE	NORMAL FOSITION	TEST	TEST FREQ	MAXIMUM STROKE TIME	MAXIMUM LEAKAGE	RELIEF Request	REMARKS	,
V46030	B-7	3	C	12	СК	AS	C	CT-CC CT-CO	ወድ ወድ					
		inn die run die rak on			1 MAY 199 (199 199) (199 199) (199 199)	, , ,				, , , , , , , , , , , , , , , , , , ,				
					<i></i> .					ſ				
							•							
				-							•			

.

•

.

• •





PREPARED BY : IELP PROGRAM : PRISIM

ISI CLASS 1, 2, 3, AND NC VALVES DUANE ARNOLD ENERGY CENTER ..

IOWA ELECTRIC LIGHT AND POWER

		TEM : D		COOLING			. 15	T PROGRA	M REVI	SION : 00	: 58 8 , 04/15/87		
VALVE NUMBER	P&ID COOR	IST CLASS	VALVE	VALVE SIZE	VALVE TYPE	ACTUATOR TYPE	NORMAL POSITION	TEST	TEST FREQ	MAXIMUM STROKE TIME	MAXIMUM LEAKAGE	RELIEF REQUEST	REMARK S
CV-5704A	H6	NC	A	. 4	GL	AO	0/F0	AT-1 BTC BTO FST PIT	RR OP OF OP 2Y	005 005	NA	VR-37 VR-17	
CV-5704B	H-6	NC	A	4	GŁ	AÜ	û∕FO	AT-1 BTC BTO FST PIT	RR OP OF OP 2Y	005 005	NA	VR-37 VR-17	
CV-5718A	₿-8	NC	A	4	GL .	AO	0/F0	AT-1 BTC BTO FST FIT	RR OF OF OP 2Y	005 005	NA	VR-37 VR-17	
CV-5718B	A-8	NC	A	4	GL	AÜ	0/FO	AT-1 BTC BTO FST FIT	RR OP OP OP 2Y	005 005	NA	VR-37 VR-17	40 au 24 au 26 au 26 au 27 au
SV-5704A	H-6	NC	B		3WY	2.0	. ND .	BTD BTE	OF OP	NA NA		VR-2 VR-2	
SV-5704B	H6	NC	B		3WY	02	ND	BTD BTE	OF OF	NA NA		VR-2 VR-2	
SV-5718A	B-8	NC	B	··· •• •• •• •• •• •• ••	3WY	5.0	ND .	BTD BTE	OF OP	NA NA		VR-2 VR-2	
SV-5718B	A~8	NC	B		ЗШҮ	\$0	D	BTD BTE	0P 0P	NA NA		VR-2 VR-2	





INSERVICE TESTING PROGRAM

PREPARED BY : IELP PROGRAM : PRISIM

 ISI CLASS 1, 2, 3; AND NC VALVES DUANE ARNOLD ENERGY CENTER IOWA ELECTRIC LIGHT AND POWER

....

	F& I SYS		I-157 RYWELL	COÓF INC	WATER		12	T PROGRA	M REVI	PAGE STON : 008			
VALVE NUMBER	F&ID COOR	IST CLASS	VAL VE CAT	VALVE SIZE	VALVE TYPE	ACTUATOR TYPE	NORMAL POSITION	TEST	TEST FREQ	MAXIMUM STROKE TIME	MAXIMUM LEAKAGE	RELIEF REQUEST	REMARKS
V-57-075	G-7	NC	A	3	GL.	м	С	AT-1	RR		NA	VR-37	
V-57-076	F-7	NC	A,	3	GL.	M ·	С:	AT-1	RR	e con fat das our par con son son son s	NA	VR-37	t 1997 2-00 2-00 1994 1994 1997 2-00 2-00 2-00
/-57-077	B7	NC	A	3	GL.	м	С	AT-1	RR		NA	VR37	*
v-57-078	A7	NC	A	3	GL.	М	C	AT-1	ŔŔ	er som vær sær sær sær sær sær	NA	VR-37	. 644 - 746 - 944 - 944 - 944 - 944 - 944 - 744 - 944

PREPAR	FD BY	: IELI			J	NSERVICE · TE	STING FRO)GRAM			IOWA ELECTRI	ר וזרעד	
FROGRA		RISIM		AT 1886 2467 2488 2486 2487 118))U	LASS 1, 2, ANE ARNOLD	ENERGY CE		4* 1 5 4 1 144 144 144 144		AND FOW		
		STEM : I				MONITORING	1.5	T FROGRAM	1 REVI	FAGE : SION : 008	04/15/87		
VALVE NUMBER	FAID	IST CLASS				ACTUATOR		•	TEST FREQ	MAXIMUM STROKE TIME	MAXIMUM LEAKAGE	RELIEF REQUEST	REMARKS
8101A	F-5	NC	A	1	GL.	S0	0/FC	AT-1 BTC FST	RR OP OP	МА	NA	VR-32 VR-17	
SV-8101B	F4	ŃC	A	1	GL.	20	0/FC	AT-1 BTC FST	RR OP OP	NA	NA	VR-32 VR-17	
SV-8102A	F-5	NC	A .	1	Gl.	58 .	0/FC	AT-'1 BTC FST	RR 0P 0P	NA	NA	VR-32 VR-17	
5V-8102B	F-4	NC	A	1.	GL.	50	0/FC	AT-1 BTC FST	RR 0F 0P	NA	NA	VR-32 VR-17	
SV-8103A	E-5	NC	A	1	GL.	SO	0/FC	AT-1 BTC FSȚ	RR OP OP	NA	NA	VR-32 VR-17	
5V-8103B	E-4	NC	A	1	GL	50	0/FC	AT-1 BTC FST	RR 0P 0F	NA	NA	VR-32 VR-17	1941 1941 1941 1941 1947 1945 1947 1947 1947 194 7 1947
SV-8104A	E5	NC	A	í	GŁ.	\$0	0/FC	AT-1 BTC FST	RR 0P 0P	NA	NA	VR-32 VR-17	20 10 10 10 10 10 10 10 10 10 10 10 10 10
SV-8104B	E4	NC	A	i	GL.	50	0/FC	AT-1 BTC FST	RR OP OP	NA	NA	VK-32 VR-17	
V-8105A	E-5	NC	A	i	GL.	\$0	0/FC	AT-1 BTC FST	RR OF OP	NA	NA	VR-32 VR-17	

PREPARED BY : IELP PROGRAM : PRISIM

ISI CLASS 1, 2, 3, AND NC VALVES DUANE ARNOLD ENERGY CENTER

	ዮል I S Y S		I-181 CONTAINM	IENT ATM	IOSTHERE	MONITORIN	IG I <i>S</i>	T FROGR		SION : 008	61 , 04/15/87		
VALVE NUMBER	P&ID COOR	IST CLASS	VALVE CAT	VALVE S'IZE	VAL VE TYPE	ACTUATOR TYPE	NORMAL FOSITION	TEST	TEST FREQ	MAXIMUM STROKE TIME	MAXIMUM	RELIEF REQUEST	REMARKS
\$V-81058	E4	NC	A	i	GI.	20	0/FC	AT-1 BTC FST	КК ОР ОР	NA	NA	VR-32 VR-17	• .
SV-8103A	E~5	NC	A	1	GL.	50	0/FC	AT-1 BTC FST	КК ОР ОР	NA	NA	VR-32 VR-17	<u></u> ,
SA-8109B	E-4	NC	A.	1	GL.	. 02	0/FC	AT-1 BTC FST	RR OP OP	NA	NA	VR-32 VR-17	
SV-8107A .	D-5	NC	A	1	GL.	2.0	0/FC	AT-1 BTC FST	ћћ ОР ОГ:	NA .	NA	VR-32 VR-17	
57-81078	Ď⊶4	NC	A	1	GL.	. 02	0/FC	AT-1 BTC FST	RR OP OP	NA	NA	VR-32- VR-17	
5V-8108A	D-5	NC	A	1	GL.	50	O/FC	AT-1 BTC FST	RR 0P 0P	NA	NA	VR-32 VR-17	
SV-8108B	D4	NC	A	1	GL	0.5	0/FC	AT-1 BTC FST	RR OP OP	NÁ	NA ·	VR-32 VR-17	*** ** == == ** ** ** **
SV-8109A	1)-5	NC	A	1	GL.	S0	0/FC	AT-1 BTC FST	RR OP OP	NA	NA	VR-32 VR-17	
SV-8109B	D4	NC	A	1	GL.	<i>S</i> 0	0/FC	AT-1 BTC FST	RR OP OP	NA	NA	VR-32 VR-17	fan ann an ann ann ann ann ann an





PREPARED BY : IELP PROGRAM : PRISIM



INSERVICE TESTING PROGRAM

IST CLASS 1, 2, 3, AND NC VALVES DUANE ARNOLD ENERGY CENTER IOWA ELECTRIC LIGHT AND FOWER

	149 272		-181 ONTAINM	ENT ATM	05'F'HERE	MONITORIN	G 15	T PROGR	AM REVI	PAGE SION : 00			
VALVE NUMBER	P&1D COOR	IST CLASS	VALVE CAT	VALVE SIZE	VALVE TYPE	ACTUATOR TYPE	NORMAL FOSITION	TEST	TEST FREQ	MAXIMUM STROKE TIME	MAXIMUM LEAKAGE	RELIEF REQUEST	REMARKS
V-8110A	D-5	NC	A	1	GŁ.	2:0	0/FC	AT-1 BTC FST	RR OP OF	NA	NA .	VR-32 VR-17	
V-8110B	D-4	NC	A	1	GL.	20	07FC	AT-1 BTC FST	RR 0P 0P	, NA	NA	VR-32 VR-17	** -** *** *** *** *** *** **

. . .

		: TELF	•				ESTING PRO				IOWA ELECTRI		~
PROGR	4M : PR				DL	JANE ARNOLD	3, AND NC D ENERGY CE	VALVES NTER			AND POW		•••••••••••
	F&I SYS	D M TEM M	I-184 ISIV LEA	KAGE CO	INTROL			T PROGRA	AM REVI	FAGE SION 008	63 , θ4/15/87		
VALVE NUMBER	F&ID COOR	IST CLASS	VALVE CAT	VALVE SIZE	VALVE TYPE	ACTUATOR TYPE	NORMAL POSITION	TEST	FREQ	MAXIMUM STROKE TIME	MAXIMUM LEAKAGE	RELIEF REQUEST	REMARKS
MO-8401A	F3	1	В	1	GA	MO	C·	BTC BTO PIT	0P 0F 2Y	020 020			
MO-8401B	F-3	1	В	1	GA	MO	· C	BTC BTO PIT	0P 0P 2Y	020 020			1000 bat) -000 1000 catt rait rait taat aa
M0-8401C	F-3	1	B	1	GA	MO	C .	BTC BTO PIT	0P 0P 2Y	020 020		17 milit tan 1971 (196 199 199 199 199 199 199 199 199	**** 754 768 787 767 767 844 844 844 84
MO-8401D	F-3	1	В	1	GA	MO	C	BTC BTO PIT	0P 0F 2Y	020 020			141 - 241 - 241 - 241 - 244 - 244 - 244 - 244 - 244 - 244 - 244 - 244 - 244 - 244 - 244 - 244 - 244 - 244 - 244
MD-8402A .	F-3	NC	в	1	GA	MO	C	BTC BTO PIT	0P 0P 2Y	020 020			
MO-8402B	F3	NC	B	í	GA	MO	Ċ.	BTC BTO PIT	0F 0F 2Y	020 020			
MD-8402C	F3	NC	в	1	GA	MO	C	BTC BTO PIT	0P 0F 2Y	020 020			
MD-8402D	F-3	NC	B	1	GA	МО	С	BTC BTO PIT	0P 0P 2Y	020 020			
MB-8403A	F4	NC	B ·	1	GA	MO .	C ·	BTC BTO	OP OF	020 020		Mar 14 4 (142 (142 (142 (142 (142 (142 (142 (14	

												VD POWER 5/87 1UM RELIEF	
	NUMBER COOR CLASS CAT SIZE TYPE TYPE FOSITION TEST FREQ TIME LEAKAGE REQUEST IN THE DATA OF 020 D-8403E F-4 NC B 1 GA MO C BTC OF 020 PIT 2Y D-8403D F-4 NC B 1 GA MO C BTC OF 020 D-8403D F-4 NC B 1 GA MO C BTC OF 020 PIT 2Y	-											
PREPARED BY : IELP FROGRAM : ISI CLASS 1, 2, 3, AND NC VALVES DUANE ARNOLD ENERGY CENTER IOWA ELECTRIC LIGHT AND POWER PAID M-184 SYSTEM : ISI CLASS 1, 2, 3, AND NC VALVES DUANE ARNOLD ENERGY CENTER PAGE : 64 VALVE M-184 SYSTEM : PAGE control IST PROGRAM REVISION : 008 , 04/15/87 VALVE PAID IST VALVE VALVE ACTUATOR NORMAL NUMBER CON CLASS CAT SIZE TYPE M0-84038 F-4 NC B I GA MO C BTC OP 020 PIT 27 M0-84030 F-4 NC B I GA MO C BTC OP 020 BTO 020 PIT 27													
NUMBER	COOR	CLASS	CAT	SIZE	TYPE	TYPE	NORMAL FOSITION	TEST	TEST Freq	MAXIMUM STROKE	MAXIMUM		REMARK S
10-84038	F-4	NC	ß	1 .	GA	МО	C	BTO	0P				
i0-8403C	'F-4	NC	B	1	GA-	MO	C	BTO PIT	0F 2Y				
10-8403D	F4	NĊ	B	1	GA	MO	С	BTC	0F'		12 14 21 21 21 21 21 21 21 21 21 21 21 21 21		

.

. · · ·

.

						•								
			••• ••• • ••• ••• ••• ••• ••• ••• •••	•• ••• ••• ••• ••• ••• •••		INSERVICE	TESTING PRO		,* 1 <u>1</u>					
FREFARED BY : IELP PROGRAM : PRISIM					ISI C	CLASS 1, 2,	3, AND NC VALVES ENERGY CENTER			IOWA ELECTRIC LIGHT AND POWER				
F&ID M-187 System = fost accident sampling system							15	PAGE : 65 IST PROGRAM REVISION : 008 , 04/15/87						
VALVE NUMBER	P&ID COOR	IST CLASS	VAL.VE CAT	VALVE SIZE	VALVE TYPE	ACTUATOR TYPE	NORMAL POSITION	TEST	TEST FREQ	MAXIMUM STROKE TIME	MAXIMUM LEAKAGE	RELIEF REQUEST	REMARKS	
SV-8772A	B8	NC	A	1	GL.	50	C	AT-1 BTC FST PIT	RR OP OP 2Y	005	NA	VR-34 VR-17		
2A-8445B	B-8	NC	A	í	GL.	02	C	AT-1 BTC FST PIT	RR OP OF 2Y	005	NA	VR-34 VR-17		

.

PROGRAM BY : IELP PROGRAM : PRISIM

ISI CLASS 1, 2, 3 AND NO VALVES DUANE ARNOLD ENERGY CENTER

IOWA ELECTRIC LIGHT AND FOWER

PAGE 66

IST FROGRAM REVISION: 008, 04/15/87

VALVE IST PROGRAM REMARKS

- NOTE 001: THERE ARE 89 CRD HYDRAULIC CONTROL MODULES EACH CONTAINING ONE OF THESE VALVES. THE VALVE NUMBER LISTED IN THE VALVE IST PROGRAM IS TYPICAL OF 89.
- NOTE 002: VALVE NO. V-18-0118 IS A TYPICAL VALVE NUMBER FROM A GROUP OF 89 VALVES. THE COMPLETE SET OF NUMBERS IS V-18-0118 THRU V-18-0206.
- NOTE 003: VALVE NO. V-18-0919 IS A TYPICAL VALVE NUMBER FROM A GROUP OF 89 VALVES. THE COMPLETE SET OF NUMBERS IS V-18-0919 THRU V-18-1007.
- NOTE 004: VALVE NO. V-18-1453 IS A TYPICAL VALVE NUMBER FROM A GROUP OF 89 VALVES. THE COMPLETE SET OF NUMBERS IS V-18-1453 THRU V-18-1541.
- NOTE 005: THESE VALVES ARE VERIFIED TO OPEN DURING PERIODIC TESTING OF THE RCIC FUMP.
- NOTE 006: SEE RELIEF REQUEST VR-2.

APPENDIX C

DATE 04/01/87 Rev. 8

The American Society of Mechanical Engineers

United Engineering Center / 345 E. 47th St., New York, N.Y. 10017 / 212 644-7815

Scope of Section XI, Division 1

ASME File #: BC 77-666

Your inquiry and our response are as stated below:

Reference: Your letter of September 19, 1977 (APO 77-59)

NI 77-371

February 16, 1978 THE BOILER AND PHESELURE VESSEL

Date 1/8/79 Revision 0

L. T. Harrold, Supervisor, ISI Programs Washington Public Power Supply System PO Box 968 3000 George Washington Way W.L. HARDING Richland, WA 99352 Subject: Section XI, Division 1, IWA-1100

C W. ALLISON 8.W. BACE R.D. BONNER R.J. BOSNAK PM BRISTER H.M. CANAVAN R.J. CEPLUCH W.E. COOPER W.D. DOTY G.E. FRATCHER R.C. GRIFFIN S.F HARRISON E.J. HEMZY WP JOHNSON E.L. KEMMLER E.L. KIME J.E. LATTAN J. L-COFF J.R. MACKAY A.H MOELLER

COMMITTEE

Charmen

Vice-Charl

Secretary

W.B. HOYT

C.E. RAWLINS WR SMITH, SR.

W.E SOMERS

Systems containing other than steam or water were not originally considered by the Committee in formulating the rules in Section XI; they may, however, be included for further consideration and for revisions to future editions of Section XI. The requirements shown in Section XI, Article IWA-1000 on Scope and Responsibility, specifically Paragraph IWA-1400, requires the Owner of the nuclear plant to determine the appropriate Code, Class or Classes for each component of the nuclear power plant to be examined according to Section XI rules.

Is it the intent of Subarticle IWA-1100 that the rules and requirements of Section XI, Division 1 for inservice inspection of Class 1, 2 & 3 pressure retaining components (and their supports) be applied only to

water and steam systems in light water cooled nuclear power plants?

Very truly yours,

Dear Mr. Harrold:

QUESTION:

REPLY:

Memetin of Fair

Kenneth I. Baron, Assistant Secretary

/fs

Member of Engineers Council for Professional Development and Engineers Joint Council

PAGE 1 of 3

APPENDIX D: COLD SHUTDOWN TEST JUSTIFICATIONS

DATE 04/01/87 Rev. 8

1. <u>MO-4841A and MO-4841B - Reactor Building Closed Cooling Water System</u> (RBCCW) Drywell Isolation Valves

During plant operation, RBCCW is supplied (and returned) through these valves to provide cooling to critical components located in the drywell including the reactor recirculation pump motor windings, seal water coolers, and lube oil coolers. Closing MO-4841A or B will interrupt cooling water flow and could result in damage to pump and motor components.

2. MO-4441 and MO-4442 - Reactor Feedwater Outboard Containment Isolation Valves

During plant operation at power, reactor feedwater is supplied through both these valves to maintain reactor coolant inventory in the reactor vessel and maintain reactor vessel water level. Closing either of these valves will isolate two of the four supplies of feedwater into the reactor vessel. This could result in thermal shock to the reactor vessel feedwater nozzles and spargers upon resumption of flow and a plant trip due to the potential for severe reactor vessel water level transients during the evolutions.

3. V-14-003 - Reactor Feedwater Inboard Containment Isolation Valve

During plant operation at power, reactor feedwater is supplied through this valve and V-14-001 to maintain reactor coolant inventory in the reactor vessel and maintain reactor vessel water level. Closing V-14-003 requires isolation of two of the four supplies of feedwater to the reactor vessel. This could result in thermal shock to the reactor vessel feedwater nozzles and spargers upon resumption of flow and a plant trip due to the potential for severe reactor vessel water level transients during the evolution.

4. MO-4627 and MO-4628 - Reactor Recirculation Pump Discharge Valves

Closing either of these valves during plant operation places the recirculation system in a "single loop" configuration. Although single-loop operation is possible, it requires power reduction and is a complex evolution. It is not considered prudent to routinely and voluntarily place the plant in this configuration.

5. MO-4629 and MO-4630 - Reactor Recirculation Pump Discharge Bypass Valves

During normal plant operation, these valves remain open to provide an improved environment for the 4-inch bypass piping. With the valves open and flow through the line, thermal stresses across the valves are eliminated as is the "dead leg" condition in the bypass line - a potential cause of stress corrosion cracking, (Reference General Electric SIL No. 104). If during testing, either of these valves were to fail in the closed position, prudency may require a plant shutdown to correct the problem and reopen the valve(s).







APPENDIX D: COLD SHUTDOWN TEST JUSTIFICATIONS

DATE 04/01/87 Rev. 8



MO-2238 - High Pressure Coolant Injection Steam Supply Valve MO-2400 - Reactor Core Isolation Cooling Steam Supply Valve

During plant operation these valves remain open to ensure steam supply to the respective turbine-driven pump. Exercising these valves to the closed position renders the associated system inoperable while the valve is closed. Since these valves are located inside the drywell and are inaccessible during operation, if one were to fail in the closed position during testing, the plant would enter into an LCO condition and ultimately require shutdown.


7. V-22-016 - HPCI Turbine Exhaust Check Valve V-24-023 - RCIC Turbine Exhaust Check Valve

During plant operation these valves must be capable of opening to allow turbine exhaust steam to exit into the suppression chamber. Testing of these valves to the closed position requires downstream valves to be closed when air pressure is used to verify valve closure. While the tests are in progress, the respective pump is effectively inoperable since there is no pathway for turbine exhaust steam.

- 8. <u>V-22-17 HPCI Turbine Exhaust Stop-Check Valve</u> <u>V-24-08 - RCIC Turbine Exhaust Stop-Check Valve</u>
 - During plant operation these valves must be capable of opening to allow turbine exhaust steam to exit in to the suppression chamber. These valves are provided with a manual operator that forces the plug to the closed position. While the manual operation is in the closed position, the respective pump is effectively inoperable since there is no pathway for turbine exhaust steam. Furthermore, the associated turbine stop valve must be defeated in the closed position to preclude turbine auto initiation that could result in personnel injury as a result of steam exhausting via the blowout plugs.
- 9. V-22-021 HPCI Condensate Drain Valve V-22-022 - HPCI Condensate Drain Valve

During HPCI system operation these valves allow condensate to drain from the HPCI turbine exhaust drain pot to the suppression chamber. Testing of this valve to the closed position requires V-22-022 to be closed. If HPCI were to initiate while this test was in progress, condensate could backup into the turbine exhaust piping and casing resulting in potential damage to critical components or adverse affects with respect to system performance.

10. V-22-63 and V-22-64 - HPCI Exhaust Line Vacuum Breakers V-24-46 and V-24-47 - RCIC Exhaust Line Vacuum Breakers



APPENDIX D: COLD SHUTDOWN TEST JUSTIFICATIONS

PAGE

DATE 04/01/87 Rev. 8

۱



11. MO-1908 and MO-1909 - Residual Heat Removal - Shutdown Cooling Supply Valves

These valves are electrically interlocked to prevent opening with reactor pressure greater than 135 psig to preclude overpressurization of the residual heat removal system.

12. V-23-049 - HPCI Pump Discharge Check Valve

This valve opens to provide an injection flow path into the reactor vessel for the HPCI system. Injection with the HPCI system at power is not possible due to the potential for severe reactor vessel water level transients that could result. This valve is not accessible during power operation.








REFERENCED MATERIAL FOR ATTACHMENT 1



.

•



October 18, 1974 Tab "A"

SIL No. 104 Category 2

OPERATION WITH OPEN BYPASS VALVE IN RECIRC SYSTEM

The following presents the recommendation of GE-NED to implement operation with the recirc bypass valve open at all operating GE/BWRs, particularly at those having recirc pumps driven by MG sets.

Operation with the bypass open will avoid the thermal stresses in the bypass by eliminating the temperature differential between the bypass and the main recirc line during normal operation. It will also eliminate the "dead leg" condition as a potential cause of stress corrosion cracking. While neither the thermal stress nor dead leg conditions have been identified as the cause of cracks in any of the recently affected plants, any reduction of stress is an improvement, and elimination of dead legs is not detrimental.

The recommendation to operate "Bypass Open" applies to all GE/BWRs although completed engineering evaluations were done only for BWR/3 and BWR/4 plants which have jet pumps, MG sets and four-inch bypass lines. The recommendation, however, is equally valid for earlier plants, although there may be differences in interlocks, operating procedures, etc., which in these cases should be reviewed on an individual plant basis. GE-NED will provide technical assistance if requested; however, it is expected that in most cases such reviews will be conducted between the utility and the AEC.

- A. <u>Recommended Procedure for Implementing "Bypass Open" Operation</u>, BWR/2, BWR/3 and BWR/4 Plants
 - 1. Obtain AEC concurrence that bypass open operation is not an unresolved safety question, does not require a tech spec change, or is otherwise unacceptable.
 - 2. During the next plant shutdown, visually or otherwise verify absence of bypass line vibration during cold pump operation at 20 percent pump speed, bypass open, main valve closed. For BWR/2, BWR/3 and BWR/4 plants, allowable vibration, as measured at the bottom of the bypass vertical leg and perpendicular to the plane formed by the vertical and horizontal legs of the main recirc pipe, should not exceed 0.4 inch, peak to peak. If the bypass has a strut, the allowable vibration is 0.07 inch, peak to peak.

NUCLEAR ENERGY DIVISION OPERATING PLANT SERVICES

SAN JOSE, CALIFORNIA 95125

NO WARRANTY OR REPRESENTATION EXPRESSED OR IMPLIED IS MADE WITH RESPECT TO THE ACCURACY, COMPLETENESS OR USEFULNESS OF THIS INFOR-MATION. GENERAL ELECTRIC COMPANY ASSUMES NO RESPONSIBILITY FOR LIA-BULTY OR DAMAGE WHICH MAY RESULT FROM THE USE OF THIS INFORMATION.





3. Existing pump start procedures still apply with the exception that bypass valve remains open instead of being closed. Keep the bypass valve open during all normal operating conditions.

-2-

- 4. There are no new restrictions on closing the bypass valve for purposes of isolating the recirc pump.
- 5. There are no changes required to the valve interlock system for either operating or safety reasons. The above is true for BWR/3 and BWR/4 plants. BWR/2 plants should review their system for confirmation.

B. <u>BWR/3 and BWR/4 Evaluations</u>

- 1. Calculations by GE-NED Engineering show that operation with the bypass valve open and the main valve closed and with the pump at 20 percent speed results in a flow of 800 1000 gpm through the bypass. Operation with the bypass valve open and the main valve open and the pump at 100 percent speed results in a flow of 500 600 gpm through the bypass. It is concluded that the flow rate during normal operation is less than during pump startup, during which no significant vibration has been noted.
- 2. For those plants having LPCI injection into the recirc loops, the discharge and bypass valves in the unbroken loop now close automatically on an accident signal. No change is required to accomplish this safety related action.
- 3. For those plants having LPCI injection into the vessel, closure of the bypass valve is not required during an accident involving severance of the recirc line.

If additional assistance is needed in implementing the above recommendation, contact GE-NED, Operating Plant Services, through your local GE service of representative.

Prepared by: V. G. Grayhek


Approved by: Issued by: D. G. Bridenbaugh, Manager

D. G. Bridenbaugh, Maynager Performance Evaluation and Improvement

V. G. Grayhek, Manager Performance Analysis and Service Communications

Product Reference:

A71 - Plant Recommendations



October 31, 1974

File: TAB "A"

SIL No. 104 Supplement 1 Category 4

OPERATION WITH OPEN BYPASS VALVE IN RECIRC SYSTEM

This supplement to SIL No. 104 (original SIL issued October 18, 1974) presents the GE-NED safety evaluation for operation with the recirculation system isolation valve bypass line open.

Operation with the recirculation pump isolation valve bypass line open is intended to provide an improved operating environment for the bypass line? The purpose of this evaluation is to verify that an unreviewed safety hazard does not exist for plant operation with the bypass valve open. Of primary concern here are the BWR 2, 3 and 4 reactors; however, the conclusions reached are considered applicable to BWR 5 and 6 reactors.

A review of the safety analysis shows that operation of the recirculation system with the bypass valve open or closed has an indeterminately negligible effect on the primary system coolant flow. Thus, operation with this valve in either position does not affect core characteristics, such as void fraction, which could have an effect on total core steady state and transient operation. Transient effects due to cold loop startup remain unchanged from the current safety analyses since the transient is based on the isolation valve being closed and the bypass valve open. Thus, there is no change from the safety analyses previously reviewed by the AEC.

A review of the accident considerations indicates that none of the analytical results would be changed. This review showed that the only case in which the bypass valve played a role was in the LPCI system operation during a LOCA. In this operating mode, initiation of the LPCI system also automatically initiates closure of the recirculation pump discharge isolation valves and the bypass valves. Regardless of the position of the valve initially, it receives a signal to close so that the final position of the valve in either case is closed. These valves are closed so that the coolant flow, which enters the recirculation system downstream of the valves, goes directly into the reactor and down through the jetpumps. This was also done (automatic

NUCLEAR ENERGY DIVISION OPERATING PLANT SERVICES

SAN JOSE, CALIFORNIA 95125

NO WARRANTY OR REPRESENTATION EXPRESSED OR IMPLIED IS MADE WITH RESPECT TO THE ACCURACY, COMPLETENESS OR USEFULNESS OF THIS INFOR-MATION. GENERAL ELECTRIC COMPANY ASSUMES NO RESPONSIBILITY FOR LIA-BILITY OR DAMAGE WHICH MAY RESULT FROM THE USE OF THIS INFORMATION.





October 31, 1974

SIL No. 104 Supplement 1

valve closure) so that the valve would close if a LOCA occurred during pump startup with the valve open. These conditions have been previously reviewed by the AEC and there is no change in the safety analyses.

Conclusion

Based on this review of the safety analyses, operation with the bypass valve open does not present any new conditions which the AEC has not previously reviewed. This operation with this valve configuration does not present an unreviewed safety hazard.

Prepared by: V.G. Grayhek

Approved by: Issued by: D.G. Bridenbaugh, Manager

Performance Evaluation and Improvement

UL

V.G. Grayhek, Manager Performance Analysis and Service Communications

Product Reference:

A71 - Plant Recommendations



* * REFERENCE FOR NRC QUESTIONS I.3, I.5, AND I.12 * * *



UNITED STATES NUCLEAR REGULATORY COMMISSION WASHINGTON, D. C. 20555

April 8, 1987



Docket No. 50-331

Mr. Lee Liu
Chairman of the Board and
Chief Executive Officer
Iowa Electric Light and Power Company
Post Office Box 351
Cedar Rapids, Iowa 52406


Dear Mr. Liu:

SUBJECT: TECHNICAL EXEMPTION FROM THE REQUIREMENTS OF APPENDIX J (TAC 56809)

Re: Duane Arnold Energy Center

The Commission has issued an exemption from certain requirements of Appendix J to 10 CFR Part 50 in response to your letters dated October 29, 1984 and December 7, 1984. Additional letters dated April 22, 1985 and July 15, 1985 clarified the request and responded to staff requests for additional information. Your letters requested two exemptions. One would exempt containment spray isolation valves from Appendix J, Type C, testing requirements and the other would exempt the flanges connecting the torus to the torus drain line piping from Type B testing requirements.

We have granted the exemption of the containment spray isolation valves from Type C testing. The basis for this action is included in the exemption and a Safety Evaluation supporting the staff's action is enclosed. The staff has determined that the exemption from Type B testing of the flanges connecting the torus to the torus drain line piping is not needed because there is a 30 day water seal around the flanges which places them outside Appendix J requirements. The basis for the staff position is also presented in the enclosed Safety Evaluation.



The Exemption is being forwarded to the Office of the Federal Register for publication. The enclosed Environmental Assessment and Finding of No Significant Impact has been published in the Federal Register.

Sincerely,

- Erlert A Filbert

Robert A. Gilbert, Project Manager BWR Project Directorate #2 Division of BWR Licensing

مجيى

Enclosures:

- 1. Exemption
- 2. Safety Evaluation

3. Environmental Assessment and Finding of No Significant Impact

cc w/enclosures: See next page



cc:

Mr. Lee Liu Iowa Electric Light and Power Company

Jack Newman, Esquire Kathleen H. Shea, Esquire Newman and Holtzinger 1615 L Street, N. W. Washington, D. C. 20036

5

Office for Planning and Programming 523 East 12th Street Des Moines, Iowa 50319

Chairman, Linn County Board of Supervisors Cedar Rapids, Iowa 52406

Iowa Electric Light and Power Company ATTN: D. L. Mineck Post Office Box 351 Cedar Rapids, Iowa 52405



U. S. Nuclear Regulatory Commission Resident Inspector's Office Rural Route #1 Palo, Iowa 52324

Regional Administrator, Region III U. S. Nuclear Regulatory Commission 799 Roosevelt Road Glen Ellyn, Illinois 60137

Mr. Thomas Houvenagle Regulatory Engineer Iowa Commerce Commission Lucas State Office Building Des Moines, Iowa 50319

Duane Arnold Energy Center

للملح

UNITED STATES OF AMERICA

NUCLEAR REGULATORY COMMISSION

In the Matter of

IOWA ELECTRIC LIGHT AND POWER COMPANY, ET AL

Docket No. 50-331

Duane Arnold Energy Center

EXEMPTION

Ι.

Iowa Electric Light and Power Company (IELP/the licensee) is the holder of Facility Operating License No. DPR-49 which authorizes operation of the Duane Arnold Energy Center (DAEC/the facility). This license provides, among other things, that the facility is subject to all rules, regulations and orders of the Nuclear Regulatory Commission (the Commission) now or hereafter in effect.

The facility is a boiling water reactor located at the licensee's site in Linn County, lowa.

II.

By letters dated October 29 and December 7, 1984, as supplemented April 22 and July 12, 1985, IELP requested two exemptions from the requirements of Appendix J, 10 CFR Part 50. The first would exempt containment spray isolation valves from Appendix J, 10 CFR Part 50, Section III.C.1 Type C testing and the second would exempt the flanges connecting the torus to the torus drain line piping from Appendix J, 10 CFR Part 50, Section III.B Type B test requirements. The staff has determined that the second exemption is not needed because the flanges are outside Appendix J requirements.

Pursuant to Final Rule 10 CFR 50.12 (50 FR 50764), published on December 12, 1985, the special circumstance for granting the one remaining exemption has been identified as follows:

The containment spray subsystem consists of two 10" diameter lines to the spray headers in the drywell and two 4" diameter lines to the spray headers on top of the torus. Each line has two isolation valves outside containment that are normally closed. The inboard valves are required by Appendix J to be Type C tested. However, since the packing and body-to-bonnet seals are the only potential sources of leakage, the testing may be limited to these areas. To do this test according to Type C Appendix J requirements would require installation of an additional inboard valve inside containment and a test connection. Due to limited space in the drywell, such a modification would be difficult. The licensee, therefore, has proposed the following two-part alternative testing program:

(1) perform soap bubble testing on the valve body-to-bonnet seals during Type A Integrated Leak Rate testing and initiate corrective action if leakage is detected and

(2) pressurize between the inboard and outboard valves at the same frequency required for Type C tests to indicate the general condition of the valves.

The staff has determined that the alternate proposal will test the valves to an equivalent level as that required by the strict interpretation of Appendix J. Therefore, the strict application of the requirements is not necessary to achieve the underlying purpose of the regulation. Thus, the special circumstance presented in 10 CFR 50.12(a)(2)(ii) is applicable.

- 2 -

Accordingly, based on the above analysis, the staff concludes that, because the licensee's proposed alternate test method for the containment spray isolation valves Type C testing is equivalent to that required by Appendix J, the exemption from the requirements of Section III.C.1 of Appendix J to 10 CFR Part 50 is justified and should be granted.

III.

Accordingly, the Commission has determined that, pursuant to 10 CFR 50.12, this exemption is authorized by law, will not endanger life or property or the common defense and security and is otherwise in the public interest; furthermore, in accordance with 10 CFR 50.12(a)(2)(ii), a special circumstance, as discussed above, is present. The Commission hereby grants an exemption, as described above, from Section III.C.1 of Appendix J to the extent that the alternate Type C test method proposed by the licensee for the containment spray isolation valves is acceptable.

Pursuant to 10 CFR 51.32, the Commission has determined that the granting of this exemption will have no significant impact on the environment (52 FR 10833).

A copy of the Commission's concurrently issued Safety Evaluation related to this action is available for public inspection at the Commission's Public

Document Room, 1717 H. Street, N.W., Washington, D.C., and at the Cedar Rapids Public Library, 500 First Street, S.E., Cedar Rapids, Iowa 52401.

This Exemption is effective upon issuance.

FOR THE NUCLEAR REGULATORY COMMISSION

duch jayne

R. Wayne Houston, Acting Director Division of BWR Licensing Office of Nuclear Reactor Regulation

۰.

Dated at Bethesda, Maryland this 8th day of April 1987



UNITED STATES NUCLEAR REGULATORY COMMISSION WASHINGTON, D. C. 20555

SAFETY EVALUATION BY THE OFFICE OF NUCLEAR REACTOR REGULATION

SUPPORTING AN EXEMPTION FROM CERTAIN REQUIREMENTS

OF APPENDIX J TO 10 CFR PART 50

IOWA ELECTRIC LIGHT AND POWER COMPANY <u>CENTRAL IOWA POWER COOPERATIVE</u> CORN BELT POWER COOPERATIVE

DUANE ARNOLD ENERGY CENTER

DOCKET NO. 50-331

1.0 INTRODUCTION

On August 7, 1975, the NRC requested the licensee (Iowa Electric Light and Power Co.) to review its containment leakage test program for Duane Arnold Energy Center (DAEC) for compliance with the requirements of 10 CFR 50, Appendix J. In a letter dated October 13, 1975, the licensee identified several areas in the current Technical Specifications (TS) which deviated from the requirements of Appendix J. Subsequently, through submittals and telephone discussions, the licensee requested that certain test methodology, components and penetrations be exempted from Appendix J requirements. The NRC staff with its consultant, the Franklin Research Center (FRC), reviewed these submittals and prepared a Safety Evaluation Report (SER). The SER was forwarded to the licensee by letter dated January 17, 1984.

By letter dated October 29, 1984, as supplemented December 7, 1984 and April 22 and July 12, 1985, the licensee requested an exemption from the Type C testing requirements for containment spray isolation valves. In the December 7, 1984 letter, the licensee submitted a summary status of Appendix J issues resulting from the previous staff review:

- Torus Drain Line and RCIC steam supply line modifications to allow testing in accordance with Appendix J requirements are to be completed by the cycle 7/8 refueling outage.
- Valves MO-4423, MO-2238, MO-2400 are now leak testable in accordance with Appendix J. The Technical Specifications will be revised accordingly.

and requested the following exemptions from Appendix J:

 Exemptions from Appendix J testing requirements for containment spray isolation valves and torus drain line flanges.

The following evaluation addresses the acceptability of the licensee's Appendix J exemption requests.

8704100073- (4pp)

2.0 EVALUATION

2.1 Containment Spray Isolation Valves

The licensee requested an exemption from the requirements of Type C testing for containment spray isolation valves, MOV-1902, 1933, 2000 and 2006.

The containment spray subsystem, which delivers water to the spray headers through low pressure coolant injection (LPCI) loops, is an integral part of the residual heat removal (RHR) system. The subsystem consists of two 10" diameter lines to the spray headers in the drywell and two 4" diameter lines to the spray headers on top of the suppression pool. Each line has two isolation valves outside containment that are normally closed. The subject valves, MOV-1902, 2000, are the inboard valves which isolate the lines to the drywell spray headers and MCV-1933, 2006 are the inboard valves which isolate the lines to the torus spray headers. These valves are manually opened following a LOCA to divert the LPCI pump flow from the reactor vessel to the spray headers after core cooling requirements have been satisfied. FRC has previously reviewed these valves and found that, if any of them leak through the packing or body-to-bonnet seals, the leakage will cause containment air to reach the outside atmosphere. Consequently, Appendix J requires that these inboard valves be Type C tested. However, since the packing and body-to-bonnet seals are the only potential sources of leakage, the testing may be limited to these potential areas.

The containment spray isolation valves do not receive containment isolation signals, are required to remain closed for the duration of the accident when sprays are not required and are single active failure protected. In a letter dated July 12, 1985, the licensee explained that the existing configuration of the valves and the associated piping allows no practical means of testing these inboard valve seals. These inboard valves are located outside the drywell and the torus. There is no flange or other valve between the valve and the spray header. To pressurize the inboard valve from the containment side would require an additional inboard valve inside containment and a test connection. Due to limited space in the drywell, modifying the containment spray piping is undesirable. The licensee has proposed the following alternate testing of these valves in lieu of Type C testing:

- (1) performing a soap bubble test on the valve body-to-bonnet seals during Type A testing and initiate corrective actions if leakage is detected.
- (2) pressurizing between the inboard and outboard valves at the same frequency required for Type C tests to indicate the general condition of the valves.

The staff has reviewed the licensee's submittals and finds Type C testing of these valves to detect potential body-to-bonnet leakage is necessary. However, because of the difficulty in modifying the system due to limited space in the drywell, the staff considered the alternative test methods in lieu of Type C testing. Through the submittals and telephone conversations

with the licensee, the staff realizes that these inboard valves are designed at zero-leakage in the body-to-bonnet seals. If any leak through valve packing or seals is detected during Type A testing, the deteriorated packing and seal materials will be replaced. Furthermore, the piping around the valves is normally filled with water and water will flow into the containment to the spray header during accident conditions. Consequently, the possibility of containment air leakage through the body-to-bonnet seals would be minimized because of the water seal in the valve. Based on the above discussion, the staff concludes that the licensee requested exemption from Type C testing requirements for the inboard valve body-to-bonnet seals and its proposed alternative test methods summarized above and as detailed in the submittals are acceptable.

2134 2 Penetrations N-221A and B 2.2

The licensee also requested an exemption from Type B testing requirements for flanges connecting the torus and torus drain line (penetrations N-231A and B). $213 ext{ scale} + \frac{1}{2187}$

The torus drain line is connected to the torus at two locations with flanges sealed with FLEXITALLIC spiral wound (inorganic) gaskets. The torus drain connections afford no mechanism for performing Type B testing. To perform Type B testing would require replacing the existing flanges and gaskets with flanges designed for double O-ring (organic) gaskets. The licensee stated that such a design modification would downgrade the integrity of the containment and requested an exemption from Type B testing with the following justification:

- (1) The gasket and flange assemblies will be exposed to the Appendix J required Type A Containment Integrated Leak Rate Test (CILRT) pressure. Leakage through flanges could be identified and corrected.
- (2) A constant pressure of approximately 5 psi (torus water head) would detect gross leakage of the gaskets.
- (3) The flanges are rarely disassembled for maintenance or access. The probability of leakage through the flanges would not increase.
- (4) The torus water provides a water seal for the submerged torus drain line. If the existing flanges should leak, the leakage rate would not be sufficient to expose the connection to the containment atmosphere within 30 days following a postulated accident.

The staff has reviewed the licensee's submittals and finds the torus drain line is below the torus water level and is water sealed. Since the licensee stated that the water seal will be maintained for 30 days following a postulated accident, there is no potential air leakage from containment through the flanges. Consequently, no Type B testing on the flanges is required and no exemption from Appendix J is required.

- 4 -

3.0 CONCLUSIONS

From its review of the licensee's submittals, the staff concludes the following:

- (1) The licensee's proposals to exempt containment spray isolation values from Type C testing and to use the alternative testing methods described above are acceptable.
- (2) The licensee's proposed exemption from Type B testing for the flanges connected to the torus drain line is not required since the system is water sealed.

đ

Principal Contributors: J. Guo

Dated: April 8, 1987

UNITED STATES NUCLEAR REGULATORY COMMISSION

IOWA ELECTRIC LIGHT AND POWER COMPANY <u>CENTRAL IOWA POWER COOPERATIVE</u> CORN BELT POWER COOPERATIVE

ENVIRONMENTAL ASSESSMENT AND FINDING OF

NO SIGNIFICANT IMPACT

The U.S. Nuclear Regulatory Commission (the Commission) is considering issuance of an exemption from certain testing requirements of Appendix J to 10 CFR Part 50 to the Iowa Electric Light and Power Company (IELP/the licensee) for the Duane Arnold Energy Center located at the licensee's site in Linn County, Iowa.

ENVIRONMENTAL ASSESSMENT

Identification of Proposed Action

The proposed action would grant an exemption from Appendix J, Type[®]C, testing requirements for containment spray isolation valves.

The Need for the Proposed Action:

The licensee has stated that the Type C testing requirement for the containment spray isolation valves is not practicable with the existing Duane Arnold Energy Center piping arrangement and proposes an alternate testing method which will also accurately determine the leakage rates for the valves. Environmental Impact of the Proposed Action:

The proposed exemption only effects components which are within the site boundaries and actually within reactor secondary containment. There is no anticipated decrease in the reliability of these components to operate as designed in the event of an accident. Post-accident radiological releases will not differ from those determined previously and the proposed exemption

876462p638 3pp

does not otherwise affect facility radiological effluent or occupational exposures. With regard to potential nonradiological impacts, the proposed exemption does not affect plant nonradiological effluents and have no other environmental impact. Therefore, the Commission concludes there are no measurable radiological or nonradiological environmental impacts associated with the proposed exemption.

Alternatives to the Proposed Action:

Since the Commission has concluded there is no measurable environmental impact associated with the proposed exemption, any alternatives with equal or greater environmental impact need not be evaluated. The principal alternative to the exemption would be to require rigid compliance with the test procedures for Type C components required in Appendix J. Such action would not enhance the protection of the environment.

Alternative Use of Resources:

This action does not involve the use of resources not considered previously in the Final Environmental Statement for the Duane Arnold Energy Center, dated March 1973.

Agencies and Persons Consulted:

The NRC staff reviewed the licensee's request and did not consult other agencies or persons.

FINDING OF NO SIGNIFICANT IMPACT

The Commission has determined not to prepare an environmental impact statement for the proposed exemption. Based upon the environmental assessment, the NRC staff concludes that the proposed action will not have a significant effect on the quality of the human environment.

- 2 -

For further details with respect to this proposed action, see the licensee's letters dated October 29, 1984, December 7, 1984, April 22, 1985 and July 12, 1985. These letters are available for public inspection at the Commission's Public Document Room, 1717 H Street, N.W., Washington, D.C. and at the Cedar Rapids Public Library, 500 First Street, S.E., Cedar Rapids, Iowa 52401.

Dated at Bethesda, Maryland this 31st day of March 1987.

FOR THE NUCLEAR REGULATORY COMMISSION

21

Daniel R. Muller, Director BWR Project Directorate #2 Division of BWR Licensing

Iowa Electric Light and Power Company

December 7, 1984 NG-84-5036

Mr. Harold Denton, Director Office of Nuclear Reactor Regulation U.S. Nuclear Regulatory Commission Washington, D.C. 20555

> Duane Arnold Energy Center Subject: Docket No. 50-331 Operating License No. DPR-49 Revised Schedule for 10 CFR Part 50, Appendix J Modifications and Requests for Relief

References:

- Letter, R. W. McGaughy (Iowa Electric) to H. R. 1) Denton (NRC), March 16, 1984 (NG-84-0668), RTS-1128 Safety Evaluation Report, D. Eisenhut (NRC) to 2)
 - L. Liu (Iowa Electric), January 17, 1984 Letter, R. W. McGaughy (Iowa Electric) to H. R.
 - 3) Denton (NRC), August 24, 1984 (NG-84-3601)
 - Letter, M. Thadani (NRC) to L. Liu (Iowa Electric), 4) August 24, 1984 5) Letter, R. W. McGaughy (Iowa Electric) to H. R.
 - Denton (NRC), October 29, 1984 (NG-84-4469)

File: A-286

Dear Mr. Denton:

The purpose of this letter is to inform you of the revised status of modifications required to conform to the testing requirements of 10 CFR Part 50, Appendix J and to request relief from certain portions of Appendix J. This letter is being submitted at the request of our NRC Project Manager so that all issues pertaining to the subject matter are addressed in a single document.

In our letter dated March 16, 1984 (Reference 1), we requested revision to the Technical Specifications (TS) for the Duane Arnold Energy Center (DAEC). The TS revisions were required to incorporate the findings of the NRC staff's Safety Evaluation Report (SER) (Reference 2). During the review of Reference 2, it was determined that several plant modifications were needed to fully implement the TS changes required by the NRC staff.

-8412310176 (PP)

Mr. Denton NG-84-5036 Page Two

•

In our letter of August 24, 1984 (Reference 3), it was noted that we had previously discussed the scope of the modifications with our NRC Project Manager in a March 15, 1984, telephone call and had agreed to provide, by September 15, 1984, a schedule for their completion. (Please note that our August 24 letter fulfilled our September 15 commitment.)

In Reference 3, we stated that three (3) modifications were needed to comply with the testing requirements of 10 CFR Part 50, Appendix J and that the modifications would be completed during the Cycle 8/9 refueling outage. The scope and schedule of these modifications were determined as a result of an ongoing Appendix J engineering evaluation.

Following our submittal of Reference 3, our NRC Project Manager requested that we expedite the completion of the modifications prior to the Cycle 8/9 refueling outage. Because our engineering evaluation was still in progress, we later determined that instead of three (3) modifications being needed, only two (2) were required to conform to the testing requirements of Appendix J (our engineering evaluation concluded that modification of the Main Steam Line Drain (Penetration No. X-8, Valve MO-4423) was not needed). In addition, it was found that the modifications needed for the Torus Drain Lines (Penetration No. N-213A/B, expansion bellows) and the RCIC and HPCI Steam Supply (Penetration No. X-10 and X-11, Valves CV-2410 and CV-2211) could be implemented during the upcoming Cycle 7/8 refueling outage instead of the Cycle 8/9 refueling outage.

On the same date that Iowa Electric transmitted Reference 3 to the NRC, we sceived Amendment No. 106 (Reference 4) to the Facility Operating License for the DAEC. Amendment No. 106 incorporated those changes that were requested via Reference 1. The transmittal letter of Reference 4 noted that implementation of other requested changes (Type B testing of containment penetrations N-213 A and B, and Type C testino of containment isolation valves MO-4423, CV-2410, MO-2400, MO-2238, CV-2211, MO-2000, MO-1902, MO-1933 and MO-2006) required completion of plant modifications scheduled in the future and that those changes would be considered in a future action when the required plant modification schedules were established. We agree with the NRC philosophy that Amendment No. 106 should have incorporated those TS changes which could be immediately implemented. However, the other changes which required modification to conform to 10 CFR Part 50, Appendix J, were still undergoing an engineering evaluation to determine if modifications were necessary. Thus, until Iowa Electric had concluded its engineering evaluation, we could not identify, with a high degree of confidence, those plant systems which required modifications to comply with the testing requirements of 10 CFR Part 50, Appendix J.

Mr. Denton NG-84-5036 Page Three

It is our understanding that Amendment No. 106 was issued based on a July 24, 1984, telephone conversation with our NRC Project Manager. During the telephone conversation, we informed our NRC Project Manager of the status of our Appendix J compliance effort with the best information available at the time. As discussed above, we were unaware that the modifications described in Reference 3 could be reduced from three to two and that we could expedite the modification schedules pursuant to our NRC Project Manager's request. We hope the revised modifications and schedules have not inconvenienced the Staff.

Iowa Electric has concluded its engineering evaluation and is providing, in Attachment 1, the latest status of our Appendix J effort.

Furthermore, as a result of our engineering evaluation, we have also concluded that two additional requests for relief are needed. These requests are presented in Attachments 2 and 3.

Because an application fee of \$150 was submitted with our October 29, 1984, letter (Reference 5), additional application fees are not being submitted with this letter.

We appreciate the opportunity to discuss the status and background of Iowa Electric's efforts to comply with the testing provisions of 10 CFR Part 50. Appendix J.

Should you require any additional assistance, please feel free to contact my staff.

Very truly yours,

Crarks Richard HI YADan

Richard W. McGauchyll Manager, Nuclear Generation

RWM/MG/ta* Attachments:

Summary Status of 10 CFR Part 50, Appendix J Issues
 Request for Exemption from Type C Testing Requirements

- 3) Request for Exemption from Type B Testing Requirements
- cc: M. Grim
 - L. Liu
 - S. Tuthill
 - S. Swails
 - M. Thadani
 - T. Houvenagle (ICC)
 - NRC Resident Office
 - Commitment Control No. 84-0110

IOWA ELECTRIC LIGHT AND POWER COMPANY DUANE ARNOLD ENERGY CENTER DOCKET NO: 50-331 OPERATING LICENSE NO: DPR-49

SUMMARY STATUS OF 10 CFR PART 50, APPENDIX J ISSUES

- I. The following items require modification to conform to the testing requirements of 10 CFR Part 50, Appendix J. This attachment supersedes the information contained in Reference 3.
 - A) Torus Drain Lines

- Modifications to the expansion bellows on Penetrations N-213 A and B are required to permit testing in accordance with 10 CFR Part 50, Appendix J.
- Schedule: The modification to the expansion bellows will be completed by the Cycle 7/8 refueling outage.

Reference: Letter, R. W. McGauchy (Iowa Electric) to H. R. Denton (NRC) dated August 24, 1984 (NG-84-3601)

- B) RCIC and HPCI Steam Supply
 - 1) Modifications to the test connections to permit leaktesting of valves CV-2410 and CV-2211 (Penetrations X-10 and X-11) in the correct direction are required to meet the requirements of 10 CFR Part 50, Appendix J.
- Schedule: The modifications to relocate the test connections will be completed by the Cycle 7/8 refueling outage.

Reference: Letter, R. W. McGauchy (Iowa Electric) to H. R. Denton (NRC) dated August 24, 1984 (NG-84-3601)

II. The following values can be leak tested in accordance with 10 CFR Part 50, Appendix J. The DAEC Technical Specifications will be revised accordingly:

> MO-4423 MO-2238 MO-2400

III. Relief is requested from the testing requirements of 10 CFR Part 50, Appendix J for the following areas:

1 a .

1) Torus and Containment Spray Isolation Valves MOV-1902, 1933, 2000 and 2006 (Penetrations X-39 A/B and N-211 A/B).

Justification for the relief request is provided in Attachment 2.

2) Torus Drain Line Piping Flanges (Penetrations N-213 A and B).

Justification for the relief request is provided in Attachment 3.

IOWA ELECTRIC LIGHT AND POWER COMPANY DUANE ARNOLD ENERGY CENTER DOCKET NO: 50-331 OPERATING LICENSE NO: DPR-49

REQUEST FOR EXEMPTION FROM TYPE C TESTING REQUIREMENTS

Introduction

Pursuant to 10 CFR 50.55a(a)(5)(iv) and 10 CFR 50.12, Iowa Electric Light and Power Company requests exemption from the requirements of 10 CFR Part 50, Appendix J, Paragraph III.C (Type C Testing Requirements) for the Duane Arnold Energy Center (DAEC) Containment Spray Isolation Valves MOV-1902, 1933, 2000 and 2006.

It has been determined that the Type C testing requirement is not practicable with the existing DAEC piping arrangement; therefore, exemption is requested from the Type C testing requirement with proposed alternate testing methods to determine the leakage rates for the valves. This relief request supersedes a similar request proffered in our letter dated October 29, 1984 (Reference 5).

The following information provides the background and justification pertinent to our request for relief from the requirements for Type C testing of the Torus/Containment Spray isolation valves.

Background

In letters dated October 13, 1975 (L. Liu (Iowa Electric) to K. Goller (NRC), IE-75-1103) and August 29, 1978 (L. Liu (Iowa Electric) to H. Denton (NRC), IE-78-1269), Iowa Electric Light and Power Company requested exemption from Type C testing requirements for penetrations X-39A/B and N-211A/B (Torus and Containment Spray Lines).

In a Safety Evaluation Report (SER) dated December 29, 1976, the NRC staff provided their disposition of the October 13, 1975, letter. The NRC staff stated,

"IELPCo (Iowa Electric) maintains that several lines do not include containment isolation valves corresponding to the definition of valves requiring Type C tests in Appendix J because these valves do not receive containment isolation signals, are required to remain open for the duration of the accident, or would remain pressurized for the duration of the accident. The lines containing these valves are the RHR suppression pool suction, the core spray suction, the suppression pool suction for RCIC and HPCI, the LPCI injection, the suppression pool spray, the RHR test line, the vessel head spray, and the containment spray.



Attachment 2 NG-84-5036 December 7, 1984 Page Two

' س

In conclusion, the NRC staff stated, "We find that the licensee's proposed exemption from the requirements of Section II.H of Appendix J for the above cited valves is acceptable, provided that the licensee shows that these valves will continue to function even if a single active failure were to occur." (emphasis added)

By letter dated August 29, 1978, Iowa Electric responded to the Staff's request for additional information. In our response, we noted, "the containment isolation function is single active failure protected..."

The above noted Iowa Electric exemption request and clarification, and the Staff's subsequent disposition, are further embodied in the attachment to the Staff's SER dated January 17, 1984. The Staff's prime contractor for the review of the exemption request, Franklin Research Center (FRC), stated that the inboard isolation valves for both the containment spray and suppression pool (torus) are located outside containment (e.g., valves MOV 1902, 2000, 1933 and 2006) and that, "if any of these valves leak through the packing or body-to-bonnet seals, the leakage of containment air reaches the outside atmosphere. Consequently, Appendix J requires that these valves be tested. However, since the packing and body-to-bonnet seals are the only potential sources of leakage, the testing may be limited to these particular areas" (emphasis added).

The NRC staff, in their January 17, 1984, SER, agreed with FRC by stating,

"for penetration X-39B (sic), the inboard isolation valves should be tested in the direction of accident pressure or by pressurizing between the inboard and outboard isolation valves in order to test the valve packing and body-to-bonnet seals of the inboard valve. For penetration (sic) N-211A & B, the inboard isolation valves should be tested in the direction of accident pressure or by pressurizing between the inboard and outboard valves provided that this testing will expose the packing and body-to-bonnet seal areas of the inboard valves to the test pressure."

Basis for Relief from Type C Testing Requirements

With regard to the foregoing background information and NRC guidance, Iowa Electric requests exemption from the requirements of Type C testing (as interpreted by the Staff) for valves MOV-1902, 1933, 2000 and 2006. In lieu of the Type C testing, we propose the following testing alternative.

 During Type A testing, the subject valves will be placed in the open position, thereby exposing the gaskets and packing to the containment test pressure. While maintaining containment test pressure, leakage from the valve gaskets and stem packings will be locally identified by nonobtrusive leak detection techniques. Should excessive leakage be detected, corrective actions will be initiated, as appropriate, to eliminate any unacceptable leakage.



Attachment 2 NG-84-5036 December 7, 1984 Page Three

:2⁹⁴⁻³

2) The subject values will be leak tested by pressurizing between the inboard and outboard values. Although there is no conclusive evidence that the packing and gaskets are pressurized during this test, it will provide an indication of the general condition of the values.

Conclusion

Iowa Electric believes the proposed alternate testing of the subject valves is acceptable and relief from Type C testing requirements should be granted because:

- The area of potential leakage and concern, as noted by FRC, is in the packing and body-to-bonnet seals. The proposed alternate testing will be effective in identifying leakage from the packing and seals; and,
- All four values will be leak tested by pressurizing between the inboard and outboard values. Pressurizing between the values follows the Staff's guidance contained in the January 17, 1984, SER.

IOWA ELECTRIC LIGHT AND POWER COMPANY DUANE ARNOLD ENERGY CENTER DOCKET NO: 50-331 OPERATING LICENSE NO: DPR-49

REQUEST FOR EXEMPTION FROM TYPE B TESTING REQUIREMENTS

Introduction

In accordance with 10 CFR 50.12 and 10 CFR 50.55a(a)(5)(iii), Iowa Electric Light and Power Company requests exemption from the Type B testing requirements of 10 CFR Part 50, Appendix J, Paragraph II.G. Specifically, Iowa Electric requests relief from testing requirements for flanges connecting the torus and torus drain line piping (penetrations N-213A and B).

The following information provides justification for this exemption and describes alternative testing methodology. Iowa Electric believes this exemption is in the best interest of the public health and safety as modification of the flanges, to permit Type B testing, would downgrade the integrity of the containment system.

Paragraph II.G of 10 CFR Part 50, Appendix J describes Type B tests as, "...tests intended to detect local leaks and to measure leakage across each pressure-containing or leakage-limiting boundary for the following primary reactor containment penetrations:

> Containment penetrations whose design incorporates resilient seals, paskets, or sealant componds (sic), piping penetrations fitted with expansion bellows, and electrical penetrations fitted with flexible metal seal assemblies."

The Duane Arnold Energy Center (DAEC) torus drain line is connected to the torus at two locations with 150 pound ASA class flanges sealed with spiral-wound gaskets. These connections afford no mechanism for conducting conventional Type B testing, e.g., pressurizing between two concentric gaskets.

Performance of Type B testing on the flanges and gaskets would require their replacement. Iowa Electric believes modification or replacement of the flanges would downgrade the integrity of the containment system.

Basis for Relief from Type B Testing Requirements

As noted above, the torus drain connections afford no mechanism for performing conventional Type B testing. Flanges with spiral-wound gaskets are used throughout the power industry and have proven to be highly reliable. Due to the mild service conditions to which these gaskets are subjected, and because of their design specification, significant gasket degradation during the life of the plant is highly unlikely. To perform Type B testing pursuant to Paragraph II.G.1 of 10 CFR Part 50, Appendix J would require replacing the existing flanges and spiral-wound gaskets, composed of inorganic material such as asbestos and stainless steel, with new flanges whose design accommodates two

Attachment 3 NG-84-5036 December 7, 1984 Page Two

concentric O-ring gaskets composed of organic material. Iowa Electric believes such a modification, to permit Type B testing, would introduce an inferior gasket material subject to aging, deterioration and leakage. Thus, modifying the present connection would decrease the reliability and integrity of the containment system.

Relief from the Type B testing requirements of Paragraph II.G.1 of 10 CFR Part 50, Appendix J should be granted for the following reasons:

- The gasket and flange assemblies are tested during performance of the DAEC Integrated Leakrate Test (ILRT) which is conducted at approximately one-half the frequency of the Local Leakrate Test (Type B). Pressurizing the torus during the ILRT places full accident pressure across the gaskets. Any leaks would be identified and corrected.
- 2) A constant internal pressure of approximately 5 psi is applied to the flanges and baskets by the water head in the torus. Any pross leakage of the baskets would be identified during routine plant inspection tours. (The existing type of basket utilized at the DAEC is not known to be susceptible to pross, catastrophic failure).
- 3) These flances are rarely disassembled either for maintenance or access; therefore, damage or errors during flance assembly do not increase the probability of these connections leaking.
- 4) The torus water provides a water seal for the submerged torus drain line. If the existing flanges should leak, the leakage rate would not be sufficient to expose the connection to the containment atmosphere within thirty (30) days, at a pressure of L_a , following a postulated accident.

Conclusion

Based on the foregoing information, relief should be granted from the Fype B testing requirements of Paragraph II.G.1 of 10 CFR Part 50, Appendix J for these flanges since it would be in the best interest with regard to protection of the public health and safety.

Iowa Electric Light and Power Company

April 30, 1986 NG-86-0795

Mr. Harold Denton, Director Office of Nuclear Reactor Regulation U.S. Nuclear Regulatory Commission Washington, DC 20555

> Subject: Duane Arnold Energy Center Docket No: 50-331 Op. License No: DPR-49 Technical Specification Change (RTS-174A) Maintenance of ECCS Discharge Piping Fluid References: 1) Letter, M. Thadani (NRC) to L. Liu (Iowa Electric) dated January 9, 1986 2) Letter, R. McGaughy (Iowa Electric) to H. Denton (NRC) dated October 17, 1984 (NG-84-4273)

File: A-107a

Dear Mr. Denton:

In accordance with the Code of Federal Regulations, Title 10, Sections 50.59 and 50.90, Iowa Electric Light and Power Company hereby supplements its request of October 17, 1984, for revision of the Technical Specifications (TS) for the Duane Arnold Energy Center (DAEC).

This submittal responds to the referenced letter in which the $\sqrt[c]{NRC}$ staff requested additional clarification regarding action to be taken if the emergency core cooling system piping cannot be filled with water within one hour after discovery of its unfilled status.

This supplement (proposed change RTS-174A) has been reviewed by the DAEC Operations Committee and DAEC Safety Committee. As a fee of \$150 was included with our initial application, additional fees are not being included with this letter.

Pursuant to the requirements of 10 CFR 50.91, a copy of this submittal, including the hazards considerations analysis, is being forwarded to our appointed state official.

86\$5\$6\$124(Spp)

Mr. Harold Denton April 30, 1986 NG-86-0795 Page Two

• •

This application, which consists of three signed originals and 37 copies with their enclosures, is true and accurate to the best of my knowledge and belief.

IOWA ELECTRIC LIGHT AND POWER COMPANY BY McGaughy Manager, Nuclear Division

Subscribed, and sworn to Before Me on this 1st day of mark 1986.

Notary Public in and for the State of Iowa

۰."

RWM/MSG/ta*

Attachments: 1) Evaluation of Change Pursuant to 10 CFR 50.92 2) Proposed Change RTS-174A including List of Affected Pages

- cc: M. Grim
 - L. Liu
 - L. Root M. Thadani NRC Resident Office T. Houvenagle (ICC)

1.

EVALUATION OF CHANGE WITH RESPECT TO 10 CFR 50.92

Summary

By submittal dated October 17, 1984 (RTS-174), supplemented by submittal dated April 28, 1986 (RTS-174A), Iowa Electric Light and Power Company (the licensee) requested amendment of Facility Operating License No. DPR-49 for the Duane Arnold Energy Center (DAEC) to add action statements to Technical Specification (TS) 3.5.H, Limiting Condition for Operation (LCO), Maintenance of Filled Discharge Pipe. The proposed action statements would direct operator action in the event the LCOs cannot be met. (The Technical Specifications presently give no such guidance.)

DAEC Technical Specification 3.5.H presently requires that the discharge piping of the HPCI, RCIC, LPCI, and Core Spray Systems be maintained filled with fluid to the last block valve when operability of these systems or subsystems is required. Maintaining the lines filled minimizes the possibility of water hammer and system damage, when the systems are started to provide their designed safety function.

The filled status of the core spray and LPCI lines is continuously monitored by measuring the static pressure in the filled lines; annunciation occurs if the pressure decreases below a set limit. The HPCI and RCIC systems are normally aligned to the Condensate Storage Tank (CST) and, in this alignment, the piping is maintained full.

The licensee proposes to add Action Statement 3.5.H.1.a which specifies that, when these systems are required to be operable, the lines must be returned to the filled condition within 1 hour. If Action Statement 3.5.H.1.a cannot be met, the licensee must follow Action Statement 3.5.H.1.b which requires that the affected system(s) be placed in the test mode (i.e., the pump will be operated, thus assuring the lines are filled) or declared inoperable. In the latter event, the existing LCO for that system must be implemented.

The licensee also proposes to remove Surveillance Requirement 4.5.H.1 from the Technical Specifications. This surveillance test requires that, whenever the HPCI or RCIC systems are aligned to take suction from the torus (the storus serves as a backup water supply to the CST), the discharge piping of the HPCI and RCIC shall be vented from the high point on the injection line and water flow observed on a monthly basis. The basis for removal of the surveillance requirement is threefold. First, should the HPCI or RCIC automatically switch from the normal source of water (the CST) to the backup water supply (the torus), the plant operator may return the system to its normal supply (the CST) after the signal, which caused the switch, is cleared. Thus, a situation where the HPCI or RCIC systems would be lined up to the backup water supply (the torus) may occur for only a few minutes, not for an entire month which is currently implied by Technical Specification 3.5.H.1. Second, the normal torus water level is at an elevation of 729 feet 5 1/4 inches with the high point vent of the systems at an elevation of 760 feet. Therefore, with neither the HPCI nor RCIC pump in operation, a downward gravity flow is assumed and the water in the discharge line would reach equilibrium with the torus water level of 729 feet 5 1/4 inches.

Third, the implementation of proposed Action Statement 3.5.H.1.b provides assurance the plant is placed in a safe condition if the discharge lines from the pump discharge of these systems to the last block valve cannot be filled.

In accordance with the requirements of 10 CFR 50.92, the enclosed application is judged to involve no significant hazards based upon the following information:

- (1) Does the proposed license amendment involve a significant increase in the probability or consequences of an accident previously evaluated?
- Response: Iowa Electric has evaluated the proposed license amendment and has determined it does not involve a significant increase in the probability or consequences of an accident previously evaluated. The proposed license amendment provides direction to the operator regarding the actions to be taken if the discharge piping of the above-mentioned system(s) cannot be filled. The actions to be taken are conservative in nature, and would minimize the possibility of a water hammer in the affected piping.

Removal of the surveillance requirement which requires venting of the HPCI and RCIC systems whenever they are lined up to take suction from the torus does not involve any increase in the consequences of ar cident previously evaluated as the implementation of Action Statements 3.5.H.1, 3.5.H.1.a and 3.5.H.1.b further minimize the possibility of water hammer occurrence.

- (2) Does the proposed license amendment create the possibility of a new or different kind of accident from any accident previously evaluated?
- Response: Iowa Electric has evaluated the proposed license amendment and has concluded that, if action is taken to ensure that the discharge piping is maintained in a filled configuration, the possibility of a water hammer is minimized. In addition, if the discharge piping , cannot be maintained in a filled configuration, the operator must take direct (and conservative) action to either fill the piping or declare the affected system(s) inoperable and enter the applicable Limiting Condition for Operation.

Based upon the proposed action statements, we conclude the proposed license amendment does not create the possibility of a new or different kind of accident from those previously evaluated.

- (3) Does the proposed amendment involve a significant reduction in a margin of safety?
- Response: The proposed license amendment does not involve any reduction in the plant margin of safety. The adoption of Action Statements 3.5.H.l.a and 3.5.H.l.b will direct the course of action for the operator to take if the discharge piping is not maintained in a filled condition. As these actions are conservative, the possibility of introducing a water hammer into the piping system is minimized.

In the April 6, 1983 Federal Register, the NRC published examples of license amendments that are not likely to involve a significant hazards concern if operation of the facility, in accordance with the proposed amendment, involves only one or more of the following examples:

(ii) A change that constitutes an additional limitation, restriction, or control not presently included in the Technical Specifications: for example, a more stringent surveillance requirement.

Iowa Electric believes this proposed license amendment request (RTS-174A) does not involve a significant hazards concern as it clearly fits within the framework of the above example.

Proposed Change RTS-174A to the Duane Arnold Energy Center Technical Specifications

The holders of license DPR-49 for the Duane Arnold Energy Center propose to amend Appendix A (Technical Specifications) to said license by deleting the current pages and replacing them with the attached, new pages. A List of the Affected Pages is provided below.

List of Affected Pages

3.5-11 3.5-24

1)	3.5-11	Add additional Limiting Condition for Operation statements 3.5.H.l.a and 3.5.H.l.b. These additional restrictions require that the plant operator take specific actions whenever the discharge piping for the core spray or LPCI subsystems, HPCI or RCIC systems is not filled to the last block valve.

Description

2) 3.5-11 Remove Surveillance Requirement 4.5.H.1. Change test frequency of Item 1 from "every operating cycle" to "once per operating cycle." Remove reference to HPCI and RCIC systems.

Bases

Page

1) 3.5-24 Provide additional information in the technical specification bases to address the addition of Specifications 3.5.H.1.a and 3.5.H.1.b.

8605060126 (7pp



DAEC-1

- H. <u>Maintenance of Filled</u> Discharge Pipe
- Whenever core spray subsystems, LPCI subsystems, HPCI, or RCIC are required to be OPERABLE, the discharge piping from the pump discharge of these systems to the last block valve shall be filled.

LIMITING CONDITION FOR OPERATION

- a. If the pump discharge piping of the core spray or LPCI subsystems depressurizes below the system low pressure alarm setpoint while these systems are required to be OPERABLE, the pressure shall be restored within one hour.
- b. If Specification 3.5.H.1 or 3.5.H.1.a cannot be met, either place the affected system(s) in the test mode or declare the affected system(s) inoperable and enter the applicable LIMITING CONDITION FOR OPERATION as described in Specification 3.5.A, 3.5.D or 3.5.E.
- I. Engineered Safeguards Compartments Cooling and Ventilation

If both unit coolers serving either the RCIC or HPCI room are out of service, the associated pump shall be considered inoperable for purposes of Specifications 3.5.D or 3.5.E as applicable.

If the single unit cooler serving either compartment which houses two RHR pumps and a core spray pump is out of service for a period greater than seven days, the associated pumps shall be considered inoperable for purposes of Specification 3.5.A. H. <u>Maintenance of Filled</u> Discharge Pipe

- The following surveillance requirement shall be adhered to, to assure that the discharge piping of the core spray and LPCI subsystems are filled:
 - a. The pressure switches which monitor the LPCI and core spray lines to ensure they are full shall be functionally tested once per operating cycle.

I. Engineered Safeguards Compartments Cooling and Ventilation

> The unit coolers for each of the RCIC, HPCI, Core Spray, and RHR pump rooms shall be checked for operability during surveillance testing of the associated pumps.

RTS-174A

DAEC-1

in this piping when the pump and/or pumps are started. If a water hammer were to occur at the time at which the system were required, the system would still perform its design function. However, to minimize damage to the discharge piping, Specification 3.5.H requires that the core spray and LPCI discharge piping pressure be restored within one hour after system depressurization when the system is required to be operable. Likewise, for HPCI and RCIC, the discharge piping to the last block valve shall be filled when these systems are required to be operable. If the discharge piping pressure for the core spray and LPCI subsystems cannot be restored within one hour or the discharge piping for HPCI and RCIC cannot be maintained in a filled condition to the last block valve, the operator is required to perform either of the following actions:

- 1) place the affected system(s) in the test mode which will ensure that the discharge piping is filled with water, or
- 2) declare the affected system(s) inoperable in which case the operator will enter the applicable LCO for the affected system(s) as defined in Specification 3.5.A (core spray and LPCI), 3.5.D (HPCI), or 3.5.E (RCIC).

The above actions minimize the possibility of a water hammer and are considered conservative in nature.

I. Engineered Safeguards Compartments Cooling and Ventilation

One unit cooler in each pump compartment is capable of providing adequate ventilation flow and cooling. Engineering analyses indicate that the temperature rise in safeguards compartments without adequate ventilation flow or cooling is such that continued operation of the safeguards equipment or associated auxiliary equipment cannot be assured.

3.5-24

04/86

Attachment 2 NG-87-1629 Page 1 of 4

SUMMARY - IST PROGRAM CHANGES

- 1. Changed paragraph 3 of the instructions (Page 7) to delete the statement that the ISI boundaries are identical to the design classification or quality group boundaries. This is no longer correct.
- 2. Delete bearing temperatures from Relief Request PR-1 since PR-14 has been expanded to include the diesel fuel oil pumps.
- 3. Delete Relief Request PR-2 since PR-14 has been expanded to include the ESW pumps.
- 4. Delete Relief Request PR-3 since the modifications for HPCI vibration monitoring have been completed.
- 5. Expanded Relief Request PR-5 to include all pumps in the IST Program.
- 6. Delete Relief Request PR-6 since modifications have been made allowing the pumps to run for more than 5 minutes.
- 7. Deleted RCIC pump from Relief Request PR-7 since the RCIC system will be removed from the IST Program.
- 8. Deleted Relief Request PR-8 since the NRC has not provided guidance on velocity vibration acceptance criteria.
- 9. Deleted Relief Request PR-9 since modifications to the screen wash pump instrumentation have been completed.
- Changed effected pumps for Relief Request PR-11 from "various" to "all pumps in Program".
- 11. Deleted RCIC pump from Relief Request PR-12 since the RCIC system will be removed from the Program.
- 12. Changed effected pumps listing in Relief Request PR-13 from "all pumps" to "all pumps in the Program".
- Changed effected pumps for Relief Request PR-14 from "various" to "all pumps in Program".
- 14. Added deferred testing (Section 3.2) to Section 3.0, Inservice Testing Program for valves.
- 15. Added partial stroke exercise test to the closed position and check valve partial stroke exercise test to the open position to the list of Inservice Valve Tests.
- 16. Added Relief Request VR-1.
- 17. Added Relief Request VR-3.
- 18. Added to the Basis for Relief Section of Relief Request VR-4 reasons why it is impractical to exercise this valve during normal plant operation.



CHANGES TO THE IST PROGRAM

- 19. Added new Relief Request VR-5.
- 20. Added information to the Alternate Testing Section of VR-6 describing the Technical Specification testing.
- 21. Deleted Revision 7 Relief Request VR-7. Added new Relief Request VR-7.
- 22. Added information to the Alternate Testing Section of VR-8 describing the Technical Specification.
- 23. Added information to the Basis For Relief section of VR-11 describing the referenced Technical Specification.
- 24. Added information to the Alternate Testing section of VR-12 describing the Technical Specification testing.
- 25. Added valves SV-1868 A&B and SV-1869 A&B to Relief Request VR-13. Also added information to Alternate Testing section of Relief Request VR-13 as to how each of the sets of valves is tested.
- 26. Changed the function for valves V-18-118 and V-18-206 to "prevent SCRAM water (from the accumulators) being bypassed to charging H_2O header" on Relief Request VR-13.
- 27. Deleted Relief Request VR-14.
- 28. Removed pages of voided Relief Requests; VR-9, VR-10, VR-15, VR-16, VR-18, VR-22, VR-23, VR-26, VR-27, VR-28, VR-29 and VR-38.
- 29. Added information to the Alternate Testing section of VR-20 describing the Technical Specification testing.
- 30. Deleted the RCIC valve V-25-1 from Relief Request VR-21.
- 31. Deleted Relief Request VR-24.
- 32. Added information to the Alternate Testing section of VR-25 describing the Technical Specification testing.
- Deleted Relief Request VR-30 since V-17-52 and V-17-53 are passive valves.
- 34. Added information to the Alternate Testing section of VR-32 describing the Technical Specification testing.
- 35. VR-33 has been modified to reflect the removal of the actuator from the core spray valves.
- 36. Deleted Relief Request VR-36.
- 37. Changed description in the Alternate Testing of VR-40 on what leakrate testing ensures.

CHANGES TO THE IST PROGRAM

- 38. Changed description in the Alternate Testing of VR-41 on what leakrate testing ensures.
- 39. Deleted VR-42.
- 40. Changed description in the Alternate Testing of VR-44 on what leakrate testing ensures.
- 41. Removed the open test relief for RCIC valves V-24-8 and V-24-23 from VR-47. Changed description in the Alternate Testing of VR-47 on what leakrate testing ensures.
- 42. Corrected spelling of "partial" in Alternate Testing section of VR-49.
- 43. Changed the function of the valves listed in VR-50 to better describe the vacuum breaker function.
- 44. Updated pump listing to Relief Request deletions and additions. Also deleted RCIC Pump 1P-226 since the RCIC system is not required for mitigating the consequences of an accident or for safe shutdown of the reactor.
- 45. Updated valve listing to reflect deleted Relief Request and removed P&ID revision numbers.
- 46. Added the word "passive" to the Remarks section for valves V-09-065 and V-09-111 (P&ID M-109).
- 47. Added valves MO-1947 and MO-2046 to the valve listing (M-113).
- 48. Deleted maximum stroke times for CV-1956A and B (M-113).
- 49. Deleted CV-4428 and CV-4429 (also SV-4428 and SV-4429) from valve listing (M-114).
- 50. Deleted the CT-CC and CT-CO tests from PSV-4439A through F since they are not required because the valves are relief valves, not check valves.
- 51. Changed the normal position for valves MO-4629 and MO-4630 to reflect current plant status (M-116).
- 52. Changed the "normal position" for valves CV-4639 and CV-4640 to open since they are the injection path for the hydrogen water chemistry system.
- 53. Deleted the CT-CC tests from V-17-52 and V-17-53 (M-117) because the test is not required by the Code since the valves are passive (as is noted in the Remarks section of the valves).
- 54. Changed the frequency of testing for valves CV-1859 A&B and CV-1867 A&B from CS to OP (M-118).





CHANGES TO THE IST PROGRAM

55. Deleted SV-1851, SV-1852, SV-1853, SV-1854 from the valve listing (M-118).

1

- 56. Added SV-1868B and SV-1869B to the valve listing and added "A" designation to SV-1868 and SV-1869 (M-118).
- 57. Changed CV-1906 to V-19-149 and the testing frequency to reflect removal of operator (M-119).
- 58. Removed MO-1900 and MO-1901 from the valve listing (M-119).
- 59. Changed CV-2002 to V-20-082 and the testing frequency to reflect removal of operator (M-120).
- 60. Changed CV-2118 and CV-2138 to V-21-072 and V-21-073 respectively, reflecting removal of the operators from the values (M-121).
- 61. Deleted CV-2235 and SV-2235 from the valve listing (M-122).
- 62. Changed testing frequency from MO-2238 from Operation to Cold Shutdown.
- 63. Added CT-CC tests to V-22-17 and V-22-22 (M-122).
- 64. Added CV-2315 to valve listing (M-123).
- 65. Changed CV-2313 to V-23-049 to reflect removal of operator (M-123).
- 66. Changed frequency of testing for MO-2400 from OP to CS.
- 67. Added CT-CC test to V-24-8 test list.
- 68. Added the word "passive" to the Remarks section of V-20-287 (M-130).
- 69. Added SV-3261 A&B, SV-3262 A&B, V-32-43, V-32-45, V-32-52 and V-32-54 to valve listing (M-132).
- 70. Changed test frequency from "RR" to "OP" for V-43-082, V-43-084, V-43-086 and V-43-088 (M-143).
- 71. Added Cold Shutdown Justifications for all of the valves in the IST Program exercised on a Cold Shutdown basis.

