

IOWA ELECTRIC LIGHT AND POWER COMPANY

DUANE ARNOLD ENERGY CENTER

CALCULATION COVERSHEET

ANALYSIS/CALCULATION NO: NA84-11

ANALYSIS/CALCULATION TITLE: SEISMIC STRESS ANALYSIS
HILLS - MCCANNA DAMPER ACTUATORS R-260 FS

REFERENCE DOCUMENTS

MAR NO: _____

DCR NO: _____

OTHERS: DOC 769

calc MB4-12

PREPARED BY: Donald W. Church

DATE: 4/25/84

REVIEWED BY: A. J. Ralston

DATE: 4-26/84

APPROVED BY: Mike McDermott

DATE: 4/30/84

FINAL APPROVAL BY: J. J. C. C. C.

DATE: 30 April 1984

FORM NG-007Z REV. 0

REGULATORY DOCKET FILE COPY

FOR INFORMATION ONLY

8502060249 840403
PDR ADDCK 05000331
PDR

Background

The purpose for compiling calculations M84-11, 12, 13, 14, 15 was to perform a seismic analysis on the critical components of the Hills-McCanna Pneumatic Damper Actuators. These actuators are part of the secondary containment isolation system at the Duane Arnold Energy Center.

On January 26, 1984, Iowa Electric notified the NRC by telephone that the above mentioned actuators were potentially deficient in meeting their purchase specification. A review of the documents relating to this discrepancy revealed that the isolation damper assemblies were purchased originally as complete assemblies which included the damper actuators. Subsequent orders for "like-for-like" replacement actuators were placed directly with the actuator manufacturer who was a subvendor to the damper manufacturer. This most recent purchase order for actuators revealed that a quality assurance program, as required for safety related equipment per 10CFR Part 50, is not currently in effect at the actuators manufacturer's facility.

Further review of the damper assembly documentation revealed that the seismic analysis performed on the damper assemblies did not seismically analyze the actuators themselves, but only considered their weight as it seismically affected the damper frame. This information prompted Iowa Electric to audit the damper manufacturer and check for documentation that pertained to the seismic qualifications of the isolation damper actuators. Results from the audit of the damper manufacturer revealed that the actuators were never purchased by the damper manufacturer as seismically qualified components nor did the damper manufacturer administer a Quality Assurance program concerning the purchase of the actuators.

Since no traceability or Certificate of Conformance was available for the seismic qualifications of the actuators, a seismic analysis was performed on the critical components of the actuators in order to seismically qualify the damper actuators for use in the Duane Arnold Energy Center. This seismic analysis followed the guidelines set forth in the original purchase specification for the isolation dampers (ref. Bechtel 7884-M-100). By seismically qualifying the isolation damper actuators, Iowa Electric will be able to buy Quality Level I actuators in accordance with Revision 1, Chapter 4 of the Quality Assurance Manual under Standard Industrial Quality Items 4.7.3.

Solution

A seismic analysis was performed on five models of the Rockwell Hills-McCanna Ramcon Pneumatic Actuator product line that are installed as isolation damper actuators at the Duane Arnold Energy Center. These five models include the following:

- R-260 FS
- R-450 FS
- R-960 FS
- R-2000 FS
- R-4200 FS

FOR INFORMATION ONLY

II

The seismic analysis on the actuators followed the general project seismic requirements for frequency-not-determined class 1 equipment in the reactor building and in the control building (ref. Bechtel 7884-M-100, Technical Specifications for Isolation Dampers for the Duane Arnold Energy Center Unit 1, Revision 0, 12-28-70).

A visual inspection of all isolation damper actuators at the Duane Arnold Energy Center was made in order to verify model number, serial number and elevation location in the plant. After verifying the elevation location in the plant, static coefficients (g units) were determined for the highest installed actuator for each of the five actuator models. The horizontal static coefficient was then applied to all three of the orientation axis which eliminated many repetitious calculations and the need for detailed actuator orientation information. Applying the horizontal static coefficient to each axis provided conservative results since the horizontal coefficient is always greater than one plus the vertical coefficient ($F_{\text{vertical}} = (\text{Weight}) (1 + g_v)$, $F_{\text{horizontal}} = (\text{Weight}) (g_h)$, $g_h > 1 + g_v$).

The seismic analysis concentrated on the critical areas of the damper actuator where the seismically induced loads could possibly make the actuator fail, malfunction, or prevent operation. Five areas on each actuator model were identified as critical areas requiring a seismic analysis of the various components interfacing with that critical area. These five critical areas are identified as the following:

- Retaining key which holds the spring cylinder assembly to the main body cylinder
- Main body cylinder
- Press fit between main body cylinder and the mounting yoke
- Mounting hardware
- Mounting yoke

Dimensions and material specifications for the seismic analysis were obtained through the use of proprietary component drawings that were on loan to Iowa Electric from Rockwell Hills-McCanna of Carpentersville, Illinois. All prints applicable to this seismic analysis are listed in the reference section of the referenced calculations.

Four basic assumptions are applied throughout the entire seismic analysis of the damper actuators. These assumptions allow Iowa Electric to use the floor response spectra as the design/qualification spectra for the seismic analysis. The four basic assumptions are as follows:

- The mounting of the damper is a rigid structure ($f > 33$ cps)
- The damper itself is a rigid structure ($f > 33$ cps)
- The support bracket for the actuator is a rigid structure ($f > 33$ cps)
- The seismic requirements for evaluating the actuators are the same as those for the isolation dampers.

FOR INFORMATION ONLY

III

The maximum seismic stresses were calculated by using the square root sum of the squares method for combining the three earthquake direction stresses as recommended in the UFSAR for seismic analysis at the Duane Arnold Energy Center. A second method, the distortion energy method was used for combining stresses at the press fit between the main body cylinder and the mounting yoke. The distortion energy method was used in place of the square root sum of the squares method because the stresses due to the press-fit condition exceeded and dominated those caused by the seismic event. All maximum stresses were then compared to some fraction of the yield strength depending on the material type and stress type. Operability after a DBE event was ensured by requiring that the maximum stress from combined seismic and normal loads should not exceed 90% of the yield stress of the material.

Conclusion

After completing the above described seismic analysis on the five models of Hills-McCanna actuators installed on the isolation dampers at the Duane Arnold Energy Center, it was found that the maximum stresses from the combined seismic and normal loads do not exceed the material yield requirements defined in the isolation damper purchase specification. The results of this seismic analysis reveal that the five models of Hills-McCanna actuators are seismically qualified for use at the Duane Arnold Energy Center.

References

Bechtel Purchase Specification 7884-M-100

Formulas for Stress and Strain; Raymond J. Roark, Warren C. Young, Fifth Edition, McGraw-Hill Book Co. 1975

Hills-McCanna Information Bulletins; R-1090, R-1090A, R110C, R1100A, R-111C, R-1110A, R-112D, R-1120A, R-113D, R-1130A

Marks' Standard Handbook for Mechanical Engineers' Baumeister Eighth Edition, McGraw-Hill Book Company 1978

Materials Selector 75; Reinhold Publishing Co. Mid September 1974, Vol. 80, No. 4, Brown Printing Co.

Mechanical Engineering Design; Joseph E. Shigley, Third Edition, McGraw-Hill Book Co. 1977

Mechanics of Materials; Higdon, Ohlsen, Stiles, Weese, Riley Third Edition, John Wiley and Sons 1978

FOR INFORMATION ONLY

IV

Rockwell Hills-McCanna; Proprietary Drawings

DATA: Information contained on drawings is proprietary and confidential and is not to be given or loaned to others. Drawings are to be returned to Rockwell upon completion of their intended use in making the seismic analysis.

<u>R260</u>	<u>R450-R960</u>	<u>R2000-R4200</u>
430-1004	450-7511	460-7511
430-7510	450-1005	460-1001
430-7511	450-7512	460-7509
430-3003	450-3005	460-3001
430-3005	450-3007	460-3003
430-4101	450-4101	460-4101
430-4102	450-4102	460-4102
430-2101	450-2101	460-2101
430-2904	450-2906	460-2904
430-2502	450-2507	460-2503
430-2501	450-2501	460-2502
430-3321	450-3201	460-3208
430-3322	450-3202	460-3209
430-3325	450-3203	460-3210
430-3201	450-3326	460-3317
430-3202	450-3325	460-3316
430-8203	450-3321	460-3320
	450-3320	460-3321
		460-3314
		460-3315

U.S.S. Steel Design Manual; R.L. Brockenbrough and B.G. Johnson, Jan. 1981

FOR INFORMATION ONLY

MARTIN REIFSCHNEIDER Reviewer for Calculations M84-11,12,13,14,15

POSITION

Senior Civil/Structural Engineer

EDUCATION

BS, Civil Engineering, University of Michigan
MS, Civil/Structural Engineering,
University of Michigan

PROFESSIONAL
DATA

Registered Professional Engineer in Michigan

SUMMARY

1 year: Senior Engineer; Civil/
Structural Staff
4 years: Senior Engineer; Midland,
Palisades, and Big Rock
Point Nuclear Power Plants
1 year: Resident Engineer,
Midland Nuclear Power Plant

EXPERIENCE

Mr. Reifschneider is currently assigned as a civil/structural engineer on the civil/structural staff. His duties include; preparation of design standards; review of project calculations, drawings, specifications and seismic qualification of equipment; providing consultation to civil/structural engineers engaged in the design of nuclear and fossil power plants; solving special static and dynamic structural problems.

Prior to joining the civil/structural staff, Mr. Reifschneider was a civil/structural engineer on Consumers Power Company's Palisades project. His duties included finite element analysis of the biological shield wall, seismic analysis and design of blockwall supports, and seismic analysis and design of the auxiliary building addition including the review of seismic equipment qualifications.

Prior to joining the Palisades project, Mr. Reifschneider was a civil/structural resident engineer at the jobsite of Consumers Power company's Midland nuclear plant project. His duties included interfacing with construction personnel on the design, erection, and construction of seismic instrument and equipment supports.

FOR INFORMATION ONLY

Prior to his jobsite assignment, Mr. Reifschneider conducted research on the inelastic design and behavior of braced structural steel systems, moment frame structural steel system, and reinforced concrete shear wall systems. He co-authored three Bechtel reports on the findings of this research.

Prior to his research assignment, Mr. Reifschneider was a civil/structural engineer on the Midland nuclear plant project. His duties included designing seismic supports for HVAC ducts and electrical cabletrays.

FOR INFORMATION ONLY

IOWA ELECTRIC LIGHT
AND POWER COMPANY
CEDAR RAPIDS, IOWA

DEPT. DESIGN ENGINEERING

PROJECT DWANE ARNOLD ENERGY CENTER Sheet No. VII of VIII

SUBJECT SEISMIC ANALYSIS HILLS-MCCANNA ACTUATORS

Computed by DR

Date _____

Checked by _____

Date _____

FOR INFORMATION ONLY

SUMMARY OF RESULTS R-260 FS

<u>COMPONENT</u>	<u>MANUFACTURED MATERIAL</u> <u>ALLOWABLE STRESS</u>	<u>LOW GRADE MATERIAL</u> <u>ALLOWABLE STRESS</u>	* <u>CALCULATED STRESS (σ_F, γ_F)</u> <u>STRESS COMPARISON</u>
<u>RETAINING KEY</u>	303 STAINLESS STEEL $S_{YA} = (0.5) S_Y$ $S_{YA} = 17500 \text{ psi}$	NOT APPLICABLE NOT APPLICABLE	$\gamma_F = 1360 \text{ psi}$ <u>$1360 \ll 17500 \text{ psi}$</u>
<u>MAIN BODY CYLINDER</u> OUTSIDE SURFACE INSIDE SURFACE	1020 STEEL $S_Y = (0.9) S_Y$ $S_{YA} = 43200 \text{ psi}$	1006 STEEL $S_{YA} (0.9) S_Y$ $S_{YA} = 36900$	$\sigma_F = 15092 \text{ psi}$ <u>$15092 < 36900$</u> $\sigma_F = 17014 \text{ psi}$ <u>$17014 < 36900$</u>

MOUNTING HARDWARE

A 307 GRADE 1
BOLT

$\sigma_F = 3455 \text{ psi}$

$\gamma_F = 1759 \text{ psi}$

3/8-16 BOLTS

$\sigma_A = 20000 \text{ psi}$
 $\gamma_A = 10000 \text{ psi}$

NOTE: LOWEST GRADE BOLT ASSUMED INSTALLED

BASIS FOR COMPARISON: $\frac{\gamma_F}{\gamma_A} + \frac{\sigma_F}{\sigma_A} \leq 1.5$ FOR DBE ANALYSIS

$0.349 \leq 1.5$

* CALCULATED STRESS USING SRSS OF THREE EARTHQUAKE DIRECTIONS OR MAXIMUM DISTORTION ENERGY THEORY.

IOWA ELECTRIC LIGHT
AND POWER COMPANY
CEDAR RAPIDS, IOWA

DEPT. DESIGN ENGINEERING
PROJECT DWANE ARNOLD ENERGY CENTER Sheet No. VIII of VIII
SUBJECT SEISMIC ANALYSIS HILLS-MCCANNA ACTUATORS
Computed by DP Date _____ Checked by _____ Date _____

SUMMARY OF RESULTS CONTINUED R-260 FS

<u>COMPONENT</u>	<u>MANUFACTURED MATERIAL</u> <u>ALLOWABLE STRESS</u>	<u>LOW GRADE MATERIAL</u> <u>ALLOWABLE STRESS</u>	<u>*CALCULATED STRESS</u> <u>STRESS COMPARISON</u>
<u>BODY CASTING</u> <u>(MOUNTING YOKES)</u>	<u>CLASS 35</u> <u>CAST IRON</u> $S_{YA} = (0.6)(S_u)$ $S_{YA} = 18000 \text{ PSI}$ $S_{YA} = (0.4)(S_u)$ $S_{YA} = 12000 \text{ PSI}$	<u>CLASS 20</u> <u>CAST IRON</u> $S_{YA} = (0.6)(S_u)$ $S_{YA} = 12000$ $S_{YA} = (0.4)(S_u)$ $S_{YA} = 8000 \text{ PSI}$	$\sigma_F = 1137 \text{ PSI}$ $\gamma_F = 122 \text{ PSI}$ <u>$1137 < 12000$</u> <u>$122 < 8000$</u>
<u>PRESS FIT</u> <u>BETWEEN</u> <u>MAIN CYLINDER</u> <u>AND MOUNTING</u> <u>YOKES</u>	<u>CAST IRON-</u> <u>1030 STEEL</u> <u>MINIMUM INTERFERENCE = 0.001"</u> <u>FORCE REQUIRED TO SLIDE CYLINDER</u> <u>FROM MOUNTING YOKES = 1005 #</u>	<u>RESULTANT</u> <u>AXIAL FORCE = 237 #</u> <u>$237 < 1005$</u>	

FOR INFORMATION ONLY

IOWA ELECTRIC LIGHT
AND POWER COMPANY
CEDAR RAPIDS, IOWA

DEPT. DESIGN ENGINEERING CALC M-84-11
PROJECT DUANE ARNOLD ENERGY CENTER Sheet No. 1 of 18
SUBJECT SEISMIC STRESS ANALYSIS HILLS-MCCANNA ACTUATORS
Computed by DN Date _____ Checked by MR / AJR Date _____

WEIGHT DETERMINATION

CYLINDER - SPRING CYLINDER

R-260 FS

$$\begin{aligned} D_o &= 3.62" \\ D_i &= 3.25" \\ h &= 5.84" \\ \rho &= 0.283 \text{ #/in}^3 \end{aligned}$$

$$\text{WEIGHT} = \frac{\pi (3.62^2 - 3.25^2) (5.84) (0.283)}{4}$$

$$\text{WEIGHT} = 3.30 \text{ #}$$

MAIN BODY CYLINDER

$$\begin{aligned} D_o &= 3.871" \\ D_i &= 3.520" \\ h &= 12.605" \\ \rho &= 0.283 \text{ #/in}^3 \end{aligned}$$

$$\text{WEIGHT} = \frac{\pi (3.871^2 - 3.520^2) (12.605) (0.283)}{4}$$

$$\text{WEIGHT} = 7.27 \text{ #}$$

END CAP SPRING CYLINDER

$$\begin{aligned} D_1 &= 3.31" \\ D_2 &= 2.14" \\ \rho &= 0.283 \text{ #/in}^3 \end{aligned}$$

$$\text{WEIGHT} = 0.283 \left[\frac{\pi (3.31)^2 (0.25)}{4} + \frac{\pi (2.14)^2 (0.25)}{4} \right]$$

$$\text{WEIGHT} = 0.86 \text{ #}$$

SPRING

$$\text{LENGTH OF ONE COIL} = \sqrt{(2\pi r)^2 + h^2}$$

r = radius

h = DISTANCE BETWEEN TWO COILS OF HELIX

SPRING OD = 2.88

SPRING ID = 2.17

$$h = 0.331$$

$$r = \frac{(2.88 - 2.17)/2 + 2.17}{2} = 1.26"$$

$$\text{LENGTH OF ONE COIL} = \sqrt{[(2\pi)(1.26)]^2 + 0.331^2}$$

$$\text{LENGTH OF ONE COIL} = 7.94"$$

$$(13.0 \text{ # COILS}) (7.94") \left(\frac{\pi (0.331)^2 (0.283)}{4} \right) = 2.51 \text{ #}$$

FOR INFORMATION ONLY

IOWA ELECTRIC LIGHT
AND POWER COMPANY

CEDAR RAPIDS, IOWA
R-260 FS

DEPT. DESIGN ENGINEERING

PROJECT DUGNE ARNOLD ENERGY CENTER

SUBJECT SEISMIC STRESS ANALYSIS HILLS-MCCANNA ACTUATORS

Computed by MR. [Signature]

Date

Checked by MR. AJR

Date



CALC. M24-11

Sheet No. 2 of 18

WEIGHT DETERMINATION CONTINUED

PISTON


HEAD



$$VOLUME = \frac{\pi (3.515)^2 (0.788)}{4} =$$

$$V_1 = 7.65 \text{ IN}^3$$

LOWER SEAT



$$\theta = \sin^{-1} \frac{1.06}{1.758} = 37.1^\circ$$

$$d = 1.758 \cos 37.1^\circ - 0.757$$

$$d = 0.6452$$


$$h = 1.758 \left(\cos \left[\sin^{-1} \frac{0.425}{1.758} \right] - \cos \theta \right) =$$

$$h = 0.304$$

$$AREA = \left(\frac{37.1}{180} \right) (\pi) (1.758)^2 - (1.4022)(1.06) + (2)(0.6452)(0.635)$$

$$- (0.850)(0.304) = 1.076 \text{ IN}^2$$

$$V_2 = 1.076 \text{ IN}^2 \times 4.808 \text{ IN} = 5.173 \text{ IN}^3$$



$$\theta = \sin^{-1} \left(\frac{0.425}{1.758} \right) = 14^\circ$$

$$A = \left[\frac{14^\circ}{180} \pi (1.758)^2 \right] - 1.758 (\cos 14^\circ) (0.425) +$$

$$\left[1.758 \cos 14^\circ - 0.757 \right] (0.85) = 0.837 \text{ IN}^2$$

$$V_3 = (0.837)(1.448) = 1.212 \text{ IN}^3$$

FOR INFORMATION ONLY


IOWA ELECTRIC LIGHT
AND POWER COMPANY
CEDAR RAPIDS, IOWA

DEPT. DESIGN ENGINEERING CALC. M24-11
PROJECT DUANE ARNOLD ENERGY CENTER Sheet No. 3 of 13
SUBJECT SEISMIC STRESS ANALYSIS HILLS-MCCANNA ACTUATORS
Computed by [Signature] Date Checked by R/AJR Date

WEIGHT DETERMINATION CONTINUED

PISTON CONTINUED

R-260 FS



$$V_4 = \frac{1}{2} (1.448 \times 1.264) \times 2.12 = 1.940 \text{ in}^3$$

(CONSERVATIVE)

$$V_{\text{PISTON}} = V_1 + V_2 + V_3 + V_4 = 7.65 + 5.173 + 1.212 + 1.940$$
$$= 15.975$$

$$\text{WEIGHT PISTON} = PV = (0.26)(15.975) = 4.1 \text{ \#}$$

FOR INFORMATION ONLY

IOWA ELECTRIC-LIGHT
AND POWER COMPANY

CEDAR RAPIDS, IOWA
R-260 FS

DEPT. DESIGN ENGINEERING

PROJECT DUANE ARNOLD ENERGY CENTER Sheet No. 4 of 18

SUBJECT SEISMIC STRESS ANALYSIS HILLS-MCCANNA ACTUATORS

Computed by DA

Date _____

Checked by MR LAIR

Date _____

REFERENCE BECHTEL 7884-M-100

HORIZONTAL g LOADS

11-AD-15A & B REACTOR BUILDING ELEVATION 822
11-AD-51A & B REACTOR BUILDING ELEVATION 779


OBE	OGE
4.1	8.2
3.5	7.0

FREQUENCY NOT DETERMINED, BOLTED SUPPORT SYSTEM

- MAXIMUM HORIZONTAL (g) LOAD FOR WORST CASE ACTUATOR ELEVATION APPLIED TO ALL AXIS OF SEISMIC ANALYSIS. HORIZONTAL (g) LOAD IS GREATER THAN $(1+g)$ LOAD ON VERTICAL

- MAXIMUM AIR PRESSURE = 100 PSI ACTING ON PISTON
3.524" IN DIAMETER $F_{AP} = \frac{(100 \text{ PSI})(3.524)^2 \pi}{4} = 975.35 \text{ #}$

SHEAR STRESS ON THE RETAINING KEY AXIAL ORIENTATION



$$\begin{aligned} M_1 (\text{END CAP}) &= 0.86 \text{ #} \\ M_2 (\text{SPRING CYL}) &= 3.30 \text{ #} \\ M_3 (\text{SPRING}) &= 2.51 \text{ #} \\ M_4 (\text{PISTON}) &= 4.10 \text{ #} \\ \hline &10.77 \text{ #} \end{aligned}$$

SPRING TEST LENGTH REFERENCE 420-3003

AT 7.88" SPRING LOAD = 257 #

SPRING RATE = 100 #/IN

MAXIMUM SPRING COMPRESSION = 5.81"

$$F_{\text{SPRING}} = 257 \text{ #} + 100(7.88 - 5.81) = 464.00 \text{ #}$$

$$F_{\text{WEIGHT}} = (8.2)(10.77) = 88.31 \text{ #}$$

$$F_{\text{AIR PRESSURE}} = \frac{(100 \text{ PSI})(\pi)(3.524)^2}{4} = 975.35 \text{ #}$$

$$F_{\text{TOTAL}} = 464 \text{ #} + 88.31 \text{ #} + 975.35 \text{ #} = 1527.66 \text{ #} \quad \text{CONSERVATIVE APPROXIMATION}$$

FOR INFORMATION ONLY


SHEAR STRESS ON THE RETAINING KEY

RETAINING KEY 303 STAINLESS STEEL 0.125" SQUARE

$$\text{ACTIVE CIRCUMFERENTIAL LENGTH} = 11.20 - 0.355 - \frac{0.125}{\tan 15^\circ} = 10.39"$$

$$\tau_a = \frac{F_t}{A} = \frac{1527.66}{(0.125)(10.39)} = \underline{\underline{1176.25 \text{ PSI}}}$$

STRESS ON THE RETAINING KEY FROM MOMENTS
CAUSED BY THE SPRING CYLINDER ASSEMBLY



$$M_y = 8.7 \left[(0.86)(5.28) + (2.36)(3.30 + 2.51) \right]$$

$$M_y = 149.67 \text{ IN-LB}$$

$$\int \tau(\theta) t r^2 \sin \theta d\theta = \frac{M}{4} \quad \text{REFERENCE R-450 FS CALC Pg. 6}$$

$$\tau(\theta) = K r \sin \theta$$

$$\text{QUAD ACTIVE LENGTH} = \frac{10.39}{4} = 2.60"$$

$$\int K t r^3 \sin^2 \theta d\theta$$

$$K t r^3 \int \sin^2 \theta d\theta = K t r^3 \left[-\frac{1}{4} \sin 2\theta + \frac{\theta}{2} \right]_0^\theta = \frac{M}{4}$$

$$t = 0.125"$$

$$r = 3.568/2 = 1.78"$$

$$M = 149.67 \text{ IN-LB}$$

$$C_{\text{QUAD}} = \frac{2\alpha(1.78)}{4} = 2.80$$

$$\theta = \frac{2.60}{2.80} \times \frac{\pi}{2} = 1.46 \text{ RADIAN}$$

$$-\frac{1}{4} \sin(2)(1.46) + \frac{1.46}{2} = 0.6751$$

$$\frac{M}{4} = K t r^3 (0.6751) \quad \frac{149.67}{(4)(0.125)(1.78)^3(0.6751)} = K$$

$$K = 78.62$$

$$\tau(\theta) = (78.62)(1.78) \sin(1.46) = \underline{\underline{139.09 \text{ PSI}}}$$

FOR INFORMATION ONLY

$$\tau_{TOTAL} = \tau_A + \tau(\theta) = 1176.25 + 139.09 = 1315.34 \text{ PSI}$$

S_y = YIELD STRENGTH 303 STAINLESS STEEL = 35,000 PSI
 S_y = SHEAR STRENGTH = $(0.5)(S_y) = (0.5)(35,000) = 17,500 \text{ PSI}$
ALLOWABLE SHEAR STRESS = 17,500 PSI

$$\underline{1315.34 \text{ PSI} < 17500 \text{ PSI}}$$

STRESSES DUE TO THE PRESS FIT CONDITIONS
BETWEEN THE YOKE AND THE CYLINDER BODY

- REFERENCE HIGDON "MECHANICS OF MATERIALS"
JOHN WILEY & SONS 1978 Pg 163, 164

$$I (\text{INTERFERENCE}) = 3.856 - 3.852 = 0.004'' (\text{MAXIMUM})$$


$$\text{YOKE BODY} = \frac{3.852}{3.852}$$

$$I = 2\epsilon_1 + 2\epsilon_2$$

$$\text{MAIN CYLINDER} = \frac{3.856}{3.854}$$

$$\epsilon_1 = \frac{b_1^2 P_s}{(c^2 - b_1^2) E_y b_1} \left[(1-\nu) b_1^2 + (1+\nu) c^2 \right]$$

$$\epsilon_2 = \frac{b_2^2 P_s}{(b_2^2 - a^2) E_c b_2} \left[(1-\nu) b_2^2 + (1+\nu) a^2 \right]$$



$$\begin{aligned} a &= 1.762'' \\ b_1 &= 1.926'' \\ b_2 &= 1.928'' \\ c &= 2.30'' \end{aligned}$$

SOLVE FOR P_s INTERFACIAL PRESSURE

$$\begin{aligned} 0.004 &= 2 \left[\frac{1.926^2 P_s}{(2.30^2 - 1.926^2)(15 \times 10^6)(1.926)} \right] \left[(0.71)(1.926)^2 + (1.29)(2.30)^2 \right] \\ &+ 2 \left[\frac{1.928^2 P_s}{(1.928^2 - 1.762^2)(30 \times 10^6)(1.928)} \right] \left[(0.70)(1.928)^2 + (1.3)(1.762)^2 \right] \end{aligned}$$

$$0.004 = 1.5367 \times 10^{-6} P_s + 1.3929 \times 10^{-6}$$

$$P_s = 1365.37 \text{ \#} (\text{MAXIMUM INTERFERENCE})$$

FOR INFORMATION ONLY

IOWA ELECTRIC LIGHT AND POWER COMPANY CEDAR RAPIDS, IOWA R-260 FS	DEPT. <u>DESIGN ENGINEERING</u>	CALC. MPA-11
	PROJECT <u>DUANE ARNOLD ENERGY CENTER</u>	Sheet No. <u>7</u> of <u>18</u>
	SUBJECT <u>SEISMIC STRESS ANALYSIS HILLS-MCCANNA ACTUATOR</u>	
	Computed by <u>BW</u>	Date _____ Checked by <u>MP/AJR</u> Date _____

STRESSES DUE TO THE PRESS FIT CONDITIONS
BETWEEN THE YOKE AND THE CYLINDER BODY

EXTERNAL PRESSURE

$$\sigma_r = \frac{-b^2 p_o}{b^2 - a^2} \left[1 - \frac{a^2}{r^2} \right]$$

$$\sigma_t = \frac{-b^2 p_o}{b^2 - a^2} \left[1 + \frac{a^2}{r^2} \right]$$

INTERNAL PRESSURE

$$\sigma_r = \frac{a^2 p_i}{b^2 - a^2} \left[1 - \frac{b^2}{r^2} \right]$$

$$\sigma_t = \frac{a^2 p_i}{b^2 - a^2} \left[1 + \frac{b^2}{r^2} \right]$$

STRESS IN BODY CASTING INTERNAL PRESSURE

$$\sigma_r = \frac{(1.926)^2 (1365.37)}{(2.30^2 - 1.926^2)} \left(1 - \frac{2.30^2}{1.926^2} \right) = -1365.37 \text{ PSI}$$

$$\sigma_t = \frac{(1.926)^2 (1365.37)}{(2.30^2 - 1.926^2)} \left(1 + \frac{2.30^2}{1.926^2} \right) = 7774.39 \text{ PSI}$$

STRESS IN MAIN CYLINDER EXTERNAL PRESSURE

OUTSIDE CYLINDER SURFACE

$$\sigma_r = - \frac{(1.928)^2 (1365.37)}{(1.928^2 - 1.762^2)} \left(1 - \frac{1.762^2}{1.928^2} \right) = -1365.37 \text{ PSI}$$

$$\sigma_t = - \frac{(1.928)^2 (1365.37)}{(1.928^2 - 1.762^2)} \left(1 + \frac{1.762^2}{1.928^2} \right) = -15206.06 \text{ PSI}$$

FOR INFORMATION ONLY

IOWA ELECTRIC LIGHT AND POWER COMPANY CEDAR RAPIDS, IOWA R-260 FS	DEPT. <u>DESIGN ENGINEERING</u>	CALC <u>M84-11</u>
	PROJECT <u>DUANE ARNOLD ENERGY CENTER</u>	SHEET No. <u>8</u> OF <u>18</u>
	SUBJECT <u>SEISMIC STRESS ANALYSIS HILLS-MCCANNA ACTUATOR</u>	
	Computed by <u>PLC</u>	Date _____ Checked by <u>1/ADR</u> Date _____


STRESSES DUE TO THE PRESS FIT CONDITIONS
BETWEEN THE YOKE AND THE CYLINDER BODY

STRESS IN THE MAIN CYLINDER EXTERNAL PRESSURE
INSIDE CYLINDER SURFACE

$$\sigma_r = -\frac{(1.928)^2(1365.37)}{(1.928^2 - 1.762^2)} \left(1 - \frac{1.762^2}{1.928^2}\right) = 0$$

$$\sigma_t = -\frac{(1.928)^2(1365.37)}{(1.928^2 - 1.762^2)} \left(1 + \frac{1.762^2}{1.928^2}\right) = -16571.43 \text{ PSI}$$

STRESS ON THE MAIN CYLINDER DUE TO MOMENTS CAUSED
BY THE MAIN BODY CYLINDER, PISTON, SPRING CYLINDER
AND END CAP



$$\begin{aligned} M_1(\text{END CAP}) &= 0.86^* \\ M_2(\text{SPRING CYL}) &= 3.30^* \\ M_3(\text{SPRING}) &= 2.51^* \\ M_4(\text{PISTON}) &= 4.10^* \\ M_5(\text{MAIN CYL}) &= 7.27^* \end{aligned}$$

NOTE: $l_s = 2.54$ WHEN CALCULATED
BY CENTERING MOUNTING
YOKE ON MAIN CYLINDER.
(NOT MACHINED DIAMETER)

- MASS OF CYLINDER IS MODELLED TO ACT ON THE RIGHT SIDE OF THE YOKE. EXCLUDES COUNTERACTING MOMENT DUE TO MASS ON THE LEFT SIDE OF YOKE &

$$M_{xx} = 8.2 \left[(10.091)(0.86) + (3.30 + 2.51)(7.171) + (4.10)(2.3857) + (7.27)(2.518) \right]$$

$$M_{xx} = 643.11 \text{ IN-LB}$$

FOR INFORMATION ONLY

STRESSES ON THE MAIN CYLINDER

MOMENT OF INERTIA @ AXIS X-X ACTUATOR @ IS NEUTRAL AXIS


$$I = \frac{\pi}{64} (d_o^4 - d_i^4) = \frac{\pi}{64} (3.856^4 - 3.524^4) = 3.282 \text{ IN}^4$$

$$\sigma' = \frac{M_c}{I} = \frac{(643.11 \text{ IN-LB})(3.856)}{3.282 (2)} = 377.8 \text{ PSI}$$

$$\sigma = \frac{M_c}{I} = \frac{(643.11)(3.524)}{3.282 (2)} = 345.3 \text{ PSI}$$

$$\sigma_{\text{AIR PRESSURE}} = \frac{975.35 \text{ \#}}{(3.856^2 - 3.524^2) \pi / 4} = 506.85 \text{ PSI}$$

SUMMATION OF CYLINDER STRESSES



$$\sigma'_b = \sigma' + \sigma_{\text{AIR}} = 377.8 + 506.85 = 884.7 \text{ PSI}$$

$$\sigma'_{\text{r}} = -1365.37 \text{ PSI}$$

$$\sigma'_{\text{t}} = -15206.06 \text{ PSI}$$

$$\sigma_b = \sigma + \sigma_{\text{AIR}} = 345.3 + 506.85 = 852.1 \text{ PSI}$$

$$\sigma_{\text{r}} = 0$$

$$\sigma_{\text{t}} = -16571.43$$

MAXIMUM DISTORTION ENERGY STRESS THEORY

$$\sigma_F = \left\{ \frac{1}{2} \left[(\sigma_b - \sigma_t)^2 + (\sigma_t - \sigma_r)^2 + (\sigma_r - \sigma_b)^2 \right] \right\}^{1/2}$$

ALL INFORMATION CONTAINED
HEREIN IS UNCLASSIFIED
DATE 01-10-2001 BY 60322 UCBAW

IOWA ELECTRIC LIGHT
AND POWER COMPANY

CEDAR RAPIDS, IOWA

R-260 FS

DEPT. DESIGN ENGINEERING

CALC. ME4-11

PROJECT DUANE ARNOLD ENERGY CENTER Sheet No. 10 of 18

SUBJECT SEISMIC STRESS ANALYSIS HILLS-MCCANNA ACTUATOR

Computed by

DL

Date

Checked by

RA / AJR

Date

SUMMATION OF CYLINDER STRESSES

$$\sigma_F = \left\{ \frac{1}{2} \left[(852.1 + 16571.4)^2 + (-16571.4 - 0)^2 + (0 - 852.1)^2 \right] \right\}^{1/2}$$

$$\sigma_F = 17013.5 \text{ PSI}$$

$$\sigma_F' = \left\{ \frac{1}{2} \left[(884.7 + 15206.06)^2 + (-15206.06 + 1365.37)^2 + (-1365.37 - 884.7)^2 \right] \right\}^{1/2}$$

$$\sigma_F' = 15092.0 \text{ PSI}$$

$$S_y \text{ 1020 STEEL} = 48,000 \text{ PSI}$$

$$90\% S_y = (0.90)(48000) = 43200 \text{ PSI}$$

$$\underline{\underline{\sigma_F = 17013.5 \text{ PSI} < 43200 \text{ PSI}}}$$

$$\underline{\underline{\sigma_F' = 15092.0 \text{ PSI} < 43200 \text{ PSI}}}$$

FOR INFORMATION ONLY

IOWA ELECTRIC LIGHT
AND POWER COMPANY

CEDAR RAPIDS, IOWA
R-260 FS

DEPT. DESIGN ENGINEERING


CALC. M84-11

PROJECT DUANE ARNOLD ENERGY CENTER Sheet No. 11 of 15


SUBJECT SEISMIC STRESS ANALYSIS HILLS-MCCANNA ACTUATORS

Computed by DR Date _____ Checked by PR/ASR Date _____

SEISMIC AXIAL LOAD ACTING ON THE PRESS FIT OF
THE MAIN CYLINDER AND MOUNTING YOKE



MINIMUM INTERFERENCE
 $I = 3.854 - 3.853$
 $I = 0.001$



MINIMUM PRESSURE FROM PRESS FIT
WITH MINIMUM INTERFERENCE

SOLVING FOR MINIMUM PRESSURE
(P) Pg 164 MECHANICS OF MATLS.

$$0.001 = 2 \left[\frac{1.9265^2 P_s}{(2.30^2 - 1.9265^2)(15 \times 10^6)(1.9265)} \right] \left[(0.71)(1.9265)^2 + (1.29)(2.30)^2 \right]$$

$$+ 2 \left[\frac{1.9270^2 P_s}{(1.9270^2 - 1.762^2)(30 \times 10^6)(1.927)} \right] \left[(0.70)(1.927)^2 + (1.3)(1.762)^2 \right]$$

$$0.001 = 1.400 \times 10^{-6} P_s + 1.5392 \times 10^{-6} P_s$$

$$P_s = 340.2 \text{ #}$$

DETERMINATION OF AXIAL LOAD

$$M_1 (\text{END CAPS}) = (2)(0.86) = 1.72$$

$$M_2 (\text{SPRING CYL}) = (2)(3.30) = 6.60$$

$$M_3 (\text{SPRING}) = (2)(2.51) = 5.02$$

$$M_4 (\text{PISTON}) = (2)(4.10) = 8.20$$

$$M_5 (\text{MAIN CYL}) = (1.27)$$

$$\text{TOTAL WEIGHT} = 28.81$$

$$\text{AXIAL FORCE} = (28.81)(8.2) = 236.24 \text{ #}$$

FOR INFORMATION ONLY

IOWA ELECTRIC LIGHT
AND POWER COMPANY

CEDAR RAPIDS, IOWA
R-260 FS

DEPT. DESIGN ENGINEERING

CALC M24-11

PROJECT DUANE ARNOLD ENERGY CENTER Sheet No. 12 of 18

SUBJECT SEISMIC STRESS ANALYSIS HILLS-McCANN ACTUATORS

Computed by [Signature] Date [] Checked by [Signature] / AJR Date []

FORCE REQUIRED TO SLIDE CYLINDER FROM MOUNTING YOKE

$$F_s = \pi f p d l$$

REFERENCE: MARKS HANDBOOK 8-47

$$l = 2.44"$$

$$d = 3.854"$$

$$p = 314.99 \#$$


f = COEFFICIENT OF FRICTION AVERAGE RANGE 0.10 → 0.15

$$\text{LET } f = 0.10$$

$$F_s = \pi (0.10)(314.99)(3.854)(2.44) = 1005 \#$$

$$1005 \# > 236.24 \#$$

SEISMIC LOADING ON THE MOUNTING HARDWARE



TENSION AREA = 0.0775 in^2
WEIGHT OF TOTAL ACTUATOR
ASSEMBLY = $47 \#$

g_z LOADING


$$M_y = (8.2)(47 \#)(2.75) = 1059.85 \text{ in-lb}$$

$$M_y = 2 F_T (3) \quad F_T = \text{TENSION IN BOLTS } 1 \text{ of } 2$$

$$F_T = \frac{(1059.85)}{(2)(3.0)} = 176.64 \#$$

$$\sigma_{xT} = \frac{176.64 \#}{0.0775 \text{ in}^2} = 2279.25 \text{ PSI}$$

$$\gamma_{yz} = \frac{(47 \#)(8.2)}{(0.0775)(4 \text{ bolts})} = 1243.23 \text{ PSI}$$



FOR INFORMATION ONLY


IOWA ELECTRIC LIGHT
AND POWER COMPANY

CEDAR RAPIDS, IOWA
K-260 FS

DEPT. DESIGN ENGINEERING CALC ME4-11
PROJECT DWANE ARNOLD ENERGY CENTER Sheet No. 13 of 18
SUBJECT SEISMIC STRESS ANALYSIS HILLS-MCGRAW ACTUATORS
Computed by EW Date _____ Checked by PR/AJR Date _____

SEISMIC LOADING ON THE MOUNTING HARDWARE

Q_y LOADING



$$M_z = (8.2)(47\#)(2.75\text{IN}) = 1059.85\text{IN}\cdot\text{lb}$$

$$M_y = 2(F_T)(3.0) \quad F_T = \text{TENSION BOLTS } 2 \times 4$$

$$F_T = \frac{(1059.85)}{(2)(3.0)} = 176.64\#$$

$$\sigma_{x2} = 2279.25 \text{ PSI}$$

$$\tau_{yz} = \frac{(47\#)(8.2)}{(0.0775)(4)} = 1243.23 \text{ PSI}$$

Q_x LOADING

$$\text{TENSION ONLY} = F_{Tx} = MA$$

$$\text{FORCE TENSION} = \frac{(47\#)(8.2)}{4 \text{ BOLTS}} = 96.35\#$$

$$\sigma_{x3} = \frac{96.35\#}{0.0775\text{IN}^2} = 1243.26 \text{ PSI}$$

SUMMATION OF STRESSES

$$\text{BASIS FOR COMPARISON} \quad \frac{\tau_F}{\tau_A} + \frac{\sigma_F}{\sigma_A} < 1.5 \text{ FOR DBE CONDITIONS}$$

FOR INFORMATION ONLY

IOWA ELECTRIC LIGHT AND POWER COMPANY CEDAR RAPIDS, IOWA R-260 FS	DEPT. <u>DESIGN ENGINEERING</u>	CALC <u>ME4-11</u>
	PROJECT <u>DUANE ARNOLD ENERGY CENTER</u>	SHEET No. <u>14</u> of <u>18</u>
	SUBJECT <u>SEISMIC STRESS ANALYSIS HILLS-MCCANNA ACTUATORS</u>	
	Computed by <u>DE</u>	Date _____ Checked by <u>MR / AR</u> Date _____

SUMMATION OF STRESSES ON THE MOUNTING HARDWARE

$$\sigma_F = \left[\sigma_{x_1}^2 + \sigma_{x_2}^2 + \sigma_{x_3}^2 \right]^{1/2} = \left[2279.25^2 + 2279.25^2 + 1243.26^2 \right]^{1/2}$$

$$\sigma_F = 3454.79 \text{ PSI}$$

$$\tau_F = \left[\tau_{24_1}^2 + \tau_{24_2}^2 + \tau_{24_3}^2 \right]^{1/2} = \left[1243.23^2 + 1243.23^2 + 0^2 \right]^{1/2}$$

$$\tau_F = 1758.19 \text{ PSI}$$

BOLTS ASSUMED TO BE A307 GRADE (1) BOLTS

$$\sigma_A = 20000 \text{ PSI}$$

$$\tau_A = 10000 \text{ PSI}$$

$$\frac{1758.19}{10,000} + \frac{3454.79}{20,000} = 0.3486$$

$$\underline{\underline{0.349 \leq 1.5}}$$

FOR INFORMATION ONLY

IOWA ELECTRIC LIGHT
AND POWER COMPANY

CEDAR RAPIDS, IOWA

DEPT. DESIGN ENGINEERING


CALC M&E-11

PROJECT DURNE ARNOLD ENERGY CENTER Sheet No. 15 of 18

SUBJECT SEISMIC STRESS ANALYSIS - HILLS-McCANN ACTUATORS

Computed by DR Date _____ Checked by RAJ Date _____
SEISMIC STRESS ANALYSIS ON THE MOUNTING YOKES

R-260 FS



A = 4.60
B = 2.25
C = 2.50
D = 2.50
E = 1.50 " DIA.
F = 4.00
G = 4.00
H = 0.12
I = 5.50
K = 3.85
R = 0.22

ELASTIC STRESS IN-PLANE BENDING

REF: FORMULAS FOR STRESS AND
STRAIN Pg 593

$$K_T = K_1 + K_2 \left(\frac{zh}{d} \right) + K_3 \left(\frac{zh}{d} \right)^2 + K_4 \left(\frac{zh}{d} \right)^3$$

$$K_1 = 1.042 + 0.982 \left(\frac{h}{r} \right)^{1/2} - 0.036 \left(\frac{h}{r} \right)$$

$$K_2 = -3.599 + 1.619 \left(\frac{h}{r} \right)^{1/2} - 0.431 \left(\frac{h}{r} \right)$$

$$K_3 = 6.084 - 5.607 \left(\frac{h}{r} \right)^{1/2} + 1.158 \left(\frac{h}{r} \right)$$

$$K_4 = -2.527 + 3.006 \left(\frac{h}{r} \right)^{1/2} - 0.631 \left(\frac{h}{r} \right)$$

g_z BENDING

$$h = \frac{1}{2} (G - D) \quad r = H \quad d = G$$

$$h = \frac{1}{2} (4.0 - 2.50) = 0.750$$

$$r = 0.12$$

$$d = 4.00$$

$$K_1 = 3.272$$

$$K_2 \left(\frac{zh}{d} \right) = -0.842$$

$$K_3 \left(\frac{zh}{d} \right)^2 = -0.098$$

$$K_4 \left(\frac{zh}{d} \right)^3 = 0.035$$

$$K_z = 2.367$$

FOR INFORMATION ONLY

IOWA ELECTRIC-LIGHT
AND POWER COMPANY

CEDAR RAPIDS, IOWA

R-260 FS

DEPT. DESIGN ENGINEERING CALC. W.P. 4-11
PROJECT DUANE ARNOLD ENERGY CENTER Sheet No. 16 of 18
SUBJECT SEISMIC STRESS ANALYSIS HILLS-MCCANNA ACTUATORS
Computed by PR Date _____ Checked by PR/AJR Date _____

SEISMIC STRESS ANALYSIS ON THE MOUNTING YOKE

g_y LOADING

$$h = \frac{1}{2}(G-C) \quad r=R \quad d=G$$

$$h = \frac{1}{2}(4.0-2.50) = 0.750$$

$$r = 0.22$$

$$d = 4.0$$

$$h/r = 0.750/0.22 = 6.250$$

$$K_1 = 2.732$$

$$K_2 \left(\frac{2h}{d}\right) = -0.780$$

$$K_3 \left(\frac{2h}{d}\right)^2 = -0.045$$

$$K_4 \left(\frac{2h}{d}\right)^3 = 0.035$$

$$K_f = 1.942$$

ELASTIC STRESS AXIAL TENSION

$$h = \frac{1}{2}(G-C) = \frac{1}{2}(4.0-2.50) = 0.750$$

$$r = H = 0.12$$

$$d = G = 4.00$$

$$K_1 = 1.042 + 0.982(6.250)^{1/2} - 0.036(6.250) = 3.2720$$

$$K_2 = -0.074 - 0.156(6.250)^{1/2} - 0.010(6.250) = -0.5265$$

$$K_3 = -3.418 + 1.220(6.250)^{1/2} - 0.005(6.250) = -0.3993$$


$$K_4 = 3.450 - 2.046(6.250)^{1/2} + 0.051(6.250) = -1.3463$$

$$K_f = K_1 + K_2 \left(\frac{2h}{d}\right) + K_3 \left(\frac{2h}{d}\right)^2 + K_4 \left(\frac{2h}{d}\right)^3 \quad \frac{h}{d} = \frac{0.750}{4.0} = 0.1875$$

$$K_f = 3.2720 + (-0.5265)(0.1875) + (-0.3993)(0.1875)^2 + (-1.3463)(0.1875)^3$$

$$K_f = 3.1504$$

g_z LOADING



$$M_y = (Wt) \times (\text{dim } b) \times (g \text{ LOAD})$$


$$M_y = (47\#)(2.25)(8.2) = 867.15 \text{ in-lb}$$

$$I = \frac{(2.5)^4}{12} - \frac{\pi}{4} \left(\frac{1.5}{2}\right)^4 = 3.007 \text{ in}^4$$

$$\sigma_{2B} = \frac{M_C}{I} = \frac{(867.15)(1.25)}{3.007} = 360.51 \text{ PSI}$$

$$\sigma_x = \sigma_{2B} K_2 = (360.51)(2.367) = 853.32 \text{ PSI}$$

$$\gamma_{24} = (47\#)(8.2) / (2.5)^2 - \pi (0.75)^2 = 85.97 \text{ PSI}$$



FOR INFORMATION ONLY

IOWA ELECTRIC LIGHT
AND POWER COMPANY

CEDAR RAPIDS, IOWA
2-260 FS

DEPT. DESIGN ENGINEERING

CALC. ME-4-11


PROJECT DUNE ARNOLD ENERGY CENTER 17 18

SUBJECT SEISMIC STRESS ANALYSIS HILLS-MCCANNA ACTUATORS

Computed by DR Date _____ Checked by R. JAK Date _____

SEISMIC STRESS ANALYSIS ON THE MOUNTING YOKE

g_y LOADING



$$M_z = (wt)(dim B)(g \text{ LOAD})$$


$$M_z = (47\#)(2.25)(5.2) = 867.15 \text{ IN-LB}$$

$$I = \frac{(2.50)^4}{12} - \frac{\pi}{4} \left(\frac{1.50}{2} \right)^4 = 3.007 \text{ IN}^4$$

$$\sigma_{yB} = \frac{M_z}{I} = \frac{(867.15)(1.25)}{3.007} = 360.51 \text{ PSI}$$

$$\sigma_x = \sigma_{yB} K_y = (360.51)(1.942) = 700.10 \text{ PSI}$$

$$\tau_{zy} = \frac{(47\#)(8.2)}{2.5^2 - \pi(0.75)^2} = 85.97 \text{ PSI}$$



g_x LOADING

$$F(\text{TENSION})_x = (8.2)(47\#) = 385.4 \#$$

$$\text{CROSS SECTIONAL AREA} = 2.5^2 - \pi(0.75)^2 = 4.483 \text{ IN}^2$$

$$\sigma_{xA} = \frac{385.4\#}{4.483 \text{ IN}^2} = 85.97 \text{ PSI}$$

$$\sigma_x = K_x \sigma_{xA} = (85.97)(3.1504) = 270.85 \text{ PSI}$$

FOR INFORMATION ONLY

IOWA ELECTRIC LIGHT
AND POWER COMPANY

CEDAR RAPIDS, IOWA
R-260 FS

DEPT. DESIGN ENGINEERING

CALC. M24-11

PROJECT DUANE ARNOLD ENERGY CENTER Sheet No. 18 of 18

SUBJECT SEISMIC STRESS ANALYSIS HILL-MCCANNA ACTUATORS

Computed by RW Date _____ Checked by R/AIR Date _____

SEISMIC STRESS ANALYSIS ON THE MOUNTING YOKE

SQUARE ROOT SUM OF THE SQUARES

$$\sigma_F = \left[853.32^2 + 700.10^2 + 270.85^2 \right]^{1/2} = 1136.51 \text{ PSI}$$

$$\tau_F = \left[85.97^2 + 85.97^2 + 0^2 \right]^{1/2} = 121.58 \text{ PSI}$$

$S_u = 30,000$ PSI GRADE 30 CAST IRON

NOTCHED FATIGUE STRENGTH GRADE 30 CI. = 13,500 PSI

$$\sigma_F = 1136.51 < 0.6(30,000) = 18,000 \text{ PSI}$$

< 13,500 PSI NOTCHED FATIGUE STRENGTH

$$\tau_F = 121.58 \text{ PSI} < 0.4(30,000) = 12,000 \text{ PSI}$$

< 13,500 NOTCHED FATIGUE STRENGTH

- STRESSES ON THE FOLLOWING COMPONENTS ARE GOVERNED BY THE OPERATING LOADS AND NOT THE DESIGN BASIS EARTH QUAKE CONDITIONS.

EXAMPLES : SCOTCH YOKE, CONNECTING PINS, SHAFT, PISTON

SCOTCH YOKE:

OPERATING SPRING LOADS APPROX = 257#

$$\text{SEISMIC LOADS} = (8.2)(4.10'') = 33.62\#$$

$$\text{ALLOWABLE STRESSES} \quad \frac{257}{1.0} \geq \frac{257+33.62}{1.5}$$

$$\underline{\underline{257 \geq 193.75}}$$

∴ NO DETAILED ANALYSIS REQUIRED

FOR INFORMATION ONLY

CALC No:
DCR No: M84-11





Sheet 19 of 19A

DESIGN/REVIEW COMMENTS SHEET.

DESIGN VERIFICATION

ALTERNATE CALCULATIONS

FOR INFORMATION ON

NO.	COMMENT	RESOLUTION/APPROVAL
	No Comments	<div><div> Design Engineer</div><div> Verifying Engineer</div><div> Technical Group Leader</div><div> Supervising Engr. Nuclear Projects</div></div> <div><div>4/25/84 Date</div><div>4-26/84 Date</div><div>4/30/84 Date</div><div>30 April 1984 Date</div></div>

IOWA ELECTRIC LIGHT AND POWER COMPANY

DUANE ARNOLD ENERGY CENTER

CALCULATION COVERSHEET

FOR INFORMATION ON

ANALYSIS/CALCULATION NO: M24-12

ANALYSIS/CALCULATION TITLE: SEISMIC STRESS ANALYSIS
HILLS-MCCANNA DAMPER ACTUATORS R-450 FS

REFERENCE DOCUMENTS

MAR NO: _____

DCR NO: _____

OTHERS: DDC 769

PREPARED BY: Donald W. Churd DATE: 4/19/84

REVIEWED BY: W. J. P. H. DATE: 4-19/84

APPROVED BY: Mike McDevitt DATE: 4/30/84

FINAL APPROVAL BY: A. J. Macintosh DATE: 30 APRIL

Background

The purpose for compiling calculations M84-11, 12, 13, 14, 15 was to perform a seismic analysis on the critical components of the Hills-McCanna Pneumatic Damper Actuators. These actuators are part of the secondary containment isolation system at the Duane Arnold Energy Center.

On January 26, 1984, Iowa Electric notified the NRC by telephone that the above mentioned actuators were potentially deficient in meeting their purchase specification. A review of the documents relating to this discrepancy revealed that the isolation damper assemblies were purchased originally as complete assemblies which included the damper actuators. Subsequent orders for "like-for-like" replacement actuators were placed directly with the actuator manufacturer who was a subvendor to the damper manufacturer. This most recent purchase order for actuators revealed that a quality assurance program, as required for safety related equipment per 10CFR Part 50, is not currently in effect at the actuators manufacturer's facility.

Further review of the damper assembly documentation revealed that the seismic analysis performed on the damper assemblies did not seismically analyze the actuators themselves, but only considered their weight as it seismically affected the damper frame. This information prompted Iowa Electric to audit the damper manufacturer and check for documentation that pertained to the seismic qualifications of the isolation damper actuators. Results from the audit of the damper manufacturer revealed that the actuators were never purchased by the damper manufacturer as seismically qualified components nor did the damper manufacturer administer a Quality Assurance program concerning the purchase of the actuators.

Since no traceability or Certificate of Conformance was available for the seismic qualifications of the actuators, a seismic analysis was performed on the critical components of the actuators in order to seismically qualify the damper actuators for use in the Duane Arnold Energy Center. This seismic analysis followed the guidelines set forth in the original purchase specification for the isolation dampers (ref. Bechtel 7884-M-100). By seismically qualifying the isolation damper actuators, Iowa Electric will be able to buy Quality Level I actuators in accordance with Revision 1, Chapter 4 of the Quality Assurance Manual under Standard Industrial Quality Items 4.7.3.

Solution

A seismic analysis was performed on five models of the Rockwell Hills-McCanna Ramcon Pneumatic Actuator product line that are installed as isolation damper actuators at the Duane Arnold Energy Center. These five models include the following:

- R-260 FS
- R-450 FS
- R-960 FS
- R-2000 FS
- R-4200 FS

The seismic analysis on the actuators followed the general project seismic requirements for frequency-not-determined class 1 equipment in the reactor building and in the control building (ref. Bechtel 7884-M-100, Technical Specifications for Isolation Dampers for the Duane Arnold Energy Center Unit 1, Revision 0, 12-28-70).

A visual inspection of all isolation damper actuators at the Duane Arnold Energy Center was made in order to verify model number, serial number and elevation location in the plant. After verifying the elevation location in the plant, static coefficients (g units) were determined for the highest installed actuator for each of the five actuator models. The horizontal static coefficient was then applied to all three of the orientation axis which eliminated many repetitious calculations and the need for detailed actuator orientation information. Applying the horizontal static coefficient to each axis provided conservative results since the horizontal coefficient is always greater than one plus the vertical coefficient ($F_{\text{vertical}} = (\text{Weight}) (1 + g_v)$, $F_{\text{horizontal}} = (\text{Weight}) (g_h)$, $g_h > 1 + g_v$).

The seismic analysis concentrated on the critical areas of the damper actuator where the seismically induced loads could possibly make the actuator fail, malfunction, or prevent operation. Five areas on each actuator model were identified as critical areas requiring a seismic analysis of the various components interfacing with that critical area. These five critical areas are identified as the following:

- Retaining key which holds the spring cylinder assembly to the main body cylinder
- Main body cylinder
- Press fit between main body cylinder and the mounting yoke
- Mounting hardware
- Mounting yoke

Dimensions and material specifications for the seismic analysis were obtained through the use of proprietary component drawings that were on loan to Iowa Electric from Rockwell Hills-McCanna of Carpentersville, Illinois. All prints applicable to this seismic analysis are listed in the reference section of the referenced calculations.

Four basic assumptions are applied throughout the entire seismic analysis of the damper actuators. These assumptions allow Iowa Electric to use the floor response spectra as the design/qualification spectra for the seismic analysis. The four basic assumptions are as follows:

- The mounting of the damper is a rigid structure ($f > 33$ cps)
- The damper itself is a rigid structure ($f > 33$ cps)
- The support bracket for the actuator is a rigid structure ($f > 33$ cps)
- The seismic requirements for evaluating the actuators are the same as those for the isolation dampers.

The maximum seismic stresses were calculated by using the square root sum of the squares method for combining the three earthquake direction stresses as recommended in the UFSAR for seismic analysis at the Duane Arnold Energy Center. A second method, the distortion energy method was used for combining stresses at the press fit between the main body cylinder and the mounting yoke. The distortion energy method was used in place of the square root sum of the squares method because the stresses due to the press-fit condition exceeded and dominated those caused by the seismic event. All maximum stresses were then compared to some fraction of the yield strength depending on the material type and stress type. Operability after a DBE event was ensured by requiring that the maximum stress from combined seismic and normal loads should not exceed 90% of the yield stress of the material.

Conclusion

After completing the above described seismic analysis on the five models of Hills-McCanna actuators installed on the isolation dampers at the Duane Arnold Energy Center, it was found that the maximum stresses from the combined seismic and normal loads do not exceed the material yield requirements defined in the isolation damper purchase specification. The results of this seismic analysis reveal that the five models of Hills-McCanna actuators are seismically qualified for use at the Duane Arnold Energy Center.

References

Bechtel Purchase Specification 7884-M-100

Formulas for Stress and Strain; Raymond J. Roark, Warren C. Young, Fifth Edition, McGraw-Hill Book Co. 1975

Hills-McCanna Information Bulletins; R-1090, R-1090A, R110C, R1100A, R-111C, R-1110A, R-112D, R-1120A, R-113D, R-1130A

Marks' Standard Handbook for Mechanical Engineers' Baumeister Eighth Edition, McGraw-Hill Book Company 1978

Materials Selector 75; Reinhold Publishing Co. Mid September 1974, Vol. 80, No. 4, Brown Printing Co.

Mechanical Engineering Design; Joseph E. Shigley, Third Edition, McGraw-Hill Book Co. 1977

Mechanics of Materials; Higdon, Ohlsen, Stiles, Weese, Riley Third Edition, John Wiley and Sons 1978

FOR INFORMATION ONLY

Rockwell Hills-McCanna; Proprietary Drawings

DATA: Information contained on drawings is proprietary and confidential and is not to be given or loaned to others. Drawings are to be returned to Rockwell upon completion of their intended use in making the seismic analysis.

<u>R260</u>	<u>R450-R960</u>	<u>R2000-R4200</u>
430-1004	450-7511	460-7511
430-7510	450-1005	460-1001
430-7511	450-7512	460-7509
430-3003	450-3005	460-3001
430-3005	450-3007	460-3003
430-4101	450-4101	460-4101
430-4102	450-4102	460-4102
430-2101	450-2101	460-2101
430-2904	450-2906	460-2904
430-2502	450-2507	460-2503
430-2501	450-2501	460-2502
430-3321	450-3201	460-3208
430-3322	450-3202	460-3209
430-3325	450-3203	460-3210
430-3201	450-3326	460-3317
430-3202	450-3325	460-3316
430-8203	450-3321	460-3320
	450-3320	460-3321
		460-3314
		460-3315

U.S.S. Steel Design Manual; R.L. Brockenbrough and B.G. Johnson, Jan.
1981

POSITION Senior Civil/Structural Engineer

EDUCATION BS, Civil Engineering, University of Michigan
MS, Civil/Structural Engineering, University of Michigan

PROFESSIONAL DATA Registered Professional Engineer in Michigan

SUMMARY 1 year: Senior Engineer; Civil/Structural Staff
4 years: Senior Engineer; Midland, Palisades, and Big Rock Point Nuclear Power Plants
1 year: Resident Engineer, Midland Nuclear Power Plant

EXPERIENCE

Mr. Reifschneider is currently assigned as a civil/structural engineer on the civil/structural staff. His duties include; preparation of design standards; review of project calculations, drawings, specifications and seismic qualification of equipment; providing consultation to civil/structural engineers engaged in the design of nuclear and fossil power plants; solving special static and dynamic structural problems.

Prior to joining the civil/structural staff, Mr. Reifschneider was a civil/structural engineer on Consumers Power Company's Palisades project. His duties included finite element analysis of the biological shield wall, seismic analysis and design of blockwall supports, and seismic analysis and design of the auxiliary building addition including the review of seismic equipment qualifications.

Prior to joining the Palisades project, Mr. Reifschneider was a civil/structural resident engineer at the jobsite of Consumers Power company's Midland nuclear plant project. His duties included interfacing with construction personnel on the design, erection, and construction of seismic instrument and equipment supports.

FOR INFORMATION ONLY

MARTIN REIFSCHNEIDER Reviewer for Calculations M84-11,12,13,14,15

Prior to his jobsite assignment, Mr. Reifschneider conducted research on the inelastic design and behavior of braced structural steel systems, moment frame structural steel system, and reinforced concrete shear wall systems. He co-authored three Bechtel reports on the findings of this research.

Prior to his research assignment, Mr. Reifschneider was a civil/structural engineer on the Midland nuclear plant project. His duties included designing seismic supports for HVAC ducts and electrical cabletrays.

FOR INFORMATION ONLY

IOWA ELECTRIC LIGHT
AND POWER COMPANY
CEDAR RAPIDS, IOWA

DEPT. DESIGN ENGINEERING

PROJECT DUANE ARNOLD ENERGY CENTER Sheet No. VII of VIII

SUBJECT SEISMIC ANALYSIS HILLS-MCCANNA ACTUATORS

Computed by DW Date Checked by Date

SUMMARY OF RESULTS R-450 FS

FOR INFORMATION ONLY

<u>COMPONENT</u>	<u>MANUFACTURED MATERIAL</u> <u>ALLOWABLE STRESS</u>	<u>LOW GRADE MATERIAL</u> <u>ALLOWABLE STRESS</u>	<u>* CALCULATED STRESS (σ_F, γ_F)</u> <u>STRESS COMPARISON</u>
<u>RETAINING KEY</u>	303 STAINLESS STEEL $S_{YA} = (0.5)S_Y$ $S_{YA} = 17500 \text{ psi}$	NOT APPLICABLE NOT APPLICABLE	$\gamma_F = 1019 \text{ psi}$ <u>$1019 < 17500$</u>
<u>MAIN BODY CYLINDER</u> OUTSIDE SURFACE INSIDE SURFACE	<u>1020 STEEL</u> $S_{YA} = (0.9)(S_Y)$ $S_{YA} = 43200 \text{ psi}$	<u>1006 STEEL</u> $S_{YA} = (0.9)(S_Y)$ $S_{YA} = 36900$	$\sigma_F = 12317 \text{ psi}$ <u>$12317 < 36900$</u> $\sigma_F = 12791 \text{ psi}$ <u>$12791 < 36900$</u>

MOUNTING HARDWARE

1/2-13 BOLTS

A307 GRADE 1 BOLT

$\sigma_A = 20000 \text{ psi}$
 $\tau_A = 10000 \text{ psi}$

$\sigma_F = 6019$

$\gamma_F = 3765$

NOTE: LOWEST GRADE BOLT ASSUMED INSTALLED

BASIS FOR COMPARISON: $\frac{\gamma_F}{\tau_A} + \frac{\sigma_F}{\sigma_A} \leq 1.5$ FOR DBE CONDITIONS

$0.677 < 1.5$

* CALCULATED STRESS USING SRSS OF THE EARTHQUAKE DIRECTIONS OR MAXIMUM DISTORTION ENERGY THEORY.

IOWA ELECTRIC LIGHT AND POWER COMPANY CEDAR RAPIDS, IOWA	DEPT. <u>DESIGN ENGINEERING</u>
	PROJECT <u>DUANE ARNOLD ENERGY CENTER</u> Sheet No. <u>VIII</u> of <u>VIII</u>
	SUBJECT <u>SEISMIC ANALYSIS HILLS-MCCANNA ACTUATORS</u>
	Computed by <u>(Signature)</u> Date _____ Checked by _____ Date _____

SUMMARY OF RESULTS CONTINUED R-450 FS

<u>COMPONENT</u>	<u>MANUFACTURED MATERIAL</u>	<u>LOW GRADE MATERIAL</u>	<u>*CALCULATED STRESS</u>
	<u>ALLOWABLE STRESS</u>	<u>ALLOWABLE STRESS</u>	<u>STRESS COMPARISON</u>
<u>BODY CASTING</u> <u>(MOUNTING</u> <u>YOKE)</u>	CLASS 35 CAST IRON $S_{YA} = (0.6)(S_u)$ $S_{YA} = 18000 \text{ psi}$ $S_{YA} = (0.4)(S_u)$ $S_{YA} = 12000 \text{ psi}$	CLASS 20 CAST IRON $S_{YA} = (0.6)(S_u)$ $S_{YA} = 12000$ $S_{YA} = (0.4)(S_u)$ $S_{YA} = 8000 \text{ psi}$	$\sigma_F = 2575 \text{ psi}$ $\tau_F = 1113 \text{ psi}$ <u>$2575 < 12000$</u> <u>$1113 < 8000$</u>
<u>PRESS FIT</u> <u>BETWEEN</u> <u>MAIN CYLINDER</u> <u>AND MOUNTING</u> <u>YOKE</u>	CAST IRON - 1020 STEEL MINIMUM INTERFERENCE = 0.001 FORCE REQUIRED TO SLIDE CYLINDER FROM MOUNTING YOKE = 1349 #		RESULTANT AXIAL FORCE = 418 # <u>$418 < 1349$</u>

FOR INFORMATION ONLY

R-450 FS

WEIGHT DETERMINATION

FOR INFORMATION ONLY

CYLINDER - SPRING CYLINDER (R-450, R-960)

$$D_o = 5.50"$$

$$D_i = 4.87"$$

$$h = 9.67"$$

$$\rho = 0.283 \frac{\#}{\text{IN}^3}$$

$$\text{VOLUME} = \frac{\pi(D_o^2 - D_i^2)h}{4}$$

$$\text{VOLUME} = \frac{\pi(5.50^2 - 4.87^2)(9.67)}{4} = 49.62 \text{ IN}^3$$

$$\text{WEIGHT} = (49.62 \text{ IN}^3)(0.283) = 14.04 \#$$

REFERENCE: 450-7512

MAIN BODY CYLINDER (R-450)

$$D_o = 5.86"$$

$$D_i = 5.27"$$

$$h = 14.204"$$

$$\rho = 0.283 \frac{\#}{\text{IN}^3}$$

$$\text{VOLUME} = \frac{\pi(5.86^2 - 5.27^2)(14.204)}{4}$$

$$\text{VOLUME} = 73.26 \text{ IN}^3$$

$$\text{WEIGHT} = (73.26 \text{ IN}^3)(0.283) = 20.73 \#$$

REFERENCE: 450-3325

END CAP (SPRING CYLINDER) (R-450, R-960)

$$D_1 = 5.138"$$

$$D_2 = 2.11"$$

$$\rho = 0.283 \frac{\#}{\text{IN}^3}$$


$$\text{VOLUME} = \frac{\pi(5.138^2)(0.75)}{4} - \frac{\pi(5.138^2 - 2.11^2)(0.28)}{4}$$

$$\text{VOLUME} = 10.72 \text{ IN}^3$$

$$\text{WEIGHT} = (10.72 \text{ IN}^3)(0.283 \frac{\#}{\text{IN}^3}) = 3.03 \#$$

REFERENCE: 450-1005

R-450 FS




X 2.27 DEEP

WEIGHT DETERMINATION PISTON (R-450, R-460)

$$\frac{1}{2.27} V = \pi (2.632)^2 \left(\frac{\sin^{-1} \frac{1.375}{2.632}}{180} \right) - (1.375)(2.244)$$

$$V = 1.64 \text{ in}^3$$


REFERENCE: 450-3202
450-3203



X 3.75 DEEP


$$V = 3.75 \left[\frac{1}{2} (1.512)(2.27) + 2.27(2.876 - 1.512) \right]$$

$$V = 18.047 \text{ in}^3$$



$$A = 0.7225 - 0.388(1.286)$$

$$A = 0.223 \text{ in}^2$$



X 5.2 DEEP

$$V = \left[2(1.232)(2.876) + 0.223 \right] 5.2 = 38.009 \text{ in}^3$$

$$\text{VOLUME PISTON HEAD} = \pi (2.632)^2 (1) + \pi (1.6225)^2 (0.03) - \pi (2.632^2 - 2.402^2) (0.378)$$

$$V_H = 20.637 \text{ in}^3$$

$$\text{VOLUME OF MACHINED HOLES} = \pi \left(\frac{0.437}{2} \right)^2 (2.464) = 0.37 \text{ in}^3$$

$$\text{TOTAL VOLUME} = 1.64 + 18.047 + 38.009 + 20.637 - 0.37 = 77.96 \text{ in}^3$$

$$\text{DENSITY } \rho = 0.26 \frac{\text{lb}}{\text{in}^3} \text{ WEIGHT} = PV_T = (77.96 \text{ in}^3) (0.26 \frac{\text{lb}}{\text{in}^3}) =$$

$$\text{WEIGHT} = 20.27 \text{ lb}$$

IOWA ELECTRIC LIGHT
AND POWER COMPANY
CEDAR RAPIDS, IOWA

DEPT. DESIGN ENGINEERING CALC ME-4-12
PROJECT DWANE ARNOLD ENERGY CENTER Sheet No. 3 of 19
SUBJECT SEISMIC STRESS ANALYSIS HILLS-McCANN A CTUATORS
Computed by DR Date _____ Checked by MR Date _____

R-450 ES (R-450)

WEIGHT DETERMINATION

END CAP (MAIN CYLINDER)

$$D_o = 5.438"$$

$$h = 1"$$

$$l = 0.283 \text{ in}^3$$

$$\text{Volume} = \frac{\pi (5.438)^2 (1)}{4} = 22.46 \text{ in}^3$$

$$\text{WEIGHT} = (22.46)(0.283) = 6.36 \#$$

SPRINGS (R-450, R-960)

$$\text{SPRING}_1 = 3.34 \#$$

$$\text{SPRING}_2 = 9.64 \#$$

NESTED SPRINGS

$$\text{TOTAL SPRING WEIGHT} = 12.98 \#$$

REFERENCE: PRINT A-450-3007
A-450-3005

FOR INFORMATION ONLY


IOWA ELECTRIC LIGHT AND POWER COMPANY CEDAR RAPIDS, IOWA	DEPT. <u>DESIGN ENGINEERING</u>	CALC <u>M44-12</u>
	PROJECT <u>DUANE ARNOLD ENERGY CENTER</u>	Sheet No. <u>4</u> of <u>19</u>
	SUBJECT <u>SEISMIC STRESS ANALYSIS HILLS-MCCANNA ACTUATOR</u>	
	Computed by <u>CR</u>	Date _____
	Checked by <u>MR</u>	Date _____

R-450 FS

HORIZONTAL g LOADS

	REFERENCE: <u>BECHTEL 7884-M-100</u>	OBE	DBE
IV-AO-42 A & B	REACTOR BUILDING ELEVATION 776	2.7	5.4
IV-AO-44 A & B	CONTROL BUILDING ELEVATION 786	1.7	3.3

- MAXIMUM HORIZONTAL (g) LOAD FOR WORST CASE ACTUATOR ELEVATION APPLIED TO ALL AXIS OF SEISMIC ANALYSIS. HORIZONTAL (g) LOAD IS GREATER THAN (1+g) LOAD ON VERTICAL.
- MAXIMUM AIR PRESSURE = 100 PSI ACTING ON PISTON 5.27" DIA
SHEAR STRESS ON THE RETAINING KEY
AXIAL ORIENTATION.



$$\begin{aligned}
 M_1 (\text{END CAP}) &= 3.03 \# \\
 M_2 (\text{SPRING CYL}) &= 14.04 \# \\
 M_3 (\text{SPRING}) &= 12.98 \# \\
 M_4 (\text{PISTON}) &= 20.27 \# \\
 \hline
 &= 50.32 \#
 \end{aligned}$$

$$g = 5.4$$

SPRING TEST LENGTHS (NESTED SPRINGS)

A-450-3005 @ 12.22" = 501 # WITH 115 lb/in RATE
 A-450-3007 @ 12.16" = 151 # WITH 35 lb/in RATE
 9.6" MAXIMUM SPRING COMPRESSION LENGTH
 WITH PISTON AT STOP.

$$F_{\text{SPRING}} = 151 \# + 35(12.16 - 9.60) + 501 + 115(12.22 - 9.60) = 1043 \#$$


$$F_{\text{MASS}} = 5.4(50.32) = 271.73 \#$$

$$F_{\text{AIR PRESSURE}} = \frac{(100 \text{ PSI})(\pi)(5.27)^2}{4}$$

$$F_{\text{AP}} = 2181.3 \#$$

$$F_{\text{TOTAL}} = 272 + 1043 + (2181.3 - 1043) = 2453.3 \#$$

ON CROSS SECTION OF RETAINING KEY.

RETAINING KEY  WITH APPROX 16" CIRCUMFERENTIAL ACTIVE LENGTH
 303 STAINLESS \rightarrow \leftarrow 0.187 SQUARE

$$\tau = F/A = \frac{2453.3}{0.187(16)} = 820 \text{ PSI}$$

YIELD STRENGTH OF 303 SS
 $S_y = 35000 \text{ PSI}$
 SHEAR STRENGTH S_n
 $S_n = 0.5 S_y = (0.5)(35000)$
 $S_n = 17500 \text{ PSI}$

$$\underline{820 \text{ PSI} \ll 17500 \text{ PSI}}$$


ALLOWABLE SHEAR STRENGTH = 17500 PSI

FOR INFORMATION ONLY

R-450 FS

FOR INFORMATION ONLY

STRESS ON THE RETAINING KEY FROM MOMENT
CAUSED BY THE SPRING CYLINDER ASSEMBLY




M MOMENT ABOUT RETAINING KEY &

$$M = 4.14 (M_2 + M_3) g + 9.21 (M_1) g$$

$$M = 4.14 (14.04 + 12.98) 5.4 + 9.21 (3.03) 5.4$$

$$M = 754.8 \text{ IN-LB}$$

* THETA (θ) IS THE ANGLE THAT CORRESPONDS
TO THE RETAINING RING GAP FOR ONE QUADRANT
GAP IS DIVIDED INTO TWO EQUAL PARTS AT +Y AND -Y



Y axis

LINEAR RELATIONSHIP
Y VS. F_s

RETAINING KEY ACTIVE LENGTH = 4" / QUAD

F_s = SHEAR FORCE

$$c = \frac{2\pi(2.632)}{4} = 4.1343$$

$$\theta = \frac{4}{4.1343} \times \frac{\pi}{2} = 1.519$$

SHEAR STRESS = $\gamma(\theta)$

t = THICKNESS RETAINING RING

$$t = 0.187"$$

$$r = 2.632"$$

$$M = 754.8 \text{ IN-LB}$$

$$\theta = 1.52$$

$$\int_0^{1.52} \gamma(\theta) t r^2 \sin \theta d\theta = \frac{M}{4}$$

$$\gamma(\theta) = K r \sin \theta$$

$$\int_0^{1.52} K t r^2 \sin^2 \theta d\theta$$

$$\int_0^{\theta} \sin^2 \theta d\theta = \left[-\frac{1}{4} \sin 2\theta + \frac{1}{2} \theta \right]_0^{\theta} = -\frac{1}{4} \sin 2(1.52) + \frac{1.52}{2} = 0.735$$

$$\frac{M}{4} = K t r^2 (0.735)$$

$$K = \frac{(754.8)}{(4)(0.187)(2.632)^2(0.735)}$$

$$K = 75.30$$

$$\gamma(\theta) = (75.30)(2.632) \sin\left(\frac{\pi}{2}\right) = 198.2 \text{ PSI}$$

$$\gamma_{\text{TOTAL}} = \gamma(\theta) + \gamma = 820 + 198.2 = 1018.19 \text{ PSI}$$

$$1018.19 < 17500 \text{ PSI}$$

R-450 FS

FOR INFORMATION ONLY


STRESSES DUE TO THE PRESS FIT CONDITIONS BETWEEN THE YOKE AND THE CYLINDER BODY

- REFERENCE HIGDON "MECHANICS OF MATERIALS"
JOHN WILEY & SONS 1978 PG. 164, 163

$$I (\text{INTERFERENCE}) = 0.005" = 2 \delta_1 + 2 \delta_2$$

$$\delta_1 = \frac{b_1^2 P_i}{(c^2 - b_1^2) E_Y b_1} \left[(1-\nu) b_1^2 + (1+\nu) c^2 \right]$$

$$\delta_2 = \frac{b_2^2 P_s}{(b^2 - a^2) E_C b_2} \left[(1-\nu) b_2^2 + (1+\nu) a^2 \right]$$



$$\begin{aligned} a &= 2.6375 \\ b &= 2.9205 & b_2 &= 2.923 \\ c &= 3.435 \end{aligned}$$

SOLVE FOR P_s INTERFACIAL PRESSURE

$$\begin{aligned} 0.005 &= 2 \left[\frac{(2.9205)^2 P}{[3.435^2 - 2.9205^2] (15 \times 10^6) (2.9205)} \right] \left[(1-0.29)(2.9205)^2 + (1+0.29)(3.435)^2 \right] \\ &+ 2 \left[\frac{(2.923)^2 P}{(2.923^2 - 2.6375^2) (30 \times 10^6) (2.923)} \right] \left[(1-0.3)(2.923)^2 + (1+0.3)(2.6375)^2 \right] \end{aligned}$$

$$0.005 = 2.533 \times 10^{-6} P + 1.8442 \times 10^{-6} P$$

$P = 1142$ PSI (MAXIMUM INTERFERENCE)
EXTERNAL PRESSURE INTERNAL PRESSURE

$$\sigma_r = -\frac{b^2 P_o}{b^2 - a^2} \left(1 - \frac{a^2}{r^2} \right)$$

$$\sigma_r = \frac{a^2 P_i}{b^2 - a^2} \left(1 - \frac{b^2}{r^2} \right)$$

$$\sigma_t = -\frac{b^2 P_o}{b^2 - a^2} \left(1 + \frac{a^2}{r^2} \right)$$

$$\sigma_t = \frac{a^2 P_i}{b^2 - a^2} \left(1 + \frac{b^2}{r^2} \right)$$

R-450 FS

FOR INFORMATION ONLY

STRESS IN BODY CASTING INTERNAL PRESSURE

$$\sigma_r = \frac{(2.9205)^2(1142)}{(3.435^2 - 2.9205^2)} \left(1 - \frac{(3.435^2)}{(2.9205^2)} \right) = -1112 \text{ PSI}$$

$$\sigma_t = \frac{(2.9205)^2(1142)}{(3.435^2 - 2.9205^2)} \left(1 + \frac{3.435^2}{2.9205^2} \right) = 7100 \text{ PSI}$$

STRESS IN CYLINDER EXTERNAL PRESSURE

OUTSIDE CYLINDER SURFACE

$$\sigma_r' = - \frac{(2.923)^2(1142)}{(2.923^2 - 2.6375^2)} \left(1 - \left(\frac{2.6375^2}{2.923^2} \right) \right) = -1143 \text{ PSI}$$

$$\sigma_t' = - \frac{(2.923)^2(1142)}{(2.923^2 - 2.6375^2)} \left(1 + \left(\frac{2.6375^2}{2.923^2} \right) \right) = -11150 \text{ PSI}$$

INSIDE CYLINDER SURFACE


$$\sigma_r = - \frac{(2.923)^2(1142)}{(2.923^2 - 2.6375^2)} \left(1 - \frac{2.6375^2}{2.6375^2} \right) = 0 \text{ PSI}$$

$$\sigma_t = - \frac{(2.923)^2(1142)}{(2.923^2 - 2.6375^2)} \left(1 + \frac{2.6375^2}{2.6375^2} \right) = -12292 \text{ PSI}$$

R-450 FS

FOR INFORMATION ONLY

STRESS ON THE CYLINDER DUE TO MOMENT CAUSED
BY MAIN BODY CYLINDER, PISTON, SPRING CYLINDER AND
END CAP



$$\begin{aligned} M_1(\text{END CAP}) &= 3.03 \text{ \#} \\ M_2(\text{SPRING CYL}) &= 14.04 \text{ \#} \\ M_3(\text{SPRING}) &= 12.98 \text{ \#} \\ M_4(\text{PISTON}) &= 20.27 \text{ \#} \\ M_5(\text{MAIN CYL}) &= 20.73 \text{ \#} \\ M_6(\text{MAIN END CAP}) &= 6.36 \text{ \#} \end{aligned}$$

- MASS OF CYLINDER IS MODELLED TO ACT ON RIGHT SIDE OF YOKE. EXCLUDES COUNTERACTING MOMENT DUE TO MASS OF CYLINDER ON LEFT SIDE OF YOKE & CONSERVATIVE RESULTS
- M_6 (MAIN CYLINDER END CAP) COUNTERACTING MOMENT IS NEGLECTED. THIS PROVIDES CONSERVATIVE RESULTS.

SUMMING MOMENTS ABOUT X-X

$$\begin{aligned} M_{xx} &= (5.4)(20.73)(3.875) + (5.4)(20.27)(4.25) + (5.4)(14.04 + 12.98)(18.01) \\ &\quad + (5.4)(3.03)(23.315) = 3908.25 \text{ IN-LB} \end{aligned}$$

MOMENT OF INERTIA @ AXIS X-X NEUTRAL AXIS C

$$I = \frac{\pi}{64} (d_o^4 - d_i^4) = \frac{\pi}{64} (5.860^4 - 5.275^4)$$

$$I = 19.88 \text{ IN}^4$$

$$\sigma = \frac{M_c}{I}$$

$$c = 2.93"$$

$$\sigma = \frac{(3908.25)(2.93)}{19.88} = 576 \text{ PSI}$$

STRESSES DUE TO AIR PRESSURE ACTING ON PISTON


$$\text{FORCE AIR PRESSURE} = \frac{(100 \text{ PSI}) \pi (5.27)^2}{4} = 2181.3 \text{ \#}$$

$$\sigma_{\text{AIR PRESSURE}} = \frac{2181.3 \text{ \#}}{\pi (5.860^2 - 5.275^2) / 4} = 426.4 \text{ PSI}$$

R-450 FS

FOR INFORMATION ONLY

CYLINDER STRESSES CONTINUED



$$\text{MOMENT} = 3908.3 \text{ IN-LB}$$

$$C = \frac{5.27}{2} = 2.635"$$

$$\sigma_b' = \sigma_{AP} + \sigma_T = 426.4 + 576 = 1,002.4 \text{ PSI}$$

$$C = \frac{5.86}{2} = 2.93"$$

$$\sigma_b = \sigma_{AP} + \sigma_T = 426.4 + \frac{(3908.3)(2.635)}{19.88} = 944.4 \text{ PSI}$$

$$I = 20.02 \text{ IN}^4$$

$$\sigma_t' = -11150 \text{ PSI}$$

$$\sigma_t = -12292 \text{ PSI}$$

$$S_y \text{ OF } 1020 \text{ STEEL} = 48000 \text{ PSI}$$

$$\sigma_r' = -1143 \text{ PSI}$$

$$90\% S_y = (0.9)(48000) = 43200 \text{ PSI}$$

$$\sigma_r = 0 \text{ PSI}$$

SUMMATION OF STRESSES USING MAXIMUM
DISTORTION ENERGY THEORY

• REFERENCE MECHANICS OF MATERIALS Pg 489

$$\sigma_f = \left\{ \frac{1}{2} \left[(\sigma_b - \sigma_t)^2 + (\sigma_t - \sigma_r)^2 + (\sigma_r - \sigma_b)^2 \right] \right\}^{1/2}$$

$$\sigma_f = \left\{ \frac{1}{2} \left[(944.4 - 12292)^2 + (-12292 - 0)^2 + (0 - 944.4)^2 \right] \right\}^{1/2}$$

$$\sigma_f = 12790.50 \text{ PSI} < 43,200 \text{ PSI}$$



$$\sigma_f' = \left\{ \frac{1}{2} \left[(1002.4 + 11150)^2 + (-11150 + 1143)^2 + (-1143 - 1002.4)^2 \right] \right\}^{1/2}$$

$$\sigma_f' = 12316.7 \text{ PSI} < 43,200 \text{ PSI}$$

R-450 FS

FOR INFORMATION ONLY

SEISMIC AXIAL LOAD ACTING ON PRESS FIT
OF CYLINDER THROUGH THE MOUNTING YOKE



MINIMUM INTERFERENCE ON RADIUS

$$I = \frac{5.843}{2} - \frac{5.844}{2} = 0.0005 \text{ INCH}$$

REFERENCE PRINTS 450-3321

450-3325

ON DIAMETER $I = 0.001$

MINIMUM PRESSURE FROM PRESS FIT WITH
MINIMUM INTERFERENCE

SOLVING FOR MINIMUM PRESSURE (P) - Pg 164 MECHANICS OF MATLS.

$$0.001 \text{ IN} = 2 \left[\frac{(2.9215)^2 P}{\{(3.435^2 - 2.9215^2)(15 \times 10^6)(2.9215)\}} \right] \left[(0.7)(2.9215)^2 + (1.29)(3.435)^2 \right] \\ + 2 \left[\frac{(2.922)^2 P}{\{(2.922^2 - 2.635^2)(30 \times 10^6)(2.922)\}} \right] \left[(0.7)(2.922)^2 + (1.3)(2.635)^2 \right]$$

$$0.001 = 2.5392 (10)^{-6} P + 1.8324 (10)^{-6} P$$


$$0.001 = P(4.371)10^{-6}$$

$$P = 229 \text{ PSI}$$

R-450 FS

DETERMINATION OF AXIAL LOAD

FOR INFORMATION ONLY



$$M_T = M_1 + M_2 + M_3 + M_4 + M_5 + M_6$$

$$M_1 \text{ (END CAP)} = 3.03 \#$$

$$M_2 \text{ (SPRING CYL)} = 14.04 \#$$

$$M_3 \text{ (SPRING)} = 12.98 \#$$

$$M_4 \text{ (PISTON)} = 20.27 \#$$

$$M_5 \text{ (MAIN CYL)} = 20.73 \#$$

$$M_6 \text{ (MAIN CYL. END CAP)} = 636 \#$$

$$M_{\text{TOTAL}} = 77.41 \#$$

$$\text{AXIAL FORCE} = F_A = M_T(g) = (77.41 \#)(5.4) = 418.0 \#$$

FORCE REQUIRED TO SLIDE CYLINDER FROM MOUNTING YOKE

$$F = \pi f P d l$$

REFERENCE: MARKS HANDBOOK
8-47

l = LENGTH OF FIT = 3.21

d = CYLINDER DIAMETER = 5.841

P = 229 PSI

P = UNIT PRESSURE FIT PRESSURE BETWEEN CYLINDER AND YOKE.

f = COEFFICIENT OF FRICTION AVERAGE RANGE 0.10 → 0.15

USE $f = 0.10$


$$F = \pi (0.10)(229)(5.841)(3.21) = 1349 \#$$

$$\underline{\underline{1349 \# > 418.0 \#}}$$

R-450 FS

FOR INFORMATION ONLY

SEISMIC LOADINGS ON MOUNTING HARDWARE



(g_z) LOADING

M_A = MASS OF ACTUATOR INCLUDING
MOUNTING YOKE = 104 #


$$\text{MOMENT ABOUT (Y)} = (M_A)(g)(x)$$

$$M_y = (104)(5.4)(4.12) = 2313.8 \text{ IN-LB}$$

$$M_y = (2)(F_T)(3.5)$$

2F_T = TENSION FORCE
IN TWO TOP BOLTS

$$F_T = \frac{2313.8}{(2)(3.5)} = 330.5 \text{ #}$$



1/2-13 BOLT EFFECTIVE AREA = 0.1419 in²

TENSILE STRESS AREA Pg 230
SHIGLEY MECH. ENG DESIGN

4.12" 4F_s = SHEAR FORCE IN (4) MOUNTING BOLT

$$F_s = \frac{(104 \text{ #})(5.4g)}{4} = 140.4 \text{ #}$$

$$\tau_{zy} = \frac{140.4 \text{ #}}{0.1419 \text{ in}^2} = 989.4 \text{ PSI}$$

REF: MECHANICS OF
MATERIALS P.36


$$\sigma_{x_f} = \frac{330.5 \text{ #}}{0.1419 \text{ in}^2} = 2329.1 \text{ PSI}$$

R-450 FS


SEISMIC LOADINGS ON MOUNTING HARDWARE

(g_y) LOADING

FOR INFORMATION ONLY




- M₁ (END CAP) = 303 #
- M₂ (SPRING CYL.) = 14.04 #
- M₃ (SPRING) = 12.98 #
- M₄ (PISTON) = 20.27 #
- M₅ (MAIN CYL.) = 20.73 #
- M₆ (MAIN CYL. END CAP) = 6.36 #



$$M_x = g(M_1)(D_1) + g(M_2)(D_2) + g(M_4)(D_4) + g(M_5)D_5 - g(M_6)D_6$$

$$M_x = 5.4 \left[(3.03)(24.94) + (14.04 + 12.98)(19.63) + (20.27)(5.87) + (20.73)(2.227) - (6.36)(4.38) \right]$$


$$M_x = 4014 \text{ IN-LB}$$



$$M_z = (104 \#)(5.4)(4.12") = 2313.8 \text{ IN-LB}$$

$$\text{FORCE (TENSION BOLT 1 AND 2)} = F_t$$

$$F_x = \frac{2313.8 \text{ IN-LB}}{(2 \text{ BOLTS})(3.5 \text{ IN})} = 331 \# \text{ TENSION}$$



$$F_{zy} = \text{SHEAR FORCE FROM TOTAL ACTUATOR MASSES}$$

$$F_{zy} = \frac{(104 \#)(5.4)}{4 \text{ BOLTS}} = 141 \#$$

$$F_{zy} = \text{SHEAR FORCE FROM MOMENT } M_x \text{ ON BOLT 2 WORST CASE BOLT}$$

$$F_{zy} = \frac{4014 \text{ IN-LB}}{(4 \text{ BOLTS})(1.75 \text{ IN})(\sqrt{2})} = 405.5 \#$$

$$\sigma_{x2} = \frac{331 \#}{0.1419} = 2333 \text{ PSI}$$

R-450 FS

FOR INFORMATION ONLY

SEISMIC LOADING OF MOUNTING HARDWARE

$$F_{SHCAR} = \left[(F_{24} + F_{21} \cos 45^\circ)^2 + (F_{21} \sin 45^\circ)^2 \right]^{1/2}$$

$$F_{SHCAR} = \left[(141 + 406 \cos 45^\circ)^2 + (406 \sin 45^\circ)^2 \right]^{1/2}$$

$$F_{SHCAR} = 515.4^\#$$

$$\gamma_{24} = \frac{F_{SHCAR}}{A_{BOLT}} = \frac{515.4^\#}{0.1419} = 3632.4 \text{ PSI}$$

g_x LOADING

$$\text{FORCE TENSION} = \frac{(104^\#)(5.4)}{4 \text{ BOLTS}} + \frac{(4014 \text{ IN-LB})}{(2 \text{ BOLTS})(3.5 \text{ IN})} = 713.8^\#$$

$$\text{BASIS OF COMPARISON } \frac{\gamma_F}{\gamma_A} + \frac{\sigma_F}{\sigma_A} \leq 1.5 \text{ FOR DBE CONDITIONS}$$

$\gamma_{\text{ALLOWABLE}}$ FOR A307 GRADE (1) BOLT = 10,000 PSI

$\sigma_{\text{ALLOWABLE}}$ FOR A307 GRADE (1) BOLT = 20,000 PSI

$$\sigma_F = \left[\sigma_{x_1}^2 + \sigma_{x_2}^2 + \sigma_{x_3}^2 \right]^{1/2} = \left[2329.1^2 + 2333^2 + 5035^2 \right]^{1/2}$$

$$\sigma_F = 6018.21 \text{ PSI}$$

$$\gamma_F = \left[\gamma_{xy_1}^2 + \gamma_{xy_2}^2 + \gamma_{xy_3}^2 \right]^{1/2} = \left[989.4^2 + 3632.4^2 + 0^2 \right]^{1/2}$$

$$\gamma_F = 3764.74 \text{ PSI}$$


$$\frac{3764.74}{10,000} + \frac{6018.21}{20,000} = 0.677$$

$$\underline{\underline{0.677 \leq 1.5}}$$

R-450 FS

SEISMIC STRESSES ON THE MOUNTING YOKE

FOR INFORMATION ONLY



$A = 6.87"$
 $B = 3.50"$
 $C = 3.25"$
 $D = 3.25"$
 $E(\text{OIA}) = 2.125"$
 $F = 5.00"$
 $G = 5.00"$
 $H = 0.12"$
 $J = 8.00"$
 $K(\text{OIA}) = 5.84"$
 $R(\text{RADIUS}) = 0.31"$

ELASTIC STRESS
IN-PLANE
BENDING

REF: FORMULAS FOR STRESS AND STRAIN
STRESS CONCENTRATION FACTORS p. 533

$$K_T = K_1 + K_2 \left(\frac{2h}{d}\right) + K_3 \left(\frac{2h}{d}\right)^2 + K_4 \left(\frac{2h}{d}\right)^3$$

$$K_1 = 1.042 + 0.982 \left(\frac{h}{r}\right)^{1/2} - 0.036 \left(\frac{h}{r}\right)$$

$$K_2 = -3.599 + 1.619 \left(\frac{h}{r}\right)^{1/2} - 0.431 \left(\frac{h}{r}\right)$$

$$K_3 = 6.084 - 5.607 \left(\frac{h}{r}\right)^{1/2} + 1.156 \left(\frac{h}{r}\right)$$

$$K_4 = -2.527 + 3.006 \left(\frac{h}{r}\right)^{1/2} - 0.631 \left(\frac{h}{r}\right)$$

g_z AND g_x

$$h = \frac{1}{2}(G-D) \quad r = H \quad d = G$$

g_y LOADING

$$h = \frac{1}{2}(G-C) \quad r = R \quad d = G$$

g_x LOADING g_z LOADING

$$\begin{aligned}
 h &= \frac{1}{2}(5.00 - 3.25) = 0.875 \\
 r &= 0.12 \\
 d &= 5.00
 \end{aligned}$$

$$\begin{aligned}
 K_1 &= 3.431 \\
 K_2 \left(\frac{2h}{d}\right) &= -0.829 \\
 K_3 \left(\frac{2h}{d}\right)^2 &= -0.075 \\
 K_4 \left(\frac{2h}{d}\right)^3 &= 0.024 \\
 K_T &= 2.551
 \end{aligned}$$

g_y LOADING

$$\begin{aligned}
 h &= \frac{1}{2}(5.00 - 3.25) = 0.875 \\
 r &= 0.31 \\
 d &= 5.00
 \end{aligned}$$

$$\begin{aligned}
 K_1 &= 2.590 \\
 K_2 &= -0.733 \\
 K_3 &= -0.008 \\
 K_4 &= -0.025
 \end{aligned}$$

$$K_T = 1.874$$

R-450 FS

FOR INFORMATION ONLY


SEISMIC STRESS ANALYSIS ON THE MOUNTING YOKE

STRESS CONCENTRATION FACTORS ELASTIC STRESS
AXIAL TENSION Pg. 593 FORMULAS FOR STRESS
AND STRAIN

$$h = \frac{1}{2}(G-D) \quad r = H \quad d = G$$

$$h = 0.875 \quad r = 0.12 \quad d = 5.00$$

$$h/r = 7.2917$$



$$K_1 = 1.042 + 0.982(7.2917)^{\frac{1}{2}} - 0.036(7.2917) = 3.4312$$

$$K_2 = -0.074 - 0.156(7.2917)^{\frac{1}{2}} - 0.010(7.2917) = -0.5682$$


$$K_3 = -3.418 + 1.220(7.2917)^{\frac{1}{2}} - 0.005(7.2917) = -0.1601$$

$$K_4 = 3.450 - 2.046(7.2917)^{\frac{1}{2}} + 0.051(7.2917) = -1.7030$$

$$K_X = 3.4312 + (-0.5682)(0.1750) + (-0.1601)(0.1750)^2 + (-1.7030)(0.1750)^3$$

$$K_X = 3.318$$

g_z LOADINGS




$$M_y = (104^{\#})(3.5 \text{ in})(5.4g) = 1965.6 \text{ in-lb}$$

$$I = \frac{(3.25)^4}{12} - \frac{\pi}{4} \left(\frac{2.125}{2} \right)^4 = 8.3 \text{ in}^4$$


$$\sigma_{x_1} = \frac{MC}{I} = \frac{(1965.6)(1.625)}{8.3} = 384.83 \text{ PSI}$$

$$K_z \sigma_{x_1} = (2.551)(384.83) = 981.70 \text{ PSI}$$

$$g_{z \text{ BENDING}} = 981.70 \text{ PSI}$$



STRESSES
AT A POINT
DESIGNATION
SUBSCRIPT



$$\gamma_{xz} = \gamma_{yz} = \frac{(104^{\#})(5.4)}{3.250^2 - \frac{2.125^2 \pi}{4}} = 80.05 \text{ PSI}$$


$$g_{z\gamma} = 80.05 \text{ PSI}$$

R450 FS

FOR INFORMATION ONLY

SEISMIC STRESS ANALYSIS ON THE MOUNTING YKE

g_y LOADING



$$\begin{aligned} M_1 (\text{END CAP}) &= 303 \# \\ M_2 (\text{SPRING CYL.}) &= 14.04 \# \\ M_3 (\text{SPRING}) &= 12.98 \# \\ M_4 (\text{PISTON}) &= 20.27 \# \\ M_5 (\text{MAIN CYL.}) &= 20.73 \# \\ M_6 (\text{MAIN CYL. END CAP}) &= 658 \# \end{aligned}$$


$$M_z = (W \#)(g)(3) =$$

$$M_z = (104 \#)(5.4)(3.5) = 1965.60$$

$$I = \frac{(3.25)^4}{12} - \frac{\pi (2.125)^4}{4} = 8.3 \text{ IN}^4$$

$$\sigma_{x_2} = \frac{M_z}{I} = \frac{(1965.6)(1.625)}{8.3} = 384 \text{ PSI}$$

SECTION B-B



$$g_{y \text{ ENDING}} = K \sigma_{x_2} = (1.874)(384) = 719.7 \text{ PSI}$$

$$\gamma_{yz} = \frac{(104 \#)(5.4)}{\frac{3.25^2}{4} - \frac{\pi (2.125)^2}{4}} = 80.05 \text{ PSI}$$

$$g_{y_N} = 80.05$$

SHEAR STRESS CAUSED BY MOMENT M_x

$$M_x = g \left[M_1 D_1 + M_{23} D_2 + M_4 D_4 + M_5 D_5 - M_6 D_6 \right]$$

$$\begin{aligned} M_x = 5.4 \left[(3.03)(24.94) + (14.04 + 12.98)(19.63) + (20.27)(5.87) \right. \\ \left. + (20.73)(2.227) - (658)(4.38) \right] \end{aligned}$$

$$M_x = 4010 \text{ IN-IB}$$

R-450 FS

FOR INFORMATION ONLY

SEISMIC STRESS ANALYSIS ON THE MOUNTING YOKE

- MODEL CROSS-SECTION AS AN APPROXIMATE CIRCULAR SECTION FOR COMPUTING TORSIONAL SHEAR STRESSES

REFERENCE: USS STEEL DESIGN MANUAL (JAN 1981)
R.L. BROCKENBROUGH & B.G. JOHNSON.

$$\gamma_s = \frac{TR}{I_p}$$

T = TORSIONAL LOAD

R = RADIUS FOR LOCATION OF STRESS

I_p = POLAR MOMENT OF INERTIA

$$I_p = (R_1^4 - R_2^4) \frac{\pi}{2} = \frac{(1.63^4 - 1.063^4) \pi}{2}$$

$$I_p = 8.95$$

$$\gamma_s = \frac{(4010 \text{ IN-LB})(1.625 \sqrt{2})}{8.95} = 1030 \text{ PSI}$$

q LOADINGS

$$F (\text{TENSION})_x = M_A = (104^{\text{K}})(5.4) = 561.60^{\text{K}}$$

$$\text{CROSS SECTIONAL AREA} = (3.25)(3.25) - \frac{\pi (2.125)^2}{4} = 7.02 \text{ IN}^2$$

$$\sigma_{x_A} = \frac{561.60^{\text{K}}}{7.02 \text{ IN}^2} = 80.05 \text{ PSI} \quad \sigma_{x_A K_x} = (80.05)(3.318)$$

$$q_{x \text{ AXIAL}} = 265.61 \text{ PSI}$$

$$M_y' = 5.4 \left[(3.03)(24.94) + (14.04 + 12.98)(9.63) + (20.27)(5.87) + (20.73)(2.227) - (4.58)(4.38) \right] = 4010 \text{ IN-LB}$$

$$\sigma_{x_1} = \frac{M_c}{I} = \frac{(4010)(1.625)}{8.3} = 785 \text{ PSI} \quad \sigma_{x_1 K_2} = (2.551)(785) = 2003 \text{ PSI}$$

R. 450 FS

FOR INFORMATION ONLY

SEISMIC STRESS ANALYSIS ON THE
MOUNTING YOKE

SQUARE ROOT SUM OF THE SQUARES

$$\sigma_F = \left[(265.6 + 2003)^2 + (981.7)^2 + (719.7)^2 \right]^{1/2}$$

$$\sigma_F = 2575 \text{ PSI}$$

$$\tau_F = \left[(80.05)^2 + (80.05 + 1030)^2 + (0)^2 \right]^{1/2} = 1113 \text{ PSI}$$

$$\tau_F = 1113 \text{ PSI}$$

$$\sigma_F = 2575 < 0.6(30,000) = 18000 \text{ PSI}$$

< 13500 NOTCHED FATIGUE STRENGTH

$$\tau_F = 1113 < 0.4(30,000) = 12000 \text{ PSI}$$

< 13500 NOTCHED FATIGUE STRENGTH

- STRESSES ON THE FOLLOWING COMPONENTS
ARE GOVERNED BY THE OPERATING LOADS
AND NOT THE DESIGN BASIS EARTHQUAKE
LOAD CONDITIONS.

EXAMPLES: SCOTCH YOKE, CONNECTING PINS, SHAFT, PISTON

SCOTCH YOKE: OPERATING SPRING LOADS APPROX. $510^* + 150^* = 660 \text{ lb}$

SEISMIC LOADS APPROX. $20^* \times 5.4_y = 108 \text{ lb}$

$$\text{ALLOWABLE STRESSES} \quad \frac{660}{1.0} \geq \frac{108 + 660}{1.5}$$

$$660 \geq 512$$

∴ NO DETAILED ANALYSIS REQUIRED.

CALL.
-DCR NO: M84-12





Sheet 20 of 20 c

DESIGN/REVIEW COMMENTS SHEET

DESIGN VERIFICATION

ALTERNATE CALCULATIONS

FOR INFORMATION ONLY

NO.	COMMENT	RESOLUTION/APPROVAL
	SEE PAGES 20 B+20C	COMMENTS INCORPORATED
		<div data-bbox="1006 1129 1222 1170">  </div> <div data-bbox="1006 1170 1222 1210"> Design Engineer Date </div> <div data-bbox="1006 1210 1222 1249">  </div> <div data-bbox="1006 1249 1222 1289"> Verifying Engineer Date </div> <div data-bbox="1006 1289 1222 1330">  </div> <div data-bbox="1006 1330 1222 1370"> Technical Group Leader Date </div> <div data-bbox="1006 1370 1222 1410">  </div> <div data-bbox="1006 1410 1222 1451"> Supervising Engr. Nuclear Projects Date </div>

REVIEW COMMENTS

FOR INFORMATION ONLY

1. STATE BASIC ASSUMPTIONS: THESE ASSUMPTIONS ALLOW YOU TO USE FLOOR RESPONSE SPECTRA AS THE DESIGN/QUALIFICATION SPECTRA FOR YOUR ACTUATORS

- THE MOUNTING OF THE DAMPER IS RIGID ($f > 33\text{cps}$)
- THE DAMPER ITSELF IS RIGID ($f > 33\text{cps}$)
- THE SUPPORT BRACKET FOR THE ACTUATOR IS RIGID ($f > 33\text{cps}$)
- THE SEISMIC REQUIREMENTS FOR EVALUATING THE ACTUATORS ARE THE SAME AS FOR THE DAMPERS (i.e. SPEC 7584-M-100 REV. 1)

2. PG. 4 : REMOVE REFERENCE OF R-960 FOR "END-CAP" WT. CALC. R-960 HAS NO "END-CAP"

3. PG 5 & 6 : $0.9 F_y$ APPLIES TO TENSILE STRESSES UNDER DBE LOADS USE $0.8 F_y$ FOR SHEAR STRESSES UNDER DBE LOADS.

4. PG. 13 - 15: DO NOT SOLVE FOR PRINCIPLE STRESSES IN ANCHOR BOLTS, RESOLVE INTO TENSION (T) AND SHEAR (V) AND USE INTERACTION AS FOLLOWS

$$\frac{T}{T_a} + \frac{V}{V_a} \leq 1.5 \text{ --- FOR DBE LOADS.}$$

$$T = \sqrt{T_x^2 + T_y^2 + T_z^2}$$

$$V = \sqrt{V_x^2 + V_y^2 + V_z^2}$$

T_i = LOAD DUE TO COMPONENT ACCELERATION
 V_i = " " " " " "

STATE THAT BOLTS ARE ASSUMED TO BE A307 (GRADE 1) THEREFORE:

$$T_a = 20,000 \text{ psi}$$

$$V_a = 10,000 \text{ psi}$$

5. PG. 19 : TREAT YOUR CROSS-SECTION AS AN APPROXIMATELY CIRCULAR SECTION FOR COMPUTING TORSIONAL SHEAR STRESSES:



$$f_s = \frac{TR}{I_p}$$

T = TORSIONAL LOAD
 R = RADIUS FOR LOCATION OF STRESS
 I_p = POLAR MOMENT OF INERTIA
 $I_p = (R_1^4 - R_2^4) \pi / 2 = 8.95$

$$f_s \approx \frac{4010 \text{ in-lb } (3.75/2) \sqrt{2}}{8.95} = 1030 \text{ psi}$$

REF. USS STEEL DESIGN MANUAL (JAN. 1981) by
R.L. BROCKENBROUGH & B.G. JOHNSON.

IOWA ELECTRIC LIGHT AND POWER COMPANY CEDAR RAPIDS, IOWA	DEPT. <u>DESIGN ENGINEERING</u>	CALL <u>M484-12</u>
	PROJECT <u>DUANE ARNOLD ENERGY CENTER</u>	Sheet No. <u>20 C</u> of <u>20 C</u>
	SUBJECT <u>ACTUATOR QUALIFICATION R 450</u>	
	Computed by <u>DW</u> Date _____	Checked by <u>M. REFSCHNEIDER, JR.</u> Date <u>4-18/84</u>

FOR INFORMATION ONLY

6. PG. 20 & 22 : STATE THAT THE SEISMIC STRESSES (ABSOLUTE SUM) WHICH IS CONSERVATIVE COMPARED TO SRSS
7. PG. 21 & 23 : STATE THAT NOTCH FATIGUE STRESS STRENGTH IS A CONSERVATIVE VALUE AS COMPARED TO $0.6 F_u$ TYPICALLY USED FOR DBE LOADS WHEN A $0.5 F_u$ VALUE IS NOT APPLICABLE.
8. PG. 24-26 : STATE THAT STRESSES ON THE SCOTCH YOKE ARE GOVERNED BY OPERATING LOAD AND NOT DBE LOAD CONDITIONS.

EXAMPLE : SPRING LOADS $\sim 510 + 150 = 660$ lb.
SEISMIC LOADS $\sim 2016 \times 5.4g = 10816$ lb.

$$\frac{660}{\text{ALLOWABLE STRESS } 1.0} \geq \frac{660 + 108}{1.5}$$

$$660 \geq 512 \therefore \text{NO DETAILED ANALYSIS REQ'D.}$$

→ REMOVE ANALYSIS AND MAKE ABOVE STATEMENT.

GENERAL :

- PROCEDURES VERIFIED BY EITHER VERIFICATION OF ANALYSIS KNOWN IN CALL OR OUTSIDE ANALYSIS YIELDING SAME RESULTS.
- COMPONENTS SELECTED IN THE VERIFICATION APPEAR TO BE THE HIGHEST STRESSED COMPONENTS.
- ALL FOLLOW-UP CALLS SHOULD REFERENCE THIS CALL FOR EXPLANATION OF ALLOWABLES, ASSUMPTIONS AND METHODOLOGY.
- STATE THAT ACTUATOR MOUNTING MAY BE IN ANY ORIENTATION THEREFORE "WORST CASE" ANALYSIS ASSUMES HORIZONTAL ACCELERATION COEFFICIENTS IN ALL 3 DIRECTIONS (SINCE $HORIZ > VERT + 1g$ IN ALL CASES)

IOWA ELECTRIC LIGHT AND POWER COMPANY

DUANE ARNOLD ENERGY CENTER

FOR INFORMATION ONLY

CALCULATION COVERSHEET

ANALYSIS/CALCULATION NO: M84-13

ANALYSIS/CALCULATION TITLE: SEISMIC STRESS ANALYSIS

HILLS-McCanna DAMPER ACTUATORS R-960FS

REFERENCE DOCUMENTS

MAR NO: _____

DCR NO: _____

OTHERS: DDC 769

Calc M84-12

PREPARED BY: Donald W. Church DC DATE: 4/19/84

REVIEWED BY: [Signature] DATE: 4-19/84

APPROVED BY: Mike McDermott DATE: 4/30/84

FINAL APPROVAL BY: [Signature] DATE: 30 April 1984

FOR INFORMATION ONLY

Background

The purpose for compiling calculations M84-11, 12, 13, 14, 15 was to perform a seismic analysis on the critical components of the Hills-McCanna Pneumatic Damper Actuators. These actuators are part of the secondary containment isolation system at the Duane Arnold Energy Center.

On January 26, 1984, Iowa Electric notified the NRC by telephone that the above mentioned actuators were potentially deficient in meeting their purchase specification. A review of the documents relating to this discrepancy revealed that the isolation damper assemblies were purchased originally as complete assemblies which included the damper actuators. Subsequent orders for "like-for-like" replacement actuators were placed directly with the actuator manufacturer who was a subvendor to the damper manufacturer. This most recent purchase order for actuators revealed that a quality assurance program, as required for safety related equipment per 10CFR Part 50, is not currently in effect at the actuators manufacturer's facility.

Further review of the damper assembly documentation revealed that the seismic analysis performed on the damper assemblies did not seismically analyze the actuators themselves, but only considered their weight as it seismically affected the damper frame. This information prompted Iowa Electric to audit the damper manufacturer and check for documentation that pertained to the seismic qualifications of the isolation damper actuators. Results from the audit of the damper manufacturer revealed that the actuators were never purchased by the damper manufacturer as seismically qualified components nor did the damper manufacturer administer a Quality Assurance program concerning the purchase of the actuators.

Since no traceability or Certificate of Conformance was available for the seismic qualifications of the actuators, a seismic analysis was performed on the critical components of the actuators in order to seismically qualify the damper actuators for use in the Duane Arnold Energy Center. This seismic analysis followed the guidelines set forth in the original purchase specification for the isolation dampers (ref. Bechtel 7884-M-100). By seismically qualifying the isolation damper actuators, Iowa Electric will be able to buy Quality Level I actuators in accordance with Revision 1, Chapter 4 of the Quality Assurance Manual under Standard Industrial Quality Items 4.7.3.

Solution

A seismic analysis was performed on five models of the Rockwell Hills-McCanna Ramcon Pneumatic Actuator product line that are installed as isolation damper actuators at the Duane Arnold Energy Center. These five models include the following:

- R-260 FS
- R-450 FS
- R-960 FS
- R-2000 FS
- R-4200 FS

FOR INFORMATION ONLY

The seismic analysis on the actuators followed the general project seismic requirements for frequency-not-determined class 1 equipment in the reactor building and in the control building (ref. Bechtel 7884-M-100, Technical Specifications for Isolation Dampers for the Duane Arnold Energy Center Unit 1, Revision 0, 12-28-70).

A visual inspection of all isolation damper actuators at the Duane Arnold Energy Center was made in order to verify model number, serial number and elevation location in the plant. After verifying the elevation location in the plant, static coefficients (g units) were determined for the highest installed actuator for each of the five actuator models. The horizontal static coefficient was then applied to all three of the orientation axis which eliminated many repetitious calculations and the need for detailed actuator orientation information. Applying the horizontal static coefficient to each axis provided conservative results since the horizontal coefficient is always greater than one plus the vertical coefficient ($F_{\text{vertical}} = (\text{Weight}) (1 + g_v)$, $F_{\text{horizontal}} = (\text{Weight}) (g_h)$, $g_h > 1 + g_v$).

The seismic analysis concentrated on the critical areas of the damper actuator where the seismically induced loads could possibly make the actuator fail, malfunction, or prevent operation. Five areas on each actuator model were identified as critical areas requiring a seismic analysis of the various components interfacing with that critical area. These five critical areas are identified as the following:

- Retaining key which holds the spring cylinder assembly to the main body cylinder
- Main body cylinder
- Press fit between main body cylinder and the mounting yoke
- Mounting hardware
- Mounting yoke

Dimensions and material specifications for the seismic analysis were obtained through the use of proprietary component drawings that were on loan to Iowa Electric from Rockwell Hills-McCanna of Carpentersville, Illinois. All prints applicable to this seismic analysis are listed in the reference section of the referenced calculations.

Four basic assumptions are applied throughout the entire seismic analysis of the damper actuators. These assumptions allow Iowa Electric to use the floor response spectra as the design/qualification spectra for the seismic analysis. The four basic assumptions are as follows:

- The mounting of the damper is a rigid structure ($f > 33$ cps)
- The damper itself is a rigid structure ($f > 33$ cps)
- The support bracket for the actuator is a rigid structure ($f > 33$ cps)
- The seismic requirements for evaluating the actuators are the same as those for the isolation dampers.

The maximum seismic stresses were calculated by using the square root sum of the squares method for combining the three earthquake direction stresses as recommended in the UFSAR for seismic analysis at the Duane Arnold Energy Center. A second method, the distortion energy method was used for combining stresses at the press fit between the main body cylinder and the mounting yoke. The distortion energy method was used in place of the square root sum of the squares method because the stresses due to the press-fit condition exceeded and dominated those caused by the seismic event. All maximum stresses were then compared to some fraction of the yield strength depending on the material type and stress type. Operability after a DBE event was ensured by requiring that the maximum stress from combined seismic and normal loads should not exceed 90% of the yield stress of the material.

Conclusion

After completing the above described seismic analysis on the five models of Hills-McCanna actuators installed on the isolation dampers at the Duane Arnold Energy Center, it was found that the maximum stresses from the combined seismic and normal loads do not exceed the material yield requirements defined in the isolation damper purchase specification. The results of this seismic analysis reveal that the five models of Hills-McCanna actuators are seismically qualified for use at the Duane Arnold Energy Center.

References

Bechtel Purchase Specification 7884-M-100

Formulas for Stress and Strain; Raymond J. Roark, Warren C. Young, Fifth Edition, McGraw-Hill Book Co. 1975

Hills-McCanna Information Bulletins; R-1090, R-1090A, R110C, R1100A, R-111C, R-1110A, R-112D, R-1120A, R-113D, R-1130A

Marks' Standard Handbook for Mechanical Engineers' Baumeister Eighth Edition, McGraw-Hill Book Company 1978

Materials Selector 75; Reinhold Publishing Co. Mid September 1974, Vol. 80, No. 4, Brown Printing Co.

Mechanical Engineering Design; Joseph E. Shigley, Third Edition, McGraw-Hill Book Co. 1977

Mechanics of Materials; Higdon, Ohlsen, Stiles, Weese, Riley Third Edition, John Wiley and Sons 1978

FOR INFORMATION ONLY

Rockwell Hills-McCanna; Proprietary Drawings

DATA: Information contained on drawings is proprietary and confidential and is not to be given or loaned to others. Drawings are to be returned to Rockwell upon completion of their intended use in making the seismic analysis.

<u>R260</u>	<u>R450-R960</u>	<u>R2000-R4200</u>
430-1004	450-7511	460-7511
430-7510	450-1005	460-1001
430-7511	450-7512	460-7509
430-3003	450-3005	460-3001
430-3005	450-3007	460-3003
430-4101	450-4101	460-4101
430-4102	450-4102	460-4102
430-2101	450-2101	460-2101
430-2904	450-2906	460-2904
430-2502	450-2507	460-2503
430-2501	450-2501	460-2502
430-3321	450-3201	460-3208
430-3322	450-3202	460-3209
430-3325	450-3203	460-3210
430-3201	450-3326	460-3317
430-3202	450-3325	460-3316
430-8203	450-3321	460-3320
	450-3320	460-3321
		460-3314
		460-3315

U.S.S. Steel Design Manual; R.L. Brockenbrough and B.G. Johnson, Jan. 1981

MARTIN REIFSCHNEIDER Reviewer for Calculations M84-11,12,13,14,15

POSITION Senior Civil/Structural Engineer

EDUCATION BS, Civil Engineering, University of Michigan
MS, Civil/Structural Engineering, University of Michigan

PROFESSIONAL DATA Registered Professional Engineer in Michigan

SUMMARY

1 year: Senior Engineer; Civil/Structural Staff

4 years: Senior Engineer; Midland, Palisades, and Big Rock Point Nuclear Power Plants

1 year: Resident Engineer, Midland Nuclear Power Plant

EXPERIENCE

Mr. Reifschneider is currently assigned as a civil/structural engineer on the civil/structural staff. His duties include; preparation of design standards; review of project calculations, drawings, specifications and seismic qualification of equipment; providing consultation to civil/structural engineers engaged in the design of nuclear and fossil power plants; solving special static and dynamic structural problems.

Prior to joining the civil/structural staff, Mr. Reifschneider was a civil/structural engineer on Consumers Power Company's Palisades project. His duties included finite element analysis of the biological shield wall, seismic analysis and design of blockwall supports, and seismic analysis and design of the auxiliary building addition including the review of seismic equipment qualifications.

Prior to joining the Palisades project, Mr. Reifschneider was a civil/structural resident engineer at the jobsite of Consumers Power company's Midland nuclear plant project. His duties included interfacing with construction personnel on the design, erection, and construction of seismic instrument and equipment supports.

MARTIN REIFSCHNEIDER

Reviewer for Calculations M84-11,12,13,14,15

Prior to his jobsite assignment, Mr. Reifschneider conducted research on the inelastic design and behavior of braced structural steel systems, moment frame structural steel system, and reinforced concrete shear wall systems. He co-authored three Bechtel reports on the findings of this research.

Prior to his research assignment, Mr. Reifschneider was a civil/structural engineer on the Midland nuclear plant project. His duties included designing seismic supports for HVAC ducts and electrical cabletrays.

IOWA ELECTRIC LIGHT AND POWER COMPANY CEDAR RAPIDS, IOWA	DEPT. <u>DESIGN ENGINEERING</u>
	PROJECT <u>DUANE ARNOLD ENERGY CENTER</u> Sheet No. <u>VII</u> of <u>VIII</u>
	SUBJECT <u>SEISMIC ANALYSIS HILLS-MCCANNA ACTUATORS</u>
	Computed by _____ Date _____ Checked by _____ Date _____

SUMMARY OF RESULTS R-960 FS

<u>COMPONENT</u>	<u>MANUFACTURED MATERIAL</u> <u>ALLOWABLE STRESS</u>	<u>LOW GRADE MATERIAL</u> <u>ALLOWABLE STRESS</u>	<u>*CALCULATED STRESS (σ, τ)</u> <u>STRESS COMPARISON</u>
<u>RETAINING KEY</u>	303 STAINLESS STEEL $S_{YA} = (0.5) S_Y$ $S_{YA} = 17500 \text{ psi}$	NOT APPLICABLE NOT APPLICABLE	$\tau_F = 1168 \text{ psi}$ <u>$1168 < 17500$</u>
<u>MAIN BODY CYLINDER</u> OUTSIDE SURFACE INSIDE SURFACE	1020 STEEL $S_{YA} = (0.9)(S_Y)$ $S_{YA} = 43200$	1006 STEEL $S_{YA} = (0.9)(S_Y)$ $S_{YA} = 36900$	$\sigma_F = 11461 \text{ psi}$ <u>$11461 < 36900$</u> $\sigma_F = 12968 \text{ psi}$ <u>$12968 < 36900$</u>
<u>MOUNTING HARDWARE</u> $\frac{1}{2}$ -13 BOLTS	A307 GRADE 1 BOLT $\sigma_A = 20000 \text{ psi}$ $\tau_A = 10000 \text{ psi}$		$\sigma_F = 7735 \text{ psi}$ $\tau_F = 3147 \text{ psi}$
NOTE: <u>LOWEST GRADE BOLT ASSUMED INSTALLED</u>			
BASIS FOR COMPARISON: $\frac{\tau_F}{\tau_A} + \frac{\sigma_F}{\sigma_A} \leq 1.5$ FOR DBE CONDITIONS <u>$0.701 \leq 1.5$</u>			

* CALCULATED STRESS USING SRSS OF THE EARTH QUAKE DIRECTIONS OR MAXIMUM DISTORTION ENERGY THEORY.

IOWA ELECTRIC LIGHT AND POWER COMPANY CEDAR RAPIDS, IOWA	DEPT. <u>DESIGN ENGINEERING</u> PROJECT <u>DUANE ARNOLD ENERGY CENTER</u> Sheet No. <u>VIII</u> of <u>VIII</u> SUBJECT <u>SEISMIC ANALYSIS HILLS-MCCANNA ACTUATORS</u> Computed by _____ Date _____ Checked by _____ Date _____
--	--

SUMMARY OF RESULTS CONTINUED R-960 FS

<u>COMPONENT</u>	<u>MANUFACTURED MATERIAL</u> <u>ALLOWABLE STRESS</u>	<u>LOW-GRADE MATERIAL</u> <u>ALLOWABLE STRESS</u>	<u>*CALCULATED STRESS</u> <u>STRESS COMPARISON</u>
<u>BODY CASTING</u> <u>(MOUNTING</u> <u>YOKE)</u>	<u>CLASS 35</u> <u>CAST IRON</u> $S_{YA} = (0.6)(S_M)$ $S_{YA} = 18000 \text{ psi}$ $S_{YA} = (0.4)(S_M)$ $S_{YA} = 12000$	<u>CLASS 20</u> <u>CAST IRON</u> $S_{YA} = (0.6)(S_M)$ $S_{YA} = 12000$ $S_{YA} = (0.4)(S_M)$ $S_{YA} = 8000 \text{ psi}$	$\sigma_F = 2804 \text{ psi}$ $\tau_F = 255 \text{ psi}$ <u>$2804 < 12000$</u> <u>$255 < 8000$</u>
<u>FRESS FIT</u> <u>BETWEEN</u> <u>MAIN CYLINDER</u> <u>AND MOUNTING</u> <u>YOKE</u>	<u>CAST IRON -</u> <u>1020 STEEL</u> <u>MINIMUM INTERFERENCE = 0.001"</u> <u>FORCE REQUIRED TO SLOE</u> <u>CYLINDER FROM MOUNTING</u> <u>YOKE = 1349 #</u>		<u>RESULTANT</u> <u>AXIAL FORCE = 1055 #</u> <u>$1055 < 1349$</u>

R-960 FS

WEIGHT DETERMINATION

FOR INFORMATION ONLY

CYLINDER - SPRING CYLINDER

WEIGHT = 14.04 # REFERENCE R-450 FS Pg 1

MAIN BODY CYLINDER

$$D_o = 5.86"$$

$$D_i = 5.27"$$

$$h = 18.795$$

$$\rho = 0.283 \text{ #/in}^3$$

$$\text{WEIGHT} = \frac{\pi(5.86^2 - 5.27^2)(18.795)(0.283)}{4}$$

WEIGHT = 27.92 # REFERENCE: R450-3326

END CAP (SPRING CYLINDER)

WEIGHT = 3.03 # REFERENCE: R450 FS Pg 1

YOKE

WEIGHT = 2.28 #

PISTON

WEIGHT = 20.27 # REFERENCE: R-450 FS Pg 3

END CAPS (MAIN CYLINDER)

WEIGHT = 6.58 # REFERENCE: R-450 FS Pg 4

SPRINGS

TOTAL SPRING WEIGHT = 12.98 # REFERENCE: R450 FS Pg 4

IOWA ELECTRIC LIGHT
AND POWER COMPANY
CEDAR RAPIDS, IOWA

DEPT. DESIGN ENGINEERING CALC ME4-13
PROJECT DUANE ARNOLD ENERGY CENTER Sheet No. 2 of 15
SUBJECT SEISMIC STRESS ANALYSIS HILLS-MCCANNA ACTUATORS
Computed by [Signature] Date _____ Checked by [Signature] Date _____

R-960 FS

HORIZONTAL (g) LOADS

IV-AD-19A = B
IV-AD-14A = B
IV-AD-17A1 = B1


REACTOR BUILDING ELEVATION 833'-6"
BOLTED SUPPORT SYSTEMS

OBE DBE
4.1 8.2

FOR INFORMATION ONLY

- MAXIMUM HORIZONTAL (g) LOAD FOR WORST CASE ACTUATOR ELEVATION APPLIED TO ALL AXIS OF SEISMIC ANALYSIS. 8.2g LOAD IS GREATER THAN (1+g) LOAD ON VERTICAL (g) LOAD SPECIFICATION.
- MAXIMUM AIR PRESSURE = 100 PSI ACTING ON PISTON 5.27" DIA

SHEAR STRESS ON THE RETAINING KEY AXIAL ORIENTATION



M₁ (END CAP) = 3.03 #
M₂ (SPRING CYL) = 14.04 #
M₃ (SPRING) = 12.98 #
M₄ (PISTON) = 20.27 #
50.32 #

g = 5.4

SPRING TEST LENGTHS (NESTED SPRINGS)

A-450-3005 @ 12.22" = 501 #
A-450-3007 @ 12.16" = 151 #
WITH 115 lb/in RATE
WITH 35 lb/in RATE
9.6" MAXIMUM SPRING COMPRESSION LENGTH
WITH PISTON AT STOP.

$$F_{\text{SPRING}} = 151 \# + 35(12.16 - 9.60) + 501 + 115(12.22 - 9.60) = 1043 \#$$

$$F_{\text{MASS}} = (8.2)(50.32) = 412.62 \#$$

$$F_{\text{TOTAL}} = 412.62 \# + 1043 \# + (2181.3 \# = 1043 \#)$$


$$F_{\text{TOTAL}} = 2593.9 \#$$

$$F_{\text{AIR PRESSURE}} = \frac{(100 \text{ PSI} \times \pi)(5.27)^2}{4}$$

$$F_{\text{AP}} = 2181.3 \#$$

RETAINING KEY
303 STAINLESS

16" CIRCUMFERENTIAL LENGTH



$$\tau_a = F/A = \frac{2593.9 \#}{(0.1875 \times 16)} = 867 \text{ PSI}$$


S_y = YIELD STRENGTH 303 S.S. = 25,000 PSI

S_N = SHEAR STRENGTH = (0.5)(S_y) = (0.5)(35000) = 17500 PSI
ALLOWABLE SHEAR STRESS = 17500 PSI

$$\underline{867 \text{ PSI} < 17500 \text{ PSI}}$$

R-960 FS

STRESS ON THE RETAINING KEY FROM MOMENTS
CAUSED BY SPRING CYLINDER ASSEMBLY





FOR INFORMATION ONLY

$$M_y = 4.14(M_2 + M_3) + 9.21(M_1)$$

$$M_y = E.2 \left[4.14(4.04 + 12.98) + 9.21(3.03) \right]$$

$$M_y = 1146.1 \text{ IN-LB}$$

- THETA (θ) IS THE ANGLE THAT CORRESPONDS TO THE RETAINING RING GAP FOR ONE QUADRANT. GAP IS DIVIDED IN TWO EQUAL PARTS AT $+\gamma$ AND $-\gamma$.



$$\text{SHEAR STRESS} = \gamma(\theta)$$

t = THICKNESS RETAINING RING

$$t = 0.187 \text{ "}$$

$$r = 2.632 \text{ "}$$

$$M = 1146$$

$$\text{RETAINING ACTIVE LENGTH} = 4 \text{ " / QUADRANT}$$

$$C_{avg} = \frac{2\pi r}{4} = \frac{2\pi(2.632)}{4} = 4.1343 \text{ "}$$

$$\theta = \frac{4.0}{4.1343} = 1.52 \text{ RAD}$$

$$\int_0^{\theta} \gamma(\theta) t r^3 \sin \theta d\theta = \frac{M}{4}$$

$$\gamma(\theta) = K r \sin \theta$$

$$\int_0^{\theta} K t r^3 \sin^2 \theta d\theta$$

$$\int_0^{\theta} \sin^2 \theta d\theta = \left[-\frac{1}{4} \sin 2\theta + \frac{1}{2} \theta \right]_0^{\theta} = -\frac{1}{4} \sin 2(1.52) + \frac{1.52}{2} = 0.735$$

$$\frac{M}{4} = K t r^3 (0.735)$$

$$K = \frac{1146.1}{(4)(0.187)(2.632)^3(0.735)}$$

$$K = 114.33$$

$$\gamma(\theta) = K r \sin \theta = (114.33)(2.632) \sin \left(\frac{\pi}{2} \right) = 300.93 \text{ PSI}$$

$$\gamma_{\text{TOTAL}} = \gamma_A + \gamma(\theta) = 300.93 + 867 = 1167.93 \text{ PSI}$$

$$\underline{\underline{1167.93 < 17500 \text{ PSI}}}$$

R-960 FS

STRESSES DUE TO THE PRESS FIT CONDITIONS
BETWEEN THE YOKE AND THE CYLINDER BODY


FOR INFORMATION ONLY

- REFERENCE HIGDON "MECHANICS OF MATERIALS"
JOHN WILEY & SONS 1978 Pg. 164, 163.

$$I (\text{INTERFERENCE}) = 0.005" = 2 \delta_1 + 2 \delta_2$$

$$\delta_1 = \frac{b_1^2 P_s}{(c^2 - b_1^2) E_n b_1} \left[(1-\nu) b_1^2 + (1+\nu) c^2 \right]$$

$$\delta_2 = \frac{b_2^2 P_s}{(b^2 - a^2) E_s b_2} \left[(1-\nu) b_2^2 + (1+\nu) a^2 \right]$$



$$a = 2.6375 \quad b_1 = 2.9205 \quad b_2 = 2.923 \quad c = 3.435$$

SOLVE FOR P_s INTERFACIAL PRESSURE

$$0.005 = 2 \left[\frac{(2.9205)^2 P}{[3.435^2 - 2.9205^2] (15 \times 10^6) (2.9205)} \right] \left[(1-0.29)(2.9205)^2 + (1+0.29)(3.435)^2 \right]$$

$$+ 2 \left[\frac{(2.923)^2 P}{(2.923^2 - 2.6375^2) (30 \times 10^6) (2.923)} \right] \left[(1-0.3)(2.923)^2 + (1+0.3)(2.6375)^2 \right]$$

$$0.005 = 2.533 \times 10^{-6} P + 1.8442 \times 10^{-6} P$$

$$P = 1142 \text{ PSI (MAXIMUM INTERFERENCE)}$$

EXTERNAL PRESSURE

INTERNAL PRESSURE

$$\sigma_r = - \frac{b^2 P_o}{b^2 - a^2} \left(1 - \frac{a^2}{r^2} \right)$$

$$\sigma_r = \frac{a^2 P_i}{b^2 - a^2} \left(1 - \frac{b^2}{r^2} \right)$$

$$\sigma_t = - \frac{b^2 P_o}{b^2 - a^2} \left(1 + \frac{a^2}{r^2} \right)$$

$$\sigma_t = \frac{a^2 P_i}{b^2 - a^2} \left(1 + \frac{b^2}{r^2} \right)$$

R-960 FS

FOR INFORMATION ONLY

STRESS IN BODY CASTING INTERNAL PRESSURE

$$\sigma_r = \frac{(2.9205)^2(1142)}{(3.435^2 - 2.9205^2)} \left(1 - \frac{(3.435^2)}{(2.9205^2)} \right) = -1142 \text{ PSI}$$

$$\sigma_t = \frac{(2.9205)^2(1142)}{(3.435^2 - 2.9205^2)} \left(1 + \frac{3.435^2}{2.9205^2} \right) = 7100 \text{ PSI}$$

STRESS IN CYLINDER EXTERNAL PRESSURE

OUTSIDE CYLINDER SURFACE

$$\sigma_r' = - \frac{(2.923)^2(1142)}{(2.923^2 - 2.6375^2)} \left(1 - \frac{2.6375^2}{2.923^2} \right) = -1143 \text{ PSI}$$

$$\sigma_t' = - \frac{(2.923)^2(1142)}{(2.923^2 - 2.6375^2)} \left(1 + \left(\frac{2.6375}{2.923} \right)^2 \right) = -11150 \text{ PSI}$$

INSIDE CYLINDER SURFACE

$$\sigma_r = - \frac{(2.923)^2(1142)}{(2.923^2 - 2.6375^2)} \left(1 - \frac{2.6375^2}{2.6375^2} \right) = 0 \text{ PSI}$$


$$\sigma_t = - \frac{(2.923)^2(1142)}{(2.923^2 - 2.6375^2)} \left(1 + \frac{2.6375^2}{2.6375^2} \right) = -12292 \text{ PSI}$$

IOWA ELECTRIC LIGHT AND POWER COMPANY CEDAR RAPIDS, IOWA	DEPT. <u>DESIGN ENGINEERING</u>	CALC <u>M24-13</u>
	PROJECT <u>DWANE ARNOLD ENERGY CENTER</u>	SHEET NO. <u>6</u> OF <u>15</u>
	SUBJECT <u>SEISMIC STRESS ANALYSIS HILLS-McCANN ACTUATORS</u>	
	Computed by <u>bw</u>	Date _____ Checked by _____ Date _____

R-960 FS

FOR INFORMATION ONLY

STRESS ON THE CYLINDER DUE TO MOMENT CAUSED BY MAIN BODY CYLINDER, PISTON, SPRING CYLINDER AND END CAP.



$$\begin{aligned}
 M_1 (\text{END CAP}) &= 3.03 \text{ \#} \\
 M_2 (\text{SPRING CIL}) &= 14.04 \text{ \#} \\
 M_3 (\text{SPRING}) &= 12.98 \\
 M_4 (\text{PISTON}) &= 20.27 \\
 M_5 (\text{CYLINDER}) &= 27.92
 \end{aligned}$$

MASS OF CYLINDER IS MODELLED TO ACT ON RIGHT SIDE OF YOKE. EXCLUDES COUNTERACTING MOMENT DUE TO MASS ON THE LEFT SIDE OF YOKE.

SUMMING MOMENTS ABOUT X-X

$$\begin{aligned}
 M_{xx} &= 8.2 \left[(27.92)(3.968) + (20.27)(4.25) + (12.98 + 14.04)(18.195) \right. \\
 &\quad \left. + (3.03)(23.501) \right] = 6230.12 \text{ IN-IB}
 \end{aligned}$$

MOMENT OF INERTIA C AXIS XX NEUTRAL AXIS C ACTUATOR

$$I = \frac{\pi}{64} (d_o^4 - d_i^4) = \frac{\pi}{64} (5.860^4 - 5.275^4)$$


$$I = 20.02$$

$$\sigma = \frac{M_c}{I} = \frac{(6230.12)(2.93)}{19.88} = 918.22 \text{ PSI}$$

$$\sigma_{\text{AIR PRESSURE}} = \frac{2181.3 \text{ \# (AIR FORCE)}}{\pi(5.850^2 - 5.275^2)/4} = 434.2 \text{ PSI}$$

R-960 FS

CYLINDER STRESSES CONTINUED



MOMENT = 3908.3 IN-LB

$C = \frac{5.27}{2} = 2.635"$

$\bar{C} = \frac{5.86}{2} = 2.93"$

$I = 19.88 \text{ IN}^4$

$S_y = 48000 \text{ PSI } 1020 \text{ STEEL}$

$90\% S_y = (0.9) 48000 \text{ PSI}$

$0.9 S_y = 43200 \text{ PSI}$

$\sigma'_b = \frac{M_c}{I} + \sigma_{AP} = \frac{(6230.12)(2.93)}{19.88} + 434.2$

$= 13524 \text{ PSI}$

$\sigma_b = \frac{M_c}{I} + \sigma_{AP} = \frac{(6230.12)(2.635)}{19.88} + 434.2$

$= 1259.97 \text{ PSI}$

$\sigma'_t = -11150 \text{ PSI}$

$\sigma_t = -12292 \text{ PSI}$

$\sigma'_r = -1143 \text{ PSI}$

$\sigma_r = 0 \text{ PSI}$

SUMMATION OF STRESSES USING MAXIMUM
DISTORTION ENERGY THEORY

* REFERENCE MECHANICS OF MATERIALS Pg 489

$\sigma_F = \left\{ \frac{1}{2} \left[(\sigma_b - \sigma_t)^2 + (\sigma_t - \sigma_r)^2 + (\sigma_r - \sigma_b)^2 \right] \right\}^{1/2}$

$\sigma_F = \left\{ \frac{1}{2} \left[(1259.97 + 12292)^2 + (-12292 + 0)^2 + (0 - 1259.97)^2 \right] \right\}^{1/2}$

$\sigma_F = 12967.98 \text{ PSI} < 43200 \text{ PSI (YIELD 1020 @ 90\%)}$

$\sigma'_F = \left\{ \frac{1}{2} \left[(13524 + 11150)^2 + (-11150 + 1143)^2 + (-1143 - 13524)^2 \right] \right\}^{1/2}$



$\sigma'_F = 11460.30 \text{ PSI} < 43200 \text{ PSI (YIELD 1020 @ 90\%)}$

FOR INFORMATION ONLY

R-960 FS

FOR INFORMATION ONLY

SEISMIC AXIAL LOAD ACTING ON PRESS FIT OF CYLINDER THROUGH THE MOUNTING YOKE



MINIMUM INTERFERENCE ON RADIUS

$$I = \frac{5.843}{2} - \frac{5.844}{2} = 0.0005 \text{ INCH}$$

REFERENCE PRINTS 450-3321

450-3325

ON DIAMETER $I = 0.001$

MINIMUM PRESSURE FROM PRESS FIT WITH MINIMUM INTERFERENCE

SOLVING FOR MINIMUM PRESSURE (P) - Pg 164 MECHANICS OF MATLS.

$$0.001 \text{ IN} = 2 \left[\frac{(2.9215)^2 P}{\{(3.435^2 - 2.9215^2)(15 \times 10^6)(2.9215)\}} \right] \left[(0.71)(2.9215)^2 + (1.29)(3.435)^2 \right] \\ + 2 \left[\frac{(2.922)^2 P}{\{(2.922^2 - 2.635^2)(30 \times 10^6)(2.922)\}} \right] \left[(0.7)(2.922)^2 + (1.3)(2.635)^2 \right]$$

$$0.001 = 2.5392 (10^{-6}) P + 1.8324 (10^{-6}) P$$


$$0.001 = P(4.371)10^{-6}$$

$$P = 229 \text{ PSI}$$

R-960 FS

FOR INFORMATION ONLY

DETERMINATION OF AXIAL LOAD



$$\begin{aligned}M_1 (\text{END CAPS}) &= (2)(3.03) \\M_2 (\text{SPRING CYL}) &= (2)(14.04) \\M_3 (\text{SPRING}) &= (2)(2.98) \\M_4 (\text{PISTON}) &= (2)(20.27) \\M_5 (\text{MAIN CYL}) &= 27.92\end{aligned}$$

$$M_T - \text{TOTAL MASS} = 128.56 \#$$

$$\text{AXIAL FORCE} = F_A = M_T(g) = (128.56)(8.2) = 1054.19 \#$$

FORCE REQUIRED TO SLIDE CYLINDER FROM MOUNTING YOKE

$$\text{SLIDE FORCE} = F_S = \pi f P d l$$

l = LENGTH OF FIT = 3.21"

d = CYLINDER DIA = 5.841

P = UNIT FIT PRESSURE

f = COEFFICIENT OF FRICTION

AVERAGE RANGE 0.10 \rightarrow 0.15

USE $f = 0.10$


$$F_S = \pi(0.10)(229)(5.841)(3.21) = 1349 \#$$

$$\underline{\underline{1349 \# > 1054 \#}}$$

REF: MARKS HAND BOOK 8-47

R-960 FS

SEISMIC LOADINGS ON MOUNTING HARDWARE **FOR INFORMATION ONLY**



(g_Z) LOADING

M_A = MASS OF ACTUATOR INCLUDING
MOUNTING YOKE = 154#

$$\text{MOMENT ABOUT (Y)} = (M_A)(g)(L)$$

$$M_y = (154)(8.2)(4.12) = 5202.7$$

$$M_y = (2)(F_T)(3.5)$$

$2F_T$ = TENSION FORCE
IN TWO TOP BOLTS

$$F_T = \frac{(5202.7)}{(2)(3.5)} = 743.25$$

$\frac{1}{2}$ -13 BOLT EFFECTIVE AREA = 0.1419 in²

TENSILE STRESS AREA Pg 230
SHIGLEY MECH ENG DESIGN

$4F_s$ = SHEAR FORCE IN (4) MOUNTING BOLT

$$F_s = \frac{(154\#)(8.2g)}{4} = 315.7\#$$

$$\sigma_{x_i} = \frac{F_T}{A_{\text{BOLT}}} = \frac{743.25}{0.1419} = 5237.8 \text{ psi}$$



$$\tau_{24} = \frac{315.7}{0.1419} = 2224.8 \text{ PSI}$$

R-960 FS

FOR INFORMATION ONLY

SEISMIC LOADINGS ON MOUNTING HARDWARE

Q_y LOADING



$$M_z = (154\#)(8.2)(4.12") = 5202.7 \text{ IN-IB}$$

TENSION FORCE IN BOLTS 1 & 2
DUE TO MOMENT M_z

$$F_T = \frac{(5202.7 \text{ IN-IB})}{(3.5 \text{ IN})(2 \text{ BOLTS})} = 743.25 \#$$

F_s = SHEAR FORCE FROM TOTAL
ACTUATOR MASS

$$F_s = \frac{(154\#)(8.2)}{4 \text{ BOLTS}} = 315.7 \#$$

$$\text{EFFECTIVE AREA } \frac{1}{2}\text{-13 BOLT} = 0.1419 \text{ IN}^2$$

$$\sigma_{x/2} (\text{STRESS-TENSION}) = \frac{743.25 \#}{0.1419 \text{ IN}^2} = 5238 \text{ PSI}$$

$$\tau_{z/2} (\text{SHEAR STRESS}) = \frac{315.7 \#}{0.1419 \text{ IN}^2} = 2225 \text{ PSI}$$

R-960 FS

SEISMIC LOADING OF MOUNTING HARDWARE

g_x LOADING

TENSION ONLY

$$F_{Tx} = MA$$

$$\text{FORCE TENSION} = \frac{(54\#)(8.2)}{(4 \text{ BOLTS})} = 315.7 \#$$

$$\sigma_{x_3} = \frac{315.7 \#}{0.1419 \text{ in}^2} = 2224.8 \text{ PSI}$$

SUMMATION OF STRESSES

$$\text{BASIS FOR COMPARISON} = \frac{\gamma_F}{\gamma_A} + \frac{\sigma_F}{\sigma_A} \leq 1.5 \quad \text{FOR DBE CONDITIONS}$$

$$\sigma_F = \left[\sigma_{x_1}^2 + \sigma_{x_2}^2 + \sigma_{x_3}^2 \right]^{1/2} = \left[5237.8^2 + 5238^2 + 2224.8^2 \right]^{1/2}$$

$$\sigma_F = 7734.40 \text{ PSI}$$

$$\gamma_F = \left[\gamma_{zy_1}^2 + \gamma_{zy_2}^2 + \gamma_{zy_3}^2 \right]^{1/2} = \left[2224.8^2 + 2225^2 + 0^2 \right]^{1/2}$$

$$\gamma_F = 3146.63 \text{ PSI}$$

BOLTS ASSUMED TO BE A307 GRADE (1) BOLTS

$$\sigma_A = 20000 \text{ PSI}$$

$$\gamma_A = 10000 \text{ PSI}$$

$$\frac{3146.63}{10000} + \frac{7734.4}{20000} = 0.701$$

$$\underline{\underline{0.701 \leq 1.5}}$$

FOR INFORMATION ONLY

R-960 FS

SEISMIC STRESSES ON THE MOUNTING YOKE


FOR INFORMATION ONLY

ELASTIC STRESS
IN PLANE BENDING
STRESS CONCENTRATION
FACTORS THE SAME AS
R-450 FS Pg 16


VERTICAL LOADS (g_z)
 $K_z = 2.551$

HORIZONTAL LOADS (g_y)
 $K_y = 1.874$

AXIAL TENSION



R-450 FS Pg 17
HORIZONTAL LOADS (g_x)
 $K_x = 3.318$



g_z LOADINGS

$$M_y = (Wt) \times (dim B) \times (g \text{ LOAD})$$


$$M_y = (154^{\#})(3.5)(8.2) = 4420 \text{ IN-16}$$

$$I = \frac{(3.25)^4}{12} - \frac{\pi}{4} \left(\frac{2.125}{2} \right)^4 = 8.3 \text{ IN}^4$$


$$\sigma_{zB} = \frac{M_C}{I} = \frac{(4420)(1.625)}{8.3} = 865.4 \text{ PSI}$$

$$K_z \sigma_{zB} = (2.551)(865.4) = 2207.5 \text{ PSI}$$

$$\gamma_{xy} = \frac{(154^{\#})(8.2)}{2.750^2 - \pi(2.125)^2} = 180 \text{ PSI}$$



SECTION A-A
3.250




$$c = \frac{3.250}{2} = 1.625$$

R-960 FS

FOR INFORMATION ONLY

SEISMIC STRESS ANALYSIS ON THE MOUNTING YOKES

g_y LOADING



$$M_z = (Wt)(dim B)(g_{LOAD})$$

$$M_z = (154)(3.5)(8.2) = 4420 \text{ IN-LB}$$


$$I = \frac{(3.25)^4}{12} - \frac{\pi (2.125)^4}{4} = 8.3 \text{ IN}^4$$

$$\sigma_{y_B} = \frac{M_z}{I} = \frac{(4420)(1.625)}{8.3} = 865.4 \text{ IN-LB}$$

$$K_y \sigma_{y_B} = (1.874)(865.4) = 1621.7 \text{ PSI}$$

$$\tau_{zy} = \frac{(154 \#)(8.2)}{3.25^2 - \frac{\pi (2.125)^2}{4}} = 180 \text{ PSI}$$

SECTION B-B



g_x LOADINGS

$$F (\text{TENSION})_x = MA = (154 \#)(8.2g) = 1262.8 \#$$

$$\text{CROSS SECTIONAL AREA} = (3.25)(3.25) - \frac{\pi (2.125)^2}{4} = 7.02 \text{ IN}^2$$

$$\sigma_{y_A} = \frac{1262.8 \#}{7.02 \text{ IN}^2} = 180 \text{ PSI}$$

$$\sigma_{y_A} K_x = (180)(3.318) = 597.2 \text{ PSI}$$

IOWA ELECTRIC LIGHT
AND POWER COMPANY
CEDAR RAPIDS, IOWA

DEPT. DESIGN ENGINEERING CALC M34-13
PROJECT DWANE ARNOLD ENERGY CENTER Sheet No. 15 of 15
SUBJECT SEISMIC STRESS ANALYSIS HILLS-MCCANNA ACTUATORS
Computed by [Signature] Date _____ Checked by PK Date _____

R-960 FS

FOR INFORMATION ONLY

SEISMIC STRESS ANALYSIS ON THE MOUNTING YOKE
SQUARE ROOT SUM OF THE SQUARES

$$\sigma_F = \left[(597.2)^2 + (1621.7)^2 + (2207.5)^2 \right]^{1/2}$$

$$\sigma_F = 2803.11 \text{ PSI}$$

$$\tau_F = \left[(180)^2 + 180^2 + 0^2 \right]^{1/2}$$

$$\tau_F = 254.56 \text{ PSI}$$

$$\sigma_F = 2803.11 < 0.6(30000) = 18000 \text{ PSI}$$

< 13500 NOTCHED FATIGUE STRENGTH

$$\tau_F = 254.56 < 0.4(30,000) = 12000$$

< 13500 NOTCHED FATIGUE STRENGTH

- ANALYSIS OF INTERNAL ACTUATOR NOT REQUIRED
REFERENCE R-450 FS CALCULATIONS Pg. 20

CALC. NO:

DER No: M84-13

Sheet 16 of 16A

DESIGN/REVIEW COMMENTS SHEET

DESIGN VERIFICATION

ALTERNATE CALCULATIONS

FOR INFORMATION ONLY

NO.	COMMENT	RESOLUTION/APPROVAL
	NO COMMENTS	<div data-bbox="817 1361 1445 1447"><u>Donald W. Church</u> 4/19/84 Design Engineer Date</div> <div data-bbox="817 1457 1445 1627"><u>[Signature]</u> 4-19/84 Verifying Engineer Date</div> <div data-bbox="817 1638 1445 1776"><u>M. L. McDermott</u> 4/30/84 Technical Group Leader Date</div> <div data-bbox="355 1766 776 1936"><u>[Signature]</u> 4-19/84 Verifying Engineer Date</div> <div data-bbox="817 1808 1445 1936"><u>[Signature]</u> 4/30/84 Supervising Engr. Nuclear Projects Date</div>

FOR INFORMATION ONLY

IOWA ELECTRIC LIGHT AND POWER COMPANY

DUANE ARNOLD ENERGY CENTER

CALCULATION COVERSHEET

ANALYSIS/CALCULATION NO: M84-14

ANALYSIS/CALCULATION TITLE: SEISMIC STRESS ANALYSIS

HILLS-MCCANNA DAMPER ACTUATORS R-2000FS

REFERENCE DOCUMENTS

MAR NO: _____

DCR NO: _____

OTHERS: DOC 769

calc M84-12

PREPARED BY: Donald W. Church @ DATE: 4/20/84

REVIEWED BY: [Signature] MR DATE: 4-24/84

APPROVED BY: [Signature] DATE: 4/30/84

FINAL APPROVAL BY: [Signature] DATE: 4/30/84

I
FOR INFORMATION ONLY

Background

The purpose for compiling calculations M84-11, 12, 13, 14, 15 was to perform a seismic analysis on the critical components of the Hills-McCanna Pneumatic Damper Actuators. These actuators are part of the secondary containment isolation system at the Duane Arnold Energy Center.

On January 26, 1984, Iowa Electric notified the NRC by telephone that the above mentioned actuators were potentially deficient in meeting their purchase specification. A review of the documents relating to this discrepancy revealed that the isolation damper assemblies were purchased originally as complete assemblies which included the damper actuators. Subsequent orders for "like-for-like" replacement actuators were placed directly with the actuator manufacturer who was a subvendor to the damper manufacturer. This most recent purchase order for actuators revealed that a quality assurance program, as required for safety related equipment per 10CFR Part 50, is not currently in effect at the actuators manufacturer's facility.

Further review of the damper assembly documentation revealed that the seismic analysis performed on the damper assemblies did not seismically analyze the actuators themselves, but only considered their weight as it seismically affected the damper frame. This information prompted Iowa Electric to audit the damper manufacturer and check for documentation that pertained to the seismic qualifications of the isolation damper actuators. Results from the audit of the damper manufacturer revealed that the actuators were never purchased by the damper manufacturer as seismically qualified components nor did the damper manufacturer administer a Quality Assurance program concerning the purchase of the actuators.

Since no traceability or Certificate of Conformance was available for the seismic qualifications of the actuators, a seismic analysis was performed on the critical components of the actuators in order to seismically qualify the damper actuators for use in the Duane Arnold Energy Center. This seismic analysis followed the guidelines set forth in the original purchase specification for the isolation dampers (ref. Bechtel 7884-M-100). By seismically qualifying the isolation damper actuators, Iowa Electric will be able to buy Quality Level I actuators in accordance with Revision 1, Chapter 4 of the Quality Assurance Manual under Standard Industrial Quality Items 4.7.3.

Solution

A seismic analysis was performed on five models of the Rockwell Hills-McCanna Ramcon Pneumatic Actuator product line that are installed as isolation damper actuators at the Duane Arnold Energy Center. These five models include the following:

- R-260 FS
- R-450 FS
- R-960 FS
- R-2000 FS
- R-4200 FS

FOR INFORMATION ONLY

The seismic analysis on the actuators followed the general project seismic requirements for frequency-not-determined class 1 equipment in the reactor building and in the control building (ref. Bechtel 7884-M-100, Technical Specifications for Isolation Dampers for the Duane Arnold Energy Center Unit 1, Revision 0, 12-28-70).

A visual inspection of all isolation damper actuators at the Duane Arnold Energy Center was made in order to verify model number, serial number and elevation location in the plant. After verifying the elevation location in the plant, static coefficients (g units) were determined for the highest installed actuator for each of the five actuator models. The horizontal static coefficient was then applied to all three of the orientation axis which eliminated many repetitious calculations and the need for detailed actuator orientation information. Applying the horizontal static coefficient to each axis provided conservative results since the horizontal coefficient is always greater than one plus the vertical coefficient ($F_{\text{vertical}} = (\text{Weight}) (1 + g_v)$, $F_{\text{horizontal}} = (\text{Weight}) (g_h)$, $g_h > 1 + g_v$).

The seismic analysis concentrated on the critical areas of the damper actuator where the seismically induced loads could possibly make the actuator fail, malfunction, or prevent operation. Five areas on each actuator model were identified as critical areas requiring a seismic analysis of the various components interfacing with that critical area. These five critical areas are identified as the following:

- Retaining key which holds the spring cylinder assembly to the main body cylinder
- Main body cylinder
- Press fit between main body cylinder and the mounting yoke
- Mounting hardware
- Mounting yoke

Dimensions and material specifications for the seismic analysis were obtained through the use of proprietary component drawings that were on loan to Iowa Electric from Rockwell Hills-McCanna of Carpentersville, Illinois. All prints applicable to this seismic analysis are listed in the reference section of the referenced calculations.

Four basic assumptions are applied throughout the entire seismic analysis of the damper actuators. These assumptions allow Iowa Electric to use the floor response spectra as the design/qualification spectra for the seismic analysis. The four basic assumptions are as follows:

- The mounting of the damper is a rigid structure ($f > 33$ cps)
- The damper itself is a rigid structure ($f > 33$ cps)
- The support bracket for the actuator is a rigid structure ($f > 33$ cps)
- The seismic requirements for evaluating the actuators are the same as those for the isolation dampers.

The maximum seismic stresses were calculated by using the square root sum of the squares method for combining the three earthquake direction stresses as recommended in the UFSAR for seismic analysis at the Duane Arnold Energy Center. A second method, the distortion energy method was used for combining stresses at the press fit between the main body cylinder and the mounting yoke. The distortion energy method was used in place of the square root sum of the squares method because the stresses due to the press-fit condition exceeded and dominated those caused by the seismic event. All maximum stresses were then compared to some fraction of the yield strength depending on the material type and stress type. Operability after a DBE event was ensured by requiring that the maximum stress from combined seismic and normal loads should not exceed 90% of the yield stress of the material.

Conclusion

After completing the above described seismic analysis on the five models of Hills-McCanna actuators installed on the isolation dampers at the Duane Arnold Energy Center, it was found that the maximum stresses from the combined seismic and normal loads do not exceed the material yield requirements defined in the isolation damper purchase specification. The results of this seismic analysis reveal that the five models of Hills-McCanna actuators are seismically qualified for use at the Duane Arnold Energy Center.

References

Bechtel Purchase Specification 7884-M-100

Formulas for Stress and Strain; Raymond J. Roark, Warren C. Young, Fifth Edition, McGraw-Hill Book Co. 1975

Hills-McCanna Information Bulletins; R-1090, R-1090A, R110C, R1100A, R-111C, R-1110A, R-112D, R-1120A, R-113D, R-1130A

Marks' Standard Handbook for Mechanical Engineers' Baumeister Eighth Edition, McGraw-Hill Book Company 1978

Materials Selector 75; Reinhold Publishing Co. Mid September 1974, Vol. 80, No. 4, Brown Printing Co.

Mechanical Engineering Design; Joseph E. Shigley, Third Edition, McGraw-Hill Book Co. 1977

Mechanics of Materials; Higdon, Ohlsen, Stiles, Weese, Riley Third Edition, John Wiley and Sons 1978

Rockwell Hills-McCanna; Proprietary Drawings

DATA: Information contained on drawings is proprietary and confidential and is not to be given or loaned to others. Drawings are to be returned to Rockwell upon completion of their intended use in making the seismic analysis.

<u>R260</u>	<u>R450-R960</u>	<u>R2000-R4200</u>
430-1004	450-7511	460-7511
430-7510	450-1005	460-1001
430-7511	450-7512	460-7509
430-3003	450-3005	460-3001
430-3005	450-3007	460-3003
430-4101	450-4101	460-4101
430-4102	450-4102	460-4102
430-2101	450-2101	460-2101
430-2904	450-2906	460-2904
430-2502	450-2507	460-2503
430-2501	450-2501	460-2502
430-3321	450-3201	460-3208
430-3322	450-3202	460-3209
430-3325	450-3203	460-3210
430-3201	450-3326	460-3317
430-3202	450-3325	460-3316
430-8203	450-3321	460-3320
	450-3320	460-3321
		460-3314
		460-3315

U.S.S. Steel Design Manual; R.L. Brockenbrough and B.G. Johnson, Jan. 1981

FOR INFORMATION ONLY

POSITION Senior Civil/Structural Engineer

EDUCATION BS, Civil Engineering, University of Michigan
 MS, Civil/Structural Engineering, University of Michigan

PROFESSIONAL DATA Registered Professional Engineer in Michigan

SUMMARY 1 year: Senior Engineer; Civil/Structural Staff
 4 years: Senior Engineer; Midland, Palisades, and Big Rock Point Nuclear Power Plants
 1 year: Resident Engineer, Midland Nuclear Power Plant

EXPERIENCE Mr. Reifschneider is currently assigned as a civil/structural engineer on the civil/structural staff. His duties include; preparation of design standards; review of project calculations, drawings, specifications and seismic qualification of equipment; providing consultation to civil/structural engineers engaged in the design of nuclear and fossil power plants; solving special static and dynamic structural problems.

 Prior to joining the civil/structural staff, Mr. Reifschneider was a civil/structural engineer on Consumers Power Company's Palisades project. His duties included finite element analysis of the biological shield wall, seismic analysis and design of blockwall supports, and seismic analysis and design of the auxiliary building addition including the review of seismic equipment qualifications.

 Prior to joining the Palisades project, Mr. Reifschneider was a civil/structural resident engineer at the jobsite of Consumers Power company's Midland nuclear plant project. His duties included interfacing with construction personnel on the design, erection, and construction of seismic instrument and equipment supports.

FOR INFORMATION ONLY

Prior to his jobsite assignment, Mr. Reifschneider conducted research on the inelastic design and behavior of braced structural steel systems, moment frame structural steel system, and reinforced concrete shear wall systems. He co-authored three Bechtel reports on the findings of this research.

Prior to his research assignment, Mr. Reifschneider was a civil/structural engineer on the Midland nuclear plant project. His duties included designing seismic supports for HVAC ducts and electrical cabletrays.

IOWA ELECTRIC LIGHT AND POWER COMPANY CEDAR RAPIDS, IOWA	DEPT. <u>DESIGN ENGINEERING</u>
	PROJECT <u>DUANE ARNOLD ENERGY CENTER</u> Sheet No. <u>VII</u> of <u>VIII</u>
	SUBJECT <u>SEISMIC ANALYSIS HILLS-MCCANNA ACTUATORS</u>
	Computed by <u>QW</u> Date _____ Checked by _____ Date _____

SUMMARY OF RESULTS R-2000 FS **FOR INFORMATION ONLY**

<u>COMPONENT</u>	<u>MANUFACTURED MATERIAL</u> <u>ALLOWABLE STRESS</u>	<u>LOW GRADE MATERIAL</u> <u>ALLOWABLE STRESS</u>	<u>*CALCULATED STRESS (σ_F, γ_F)</u> <u>STRESS COMPARISON</u>
<u>RETRAINING KEY</u>	<u>303 STAINLESS STEEL</u> $S_{YA} = (0.5)(S_Y)$ $S_{YA} = 17500 \text{ psi}$	<u>NOT APPLICABLE</u> <u>NOT APPLICABLE</u>	$\gamma_F = 2691 \text{ psi}$ <u>$2691 < 17500$</u>
<u>MAIN BODY CYLINDER</u> OUTSIDE SURFACE INSIDE SURFACE	<u>1020 STEEL</u> $S_{YA} = (0.9)(S_Y)$ $S_{YA} = 43200 \text{ psi}$	<u>1006 STEEL</u> $S_{YA} = (0.9)(S_Y)$ $S_{YA} = 36900$	$\sigma_F = 9015 \text{ psi}$ <u>$9015 < 36900$</u> $\sigma_F = 9667 \text{ psi}$ <u>$9667 < 36900$</u>
<u>MOUNTING HARDWARE</u> 5/8-11 BOLT	<u>A307 GRADE 1 BOLT</u> $\sigma_A = 20000 \text{ psi}$ $\gamma_A = 10000 \text{ psi}$		$\sigma_F = 14053 \text{ psi}$ <u>$\gamma_F = 4283 \text{ psi}$</u>
NOTE: <u>LOWEST GRADE BOLT ASSUMED INSTALLED</u>			
BASIS FOR COMPARISON: $\frac{\gamma_F}{\gamma_A} + \frac{\sigma_F}{\sigma_A} \leq 1.5$ FOR DBE CONDITIONS <u>$1.131 < 1.5$</u>			

* CALCULATED STRESS USING SRSS OF THE EARTHQUAKE DIRECTIONS OR MAXIMUM DISTORTION ENERGY THEORY.

IOWA ELECTRIC LIGHT AND POWER COMPANY CEDAR RAPIDS, IOWA	DEPT. <u>DESIGN ENGINEERING</u>
	PROJECT <u>DUANE ARNOLD ENERGY CENTER</u> Sheet No. <u>VIII</u> of <u>VIII</u>
	SUBJECT <u>SEISMIC ANALYSIS HILLS-MCCANNA ACTUATORS</u>
	Computed by <u>DW</u> Date _____ Checked by _____ Date _____

SUMMARY OF RESULTS CONTINUED R-2000 FS

<u>COMPONENT</u>	<u>MANUFACTURED MATERIAL</u> <u>ALLOWABLE STRESS</u>	<u>LOW GRADE MATERIAL</u> <u>ALLOWABLE STRESS</u>	<u>*CALCULATED STRESS</u> <u>STRESS COMPARISON</u>
<u>E004 CASTING (MOUNTING YOKE)</u>	<u>CLASS 35 CAST IRON</u> $S_{YA} = (0.6)(S_Y)$ $S_{YA} = 18000 \text{ psi}$ $S_{YA} = (0.4)(S_Y)$ $S_{YA} = 12000 \text{ psi}$	<u>CLASS 20 CAST IRON</u> $S_{YA} = (0.6)(S_Y)$ $S_{YA} = 12000 \text{ psi}$ $S_{YA} = (0.4)(S_Y)$ $S_{YA} = 8000 \text{ psi}$	$\sigma_F = 3331 \text{ psi}$ $\tau_F = 1894 \text{ psi}$ <u>$3331 < 12000$</u> <u>$1894 < 8000$</u>
<u>PRESS FIT BETWEEN MAIN CYLINDER AND MOUNTING YOKE</u>	<u>CAST IRON - 1020 STEEL</u> <u>MINIMUM INTERFERENCE = 0.001"</u> <u>FORCE REQUIRED TO SLIDE MAIN CYLINDER FROM MOUNTING YOKE = 2970 #</u>		<u>RESULTANT AXIAL FORCE = 1902 #</u> <u>$1902 < 2970$</u>

FOR INFORMATION ONLY

WEIGHT DETERMINATION

FOR INFORMATION ONLY

END CAP (MAIN CYLINDER)

$$D_o = 8.644''$$

$$h = 1.125$$

$$\rho = 0.283 \#/\text{IN}^3$$

$$\text{WEIGHT} = \frac{\pi (8.644)^2 (1.125) (0.283)}{4} = 18.68 \#$$

SPRINGS

$$\text{LENGTH OF ONE COIL} = \sqrt{(2\pi r)^2 + h^2}$$

MARKS HANDBOOK
Pg 2-41

r = radius

h = distance BETWEEN TWO COILS OF HELIX

SPRING₁

$$\text{SPRING O.D.} = 7.40 \quad \text{SPRING I.D.} = 5.60''$$

$$\text{WIRE DIA} = 0.812'' \pm 0.010$$

$$\text{TOTAL \# OF COILS} = 13.5 \quad \rho = 0.283 \#/\text{IN}^3$$

$$\text{LET } h = 0.822''$$

$$\text{LET } r = \frac{(7.40 - 5.60)}{2} + 5.60 = 3.25''$$

$$\text{LENGTH OF ONE COIL} = \sqrt{[2\pi(3.25)]^2 + (0.822)^2}$$

$$\text{LENGTH OF ONE COIL} = 20.44''$$

$$(13.5 \text{ TOTAL NO COILS}) (20.44'') = 275.90 \text{ INCHES}$$

$$\text{CROSS SECTIONAL AREA} = \frac{\pi (0.822)^2}{4} = 0.531 \text{ IN}^2$$

$$\text{VOLUME} = (0.531 \text{ IN}^2) (275.90) = 146.42 \text{ IN}^3$$

$$\text{WEIGHT} = (146.42) (0.283 \#/\text{IN}^3) = 41.44 \#$$

SPRING₂

$$\text{WIRE DIA} = 0.532''$$

$$\text{SPRING O.D.} = 5.25'' \quad \text{MEAN DIA} = 4.66''$$

$$\text{TOTAL \# COILS} = \frac{\text{SOLID HEIGHT}}{\text{WIRE DIA}} = \frac{10.75''}{0.532''} = 20.21 \text{ COILS}$$

$$\text{LET } h = 0.532$$

$$r = 4.66/2 = 2.33''$$

$$\text{LENGTH ONE COIL} = \sqrt{[2\pi(2.33)]^2 + 0.532^2}$$

$$\text{WEIGHT} = (20.21) (14.65'') (\pi) (0.532)^2 (0.283) / 4 = 18.63 \#$$

IOWA ELECTRIC LIGHT
AND POWER COMPANY

CEDAR RAPIDS, IOWA

R-2000 ES

DEPT. DESIGN ENGINEERING

CALC MB4-14

PROJECT DUANE ARNOLD ENERGY CENTER Sheet No. 2 of 23

SUBJECT SEISMIC STRESS ANALYSIS HILLS-McCANN ACTUATORS

Computed by

DL

Date

Checked by

MR

Date

WEIGHT DETERMINATION

SPRINGS CONTINUED

TOTAL SPRING WEIGHT = WEIGHT₁ + WEIGHT₂

TOTAL SPRING WEIGHT = 41.44[#] + 18.63[#] = 60.07[#]

FOR INFORMATION ONLY

IOWA ELECTRIC LIGHT AND POWER COMPANY CEDAR RAPIDS, IOWA R-2000FS	DEPT. <u>DESIGN ENGINEERING</u>	CHLC MF4-14
	PROJECT <u>DVANE ARNOLD ENERGY CENTER</u>	Sheet No. <u>3</u> of <u>23</u>
	SUBJECT <u>SEISMIC STRESS ANALYSIS HILLS-MCCANNA ACTUATORS</u>	
	Computed by <u>(2w)</u>	Date _____ Checked by <u>MR</u> Date _____

WEIGHT DETERMINATION

FOR INFORMATION ONLY

MAIN BODY CYLINDER

$$\begin{aligned} D_o &= 9.2310'' \\ D_i &= 8.560'' \\ h &= 21.262'' \\ \rho &= 0.283 \text{ #/in}^3 \end{aligned}$$

$$\text{Volume} = \frac{\pi(D_o^2 - D_i^2)h}{4}$$

$$\text{Volume} = \frac{\pi(9.2310^2 - 8.560^2)(21.262)}{4}$$

$$\text{Volume} = 199.35 \text{ in}^3$$

$$\text{WEIGHT} = (199.35 \text{ in}^3)(0.283 \text{ #/in}^3) = 56.42 \text{ #}$$

REFERENCE: 460-3316

CYLINDER-SPRING CYLINDER

$$\begin{aligned} D_o &= 8.775'' \\ D_i &= 7.975'' \\ h &= 14.63 \end{aligned}$$

$$\text{Volume} = \frac{\pi(8.775^2 - 7.975^2)14.63}{4}$$

$$\text{Volume} = 154.08 \text{ in}^3$$

$$\text{WEIGHT} = (154.08 \text{ in}^3)(0.283 \text{ #/in}^3) = 43.60 \text{ #}$$

REFERENCE: 460-7509

SPRING CYLINDER END CAP

$$\text{Volume} = \frac{(\pi \times 4.00^2)(1.00 - 0.31)}{4} + \frac{\pi(8.260^2)(0.31)}{4}$$

$$\text{Volume} = 25.28 \text{ in}^3$$

$$\text{WEIGHT} = (25.28 \text{ in}^3)(0.283) = 7.15 \text{ #}$$

REFERENCE: 460-1001

IOWA ELECTRIC LIGHT
AND POWER COMPANY
CEDAR RAPIDS, IOWA

DEPT. DESIGN ENGINEERING

CALC MB4-14

PROJECT DUANE ARNOLD ENERGY CENTER

Sheet No. 4 of 23

SUBJECT SEISMIC STRESS ANALYSIS HILLS-MCCANN ACTUATORS

Computed by DR

Date

Checked by MR

Date

PISTON

$$\theta = \sin^{-1} \frac{2.68}{4.275} = 42.4^\circ$$


$$d = 4.275 \cos \theta - 1.63 = 1.527$$

$$h = 4.275 (\cos [\sin^{-1} \frac{1.25}{4.275}]) - \cos 6^\circ = 0.931$$

$$A = \left(\frac{42.4}{180} \right) (\pi) (4.275^2) - (3.157)(2.88) + (2)(1.527)(1.63) - (2.5)(0.931) = 7.083 \text{ in}^2$$

$$V_2 = (7.083)(11.836) = 83.834$$

$R = 4.275$



$$X = 0.75 - 4.275 (1 - \cos [\sin^{-1} \frac{1.25}{4.275}]) = 0.563$$

$$A = \left(\frac{17}{180} \pi \right) (4.275^2) - (4.088)(1.25) + (2.5)(.563)$$

$$A = 1.72 \text{ in}^2$$

$$V = (1.72)(5.26) = 9.047$$


FOR INFORMATION ONLY

IOWA ELECTRIC LIGHT
AND POWER COMPANY
CEDAR RAPIDS, IOWA


DEPT. DESIGN ENGINEERING CALC. M84-14
PROJECT DUANE ARNOLD ENERGY CENTER Sheet No. 5 of 23
SUBJECT SEISMIC STRESS ANALYSIS HILLS-MCCANNA ACTUATORS
Computed by DM Date _____ Checked by MP Date _____

PISTON - CAST IRON ASTM 126-71 CLASS B


HEAD. 8.525" ϕ 1.378" THK $\Rightarrow V_1 = 78.655 \text{ in}^3$



$$\text{AREA} \times 11.836 = 83.834 \text{ in}^3 = V_2$$



$$\text{AREA} \times 5.26 = 9.047 \text{ in}^3 = V_3$$



$$(2.5)^2 (\tan 50^\circ) (0.75) = 5.586 \text{ in}^3 = V_4$$

$$V_{\text{piston}} = V_1 + V_2 + V_3 + V_4 = 177.122 \text{ in}^3$$

$$W_{\text{piston}} = \rho V = (0.26)(177.122) = 46 \text{ lb}$$

FOR INFORMATION ONLY

IOWA ELECTRIC LIGHT AND POWER COMPANY CEDAR RAPIDS, IOWA	DEPT. <u>DESIGN ENGINEERING</u>	CALC. <u>M84-14</u>
	PROJECT <u>DUANE ARNOLD ENERGY CENTER</u>	SHEET NO. <u>6</u> OF <u>23</u>
	SUBJECT <u>SEISMIC STRESS ANALYSIS HILLS-MCCANNA ACTUATORS</u>	
	Computed by <u>DP</u> Date _____	Checked by <u>Y</u> Date _____

R-2000 FS

FOR INFORMATION ONLY

HORIZONTAL (g) LOADS


IV-AD-13A1 & B1
IV-AD-17A2 & B2
IV-AD-17A3 & B3
IV-AD-30A4 & B4
IV-AD-31A5 & B5

REACTOR BUILDING
ELEVATION 833'-6"
BOLTED SUPPORT SYSTEM

OBE DBE
4.1 8.2

- MAXIMUM HORIZONTAL (g) LOAD FOR WORST CASE ACTUATOR ELEVATION APPLIED TO ALL AXIS OF SEISMIC ANALYSIS. 8.2 g LOAD IS GREATER THAN (1+g) LOAD FROM THE VERTICAL (g) LOAD SPECIFICATION FOR REACTOR BUILDING ELEVATION 833'-6".

- MAXIMUM AIR PRESSURE = 100 PSI ACTING ON PISTON 8.565" DIAMETER.



SPRING TEST LENGTHS (NESTED SPRINGS)

REFERENCE:

460-3001 @ 20.05" = 1263 # WITH 181 #/IN SPRING RATE
460-3002 @ 20.05" = 368 # WITH 64 #/IN SPRING RATE

14.55" MAXIMUM SPRING COMPRESSION LENGTH WITH PISTON AT STOP.

$$F_{\text{SPRING}} = 1263 + (20.05 - 14.55) 181 + 368 + (20.05 - 14.55) 64$$

$$F_{\text{SPRING}} = 2978.5 \#$$

$$F_{\text{AIR PRESSURE}} = (100 \text{ PSI}) \frac{\pi (8.565)^2}{4} = 5761.6 \#$$

$$F_{\text{WEIGHT}} = (8.2 \times 156.82) = 1285.92 \#$$

$$F_{\text{TOTAL}} = 1285.92 + 5761.6 + 2978.5 = 10026.02 \text{ (CONSERVATIVE ESTIMATE)}$$


IOWA ELECTRIC LIGHT
AND POWER COMPANY
CEDAR RAPIDS, IOWA

DEPT. DESIGN ENGINEERING CALC. M34-14
PROJECT DURNE ARNOLD ENERGY CENTER Sheet No. 7 of 23
SUBJECT SEISMIC STRESS ANALYSIS HILLS-MCCANNA ACTUATORS
Computed by DW Date _____ Checked by MR Date _____

R2000 FS

SHEAR STRESSES ON THE RETAINING RING AXIAL LOAD

RETAINING KEY CROSS SECTION
REFERENCE: 460-2904

 0.187" SQUARE


ACTIVE CIRCUMFERENTIAL LENGTH = 26.3 INCHES

$$\tau_A = \frac{F_{X \text{ TOTAL}}}{(26.3)(0.187)} = \frac{10026.02}{(26.3)(0.187)} = 2038.60 \text{ PSI}$$

STRESS ON THE RETAINING RING RESULTING FROM THE
MOMENT INDUCED BY THE SPRING CYLINDER

$$M_y = g [M_1(13.921) + (M_2 + M_3)(6.961)]$$

$$M_y = 8.2 [7.15(13.921) + (60.07 + 43.60)(6.961)] = 6733.7 \text{ IN-LB}$$



SHEAR STRESS = $\gamma(\theta)$

t = THICKNESS OF RETAINING RING = 0.187"

r = 4.2770"

M = 6733.7 IN-LB


ACTIVE CIRCUMFERENTIAL RETAINING
RING LENGTH = 26.3 INCH

ACTIVE LENGTH PER QUADRANT = 6.575"

$$\text{QUADRANT CIRCUM} = \frac{2\pi(4.277)}{4} = 6.7183"$$

$$\theta = \frac{6.575}{6.7183} \times \frac{\pi}{2} = 1.5373 \text{ RAD}$$

* THETA (θ) IS THE ANGLE THAT CORRESPONDS TO THE RETAINING RING GAP FOR ONE QUADRANT. GAP IS DIVIDED IN TWO EQUAL PARTS AT +Y AND -Y.



$\gamma(\theta)$ = SHEAR STRESS DUE TO M_y

$$\int_0^\theta \gamma(\theta) t r^2 \sin \theta d\theta = \frac{M_y}{4}$$

$$\gamma(\theta) = K r \sin \theta$$

$$\int_0^\theta K t r^3 \sin^2 \theta d\theta = K t r^3 \int_0^\theta \sin^2 \theta d\theta = \frac{M_y}{4}$$

$$\int_0^\theta \sin^2 \theta d\theta = \left[-\frac{1}{4} \sin 2\theta + \frac{1}{2} \theta \right]_0^{1.54} = -\frac{1}{4} \sin(2 \times 1.54) + \frac{1.54}{2}$$

$$0 = 0.755$$

$$\frac{M_y}{4} = (K) t r^3 (0.755)$$

SOLVE FOR K

$$K = \frac{(6733.7)}{(4)(0.187)(4.277)^3(0.755)} = 152.4$$

IOWA ELECTRIC LIGHT
AND POWER COMPANY
CEDAR RAPIDS, IOWA

DEPT. DESIGN ENGINEERING CALC. M44-14
PROJECT DUANE ARNOLD ENERGY CENTER Sheet No. 8 of 23
SUBJECT SEISMIC STRESS ANALYSIS HILL-MCCANNA ACTUATORS
Computed by DW Date _____ Checked by MP Date _____

2200 FS

STRESSES ON THE RETAINING RING CONTINUED

$$\tau(\theta) = K r \sin \theta = (52.4)(4.2770) \sin(1.54) = 651.51 \text{ PSI}$$

$$\tau_{\text{TOTAL}} = \tau_A + \tau_{\theta} = 2038.60 + 651.51 = 2690.11 \text{ PSI}$$

$$S_y = \text{SHEAR STRENGTH} = 0.5(S_y)$$

$$S_y = \text{YIELD STRENGTH 303 SS.} = 35000 \text{ PSI}$$

$$50\% \text{ SHEAR STRENGTH} = (0.5)(35,000) = 17500 \text{ PSI}$$

$$\text{ALLOWABLE SHEAR STRESS} = 17500 \text{ PSI}$$

$$\underline{2690.11 \text{ PSI} < 17500 \text{ PSI}}$$

FOR INFORMATION ONLY

STRESSES DUE TO THE PRESS FIT CONDITIONS BETWEEN
THE MOUNTING YOKE AND THE CYLINDER BODY.

- REFERENCE HIGDON "MECHANICS OF MATERIALS"
JOHN WILEY & SONS 1978 Pg 163, 164

$$I (\text{INTERFERENCE}) = 2 \delta_1 + 2 \delta_2$$


$$\text{MOUNTING YOKE} = \frac{9.141}{9.143} \text{ DIA} \quad \text{REF: 460-3321}$$

$$\text{ACTUATOR MAIN CYLINDER} = \frac{9.144}{9.146} \text{ DIA} \quad \text{REF: 460-3316}$$

$$\text{MAXIMUM INTERFERENCE} = |9.141 - 9.146| = 0.005$$

$$\delta_1 = \frac{b_1^2 P_s}{(c^2 - b_1^2) E_y b_1} \left[(1-\nu) b_1^2 + (1+\nu) c^2 \right]$$

$$\delta_2 = \frac{b_2^2 P_s}{(b_2^2 - a^2) E_c b_2} \left[(1-\nu) b_2^2 + (1+\nu) a^2 \right]$$



$$a = \frac{8.560}{2} = 4.280 \quad b_1 = \frac{9.143}{2} = 4.5715 \quad b_2 = \frac{9.144}{2} = 4.572 \quad c = \frac{10.44}{2} = 5.220$$

IOWA ELECTRIC LIGHT AND POWER COMPANY CEDAR RAPIDS, IOWA R-2000 FS	DEPT. <u>DESIGN ENGINEERING</u>	CALC. <u>MA4-14</u>
	PROJECT <u>DUANE ARNOLD ENERGY CENTER</u>	SHEET NO. <u>9</u> OF <u>23</u>
	SUBJECT <u>SEISMIC STRESS ANALYSIS HILLS-McCANN ACTUATORS</u>	
	Computed by <u>DM</u>	Date _____ Checked by <u>MR</u> Date _____

STRESSES DUE TO THE PRESS FIT CONDITION BETWEEN
THE MOUNTING YOKE AND THE CYLINDER BODY

$$0.005 = \frac{(4.5715)^2 P_s (2)}{(5.22^2 - 4.5715^2)(15 \times 10^6)(4.5715)} \left[(1 - 0.29)(4.5715)^2 + (0.29)(5.22)^2 \right]$$

$$+ \frac{(4.572)^2 P_s (2)}{(4.572^2 - 4.28^2)(30 \times 10^6)(4.572)} \left[(1 - 0.30)(4.572)^2 + (0.30)(4.28)^2 \right]$$

$$0.005 = 4.7985 (10)^{-6} P_s + 4.5336 (10)^{-6} P_s$$

$$P_s = 535.78 \text{ PSI (MAXIMUM INTERFERENCE)}$$

EXTERNAL PRESSURE

INTERNAL PRESSURE

$$\sigma_r = -\frac{b_o^2 P_o}{b_o^2 a^2} \left[1 - \frac{a^2}{r^2} \right]$$

$$\sigma_r = \frac{b_i^2 P_i}{c^2 b_i^2} \left[1 - \frac{c^2}{r^2} \right]$$

$$\sigma_t = -\frac{b_o^2 P_o}{b_o^2 a^2} \left[1 + \frac{a^2}{r^2} \right]$$

$$\sigma_t = \frac{b_i^2 P_i}{c^2 b_i^2} \left[1 + \frac{c^2}{r^2} \right]$$

STRESS IN MOUNTING YOKE CASTING INTERNAL PRESSURE

INSIDE SURFACE

$$\sigma_r = \frac{(4.5715^2)(535.78)}{5.22^2 - 4.5715^2} \left[1 - \frac{5.22^2}{4.5715^2} \right] = -535.78 \text{ PSI}$$

$$\sigma_t = \frac{(4.5715^2)(535.78)}{5.22^2 - 4.5715^2} \left[1 + \frac{5.22^2}{4.5715^2} \right] = 4062.53 \text{ PSI}$$

• INSIDE SURFACE WORST CASE CONDITION

FOR INFORMATION ONLY

IOWA ELECTRIC LIGHT
AND POWER COMPANY
CEDAR RAPIDS, IOWA
R-2000 FS

DEPT. DESIGN ENGINEERING CALC ME4-14
PROJECT DWANE ARNOLD ENERGY CENTER Sheet No. 10 of 23
SUBJECT SEISMIC STRESS ANALYSIS HILLS-McGANNA ACTUATORS
Computed by (DW) Date _____ Checked by _____ Date _____

STRESS IN CYLINDER EXTERNAL PRESSURE

OUTSIDE CYLINDER SURFACE

FOR INFORMATION ONLY

$$\sigma_r = \frac{-(4.572)^2 (535.78)}{4.572^2 - 4.280^2} \left[1 - \frac{4.280^2}{4.572^2} \right] = -535.78 \text{ PSI}$$


$$\sigma_t = \frac{-(4.572)^2 (535.78)}{4.572^2 - 4.280^2} \left[1 + \frac{4.280^2}{4.572^2} \right] = -8129.94 \text{ PSI}$$

INSIDE CYLINDER SURFACE

$$\sigma_r = \frac{-(4.572)^2 (535.78)}{4.572^2 - 4.280^2} \left[1 - \frac{4.280^2}{4.280^2} \right] = 0 \text{ PSI}$$

$$\sigma_t = \frac{-(4.572)^2 (535.78)}{4.572^2 - 4.280^2} \left[1 + \frac{4.280^2}{4.280^2} \right] = -8665.72 \text{ PSI}$$

STRESS ON THE CYLINDER DUE TO MOMENT CAUSED
BY MAIN BODY CYLINDER, PISTON, SPRING CYLINDER
AND SPRING CYL END CAP



$$\begin{aligned} M_1 (\text{END CAP}) &= 7.15 \text{ \#} \\ M_2 (\text{SPRING}) &= 60.07 \text{ \#} \\ M_3 (\text{SPRING CYL}) &= 43.60 \text{ \#} \\ M_4 (\text{PISTON}) &= 46.00 \text{ \#} \\ M_5 (\text{MAIN CYL}) &= 56.42 \text{ \#} \end{aligned}$$

FOR INFORMATION ONLY

- MASS OF CYLINDER IS MODELLED TO ACT ON RIGHT SIDE OF YOKE. EXCLUDES COUNTER ACTING MOMENT DUE TO MASS OF CYLINDER AND END CAP ON THE LEFT SIDE OF YOKE ϕ

SUMMING MOMENTS ABOUT Y-Y

$$M_y = g \left[M_1 l_1 + (M_2 + M_3) l_2 + M_4 l_4 + M_5 l_5 \right]$$

$$M_y = 8.2 \left[(7.15)(25.335) + (60.07 + 43.60)(17.82) + (6.100)(46.00) + 1.006(56.42) \right] =$$

$$M_y = 19400.41 \text{ IN-IB}$$

MOMENT OF INERTIA @ NEUTRAL AXIS ϕ ACTUATOR

$$I_{yy} = \frac{\pi}{64} (d_o^4 - d_i^4) = \frac{\pi}{64} (9.146^4 - 8.565^4) =$$


$$I_{yy} = 79.31 \text{ IN}^4$$

$$\sigma_T = \frac{M_y}{I_{yy}} = \frac{(19400.41)(9.146)}{(79.31)(2)} = 1118.67 \text{ PSI}$$

$$\sigma_{\text{AIR PRESSURE}} = \frac{5761.6 \text{ \#}}{\pi (9.146^2 - 8.565^2) / 4} = 712.91 \text{ PSI}$$

IOWA ELECTRIC LIGHT AND POWER COMPANY CEDAR RAPIDS, IOWA R 2000 FS	DEPT. <u>DESIGN ENGINEERING</u>	CALC <u>ME4-14</u>
	PROJECT <u>DUANE ARNOLD ENERGY CENTER</u>	SHEET NO. <u>12</u> OF <u>23</u>
	SUBJECT <u>SEISMIC STRESS ANALYSIS HILLS-MCCANNA ACTUATORS</u>	
	Computed by <u>PR</u>	Date _____
	Checked by <u>MR</u>	Date _____

CYLINDER STRESSES CONTINUED



FOR INFORMATION ONLY

$$\sigma_T = \frac{(19,400.41)(8.565)}{79.31 (2)} =$$

$$\sigma_T = 1047.6 \text{ PSI}$$

$$\sigma_b' = \sigma_{AP} + \sigma_T = 712.91 + 1118.6 = 1831.51$$

$$\sigma_b = \sigma_{AP} + \sigma_T = 712.91 + 1047.6 = 1760.51 \text{ PSI}$$

$$\sigma_t' = -8129.94 \text{ PSI}$$

$$\sigma_t = -8665.72 \text{ PSI}$$

$$\sigma_r' = -535.78 \text{ PSI}$$

$$\sigma_r = 0 \text{ PSI}$$

SUMMATION OF CYLINDER STRESSES USING MAXIMUM DISTORTION ENERGY THEORY

• REFERENCE MECHANICS OF MATERIALS Pg 489

$$\sigma_f = \left\{ \frac{1}{2} \left[(\sigma_b - \sigma_t)^2 + (\sigma_t - \sigma_r)^2 + (\sigma_r - \sigma_b)^2 \right] \right\}^{1/2}$$

$$\sigma_f = \left\{ \frac{1}{2} \left[(1831.5 + 8129.94)^2 + (-8129.94 + 535.78)^2 + (-535.78 - 1831.5)^2 \right] \right\}^{1/2}$$

$$\sigma_f = 9014.3 \text{ PSI}$$

IOWA ELECTRIC-LIGHT AND POWER COMPANY CEDAR RAPIDS, IOWA R-2000 FS	DEPT. <u>DESIGN ENGINEERING</u>	CALC <u>ME24-14</u>
	PROJECT <u>DWANE ARNOLD ENERGY CENTER</u>	Sheet No. <u>13</u> of <u>23</u>
	SUBJECT <u>SEISMIC STRESS ANALYSIS HILLS-MCCANNA ACTUATORS</u>	
	Computed by <u>QV</u>	Date _____ Checked by <u>R</u> Date _____

$$\sigma_F = \left\{ \frac{1}{2} \left[(1760.5 + 8665.7)^2 + (8665.7 - 0)^2 + (0 - 1760.5)^2 \right] \right\}$$

$$\sigma_F = 9666.9 \text{ PSI}$$


FOR INFORMATION ONLY

$$S_y = 43,200 \text{ PSI (YIELD 1020 @ 90\%)}$$

$$\sigma_F = 9014.3 < 43200 \text{ PSI}$$

$$\sigma_F = 9666.9 < 43200 \text{ PSI}$$

SEISMIC AXIAL LOAD ACTING ON PRESS FIT OF
CYLINDER THROUGH MOUNTING YOKE



MINIMUM INTERFERENCE

$$I = 9.143 - 9.144 = 0.001"$$

ON DIAMETER

SOLVING FOR INTERFACIAL PRESSURE P_s , Pg 164 MECHANICS OF MAT'L'S.

$$0.001 \text{ IN} = 2 \left[\frac{(4.572)^2 (P_s)}{(5.22^2 - 4.572^2) (5 \times 10^6) (4.572)} \right] \left[(1 - 0.29)(4.572)^2 + (1.29)(5.22)^2 \right]$$

$$+ 2 \left[\frac{(4.572)^2 P_s}{(4.572^2 - 4.283^2) (30 \times 10^6) (4.572)} \right] \left[(1 - 0.29)(4.572)^2 + (1.29)(4.283)^2 \right]$$

IOWA ELECTRIC LIGHT
AND POWER COMPANY

CEDAR RAPIDS, IOWA
8-2000 FS

DEPT. DESIGN ENGINEERING CALC. 118A-14
PROJECT DWANE ARNOLD ENERGY CENTER Sheet No. 14 of 23
SUBJECT SEISMIC STRESS ANALYSIS HILLS-MCCANNA ACTUATORS
Computed by AW Date _____ Checked by RP Date _____

SEISMIC AXIAL LOAD ACTING ON PRESS FIT OF
CYLINDER THROUGH MOUNTING YOKE

$$0.001 \text{ IN} = P_s [4.803 \times 10^{-6} + 1.003 \times 10^{-6}]$$

$$P_s = 172.24 \text{ PSI}$$

DETERMINATION OF AXIAL LOAD (SEISMIC INDUCED)

$$\text{TOTAL WEIGHT} = M_1 + M_2 + M_3 + M_4 + M_5 + M_6$$

$$M_1 (\text{END CAP}) = 7.15 \text{ \#}$$

$$M_2 (\text{SPRING CYL}) = 60.07 \text{ \#}$$

$$M_3 (\text{SPRING}) = 43.60 \text{ \#}$$

$$M_4 (\text{PISTON}) = 46.00 \text{ \#}$$

$$M_5 (\text{MAIN CYL}) = 56.42 \text{ \#}$$

$$M_6 (\text{MAIN CYL END CAP}) = 18.68 \text{ \#}$$

$$\text{TOTAL WEIGHT} = 231.92 \text{ \#} = M_T$$

$$\text{AXIAL FORCE} = F_A = M_T (g) = (231.92)(8.2) = 1901.74 \text{ \#}$$

FORCE REQUIRED TO SLIDE CYLINDER FROM MOUNTING YOKE

$$F = \pi f P_s d l \quad \text{REFERENCE: MARICS HANDBOOK 8-47}$$

$$l = \text{LENGTH OF FIT} = 6.00 \text{ \"}$$

$$d = \text{CYLINDER DIAMETER} = 9.146 \text{ \"}$$

$$P_s = \text{UNIT PRESSURE FIT} = 172.24 \text{ PSI}$$


$$f = \text{COEFFICIENT OF FRICTION} = 0.10 \quad (\text{AVERAGE VALUES } 0.10 \rightarrow 0.15)$$

$$F = (3.1415)(0.10)(172.24)(9.146)(6.00) = 2969.38 \text{ \#}$$

$$\underline{\underline{2969.38 \text{ \#} > 1901.74 \text{ \#}}}$$

IOWA ELECTRIC-LIGHT AND POWER COMPANY CEDAR RAPIDS, IOWA R-2000 FS	DEPT. <u>DESIGN ENGINEERING</u> PROJECT <u>DUANE ARNOLD ENERGY CENTER</u> Sheet No. <u>15</u> of <u>23</u> SUBJECT <u>SEISMIC STRESS ANALYSIS HILLS-MCCANNA ACTUATORS</u> Computed by <u>MR</u> Date _____ Checked by <u>MR</u> Date _____
---	---



SEISMIC LOADING ON MOUNTING HARDWARE



Q_z LOADING

MA = MASS OF ACTUATOR INCLUDING MOUNTING YOKE = 315 #

$$M_y = (3.2)(315)(6.0) = 15456.0 \text{ in-lb}$$



$$L_3 = 1.913" \\ L_2 = 4.619" \\ L_1 = 1.913 + 4.619 = 6.532"$$

$$F_1(L_1) + F_2(L_2) + F_3(L_3) = M_y$$

$$\frac{F_1}{L_1} = \frac{F_2}{L_2} = \frac{F_3}{L_3}$$

$$F_2 = F_1 \frac{L_2}{L_1}$$

$$F_3 = F_1 \frac{L_3}{L_1}$$

$$F_1(L_1) + F_1 \frac{(L_2)^2}{L_1} + F_1 \frac{(L_3)^2}{L_1} = M_y$$

$$F_1 \left(\frac{6.532 + (4.619)^2}{6.532} + \frac{(1.913)^2}{6.532} \right) = 15456.0$$

$$F_1 = 1496.16 \text{ # TENSION WORST CASE BOLT 6}$$

$$\text{FORCE @ BOLT (5)} = F_1 \frac{L_2}{L_1} = \frac{(1496.16)(4.619)}{6.532} = 1058.0 \text{ #}$$

FOR INFORMATION ONLY

IOWA ELECTRIC LIGHT AND POWER COMPANY CEDAR RAPIDS, IOWA R-2000 FS	DEPT. <u>DESIGN ENGINEERING</u>	CALC <u>ME4-14</u>
	PROJECT <u>DUANE ARNOLD ENERGY CENTER</u>	SHEET No. <u>16</u> of <u>23</u>
	SUBJECT <u>SEISMIC STRESS ANALYSIS HILL-MCCANNA ACTUATORS</u>	
	Computed by <u>(M)</u>	Date _____ Checked by <u>M</u> Date _____

SEISMIC LOADING ON MOUNTING HARDWARE

g_z LOADING CONTINUED

F_s = SHEAR FORCE IN MOUNTING BOLTS

$$F_s = \frac{(315^{\#})(8.2g)}{8 \text{ BOLTS}} = 322.88^{\#} \text{ PER BOLT}$$


TENSILE STRESS AREA $\frac{5}{8}$ -11 UNC = 0.226 IN²

$$\tau = \frac{322.88^{\#}}{0.226 \text{ IN}^2} = 1428.31 \text{ PSI}$$

$$\sigma_T = \frac{1496.16^{\#}}{0.226 \text{ IN}^2} = 6620.19 \text{ PSI (WORST CASE BOLT)}$$

FOR INFORMATION ONLY

g_y LOADING



- M_1 (END CAP) = 7.15 #
- M_2 (SPRING) = 60.07 #
- M_3 (SPRING CYL) = 43.60 #
- M_4 (PISTON) = 46.00 #
- M_5 (MAIN CYL) = 56.42 #
- M_6 (MAIN CYL END CAP) = 18.68 #

$$M_{xx} = g [m_1 l_1 + (m_2 + m_3) l_2 + M_4 l_4 + M_5 l_5 - M_6 l_6]$$

$$M_{xx} = 8.2 [(7.15)(28.335) + (60.07 + 43.60)(20.82) + (46.0)(9.10) + (56.42)(4.006) - (18.68)(6.920)] = 23586.13 \text{ IN-LB}$$

IOWA ELECTRIC-LIGHT AND POWER COMPANY CEDAR RAPIDS, IOWA R-2000 FS	DEPT. <u>DESIGN ENGINEERING</u>	CALC <u>M84-14</u>
	PROJECT <u>DWANE ARNOLD ENERGY CENTER</u>	Sheet No. <u>17</u> of <u>23</u>
	SUBJECT <u>SEISMIC STRESS ANALYSIS HILLS-MCCANNA ACTUATORS</u>	
	Computed by <u>(signature)</u> Date _____	Checked by <u>(signature)</u> Date _____

SEISMIC LOADING ON MOUNTING HARDWARE

g_y LOADING

FOR INFORMATION ONLY

TENSION ON BOLT 5 FROM g_y LOADING

$F_{T5} = 1496.16 \#$, THE SAME AS BOLT SIX
WITH g_z LOADING

TENSION OF BOLT 6 FROM g_y LOADING

$F_{T6} = 1058 \#$ THE SAME AS BOLT FIVE
WITH g_z LOADING

$$\sigma_{T6} = \frac{1058 \#}{0.226} = 4620.1 \text{ PSI}$$

$$F_{YEX} = \frac{(23586.13 \text{ in-lb})}{(8 \text{ BOLTS})(5.0")} = 589.65 \#$$

$$F_{Y5y} = \frac{(8.29)(315 \#)}{8 \text{ BOLT}} = 322.8 \#$$

$$F_{\text{TOTAL SHEAR}} \approx 589.65 \# + 322.8 \#$$

$$F_{\text{TOTAL SHEAR}} = 912.45 \#$$

$$\tau_{\text{TOTAL}} = \frac{912.45}{0.226} = 4037.4 \text{ PSI}$$

g_x LOADING

$$M_{y-y} = 23586.13 \text{ in-lb} = M_{x-x} (\text{g}_y \text{ LOADING})$$

$$F_1 \left(\frac{6.532 + (4.619)^2}{6.532} + \frac{(1.013)^2}{6.532} \right) = 23586.13$$

$$F_1 (10.36) = 23586.13$$

$$F_1 = 2276.65 \#$$

TENSION IN BOLT 6

$$\sigma_1 = \frac{2276.65 \#}{0.226 \text{ in}^2} = 10073.7 \text{ PSI}$$

$$\text{AXIAL TENSION} = \frac{(8.29)(315 \#)}{8 \text{ BOLT}} = 322.88 \#$$

$$\sigma_{AT} = \frac{322.88 \#}{0.226 \text{ in}^2} = 1428.7 \text{ PSI}$$

SQUARE ROOT SUM OF THE SQUARES

$$\sigma_F = \left[6620.1^2 + 4620.1^2 + (10073.7 + 1428.7)^2 \right]^{1/2} \text{ BOLT 6}$$

$$\sigma_F = 14052.66 \text{ PSI BOLT 6}$$

IOWA ELECTRIC LIGHT AND POWER COMPANY CEDAR RAPIDS, IOWA R-2000 FS	DEPT. <u>DESIGN ENGINEERING</u>	CALC <u>MA4-14</u>
	PROJECT <u>DUANE ARNOLD ENERGY CENTER</u>	Sheet No. <u>18</u> of <u>23</u>
	SUBJECT <u>SEISMIC STRESS ANALYSIS HILLS-MECANUA ACTUATORS</u>	
	Computed by <u>(PW)</u>	Date _____ Checked by <u>PL</u> Date _____

SEISMIC LOADING ON MOUNTING HARDWARE

SQUARE ROOT SUM OF THE SQUARES

FOR INFORMATION ONLY

$$\gamma_F = \left[\gamma_{xy_1}^2 + \gamma_{xy_2}^2 + \gamma_{xy_3}^2 \right]^{\frac{1}{2}} = \left[1428.31^2 + 4037.4^2 + 0^2 \right]^{\frac{1}{2}} \quad \text{BOLT 6}$$

$$\gamma_F = 4282.60 \text{ PSI BOLT 6}$$

BASIS FOR COMPARISON $\frac{\gamma_F}{\gamma_A} + \frac{\sigma_F}{\sigma_A} \leq 1.5$ FOR DBE CONDITIONS

ASSUME BOLTS TO BE A307 GRADE (1) BOLTS
 $\gamma_{ALLOWABLE} = 10000 \text{ PSI}$

$\sigma_{ALLOWABLE} = 20000 \text{ PSI}$

$$\frac{4282.6}{10000} + \frac{14052.67}{20,000} = 1.131 \quad \text{BOLT 6}$$

$$\underline{\underline{1.131 \leq 1.5}} \quad \text{BOLT 6}$$

IOWA ELECTRIC LIGHT
AND POWER COMPANY

CEDAR RAPIDS, IOWA
R-2000 FS

DEPT. DESIGN ENGINEERING

PROJECT DUANE ARNOLD ENERGY CENTER

SUBJECT SEISMIC STRESS ANALYSIS HILLS-MCCANNA ACTUATORS

Computed by LOW

Date


Checked by MP

Date

CALC M34-14

Sheet No. 19 of 23

SEISMIC STRESSES ON THE MOUNTING YOLK



$$A = 10.44$$

$$B = 5.25$$

$$C = 5.00$$

$$D = 6.00$$

$$E(ODIA) = 3.126$$

$$F = 8.00$$

$$G = 8.00$$

$$H = 0.12$$

$$J = 12.00$$

$$K(ODIA) = 9.14$$


$$R = 0.50$$

R-4200 FS HAS

THE SAME STRESS

CONCENTRATOR VALUES

ELASTIC STRESS IN-PLANE BENDING



REFERENCE: FORMULAS FOR STRESS
AND STRAIN CONCENTRATION FACTORS
Pg. 593

$$K_T = K_1 + K_2 \left(\frac{2h}{d}\right) + K_3 \left(\frac{2h}{d}\right)^2 + K_4 \left(\frac{2h}{d}\right)^3$$

VERTICAL LOADS g_z LOADING

$$h = \frac{1}{2}(G-D) \quad r = H \quad d = G$$

$$h = \frac{1}{2}(8.00 - 6.00) = 1.00$$

$$r = 0.12$$

$$d = 8.00$$

$$K_1 = 3.577$$

$$K_2 \left(\frac{2h}{d}\right) = -0.629$$

$$K_3 \left(\frac{2h}{d}\right)^2 = -0.028$$

$$K_4 \left(\frac{2h}{d}\right)^3 = 0.006$$

$$K_T = 2.9260$$

HORIZONTAL LOADS g_y LOADING

$$h = \frac{1}{2}(8.00 - 5.00) = 1.50$$

$$r = 0.50$$

$$d = 8.00$$

$$r = R \quad h = \frac{1}{2}(G-C)$$

$$K_1 = 2.635$$

$$K_2 \left(\frac{2h}{d}\right) = -0.783$$

$$K_3 \left(\frac{2h}{d}\right)^2 = -0.022$$

$$K_4 \left(\frac{2h}{d}\right)^3 = 0.032$$

$$K_T = 1.862$$


FOR INFORMATION ONLY

IOWA ELECTRIC LIGHT AND POWER COMPANY CEDAR RAPIDS, IOWA R-2000 FS	DEPT. <u>DESIGN ENGINEERING</u>	CALC <u>M24-14</u>
	PROJECT <u>DUANE ARNOLD ENERGY CENTER</u>	Sheet No. <u>20</u> of <u>23</u>
	SUBJECT <u>SEISMIC STRESS ANALYSIS HILLS-McCANN ACTUATORS</u>	
	Computed by <u>DPW</u>	Date _____ Checked by <u>MP</u> Date _____

SEISMIC STRESS ANALYSIS ON THE MOUNTING YOKE

ELASTIC STRESS AXIAL TENSION

REFERENCE: FORMULAS FOR STRESS AND STRAIN Pg 593



FOR INFORMATION ONLY

$$h = \frac{1}{2}(G-D) \quad r = H \quad d = G$$

$$h = \frac{1}{2}(8.00-6.00) = 1.00 \quad r = 0.12 \quad d = 8.00$$

$$h/r = 8.33 \quad 2h/d = (2 \times 1.0)/8.00 = 0.250$$

$$K_1 = 1.042 + 0.982(8.333)^{1/2} - 0.036(8.333) = 3.577$$

$$K_2 = -0.074 - 0.156(8.333)^{1/2} + 0.010(8.333) = -0.608$$

$$K_3 = -3.418 + 1.220(8.333)^{1/2} - 0.005(8.333) = 0.0622$$


$$K_4 = 3.450 - 2.046(8.333)^{1/2} + 0.051(8.333) = -2.0312$$

$$K_x = K_1 + K_2\left(\frac{2h}{d}\right) + K_3\left(\frac{2h}{d}\right)^2 + K_4\left(\frac{2h}{d}\right)^3$$

$$K_x = 3.577 - 0.608(0.25) + 0.0622(0.25)^2 - 2.0312(0.25)^3$$

$$K_x = 3.397$$

g_z LOADINGS



$$M_y = (315 \#)(5.25 \text{ in})(8.2) = 13560.75 \text{ in-lb}$$

$$I = \frac{(5)(6)^3}{12} - \frac{\pi}{4}\left(\frac{3.126}{2}\right)^4 = 85.3 \text{ in}^4$$

$$\sigma_{T2} = \frac{M_c}{I} = \frac{(13560.75)(3.0)}{85.3} = 476.93 \text{ PSI}$$

$$\sigma_x = g_{z \text{ REFINO}} = K_2 \sigma_{T2} = (476.93)(2.926) = 1395.5 \text{ PSI}$$

$$\gamma_{2y} = \frac{(315 \#)(8.2)}{(5.0)(6.0) - \frac{\pi}{4}(3.126)^2} = 115.70 \text{ PSI}$$


SECTION A-A

IOWA ELECTRIC LIGHT AND POWER COMPANY CEDAR RAPIDS, IOWA R-2000 FS	DEPT. <u>DESIGN ENGINEERING</u>	CHLC <u>ME-4-14</u>
	PROJECT <u>DUANE ARNOLD ENERGY CENTER</u>	Sheet No. <u>21</u> of <u>23</u>
	SUBJECT <u>SEISMIC STRESS ANALYSIS HILLS-McCANN ACTUATORS</u>	
	Computed by <u>DR</u> Date _____	Checked by <u>DR</u> Date _____


SEISMIC STRESS ANALYSIS ON THE MOUNTING YOKE

g_y LOADING

FOR INFORMATION ONLY



SECTION B-B



$$\begin{aligned}
 M_1 (\text{END CAP}) &= 7.15 \text{ \#} \\
 M_2 (\text{SPRING}) &= 60.07 \text{ \#} \\
 M_3 (\text{SPRING CYL}) &= 43.60 \text{ \#} \\
 M_4 (\text{PISTON}) &= 46.00 \text{ \#} \\
 M_5 (\text{MAIN CYL}) &= 56.42 \text{ \#} \\
 M_6 (\text{MAIN CYL END CAP}) &= 18.68 \text{ \#}
 \end{aligned}$$

$$\text{SHEAR STRESS} = \frac{(Wt)(g)}{A}$$

$$\gamma_{zy} = \frac{(315 \text{ \#})(8.2)}{(5.0 \times 6.0) - \pi(3.126)^2}$$

$$\gamma_{zy} = 115.70 \text{ PSI}$$

$$\begin{aligned}
 M_2 &= (Wt)(g)(L) = (315 \text{ \#})(8.2)(6.25) \\
 M_2 &= 13560.75 \text{ IN-LB}
 \end{aligned}$$

$$I = \frac{(6 \times 5)^3}{12} - \frac{\pi(3.126)^4}{4} = 57.8 \text{ IN}^4$$

$$\sigma_y = \frac{M_L}{I} = \frac{(13560.75)(2.5)}{57.8} = 586.54 \text{ PSI}$$

$$\sigma_x = g_{\text{YBENDING}} = K_y \sigma_y = (1.862)(586.54) = 1092.13 \text{ PSI}$$

SHEAR STRESS CAUSED BY MOMENT M_x

$$M_x = g [M_1 D_1 + M_2 D_2 + M_4 D_4 + M_5 D_5 - M_6 D_6]$$

$$\begin{aligned}
 M_x &= 8.2 [(28.335)(7.15) + (60.07 + 43.60)20.820 + (46.0)(9.10) + (56.42)(4.006) \\
 &\quad - (6.920)(18.68)]
 \end{aligned}$$

$$M_x = 23586.13 \text{ IN-LB}$$

IOWA ELECTRIC-LIGHT AND POWER COMPANY CEDAR RAPIDS, IOWA R-2000 FS	DEPT. <u>DESIGN ENGINEERING</u>	CALC. <u>ME4-14</u>
	PROJECT <u>DWANE ARNOLD ENERGY CENTER</u>	Sheet No. <u>22</u> of <u>23</u>
	SUBJECT <u>SEISMIC STRESS ANALYSIS HILLS-MCCANNA ACTUATORS</u>	
	Computed by <u>HW</u>	Date _____ Checked by <u>MR</u> Date _____

SEISMIC STRESS ANALYSIS ON THE MOUNTING YOKE

- MODEL CROSS-SECTION AS AN APPROXIMATE CIRCULAR SECTION FOR COMPUTING TORSIONAL SHEAR STRESSES

REFERENCE: USS STEEL DESIGN MANUAL (JAN 1981)
R.L. BROCKENBROUGH & B.G. JOHNSON

$$\gamma_s = \frac{TR}{I_p}$$

LET $R_1 = \frac{5.0}{2} = 2.5''$ ∴ CONSERVATIVE I_p

T = TORSIONAL LOAD

R = RADIUS FOR LOCATION OF STRESS

I_p = POLAR MOMENT OF INERTIA

$$I_p = \frac{(R_1^4 - R_2^4) \pi}{2} = \frac{(2.5^4 - 1.563^4) \pi}{2} = 51.98 \text{ in}^4$$

$$\gamma_s = \frac{(23586.13 \text{ in-lb})(3.91 \text{ in})}{51.98 \text{ in}^4} = 1774.18 \text{ PSI}$$

$$R = (3^2 + 2.5^2)^{1/2} = 3.91''$$

FOR INFORMATION ONLY

q_x LOADINGS

$$F (\text{TENSION})_x = MA = (315 \#)(8.2q) = 2583 \#$$

$$\text{CROSS SECTIONAL AREA} = (6.0 \times 5.0) - \frac{\pi(3.126)^2}{4} = 22.33 \text{ in}^2$$

$$\sigma_{x_A} = \frac{2583 \#}{22.33 \text{ in}^2} = 115.70 \text{ PSI}$$

$$\sigma_{\text{AXIAL}} = (K_x)(\sigma_{x_A}) = (3.397)(115.7) = 393.03 \text{ PSI}$$

$$M_y' = 8.2 \left[(28.335)(7.15) + (60.07 + 43.60)(20.820) + (46.0) 9.10 \right. \\ \left. + (56.42)(4.006) - (6.920 \times 18.65) \right]$$

$$M_y' = 23586.13 \text{ in-lb}$$

$$\sigma_{x \text{ BENDING}} = \frac{M_y}{I} = \frac{(23586.13)(3.0)}{(85.3)} = 829.52 \text{ PSI}$$

$$\sigma_{x \text{ BEND}} = \sigma_{x \text{ BEND}} K_z = (829.52)(2.9260) = 2427.18 \text{ PSI}$$

IOWA ELECTRIC LIGHT AND POWER COMPANY	DEPT. <u>DESIGN ENGINEERING</u>	CALC <u>M24-14</u>
CEDAR RAPIDS, IOWA R-2000 FS	PROJECT <u>DUANE ARNOLD ENERGY CENTER</u>	SHEET No. <u>23</u> of <u>23</u>
	SUBJECT <u>SEISMIC STRESS ANALYSIS HILLS-McCANN ACTUATORS</u>	
	Computed by <u>(PW)</u>	Date <u> </u> Checked by <u>R</u> Date <u> </u>

SEISMIC STRESS ANALYSIS ON THE MOUNTING YOKE

SQUARE ROOT SUM OF THE SQUARES

$$\sigma_F = \left[(1395.5)^2 + (1092.13)^2 + (393.03 + 2427.18)^2 \right]^{1/2}$$

$$\sigma_F = 3330.72 \text{ PSI}$$

$$\tau_F = \left[(1157)^2 + (1157 + 1774.18)^2 + (0)^2 \right]^{1/2}$$

$$\tau_F = 1893.42 \text{ PSI}$$

FOR INFORMATION ONLY

$$\sigma_F = 3330.72 < (0.6)(30,000) = 18,000 \text{ PSI}$$

< 13,500 NOTCHED FATIGUE STRENGTH

$$\tau_F = 1893.42 < (0.4)(30,000) = 12,000 \text{ PSI}$$

< 13,500 NOTCHED FATIGUE STRENGTH

- STRESSES ON THE FOLLOWING COMPONENTS ARE GOVERNED BY THE OPERATING LOADS AND NOT THE DESIGN BASIS EARTH QUAKE CONDITIONS.

EXAMPLES: SCOTCH YOKE, CONNECTING PINS, SHAFT, PISTON.

SCOTCH YOKE:

OPERATING SPRING LOADS APPROX. $1270^{\#} + 190^{\#} = 1460^{\#}$
 SEISMIC LOADS APPROX. $(46.0^{\#})(8.2) = 377.20^{\#}$

ALLOWABLE STRESSES

$$\frac{1460^{\#}}{1.0} \geq \frac{1460^{\#} + 377.2^{\#}}{1.5}$$

$$1460 \geq 1224.8$$

∴ NO DETAILED ANALYSIS REQUIRED

CALC NO:

~~DESIGN~~ NO: MB4-14

Sheet 24 of 24A

DESIGN/REVIEW COMMENTS SHEET

DESIGN VERIFICATION

ALTERNATE CALCULATIONS

FOR INFORMATION ONLY

NO.	COMMENT	RESOLUTION/APPROVAL
	<p>NO COMMENTS</p>	<div data-bbox="826 1383 1470 1478"> <p><u>Donald W. Church</u> 4/29/84 Design Engineer Date</p> </div> <div data-bbox="826 1489 1470 1649"> <p><u>[Signature]</u> 4-24/84 Verifying Engineer Date</p> </div> <div data-bbox="826 1670 1470 1808"> <p><u>[Signature]</u> 4/30/84 Technical Group Leader Date</p> </div> <div data-bbox="330 1776 792 1968"> <p><u>[Signature]</u> 4-24/84 Verifying Engineer Date</p> </div> <div data-bbox="826 1840 1470 1968"> <p><u>[Signature]</u> 4/30/84 Supervising Engr. Nuclear Projects Date</p> </div>

FOR INFORMATION ONLY

IOWA ELECTRIC LIGHT AND POWER COMPANY

DUANE ARNOLD ENERGY CENTER

CALCULATION COVERSHEET

ANALYSIS/CALCULATION NO: M84-15

ANALYSIS/CALCULATION TITLE: SEISMIC STRESS ANALYSIS
HILLS-MCCANNA DAMPER ACTUATORS R-4200FS

REFERENCE DOCUMENTS

MAR NO: _____

DCR NO: _____

OTHERS: DDC 769
calc M84-12

PREPARED BY: Donald W. Church DW DATE: 7-23-84

REVIEWED BY: [Signature] MR DATE: 4-24/84

APPROVED BY: [Signature] DATE: 4/30/84

FINAL APPROVAL BY: [Signature] DATE: 4/30/84

Background

The purpose for compiling calculations M84-11, 12, 13, 14, 15 was to perform a seismic analysis on the critical components of the Hills-McCanna Pneumatic Damper Actuators. These actuators are part of the secondary containment isolation system at the Duane Arnold Energy Center.

On January 26, 1984, Iowa Electric notified the NRC by telephone that the above mentioned actuators were potentially deficient in meeting their purchase specification. A review of the documents relating to this discrepancy revealed that the isolation damper assemblies were purchased originally as complete assemblies which included the damper actuators. Subsequent orders for "like-for-like" replacement actuators were placed directly with the actuator manufacturer who was a subvendor to the damper manufacturer. This most recent purchase order for actuators revealed that a quality assurance program, as required for safety related equipment per 10CFR Part 50, is not currently in effect at the actuators manufacturer's facility.

Further review of the damper assembly documentation revealed that the seismic analysis performed on the damper assemblies did not seismically analyze the actuators themselves, but only considered their weight as it seismically affected the damper frame. This information prompted Iowa Electric to audit the damper manufacturer and check for documentation that pertained to the seismic qualifications of the isolation damper actuators. Results from the audit of the damper manufacturer revealed that the actuators were never purchased by the damper manufacturer as seismically qualified components nor did the damper manufacturer administer a Quality Assurance program concerning the purchase of the actuators.

Since no traceability or Certificate of Conformance was available for the seismic qualifications of the actuators, a seismic analysis was performed on the critical components of the actuators in order to seismically qualify the damper actuators for use in the Duane Arnold Energy Center. This seismic analysis followed the guidelines set forth in the original purchase specification for the isolation dampers (ref. Bechtel 7884-M-100). By seismically qualifying the isolation damper actuators, Iowa Electric will be able to buy Quality Level I actuators in accordance with Revision 1, Chapter 4 of the Quality Assurance Manual under Standard Industrial Quality Items 4.7.3.

Solution

A seismic analysis was performed on five models of the Rockwell Hills-McCanna Ramcon Pneumatic Actuator product line that are installed as isolation damper actuators at the Duane Arnold Energy Center. These five models include the following:

- R-260 FS
- R-450 FS
- R-960 FS
- R-2000 FS
- R-4200 FS

II FOR INFORMATION ONLY

The seismic analysis on the actuators followed the general project seismic requirements for frequency-not-determined class 1 equipment in the reactor building and in the control building (ref. Bechtel 7884-M-100, Technical Specifications for Isolation Dampers for the Duane Arnold Energy Center Unit 1, Revision 0, 12-28-70).

A visual inspection of all isolation damper actuators at the Duane Arnold Energy Center was made in order to verify model number, serial number and elevation location in the plant. After verifying the elevation location in the plant, static coefficients (g units) were determined for the highest installed actuator for each of the five actuator models. The horizontal static coefficient was then applied to all three of the orientation axis which eliminated many repetitious calculations and the need for detailed actuator orientation information. Applying the horizontal static coefficient to each axis provided conservative results since the horizontal coefficient is always greater than one plus the vertical coefficient ($F_{\text{vertical}} = (\text{Weight}) (1 + g_v)$, $F_{\text{horizontal}} = (\text{Weight}) (g_h)$, $g_h > 1 + g_v$).

The seismic analysis concentrated on the critical areas of the damper actuator where the seismically induced loads could possibly make the actuator fail, malfunction, or prevent operation. Five areas on each actuator model were identified as critical areas requiring a seismic analysis of the various components interfacing with that critical area. These five critical areas are identified as the following:

- Retaining key which holds the spring cylinder assembly to the main body cylinder
- Main body cylinder
- Press fit between main body cylinder and the mounting yoke
- Mounting hardware
- Mounting yoke

Dimensions and material specifications for the seismic analysis were obtained through the use of proprietary component drawings that were on loan to Iowa Electric from Rockwell Hills-McCanna of Carpentersville, Illinois. All prints applicable to this seismic analysis are listed in the reference section of the referenced calculations.

Four basic assumptions are applied throughout the entire seismic analysis of the damper actuators. These assumptions allow Iowa Electric to use the floor response spectra as the design/qualification spectra for the seismic analysis. The four basic assumptions are as follows:

- The mounting of the damper is a rigid structure ($f > 33$ cps)
- The damper itself is a rigid structure ($f > 33$ cps)
- The support bracket for the actuator is a rigid structure ($f > 33$ cps)
- The seismic requirements for evaluating the actuators are the same as those for the isolation dampers.

III FOR INFORMATION ONLY

The maximum seismic stresses were calculated by using the square root sum of the squares method for combining the three earthquake direction stresses as recommended in the UFSAR for seismic analysis at the Duane Arnold Energy Center. A second method, the distortion energy method was used for combining stresses at the press fit between the main body cylinder and the mounting yoke. The distortion energy method was used in place of the square root sum of the squares method because the stresses due to the press-fit condition exceeded and dominated those caused by the seismic event. All maximum stresses were then compared to some fraction of the yield strength depending on the material type and stress type. Operability after a DBE event was ensured by requiring that the maximum stress from combined seismic and normal loads should not exceed 90% of the yield stress of the material.

Conclusion

After completing the above described seismic analysis on the five models of Hills-McCanna actuators installed on the isolation dampers at the Duane Arnold Energy Center, it was found that the maximum stresses from the combined seismic and normal loads do not exceed the material yield requirements defined in the isolation damper purchase specification. The results of this seismic analysis reveal that the five models of Hills-McCanna actuators are seismically qualified for use at the Duane Arnold Energy Center.

References

Bechtel Purchase Specification 7884-M-100

Formulas for Stress and Strain; Raymond J. Roark, Warren C. Young, Fifth Edition, McGraw-Hill Book Co. 1975

Hills-McCanna Information Bulletins; R-1090, R-1090A, R110C, R1100A, R-111C, R-1110A, R-112D, R-1120A, R-113D, R-1130A

Marks' Standard Handbook for Mechanical Engineers' Baumeister Eighth Edition, McGraw-Hill Book Company 1978

Materials Selector 75; Reinhold Publishing Co. Mid September 1974, Vol. 80, No. 4, Brown Printing Co.

Mechanical Engineering Design; Joseph E. Shigley, Third Edition, McGraw-Hill Book Co. 1977

Mechanics of Materials; Higdon, Ohlsen, Stiles, Weese, Riley Third Edition, John Wiley and Sons 1978

FOR INFORMATION ONLY

Rockwell Hills-McCanna; Proprietary Drawings

DATA: Information contained on drawings is proprietary and confidential and is not to be given or loaned to others. Drawings are to be returned to Rockwell upon completion of their intended use in making the seismic analysis.

<u>R260</u>	<u>R450-R960</u>	<u>R2000-R4200</u>
430-1004	450-7511	460-7511
430-7510	450-1005	460-1001
430-7511	450-7512	460-7509
430-3003	450-3005	460-3001
430-3005	450-3007	460-3003
430-4101	450-4101	460-4101
430-4102	450-4102	460-4102
430-2101	450-2101	460-2101
430-2904	450-2906	460-2904
430-2502	450-2507	460-2503
430-2501	450-2501	460-2502
430-3321	450-3201	460-3208
430-3322	450-3202	460-3209
430-3325	450-3203	460-3210
430-3201	450-3326	460-3317
430-3202	450-3325	460-3316
430-3203	450-3321	460-3320
	450-3320	460-3321
		460-3314
		460-3315

U.S.S. Steel Design Manual; R.L. Brockenbrough and B.G. Johnson, Jan. 1981

MARTIN REIFSCHNEIDER Reviewer for Calculations M84-11,12,13,14,15

POSITION

Senior Civil/Structural Engineer

EDUCATION

BS, Civil Engineering, University of Michigan
MS, Civil/Structural Engineering, University of Michigan

PROFESSIONAL DATA

Registered Professional Engineer in Michigan

SUMMARY

1 year: Senior Engineer; Civil/Structural Staff
4 years: Senior Engineer; Midland, Palisades, and Big Rock Point Nuclear Power Plants
1 year: Resident Engineer, Midland Nuclear Power Plant

EXPERIENCE

Mr. Reifschneider is currently assigned as a civil/structural engineer on the civil/structural staff. His duties include; preparation of design standards; review of project calculations, drawings, specifications and seismic qualification of equipment; providing consultation to civil/structural engineers engaged in the design of nuclear and fossil power plants; solving special static and dynamic structural problems.

Prior to joining the civil/structural staff, Mr. Reifschneider was a civil/structural engineer on Consumers Power Company's Palisades project. His duties included finite element analysis of the biological shield wall, seismic analysis and design of blockwall supports, and seismic analysis and design of the auxiliary building addition including the review of seismic equipment qualifications.

Prior to joining the Palisades project, Mr. Reifschneider was a civil/structural resident engineer at the jobsite of Consumers Power company's Midland nuclear plant project. His duties included interfacing with construction personnel on the design, erection, and construction of seismic instrument and equipment supports.

MARTIN REIFSCHNEIDER

Reviewer for Calculations M84-11,12,13,14,15

Prior to his jobsite assignment, Mr. Reifschneider conducted research on the inelastic design and behavior of braced structural steel systems, moment frame structural steel system, and reinforced concrete shear wall systems. He co-authored three Bechtel reports on the findings of this research.

Prior to his research assignment, Mr. Reifschneider was a civil/structural engineer on the Midland nuclear plant project. His duties included designing seismic supports for HVAC ducts and electrical cabletrays.

IOWA ELECTRIC LIGHT AND POWER COMPANY CEDAR RAPIDS, IOWA	DEPT. <u>DESIGN ENGINEERING</u>
	PROJECT <u>DUANE ARNOLD ENERGY CENTER</u> Sheet No. <u>VII</u> of <u>VIII</u>
	SUBJECT <u>SEISMIC ANALYSIS HILLS-MCCANNA ACTUATORS</u>
	Computed by <u>[Signature]</u> Date _____ Checked by _____ Date _____

SUMMARY OF RESULTS R-4200 FS

<u>COMPONENT</u>	<u>MANUFACTURED MATERIAL</u> <u>ALLOWABLE STRESS</u>	<u>LOW GRADE MATERIAL</u> <u>ALLOWABLE STRESS</u>	<u>*CALCULATED STRESS (σ_F, τ_F)</u> <u>STRESS COMPARISON</u>
<u>RETAINING KEY</u>	303 STAINLESS STEEL $S_{YA} = (0.5)(S_Y)$ $S_{YA} = 17500 \text{ psi}$	NOT APPLICABLE NOT APPLICABLE	$\tau_F = 2379 \text{ psi}$ <u>$2379 < 17500$</u>
MAIN BODY CYLINDER OUTSIDE SURFACE INSIDE SURFACE	1020 STEEL $S_{YA} = (0.9)(S_Y)$ $S_{YA} = 43200 \text{ psi}$	1006 STEEL $S_{YA} = (0.9)(S_Y)$ $S_{YA} = 36900$	$\sigma_F = 8811 \text{ psi}$ <u>$8811 < 36900$</u> $\sigma_F = 9492 \text{ psi}$ <u>$9492 < 36900$</u>
<u>MOUNTING HARDWARE</u> 5/8-11 BOLT	A307 GRADE 1 BOLT $\sigma_A = 20000 \text{ psi}$ $\tau_A = 10000 \text{ psi}$		$\sigma_F = 7918 \text{ psi}$ $\tau_F = 1943 \text{ psi}$
NOTE: <u>LOWEST GRADE BOLT ASSUMED INSTALLED.</u>			
BASIS FOR COMPARISON: $\frac{\tau_F}{\tau_A} + \frac{\sigma_F}{\sigma_A} \leq 1.5$ FOR DBE CONDITIONS <u>$0.590 \leq 1.5$</u>			

*CALCULATED STRESS USING SRSS OF THE EARTHQUAKE DIRECTIONS OR MAXIMUM DISTORTION ENERGY THEORY.

IOWA ELECTRIC LIGHT AND POWER COMPANY CEDAR RAPIDS, IOWA	DEPT. <u>DESIGN ENGINEERING</u>
	PROJECT <u>DUANE ARNOLD ENERGY CENTER</u> Sheet No. <u>VIII</u> of <u>VIII</u>
	SUBJECT <u>SEISMIC ANALYSIS HILLS-MCCANNA ACTUATORS</u>
	Computed by <u>DW</u> Date <u>6</u> Checked by <u></u> Date <u></u>

SUMMARY OF RESULTS CONTINUED R-4200FS

<u>COMPONENT</u>	<u>MANUFACTURED MATERIAL</u> <u>ALLOWABLE STRESS</u>	<u>LOW GRADE MATERIAL</u> <u>ALLOWABLE STRESS</u>	<u>*CALCULATED STRESS (σ_F, τ_F)</u> <u>STRESS COMPARISON</u>
<u>BOOM CASTING (MOUNTING YOKE)</u>	<u>CLASS 35 CAST IRON</u> $S_y = (0.6 \times S_y)$ $S_{yA} = 18000 \text{ psi}$ $S_{yA} = (0.4 \times S_y)$ $S_{yA} = 12000 \text{ psi}$	<u>CLASS 20 CAST IRON</u> $S_{yA} = (0.6 \times S_y)$ $S_{yA} = 12000 \text{ psi}$ $S_{yA} = (0.4 \times S_y)$ $S_{yA} = 8000 \text{ psi}$	$\sigma_F = 1746 \text{ psi}$ $\tau_F = 158 \text{ psi}$ <u>$1746 < 12000$</u> <u>$158 < 8000$</u>
<u>PRESS FIT BETWEEN MAIN CYLINDER AND MOUNTING YOKE</u>	<u>CAST IRON - 1020 STEEL</u> <u>MINIMUM INTERFERENCE = 0.001"</u> <u>FORCE REQUIRED TO SLIDE MAIN CYLINDER FROM MOUNTING YOKE = 2970 #</u>	<u>RESULTANT AXIAL FORCE = 2102 #</u> <u>$2102 < 2970$</u>	

IOWA ELECTRIC LIGHT AND POWER COMPANY CEDAR RAPIDS, IOWA R-4200 FS	DEPT. <u>DESIGN ENGINEERING</u>	CALC. <u>MB4-15</u>	
	PROJECT <u>DUANE ARNOLD ENERGY CENTER</u>	Sheet No. <u>1</u>	of <u>16</u>
	SUBJECT <u>SEISMIC STRESS ANALYSIS HILLS-MCCANNA ACTUATORS</u>		
	Computed by <u>DV</u>	Date _____	Checked by <u>MR</u> Date _____

WEIGHT DETERMINATION

FOR INFORMATION ONLY

CYLINDER - SPRING CYLINDER

$$\underline{\underline{WEIGHT = 43.60 \#}}$$

REFERENCE: R-2000FS Pg 3

MAIN BODY CYLINDER

$$D_o = 9.2310"$$

$$D_i = 8.560"$$

$$h = 28.445"$$

$$\rho = 0.283 \#/\text{IN}^3$$

$$\text{VOLUME} = \frac{\pi (9.2310^2 - 8.560^2) (28.445)}{4}$$

4

$$\text{VOLUME} = 266.70 \text{ IN}^3$$

$$\underline{\underline{WEIGHT = (266.70 \text{ IN}^3) (0.283 \#/\text{IN}^3) = 75.48 \#}}$$

SPRING CYLINDER END CAP

$$\underline{\underline{WEIGHT = 7.15 \#}}$$

REFERENCE: R-2000FS Pg 3

END CAP (MAIN CYLINDER)

$$\text{WEIGHT} = 18.68 \#$$

REFERENCE: R2000 FS Pg 1

SPRINGS

$$\text{WEIGHT} = 60.07 \#$$

REFERENCE R2000 FS Pg 1

PISTON

$$\text{WEIGHT} = 46.0 \#$$

REFERENCE R2000FS Pg

IOWA ELECTRIC LIGHT AND POWER COMPANY CEDAR RAPIDS, IOWA R-4200 FS	DEPT. <u>DESIGN ENGINEERING</u>	CALC. <u>ME4-15</u>
	PROJECT <u>DWANE ARNOLD ENERGY CENTER</u>	Sheet No. <u>2</u> of <u>16</u>
	SUBJECT <u>SEISMIC STRESS ANALYSIS HILLS-MCCANNA ACTUATORS</u>	
	Computed by <u>DW</u>	Date _____ Checked by <u>MP</u> Date _____

IV-AD-52 A & B

REACTOR BUILDING ELEVATION 786'-0"
BOLTED SUPPORT SYSTEM


HORIZONTAL (g) LOADS : OBE DBE
2.7 5.4

- MAXIMUM HORIZONTAL (g) LOAD FOR WORST CASE ACTUATOR ELEVATION APPLIED TO ALL AXIS OF SEISMIC ANALYSIS.

5.4 g LOAD IS GREATER THAN (1+g) LOAD ON VERTICAL (g) LOAD SPECIFICATION.

- MAXIMUM AIR PRESSURE = 100 PSI ACTING ON PISTON 8.565" DIAMETER.

SHEAR STRESSES ON RETAINING KEY AXIAL ORIENTATION



$$M_1 (\text{SPRING CYL. END CAP}) = 7.15 \#$$

$$M_2 (\text{SPRING}) = 60.07 \#$$

$$M_3 (\text{SPRING CYL.}) = 43.60 \#$$

$$M_4 (\text{PISTON}) = 46.0 \#$$

$$q_{\text{LOAD}} = 8.2 \quad \frac{156.82 \#}{156.82 \#}$$

SPRING TEST LENGTHS (NESTED SPRINGS)

REFERENCE:

$$460-3001 @ 20.05" = 1263 \# \quad \text{WITH } 181 \#/\text{IN SPRING RATE}$$

$$460-3003 @ 20.05" = 368 \# \quad \text{WITH } 64 \#/\text{IN SPRING RATE}$$

14.55" MAXIMUM SPRING COMPRESSION LENGTH WITH PISTON AT STOP.

$$F_{\text{SPRING}} = 1263 \# + (20.05 - 14.55) 181 + 368 + (20.05 - 14.55) 64$$

$$F_{\text{SPRING}} = 2978.5 \#$$

$$F_{\text{AIR PRESSURE}} = \frac{(100 \text{ PSI}) \pi (8.565)^2}{4} = 5761.6 \#$$

$$F_{\text{WEIGHT}} = (5.4)(156.82) = 846.83 \#$$


$$F_{\text{X TOTAL}} = 2978.5 \# + 5761.6 \# + 846.83 \# = 9586.93 \#$$

(CONSERVATIVE APPROACH)

FOR INFORMATION ONLY

R-4200 FS

RETAINING KEY CROSS SECTION
REFERENCE: 460-2904



0.187 SQUARE

303 STAINLESS STEEL

ACTIVE CIRCUMFERENTIAL LENGTH = 26.3"

$$\tau = \frac{F}{A} = \frac{9586.93}{(26.3)(0.187)} = 1949.32 \text{ PSI}$$

FOR INFORMATION ONLY

S_y = YIELD STRENGTH S.S. 303 = 35,000 PSI

S_y = SHEAR STRENGTH = $(0.5)(S_y) = (0.5)(35000) = 17500 \text{ PSI}$


ALLOWABLE SHEAR STRESS = 17500 PSI

$$1949.32 < 17500 \text{ PSI}$$

STRESS ON THE RETAINING RING FROM MOMENTS ABOUT THE KEY Q DUE TO THE SPRING CYLINDER

$$M_y = -q [M_1(13.921) + (M_2 + M_3)(6.961)]$$

$$M_y = 5.4 [(7.15)(13.921) + (60.07 + 43.6)(6.961)] = 4434.38 \text{ IN-LB}$$



SHEAR STRESS = $\tau(\theta)$ DUE TO M_y

t = THICKNESS OF RETAINING RING = 0.187"

$r = 4.2770$

$M = 4434.38$


ACTIVE CIRCUMFERENTIAL RETAINING RING LENGTH = 26.3 INCH

ACTIVE LENGTH PER QUADRANT = 6.575"

$$\text{QUADRANT CIRCUMFERENCE} = \frac{2\pi(4.277)}{4} = 6.7183"$$

$$\theta = \frac{6.575}{6.7183} \times \frac{\pi}{2} = 1.5373 \text{ RADIANS}$$

- THETA (θ) IS THE ANGLE THAT CORRESPONDS TO THE RETAINING RING GAP FOR ONE QUADRANT. GAP IS DIVIDED INTO TWO EQUAL PARTS AT $+\gamma$ AND $-\gamma$.



$$\int_0^\theta \tau(\theta) t r^2 \sin \theta d\theta = \frac{M_y}{4}$$

R-4200 FS**FOR INFORMATION ONLY**STRESS ON THE RETAINING RING FROM MOMENTS
ABOUT Y (M_y) DUE TO THE SPRING CYLINDER
ASSEMBLY

$$\gamma(\theta) = K r \sin \theta$$

K = CONSTANT FROM THE LINEAR
RELATIONSHIP BETWEEN SHEAR
FORCE AND DISTANCE (Y)

$$\int_0^{\theta} K t r^3 \sin^2 \theta d\theta =$$

$$= K t r^3 \int_0^{\theta} \sin^2 \theta d\theta = \frac{M_y}{4}$$

$$\int_0^{\theta} \sin^2 \theta d\theta = \left[-\frac{1}{4} \sin 2\theta + \frac{1}{2} \theta \right]_0^{1.54} = \frac{1}{4} \sin(2)(1.54) + \frac{1.54}{2}$$
$$= 0.755$$

SOLVE FOR K

$$\frac{M_y}{4} = K (t)(r)^3 (0.755) \quad K = \frac{(4434.38)}{(4)(0.187)(4.277)^3(0.755)}$$

$$K = 100.41$$

$$\gamma(\theta) = K r \sin \theta = (100.41)(4.277) \sin(1.54) = 429.26 \text{ PSI}$$

$$\gamma_{\text{TOTAL}} = \gamma(\theta) + \gamma_A = 429.26 + 1949.32 = 2378.79 \text{ PSI}$$

$$S_y = \text{SHEAR STRENGTH} = 0.5(S_y)$$

$$S_y = 35,000 \text{ PSI FOR 303 S.S.}$$

$$S_y = (0.5)(35000) = 17500 \text{ PSI}$$

$$\underline{2378.79 \text{ PSI} < 17500 \text{ PSI}}$$

STRESSES DUE TO THE PRESS FIT CONDITION BETWEEN
THE MOUNTING YOKE AND THE CYLINDER BODY

$$\text{INTERFERENCE (I)} = 2 \epsilon_1 + 2 \epsilon_2$$

$$\text{MOUNTING YOKE} = \frac{9.141}{9.143} \text{ DIA}$$

$$\text{MAIN CYLINDER BODY} = \frac{9.144}{9.146} \text{ DIA}$$

$$\text{MAXIMUM INTERFERENCE} = |9.146 - 9.141| = 0.005 \text{ IN}$$

IOWA ELECTRIC LIGHT
AND POWER COMPANY
CEDAR RAPIDS, IOWA
R-4200 FS

DEPT. DESIGN ENGINEERING CALC. MB4-15
PROJECT DUANE ARNOLD ENERGY CENTER Sheet No. 5 of 16
SUBJECT SEISMIC STRESS ANALYSIS HILLS-MCCANNA ACTUATORS
Computed by DW Date _____ Checked by MR Date _____

STRESS DUE TO THE PRESS FIT CONDITIONS BETWEEN
THE MOUNTING YOKE AND THE CYLINDER BODY

REFERENCE: HIGDON "MECHANICS OF MATERIALS"
JOHN WILEY & SONS 1978 Pg 163, 164

$$\epsilon_1 = \frac{b_1^2 P_s}{(c^2 - b_1^2)} \left[(1-\nu)b_1^2 + (1+\nu)c^2 \right]$$

$$\epsilon_2 = \frac{b_2^2 P_s}{(b_2^2 - a^2)E_c b_2} \left[(1-\nu)b_2^2 + (1+\nu)a^2 \right]$$

$$a = \frac{8.560''}{2} = 4.280'' \quad \text{CYLINDER}$$

$$b_1 = \frac{9.143''}{2} = 4.5715'' \quad \text{YOKE}$$

$$b_2 = \frac{9.144''}{2} = 4.572'' \quad \text{CYLINDER}$$

$$c = \frac{10.44''}{2} = 5.220'' \quad \text{YOKE}$$

PRINT REF.

460-3317


460-3311

460-3317

460-3311

$$I = 2\epsilon_1 + 2\epsilon_2$$

$$I = 0.005 \text{ in}$$



$$0.005 = \frac{(4.5715)^2 P_s (2)}{(5.22^2 - 4.5715^2)(15 \times 10^6)(4.5715)} \left[(1-0.29)(4.5715)^2 + (1+0.29)(5.22)^2 \right]$$

$$+ \frac{(4.572)^2 P_s (2)}{(4.572^2 - 4.28^2)(30 \times 10^6)(4.572)} \left[(1-0.30)(4.572)^2 + (1+0.30)(4.28)^2 \right]$$

$$0.005 = 4.7985 (10)^{-6} P_s + 4.5336 (10)^{-6} P_s$$

$$P_s = 535.78 \text{ PSI (MAXIMUM INTERFERENCE)}$$

FOR INFORMATION ONLY

STRESSES DUE TO THE PRESS FIT CONDITION
BETWEEN THE MOUNTING YOKE AND THE CYLINDER BODY

EXTERNAL PRESSURE

$$\sigma_r = -\frac{b_2^2 P_o}{b_2^2 - a^2} \left[1 - \frac{a^2}{r^2} \right]$$

$$\sigma_t = \frac{-b_2^2 P_o}{b_2^2 - a^2} \left[1 + \frac{a^2}{r^2} \right]$$

INTERNAL PRESSURE

$$\sigma_r = \frac{b_1^2 P_i}{c^2 - b_1^2} \left[1 - \frac{c^2}{r^2} \right]$$

$$\sigma_t = \frac{b_1^2 P_i}{c^2 - b_1^2} \left[1 + \frac{c^2}{r^2} \right]$$

STRESS IN MOUNTING YOKE CASTING INTERNAL PRESSURE
INSIDE SURFACE

$$\sigma_r = \frac{(4.5715^2)(535.78)}{5.22^2 - 4.5715^2} \left[1 - \frac{5.22^2}{4.5715^2} \right] = -535.78 \text{ PSI}$$

$$\sigma_t = \frac{(4.5715^2)(535.78)}{5.22^2 - 4.5715^2} \left[1 + \frac{5.22^2}{4.5715^2} \right] = 4062.53 \text{ PSI}$$

INSIDE SURFACE WORST CASE CONDITION

STRESS IN CYLINDER EXTERNAL PRESSURE

OUTSIDE CYLINDER SURFACE

$$\sigma_r = -\frac{(4.572^2)(535.78)}{4.572^2 - 4.280^2} \left[1 - \frac{4.280^2}{4.572^2} \right] = -535.78 \text{ PSI}$$

$$\sigma_t = -\frac{(4.572^2)(535.78)}{4.572^2 - 4.280^2} \left[1 + \frac{4.280^2}{4.572^2} \right] = -8129.94 \text{ PSI}$$

FOR INFORMATION ONLY

IOWA ELECTRIC-LIGHT
AND POWER COMPANY
CEDAR RAPIDS, IOWA
R-4200FS

DEPT. DESIGN ENGINEERING CALC. MB4-15
PROJECT DWANE ARNOLD ENERGY CENTER Sheet No. 7 of 16
SUBJECT SEISMIC STRESS ANALYSIS HILLS-MCCANNA ACTUATORS
Computed by DPW Date _____ Checked by MP Date _____

STRESSES DUE TO THE PRESS FIT CONDITION BETWEEN
THE MOUNTING YOKE AND THE CYLINDER BODY


INSIDE CYLINDER SURFACE

FOR INFORMATION ONLY

$$\sigma_r = \frac{-(4.572)^2 (535.78)}{4.572^2 - 4.280^2} \left[1 - \frac{4.280^2}{4.280^2} \right] = 0 \text{ PSI}$$

$$\sigma_t = \frac{-(4.572)^2 (535.78)}{4.572^2 - 4.280^2} \left[1 + \frac{4.280^2}{4.280^2} \right] = -8665.72 \text{ PSI}$$

STRESS ON THE CYLINDER DUE TO MOMENT CAUSED
BY MAIN CYLINDER BODY, PISTON, SPRING CYLINDER,
AND SPRING CYLINDER END CAP



M_1 (END CAP) = 7.15 #
 M_2 (SPRING) = 60.07 #
 M_3 (SPRING CIL) = 43.6 #
 M_4 (PISTON) = 46.0 #
 M_5 (MAIN CIL) = 75.48 #

- MASS OF CYLINDER IS MODELED TO ACT ON RIGHT SIDE OF YOKE. EXCLUDES COUNTERACTING MOMENT DUE TO MASS OF CYLINDER AND END CAP ON THE LEFT SIDE OF YOKE ϕ

SUMMING MOMENTS ABOUT Y-Y

$$M_y = g \left[M_1 l_1 + (M_2 + M_3) l_2 + M_4 l_4 + M_5 l_5 \right]$$

$$M_y = 5.4 \left[(7.15)(25.36) + (60.07 + 43.6)(17.846) + (46.0)(6.1263) + (75.48)(4.15) \right]$$

$$M_y = 14182.12 \text{ IN-LB}$$

STRESSES ON THE CYLINDER CONTINUED


MOMENT OF INERTIA I_{yy} & ACTUATOR NEUTRAL AXIS

$$I_{yy} = \frac{\pi}{64} (d_o^4 - d_i^4) = \frac{\pi}{64} (9.146^4 - 8.565^4) =$$

$$I_{yy} = 79.31 \text{ IN}^4$$

$$\sigma'_T = \frac{M_{yy} C}{I_{yy}} = \frac{(14182.12 \text{ IN-IB})(4.573)}{79.31} = 817.74 \text{ PSI}$$

$$\sigma_{\text{AIR PRESSURE}} = \frac{5761.6 \text{ \#}}{\pi(9.146^2 - 8.565^2)/4} = 712.91 \text{ PSI}$$



$$\sigma'_T = \frac{M_{yy} C}{I_{yy}} = \frac{(14182.12)(4.2825)}{79.31 \text{ IN}^4}$$

$$\sigma'_T = 765.79 \text{ PSI}$$

$$\sigma'_b = \sigma_{\text{AIR}} + \sigma'_T = 712.91 + 817.74 = 1530.65$$

$$\sigma'_t = -8129.94$$

$$\sigma'_r = -535.78$$

$$\sigma_b = \sigma_{\text{AIR}} + \sigma_T = 712.91 + 765.79 = 1478.7 \text{ PSI}$$

$$\sigma_t = -8665.72 \text{ PSI}$$

$$\sigma_r = 0$$

FOR INFORMATION ONLY

IOWA ELECTRIC LIGHT
AND POWER COMPANY
CEDAR RAPIDS, IOWA

DEPT. DESIGN ENGINEERING CALC: ME4-15
PROJECT DURNE ARNOLD ENERGY CENTER Sheet No. 9 of 16
SUBJECT SEISMIC STRESS ANALYSIS HILLS-MCCANNA ACTUATORS
Computed by QW Date _____ Checked by MP Date _____

R-4200 FS

SUMMATION OF CYLINDER STRESSES USING MAXIMUM
DISTORTION ENERGY THEORY

• REFERENCE: MECHANICS OF MATERIALS Pg. 405

$$\sigma_F = \left\{ \frac{1}{2} \left[(\sigma_t - \sigma_z)^2 + (\sigma_t - \sigma_r)^2 + (\sigma_r - \sigma_b)^2 \right] \right\}^{1/2}$$

$$\sigma_F = \left\{ \frac{1}{2} \left[(1530.65 + 8129.94)^2 + (-8129.94 + 535.78)^2 + (-535.78 - 1530.65)^2 \right] \right\}^{1/2}$$

$$\sigma_F = 8811.03 \text{ PSI}$$

$$\sigma_F = \left\{ \frac{1}{2} \left[(1478.7 + 8665.72)^2 + (-8665.72)^2 + (0 - 1478.7)^2 \right] \right\}^{1/2}$$

$$\sigma_F = 9491.85 \text{ PSI}$$

$$S_y = 43,200 \text{ PSI (1020 STEEL YIELD @ 90\%)}$$

$$\sigma_F = 8811.03 < 43200 \text{ PSI}$$

$$\sigma_F = 9491.85 < 43200 \text{ PSI}$$


FOR INFORMATION ONLY

IOWA ELECTRIC LIGHT
AND POWER COMPANY
CEDAR RAPIDS, IOWA


DEPT. DESIGN ENGINEERING CALC-M24-15
PROJECT DUANE ARNOLD ENERGY CENTER Sheet No. 10 of 16
SUBJECT SEISMIC STRESS ANALYSIS HILLS-MCCANNA ACTUATORS
Computed by DA Date: _____ Checked by MP Date: _____

R-4200 FS

SEISMIC AXIAL LOAD ACTING ON PRESS FIT OF
CYLINDER THROUGH MOUNTING YOKE



FOR INFORMATION ONLY



MINIMUM INTERFERENCE

$$I = 9.143 - 9.144 = 0.001''$$

ON DIAMETER

SOLVING FOR INTERFACIAL PRESSURE P_s , Pg 164 MECHANICS OF MAT'L'S.

$$0.001 \text{ IN} = 2 \left[\frac{(4.572)^2 (P_s)}{(5.22^2 - 4.572^2)(5 \times 10^6)(4.572)} \right] \left[(1-0.29)(4.572)^2 + (1.29)(5.22)^2 \right]$$

$$+ 2 \left[\frac{(4.572)^2 P_s}{(4.572^2 - 4.283^2)(30 \times 10^6)(4.572)} \right] \left[(1-0.29)(4.572)^2 + (1.29)(4.283)^2 \right]$$

$$0.001 \text{ IN} = P_s \left[4.803 \times 10^{-6} + 1.003 \times 10^{-6} \right]$$

$$P_s = 172.24$$

$$M_1 (\text{END CAP}) = 7.15 \# (2) = 14.30$$

$$M_2 (\text{SPRING OIL}) = 60.07 \# (2) = 120.14$$

$$M_3 (\text{SPRING}) = 43.60 \# (2) = 87.20$$

$$M_4 (\text{PISTON}) = 46.0 \# (2) = 92.0$$

$$M_5 (\text{MAIN CHL}) = 75.48 = 75.48$$

$$\text{TOTAL MASS } M_T = 389.12 \#$$

$$\text{AXIAL FORCE} = M_T(g) = (389.12)(5.4) = 2101.25 \#$$

FORCE REQUIRED TO SLIDE CYLINDER FROM MOUNTING YOKE

SHOE FORCE $= F_s = \pi f P d l$

l = LENGTH OF FIT = 6.00"

d = CYLINDER DIA = 9.146"

P_s = UNIT PRESSURE FIT = 172.24 PSI


f = COEFFICIENT OF FRICTION = 0.10 (AVERAGE VALUES 0.10 → 0.15)
USE 0.10

FOR INFORMATION ONLY

$$F = \pi (0.10)(172.24)(9.146)(6.00) = 2969.38 \text{ \#}$$

$$\underline{2969.38 \text{ \#} > 2101.25 \text{ \#}}$$


SEISMIC LOADING ON MOUNTING HARDWARE



g_z LOADING

M_A = MASS OF ACTUATOR INCLUDING
MOUNTING YOKE = 315 \#

g_z LOADING



$$F_1(L_1) + F_2(L_2) + F_3(L_3) = M_y$$

$$\frac{F_1}{L_1} = \frac{F_2}{L_2} = \frac{F_3}{L_3} \quad F_2 = F_1 \frac{L_2}{L_1}$$

$$F_3 = F_1 \frac{L_3}{L_1}$$

$$F_1 L_1 + F_1 \frac{L_2^2}{L_1} + F_1 \frac{L_3^2}{L_1} = M_y$$

$$M_y = (5.4)(460 \text{ \#})(6.0) = 14904.00 \text{ in-lb}$$

IOWA ELECTRIC LIGHT
AND POWER COMPANY
CEDAR RAPIDS, IOWA
R-4200 FE

DEPT. DESIGN ENGINEERING CALC. MR4-15
PROJECT DVANE ARNOLD ENERGY CENTER Sheet No. 12 of 16
SUBJECT SEISMIC STRESS ANALYSIS HILLS-MCCANNA ACTUATORS
Computed by [Signature] Date _____ Checked by [Signature] Date _____

SEISMIC LOADING ON MOUNTING HARDWARE

g_z LOADING CONTINUED

$$F_1 \left[6.532 + \frac{4.619^2}{6.532} + \frac{1.913^2}{6.532} \right] = 14904.0 \text{ IN-LB}$$

$$F_1 (10.355) = 14904.0 \text{ IN-LB}$$

$$F_1 = 1438.82 \# \text{ BOLT 6}$$

$$F_2 = \frac{F_1 L_2}{L_1} = \frac{(1438.82)(4.619)}{6.532} = 1017.44 \# \text{ BOLT 5}$$

F_S = FORCE SHEAR IN MOUNTING BOLTS

$$F_S = \frac{(460)(54)}{8 \text{ BOLTS}} = 310.5 \# \text{ PER BOLT}$$

TENSILE STRESS AREA $\frac{5}{8}$ -11 UNC = 0.226 IN^2

$$\tau_{xy} = \frac{310.5 \#}{0.226 \text{ IN}^2} = 1373.90 \text{ PSI}$$

$$\sigma_x = \frac{1438.82 \#}{0.226 \text{ IN}^2} = 6366.5 \text{ PSI}$$

g_y LOADING

TENSION ON BOLT 5 FROM g_y LOADING $F_{T5} = 1438.82 \#$,
THE SAME LOAD AS WITH A g_z LOAD ON BOLT 6

TENSION ON BOLT 6 FROM g_y LOADING $F_{T6} = 1017.44 \#$,
THE SAME LOAD AS WITH A g_z LOAD ON BOLT 5

$$\sigma_x = \frac{1017.44 \#}{0.226 \text{ IN}^2} = 4501.95 \text{ PSI}$$

$$\tau_{xy_2} = \frac{(5.4g)(460 \#)}{(8)(0.226 \text{ IN}^2)} = 1373.89 \text{ PSI}$$

FOR INFORMATION ONLY

IOWA ELECTRIC-LIGHT AND POWER COMPANY CEDAR RAPIDS, IOWA R-4200 FS	DEPT. <u>DESIGN ENGINEERING</u>	CALC. <u>M24-15</u>
	PROJECT <u>DUANE ARNOLD ENERGY CENTER</u>	Sheet No. <u>13</u> of <u>16</u>
	SUBJECT <u>SEISMIC STRESS ANALYSIS HILLS MCCANNA ACTUATORS</u>	
	Computed by <u>DW</u>	Date _____ Checked by <u>MP</u> Date _____

SEISMIC LOADING ON MOUNTING HARDWARE

g_x LOADING

FOR INFORMATION ONLY

$$\text{AXIAL TENSION} = F_x = \frac{(5.4g)(460\#)}{8 \text{ BOLTS}} = 310.5\#$$

$$\sigma_x = \frac{310.5\#}{0.226 \text{ in}^2} = 1373.89 \text{ PSI}$$

SQUARE ROOT SUM OF THE SQUARES

$$\sigma_F = \left[6366.5^2 + 4501.95^2 + 1373.89^2 \right]^{1/2}$$

$$\sigma_F = 7917.54 \text{ PSI}$$

$$\tau_F = \left[1373.9^2 + 1373.9^2 + 0^2 \right]^{1/2}$$

$$\tau_F = 1942.98 \text{ PSI}$$

BASIS FOR COMPARISON $\frac{\tau_F}{\tau_A} + \frac{\sigma_F}{\sigma_A} \leq 1.5$ FOR DBE CONDITIONS

BOLTS ASSUMED TO BE A307 GRADE (1) BOLTS

$$\begin{aligned} \sigma_A &= 20,000 \text{ PSI} \\ \tau_A &= 10,000 \text{ PSI} \end{aligned}$$

$$\frac{1942.98}{10,000} + \frac{7917.54}{20,000} = 0.5902$$

$$\underline{\underline{0.5902 \leq 1.5}}$$

IOWA ELECTRIC LIGHT
AND POWER COMPANY

CEDAR RAPIDS, IOWA

R-4200 FS

DEPT. DESIGN ENGINEERING

PROJECT DUANE ARNOLD ENERGY CENTER

SUBJECT SEISMIC STRESS ANALYSIS HILL-MCCANN ACTUATORS

Computed by

Date


Checked by

Date

CALC M84-15

Sheet No. 14 of 16

SEISMIC STRESS ANALYSIS ON THE MOUNTING YOKE



$$A = 10.44$$

$$B = 5.25$$

$$C = 5.00$$

$$D = 6.00$$

$$E(ODIA) = 3.126$$

$$F = 8.00$$

$$G = 8.00$$

$$H = 0.12$$

$$J = 12.00$$

$$K(ODIA) = 9.14$$

$$R = 0.50$$

R-4200 FS HAS
THE SAME STRESS
CONCENTRATOR VALUES

ELASTIC STRESS IN-PLANE BENDING



REFERENCE: FORMULAS FOR STRESS
AND STRAIN CONCENTRATION FACTORS
Pg. 593

$$K_T = K_1 + K_2 \left(\frac{2h}{d} \right) + K_3 \left(\frac{2h}{d} \right)^2 + K_4 \left(\frac{2h}{d} \right)^3$$

VERTICAL LOADS g_z LOADING

$$h = \frac{1}{2}(G-D) \quad r = H \quad d = G$$

$$h = \frac{1}{2}(8.00 - 6.00) = 1.00$$

$$r = 0.12$$

$$d = 8.00$$

$$K_1 = 3.577$$

$$K_2 \left(\frac{2h}{d} \right) = -0.629$$

$$K_3 \left(\frac{2h}{d} \right)^2 = -0.028$$

$$K_4 \left(\frac{2h}{d} \right)^3 = 0.006$$

$$K_T = 2.9260$$

HORIZONTAL LOADS g_y LOADING

$$h = \frac{1}{2}(8.00 - 5.00) = 1.50$$

$$r = 0.50$$

$$d = 8.00$$

$$r = R \quad h = \frac{1}{2}(G-C)$$

$$K_1 = 2.635$$

$$K_2 \left(\frac{2h}{d} \right) = -0.783$$

$$K_3 \left(\frac{2h}{d} \right)^2 = -0.022$$

$$K_4 \left(\frac{2h}{d} \right)^3 = 0.032$$

$$K_T = 1.862$$

FOR INFORMATION ONLY


IOWA ELECTRIC LIGHT
AND POWER COMPANY
CEDAR RAPIDS, IOWA

DEPT. DESIGN ENGINEERING CALC. M84-15
PROJECT DUANE ARNOLD ENERGY CENTER Sheet No. 15 of 16
SUBJECT SEISMIC STRESS ANALYSIS HILLS-McCANN ACTUATORS
Computed by EW Date _____ Checked by JP Date _____

R-4200 FS

SEISMIC STRESS ANALYSIS ON THE MOUNTING YORE

ELASTIC STRESS AXIAL TENSION



$$h = \frac{1}{2}(G-D) \quad r = H \quad d = G$$


$$h = \frac{1}{2}(8.00 - 6.00) = 1.00 \quad r = 0.12 \quad d = 8.00$$

$$h/r = 8.33 \quad 2h/d = (2 \times 1.00)/8.00 = 0.250$$

$K_x = 3.337$ REFERENCE R2000 FS CALCULATION Pg 20

g_z LOADING

FOR INFORMATION ONLY



$$M_y = (460^{\#})(5.25 \text{ in})(5.4) = 13041 \text{ in-lb}$$

$$I = \frac{(5)(6)^3}{12} - \frac{\pi}{4} \left(\frac{3.126}{2} \right)^4 = 85.3 \text{ in}^4$$

$$\theta_{z \text{ BENDING}} = \frac{M_c}{I} = \frac{(13041)(3.0)}{85.3} = 458.6 \text{ PSI}$$

$$\theta_x = K_z \theta_{z \text{ BENDING}} = (458.6)(2.926) = 1341.82 \text{ PSI}$$


$$\tau_{24} = \frac{(460^{\#})(5.4)}{\frac{(5.0)(6.0) - \pi(3.126)^2}{4}} = 111.26 \text{ PSI}$$

g_y LOADING

$$M_z = (460^{\#})(5.25 \text{ in})(5.4) = 13041 \text{ in-lb}$$

$$I = \frac{(6)(5)^3}{12} - \frac{\pi}{4} \left(\frac{3.126}{2} \right)^4 = 57.8 \text{ in}^4$$

SEISMIC STRESS ANALYSIS ON THE MOUNTING YOKE



g_y LOADING CONTINUED

$$\sigma_{YBEND} = \frac{Mc}{I} = \frac{(304 \text{ in-lb})(2.5)}{57.8 \text{ in}^4} = 563.93 \text{ PSI}$$

$$\sigma_x = K_y \sigma_{YBEND} = (563.93 \text{ PSI})(1.862) = 1050.0 \text{ PSI}$$

$$\gamma_{ZY} = \frac{(460 \#)(5.4)}{(5.0)(6.0) - \pi(3.126)^2} = 111.26 \text{ PSI}$$

g_x LOADING

$$F(\text{TENSION})_x = Mg_x = (460 \#)(5.4) = 2484 \#$$

$$\sigma_x = \frac{2484}{(6.0)(5.0) - \pi(3.126)^2} = 111.26 \text{ PSI}$$

$$\sigma_x K_x = (111.26 \text{ PSI})(3.397) = 377.95 \text{ PSI}$$

SQUARE ROOT SUM OF THE SQUARES

$$\sigma_F = \left[1341.82^2 + 1050.0^2 + 377.95^2 \right]^{1/2} = 1745.23 \text{ PSI}$$

$$\gamma_F = \left[111.26^2 + 111.26^2 + 0^2 \right]^{1/2} = 157.35 \text{ PSI}$$

$$\sigma_F = 1745.23 < (0.6)(30000) = 18000 \text{ PSI}$$

< 13500 NOTCHED FATIGUE STRENGTH

$$\gamma_F = 157.35 < (0.4)(30000) = 12000 \text{ PSI}$$

< 13500 NOTCHED FATIGUE STRENGTH

• ANALYSIS OF INTERNAL ACTUATOR NOT REQUIRED
REFERENCE R-2000 FS Pg. 23

FOR INFORMATION ONLY

FOR INFORMATION ONLY

CALC. No:

DCR No: M24-15

Sheet 16A of 16A

DESIGN/REVIEW COMMENTS SHEET

DESIGN VERIFICATION

ALTERNATE CALCULATIONS

NO.	COMMENT	RESOLUTION/APPROVAL
	<p>NO COMMENTS</p>	<div data-bbox="817 1357 1462 1457"> <p><u>Donald W. Church</u> 4-23-84 Design Engineer Date</p> </div> <div data-bbox="817 1457 1462 1617"> <p><u>[Signature]</u> 4-24/84 Verifying Engineer Date</p> </div> <div data-bbox="817 1617 1462 1776"> <p><u>McDonald</u> 4/30/84 Technical Group Leader Date</p> </div> <div data-bbox="310 1755 784 1947"> <p><u>[Signature]</u> 4-24/84 Verifying Engineer Date</p> </div> <div data-bbox="817 1808 1493 1947"> <p><u>[Signature]</u> 4/30/84 Supervising Engr. Nuclear Projects Date</p> </div>